

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

ORDER NO. 86-23

**WASTE DISCHARGE REQUIREMENTS
FOR
LOST LAKE RESORT
North of Blythe - Riverside County**

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Robert M. Brown (hereinafter also referred to as the discharger), P.O. Box 6246, Lost Lake, California, 92225, verified on December 10, 1985 that the below updated information is accurate.
2. The discharge from this mobile home and recreational vehicle park has been subject to waste discharge requirements adopted in Board Order No. 78-93.
3. The discharger is discharging a maximum of 30,000 gallons-per-day of domestic sewage from a mobile home and recreational vehicle park consisting of 98 mobile home spaces, 52 RV spaces, a laundry room and 6 (six) restrooms. A portion of the wastewater is discharged into septic tank/leach field systems and the remainder into 2 (two) oxidation basins for disposal by infiltration and evaporation. The park is located in the NE $\frac{1}{4}$ of the SE $\frac{1}{4}$ of Section 8, T2S, R24E, SBB&M.
4. The discharger reports that if any subsurface disposal system fails, the wastewater which had been discharged to that system would be diverted to the oxidation basins, and the basin capacity would be expanded to handle the increased flow.
5. There are no domestic wells within 200 feet of the sewage discharge facilities described in Finding No. 3 (above).
6. The discharger states that the wastewater disposal facilities are more than 200 feet from the high water line of the Colorado River.
7. The Water Quality Control Plan for the Colorado River Basin Region of California was adopted by the Regional Board on November 14, 1984. The Basin Plan contains water quality objectives for the Colorado Hydrologic Unit.
8. The beneficial uses of ground water of the Colorado Hydrologic Unit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply

*Rescinded
11/27/88
by order
88-21*

9. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.
10. The Board in a public meeting heard and considered all comments pertaining to the discharge.
11. These waste discharge requirements govern an existing facility, which the discharger is currently operating, and therefore is exempt from the provisions of the California Environmental Quality Act in accordance with Section 15301 Chapter 3 of Title 14, of the California Administrative Code.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications


1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. A minimum freeboard depth of at least two (2) feet shall be maintained in each basin.
4. Adequate measures shall be taken to assure that unauthorized persons and animal pets are effectively excluded from contact with the discharge.
5. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
6. Treated or untreated sludge, or similar solid waste materials, shall not be discharged to or enter any drainage channels or Colorado River.
7. There shall be no surface flow of wastewater away from the discharge facilities, and there shall be no direct discharge to any drainage channel or to Colorado River.
8. Treatment and disposal by ponding shall be conducted in such a manner that there shall be no stranded or exposed sewage solids.
9. Treatment and discharge of wastewater shall be conducted by technical procedures which will maintain a surface aerobic environment.
10. Infiltration facilities shall be maintained and operated so as to maximize infiltration and minimize the increase in salinity of the infiltrating wastewater.

11. Septic tank cleanings shall be discharged only by a duly authorized service.
12. Standby facilities shall be provided in the event of pump and/or commercial power failure.
13. There shall be no discharge of sewage within 200 feet of the regulated high water line of the Colorado River.

B. Provisions

1. Prior to any modifications in this facility which could result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. In the event of change in control or ownership of land or waste disposal facilities owned or controlled by the discharger, the discharger shall:
 - a. Notify the Board of such change; and
 - b. Transmit a copy of this Order to the succeeding owner or operator and file a copy of the transmittal letter with this Board.
4. This Order supersedes Board Order No. 78-93.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on March 19, 1986.


Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

MONITORING AND REPORTING PROGRAM NO. 86-23
FOR
LOST LAKE RESORT
North of Blythe - Riverside County

Location of Discharge: Portion of NE $\frac{1}{4}$, SE $\frac{1}{4}$ of Section 8, T2S, R24E, SBB&M

MONITORING

The discharger shall submit the following information in an annual status report:

1. Estimate of average daily flow (gpd) of sewage discharged to basin(s).
2. Estimate of number of persons presently discharging to the sewerage system.
3. List of any proposed changes during the coming year.
4. Explain any problems in the sewerage system during the preceding year.

REPORTING

Monitoring reports shall be submitted to the Regional Board annually by January 15th of each year.

Submit monitoring reports to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260

ORDERED BY:

Arthur Swajan
Executive Officer

July 15, 1987
Date

