

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
SAN DIEGO REGION

**ERRATA SHEET**  
**ITEM NO. 7**

Tentative Order No. R9-2009-0007 Waste Discharge Requirements: Garcia Residence  
Onsite Wastewater Treatment System, San Diego County

1. Page 2, Finding 4

Replace Finding 4 with the following:

“Cost estimates for connection to the sanitary sewer proved to be cost prohibitive due to the length and depth of a new sewer line. Onsite treatment of wastewater was deemed necessary. Because the site characteristics are not suitable for the use of a conventional leachfield, the Dischargers propose to install a subsurface drip irrigation system, which necessitates advanced treatment of the wastewater. The proposed OWTS is designed to meet or exceed the American National Standards Institute/National Science Foundation Standard 40 for a flow of 750 gallons per day.”