



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Edmund G. Brown, Jr.
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

March 23, 2011

In reply refer to:
rsunjed:263145

Mr. Anthony Pack
General Manger
Eastern Municipal Water District
P.O. Box 8300
Perris, CA 92572-8300

Dear Mr. Pack:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR TEMECULA VALLEY
REGIONAL WATER RECLAMATION FACILITY**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the January 2011 monthly monitoring report submitted by the Eastern Municipal Water District (EMWD) in accordance with the Monitoring and Reporting Program No. 2000-165.

The San Diego Water Board has identified the following violation of the Section B.3 (Discharge Specifications) of Order No. 2000-165:

The daily maximum discharge specification for Manganese, established at 0.06 milligrams per liter (mg/L), was exceeded on January 5, 2011, with a reported value of 0.062 mg/L.

Please take steps to implement follow-up actions necessary to ensure that the violations noted do not occur in the future. This violation subjects the EMWD to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the EMWD to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report to be submitted is the February 2011 monthly monitoring report due by March 30, 2011.

¹ Under authority of California Water Code section 13350.


Mr. Anthony Pack

- 2 -

March 16, 2011

In the subject line of any response, please include the requested **"In reply refer to:"** information located in the heading of this letter. For questions pertaining to the subject matter, please contact Ray Sunjed at (858) 627-3977 or via email at rsunjed@waterboards.ca.gov.

Sincerely,



Brian D. Kelley, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID: 377869
Violation ID: 893029

California Environmental Protection Agency