



California Regional Water Quality Control Board

San Diego Region



Matthew Rodriguez
Secretary for Environmental
Protection

Over 50 Years Serving San Diego, Orange, and Riverside Counties

Edmund G. Brown, Jr.
Governor

Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
<http://www.waterboards.ca.gov/sandiego>

February 16, 2012

In reply refer to:
224057:ccannova

Mr. Chuck Duffy
Fairbanks Ranch Community Services District
605 Third Street
Encinitas, CA 92024

Dear Mr. Duffy:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR FAIRBANKS RANCH
WATER POLLUTION CONTROL FACILITY**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the October-December 2010, January-March 2011, April-June 2011, and July-September 2011 quarterly monitoring reports and the January-December 2010 annual monitoring report submitted by the Fairbanks Ranch Community Services District in accordance with the Monitoring and Reporting Program of Order No. 93-05.

The following violations of Discharge Specification B.1 from Order No. 93-05 were identified in the quarterly monitoring reports:

1. The 30-day average for total dissolved solids, established at 1,300 milligrams per liter (mg/L), was exceeded in February 2011 and April 2011 with reported values of 1,342 and 1,476 mg/L, respectively.

Please take steps to implement follow-up actions necessary to ensure that the violations noted do not occur in the future. These violations subject the District to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the District to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

¹ Under authority of California Water Code section 13350.

The next monitoring reports to be submitted are the October-December 2011 quarterly, July-December 2011 semiannual, and January-December 2011 annual monitoring reports due by February 28, 2012.

In the subject line of any response, please include the requested "In refer to" information located in the heading of this letter. Please contact Ms. Catherine Cannova at (858) 627-3977 or at ccannova@waterboards.ca.gov if you have any questions on this matter.

Sincerely,

Brian D. Kelley

Brian D. Kelley, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID: 382882
Violation ID: 916959, 916960

