

California Regional Water Quality Control Board, San Diego Region

July 11, 2014

Mr. Mark Hammond
Compliance Officer
City of Oceanside
3950 North River Road
Oceanside, CA 92058

In reply refer to:
255386:acali

Subject: Review of Monitoring Reports for San Luis Rey Land Disposal

Mr. Hammond:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the following monitoring reports submitted by the City of Oceanside, in accordance with the Monitoring and Reporting Program of Order No. 93-07: (a) January-May 2014 monthly monitoring reports; (b) January-March 2014 quarterly monitoring report.

The San Diego Water Board has the following comments on the report referenced above:

1. The Discharge Specifications in section B.1 of Order No. 93-07 requires the daily maximum effluent limitation for total coliform shall not exceed a median number of coliform organisms of 23 per 100 milliliters or MPN (Most Probable Number). This effluent limit for total coliform was exceeded on March 18, 2014 with a reported value of 30 MPN.


The next monitoring reports required to be submitted are the June 2014 monthly monitoring report and the January-June 2014 semi-annual monitoring report, which both are due July 30, 2014.

Please take steps to implement follow-up actions necessary to ensure that the violations noted above do not occur in the future. These violations subject the Discharger to possible further enforcement action by the San Diego Water Board including administrative enforcement orders requiring the Discharger to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

¹ Under authority of California Water Code section 13350.

In the subject line of any response, please include reference **255386: acali**. Please contact Mr. Alex Cali at (619) 521-3355, or at acali@waterboards.ca.gov if you have any questions or comments.

Sincerely,



JOHN R. ODERMATT, P.G,
Senior Engineering Geologist
Groundwater Protection Branch

JRO:ac

Tech Staff Info & Use	
Place ID	255386
Party ID	32483
Reg. Measure ID	142438, 397176
Violation ID	970427