



EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

San Diego Regional Water Quality Control Board

November 21, 2016

Mr. Corey Hutchinson
Plant Operations Manager
Rancho Santa Fe Community Services
Dist605 Third Street Encinitas, California,
92024-3513

In reply refer to / attn:
255649:BBushnell

Subject: Review of Monitoring Reports for Order No. R9-2002-0013, Santa Fe Valley Waste Treatment Plant

Mr. Hutchinson:


The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the monthly reports for January 2015 through September 2016 and the January-March 2015, April-June 2015, July-September 2015, October-December 2015, January-March 2016, April-June 2016, July-September 2016 quarterly recycled water users reports. Rancho Santa Fe Community Services District submitted the monitoring reports as required by the Monitoring and Reporting Program No. R9-2002-0013.

Violations of Section B.2 (Discharge Specifications) of Order No. R9-2002-0013 identified in the monitoring reports are listed below:

1. On September 28, 2015 the Total Coliform sample was reported at 1600 Most Probable Number per 100 milliliters (MPN/mL). This exceeds the daily maximum limit established at 240 MPN/100mL.
2. On October 28, 2015 the Total Coliform sample was reported at 1600 MPN/mL. This exceeds the daily maximum limit established at 240 MPN/100mL.

In the subject line of any response, please include reference **255649:BBushnell**. Please contact Mr. Brandon Bushnell at 619-521-8044, or at brandon.bushnell@waterboards.ca.gov if you have any questions or comments.

Respectfully,



John R. Odermatt, P.G, Senior Engineering Geologist
Land Discharge Unit

JRO: ac: bb

Tech Staff Info & Use	
Place ID	255649
Reg. Measure ID	132007
SEL Reg. Measure ID	410226
Violation ID	1015289, 1015240