

**San Diego Regional Water Quality Control Board**

February 10, 2017

Mr. Richard D Beath  
Plant Manager  
All Seasons RV Park LLC  
PO Box 67  
Valley Center, California, 92082

**In reply refer to / attn:**  
**205079:BBushnell**

**Subject: Review of Monitoring Reports for Order No. 94-05, All Seasons Campground**

Mr. Beath:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the monitoring reports listed below in Table 1. The All Seasons RV Park LLC (Discharger) submitted the monitoring reports as required by the Monitoring and Reporting Program No. 94-05.

**Table 1. List of Monitoring Reports Reviewed**

Report Type	Report Date
Semi-Annual Monitoring Reports	January-June 2015, July-December 2015, January-June 2016, and July-December 2016
Annual Monitoring Reports	2015 Annual Report and 2016 Annual report

Violations of Section B.1 (Discharge Specifications) of Order No. 94-05 were identified in the monitoring reports are described below:

1. The 12 month average discharge specification for chloride, established at 150 milligrams per liter (mg/L), was exceeded on December 23, 2015 and December 21, 2016 with sample values of 168 mg/L and 161.5 mg/L respectively.
2. The daily maximum discharge specification for sulfate, established at 300 mg/L, was exceeded on December 23, 2015 with a sample value of 325 mg/L.
3. The daily maximum discharge specification for total suspended solids, established at 45 mg/L, was exceeded on March 30, 2016 with a sample value of 67.2 mg/L.

Violations of Section B. (Effluent Monitoring) of Monitoring and Reporting Program 94-05 (MRP) were identified in monitoring reports are described below:

1. The MRP requires annual monitoring for Formaldehyde and there was no Formaldehyde concentration reported in any report from 2015 and 2016.

In future monitoring reports provide the 12-month effluent average concentrations for all the constituents that have 12-month average effluent limitations specified in the Discharge Specifications identified in Section B of Order 94-05.


The next monitoring report due is the January-June 2017 semi-annual report, which is due by July 30, 2017.

Please implement follow-up actions necessary to ensure that the violations noted above do not occur in the future. These violations may subject the Discharger to possible further enforcement action by the San Diego Water Board including but not limited to: administrative enforcement orders requiring the City to cease and desist from violations, or administrative assessments of civil liabilities in amounts of up to \$5,000 per day per violation; referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

In the subject line of any response, please include reference **205079:BBushnell**. Please contact Mr. Brandon Bushnell at 619-521-8044, or at [brandon.bushnell@waterboards.ca.gov](mailto:brandon.bushnell@waterboards.ca.gov) if you have any questions or comments.

Respectfully,

John R. Odermatt, M.Sc. P.G., Senior Engineering Geologist  
Land Discharge Unit



JRO: ac: bb

Tech Staff Info & Use	
Place ID	205079
Reg. Measure ID	205079
SEL Reg. Measure ID	411482
Violation ID	1018906, 1018908, 1018907, 1018100, 1018909, 1018910