

ERRATA SHEET

TENTATIVE ORDER NO R9-2007-0148

WASTE DISCHARGE REQUIREMENTS FOR THE CALIFORNIA DEPARTMENT OF TRANSPORTATION TECATE TRUCK INSPECTION STATION

The following changes have been made to tentative Order No. R9-2007-0148. Some changes/corrections below are shown in **bold and underline**/~~strikeout~~ format to indicate added and removed language, respectively.

Errata #	SECTION	REVISION																				
1.	Finding No. 9	The following text will be revised as follows: 9. In accordance with Section 2200, Title 23 of the California Code of Regulations, the threat to water quality and complexity of the treated wastewater discharge from the treatment system is determined to be category 2C <u>3B</u> .																				
2.	Monitoring and Reporting Program, Section B.1	Footnote No. 2 will be revised as follows: 2. If there are no impacts to groundwater quality, semiannual monitoring may be reduced to annually five years <u>two years</u> after the first series of sampling. Annual reports shall be submitted in accordance with Section F of the M&RP.																				
3.	Monitoring and Reporting Program, Section B.1	The following footnote shall be added to Section B.1: <u>3. Flowrate to the septic tank/leach field shall be determined based on water meter usage.</u>																				
4.	Monitoring and Reporting Program, Section B.2	The following table in Section B.2 has been deleted: <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th style="text-align: center;">CONSTITUENT</th> <th style="text-align: center;">UNIT</th> <th style="text-align: center;">TYPE OF SAMPLE</th> <th style="text-align: center;">SAMPLING FREQUENCY^{1,2}</th> <th style="text-align: center;">REPORTING FREQUENCY^{1,2}</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">Total Dissolved Solids</td> <td style="text-align: center;">Units</td> <td style="text-align: center;">Grab</td> <td style="text-align: center;">June, December</td> <td style="text-align: center;">Semiannually</td> </tr> <tr> <td style="text-align: center;">Total Nitrogen (as N)</td> <td style="text-align: center;">Units</td> <td style="text-align: center;">Grab</td> <td style="text-align: center;">June, December</td> <td style="text-align: center;">Semiannually</td> </tr> <tr> <td style="text-align: center;">Sulfate</td> <td style="text-align: center;">mg/l</td> <td style="text-align: center;">Grab</td> <td style="text-align: center;">June, December</td> <td style="text-align: center;">Semiannually</td> </tr> </tbody> </table>	CONSTITUENT	UNIT	TYPE OF SAMPLE	SAMPLING FREQUENCY ^{1,2}	REPORTING FREQUENCY ^{1,2}	Total Dissolved Solids	Units	Grab	June, December	Semiannually	Total Nitrogen (as N)	Units	Grab	June, December	Semiannually	Sulfate	mg/l	Grab	June, December	Semiannually
CONSTITUENT	UNIT	TYPE OF SAMPLE	SAMPLING FREQUENCY ^{1,2}	REPORTING FREQUENCY ^{1,2}																		
Total Dissolved Solids	Units	Grab	June, December	Semiannually																		
Total Nitrogen (as N)	Units	Grab	June, December	Semiannually																		
Sulfate	mg/l	Grab	June, December	Semiannually																		

Errata #	SECTION	REVISION				
		CONSTITUENT	UNIT	TYPE OF SAMPLE	SAMPLING FREQUENCY ^{1,2}	REPORTING FREQUENCY ^{1,2}
		MBAS	mg/l	Grab	June, December	Semiannually
		Boron	mg/l	Grab	June, December	Semiannually
		Aluminum	mg/l	Grab	June, December	Semiannually
		Arsenic	mg/l	Grab	June, December	Semiannually
		Antimony	mg/l	Grab	June, December	Semiannually
		Barium	mg/l	Grab	June, December	Semiannually
		Beryllium	mg/l	Grab	June, December	Semiannually
		Cadmium	mg/l	Grab	June, December	Semiannually
		Chromium	mg/l	Grab	June, December	Semiannually
		Copper	mg/l	Grab	June, December	Semiannually
		Cyanide	mg/l	Grab	June, December	Semiannually
		Mercury	mg/l	Grab	June, December	Semiannually
		Nickel	mg/l	Grab	June, December	Semiannually
		Selenium	mg/l	Grab	June, December	Semiannually
		Thallium	mg/l	Grab	June, December	Semiannually
		Asbestos	mg/l	Grab	June, December	Semiannually
		Benzene	mg/l	Grab	June, December	Semiannually
		Carbon Tetrachloride	mg/l	Grab	June, December	Semiannually
		1,2-Dichlorobenzene	mg/l	Grab	June, December	Semiannually
		1,4-Dichlorobenzene	mg/l	Grab	June, December	Semiannually
		1,1-Dichloroethane	mg/l	Grab	June, December	Semiannually
		1,2-Dichloroethane	mg/l	Grab	June, December	Semiannually

Errata #	SECTION	REVISION				
		CONSTITUENT	UNIT	TYPE OF SAMPLE	SAMPLING FREQUENCY ^{1,2}	REPORTING FREQUENCY ^{1,2}
		1,1-Dichloroethylene	mg/l	Grab	June, December	Semiannually
		cis-1,2-Dichloroethylene	mg/l	Grab	June, December	Semiannually
		trans-1,2-Dichloroethylene	mg/l	Grab	June, December	Semiannually
		Dichloromethane	mg/l	Grab	June, December	Semiannually
		1,2-Dichloropropane	mg/l	Grab	June, December	Semiannually
		1,3-Dichloropropene	mg/l	Grab	June, December	Semiannually
		Ethylbenzene	mg/l	Grab	June, December	Semiannually
		MTBE	mg/l	Grab	June, December	Semiannually
		Monochlorobenzene	mg/l	Grab	June, December	Semiannually
		Styrene	mg/l	Grab	June, December	Semiannually
		1,1,2,2-Tetrachloroethane	mg/l	Grab	June, December	Semiannually
		Tetrachloroethylene	mg/l	Grab	June, December	Semiannually
		Toluene	mg/l	Grab	June, December	Semiannually
		1,2,4-Trichlorobenzene	mg/l	Grab	June, December	Semiannually
		1,1,1-Trichloroethane	mg/l	Grab	June, December	Semiannually
		1,1,2-Trichloroethane	mg/l	Grab	June, December	Semiannually
		Trichloroethylene	mg/l	Grab	June, December	Semiannually
		Trichlorofluoromethane	mg/l	Grab	June, December	Semiannually
		1,1,2-Trichloro-1,2,2-Trifluoroethane	mg/l	Grab	June, December	Semiannually
		Vinyl Chloride	mg/l	Grab	June, December	Semiannually
		Xylenes	mg/l	Grab	June, December	Semiannually

Errata #	SECTION	REVISION				
		CONSTITUENT	UNIT	TYPE OF SAMPLE	SAMPLING FREQUENCY ^{1,2}	REPORTING FREQUENCY ^{1,2}
		Alachlor	mg/l	Grab	June, December	Semiannually
		Atrazine	mg/l	Grab	June, December	Semiannually
		Bentazon	mg/l	Grab	June, December	Semiannually
		Benzo(a)pyrene	mg/l	Grab	June, December	Semiannually
		Carbofuran	mg/l	Grab	June, December	Semiannually
		Chlordane	mg/l	Grab	June, December	Semiannually
		2,4-D	mg/l	Grab	June, December	Semiannually
		Dalapon	mg/l	Grab	June, December	Semiannually
		1,2-Dibromon-3-chloropropane	mg/l	Grab	June, December	Semiannually
		Di(2-ethylhexyl)adipate	mg/l	Grab	June, December	Semiannually
		Di(2-ethylhexyl)phthalate	mg/l	Grab	June, December	Semiannually
		Dinoseb	mg/l	Grab	June, December	Semiannually
		Diquat	mg/l	Grab	June, December	Semiannually
		Endothall	mg/l	Grab	June, December	Semiannually
		Endrin	mg/l	Grab	June, December	Semiannually
		Ehtylene Dibromide	mg/l	Grab	June, December	Semiannually
		Glyphosate	mg/l	Grab	June, December	Semiannually
		Heptachlor	mg/l	Grab	June, December	Semiannually
		Heptachlor Epoxide	mg/l	Grab	June, December	Semiannually
		Hexachlorobenzene	mg/l	Grab	June, December	Semiannually
		Hexachlorocyclopentadiene	mg/l	Grab	June, December	Semiannually
		Lindane	mg/l	Grab	June, December	Semiannually

Errata #	SECTION	REVISION				
		CONSTITUENT	UNIT	TYPE OF SAMPLE	SAMPLING FREQUENCY ^{1,2}	REPORTING FREQUENCY ^{1,2}
		Methaxychlor	mg/l	Grab	June, December	Semiannually
		Molinate	mg/l	Grab	June, December	Semiannually
		Oxamyl	mg/l	Grab	June, December	Semiannually
		Pentachlorophenol	mg/l	Grab	June, December	Semiannually
		Picloram	mg/l	Grab	June, December	Semiannually
		Polychlorinated Biphenyls	mg/l	Grab	June, December	Semiannually
		Simazine	mg/l	Grab	June, December	Semiannually
		Thiobencarb	mg/l	Grab	June, December	Semiannually
		Toxaphene	mg/l	Grab	June, December	Semiannually
		2,3,7,8-TCDD (Dioxin)	mg/l	Grab	June, December	Semiannually
		2,4,5-TP Silvex	mg/l	Grab	June, December	Semiannually

The table in section B.2 is replaced with the following:

CONSTITUENT	UNIT	TYPE OF SAMPLE	SAMPLING FREQUENCY ^{1,2}	REPORTING FREQUENCY ^{1,2}
Total Dissolved Solids	mg/l	Grab	June, December	Semiannually
MBAS	mg/l	Grab	June, December	Semiannually
Boron	mg/l	Grab	June, December	Semiannually
BTEX	mg/l	Grab	June, December	Semiannually
MTBE	mg/l	Grab	June, December	Semiannually
Naphthalene	mg/l	Grab	June, December	Semiannually
Total Petroleum Hydrocarbons (TPH)	mg/l	Grab	June, December	Semiannually

Errata #	SECTION	REVISION
5.	Tentative Order (Global)	Other typographical errors and other minor corrections to the wording in the tentative Order have been or will be made prior to sending out the final version.