## ERRATA SHEET

ADDENDUM NO. 2 TO ORDER NO. R9-2002-0025 NPDES NO. CA0107409

WASTE DISCHARGE REQUIREMENTS AND NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT FOR THE CITY OF SAN DIEGO E. W. BLOM POINT LOMA METROPOLITAN WASTEWATER TREATMENT PLANT DISCHARGE TO THE PACIFIC OCEAN THROUGH THE POINT LOMA OCEAN OUTFALL

The following changes have been made to tentative Addendum No. 2 to Order No. R9-2002-0025. The changes/corrections are shown below in **bold and underline**/strikeout format to indicate added and removed language, respectively.

1. The title on Page 2 has been modified as such:

AMENDMENT TO THE FACT SHEETORDER AND ASSOCIATED MONITORING AND REPORTING PROGRAM FOR THE CITY OF SAN DIEGO E. W. BLOM POINT LOMA METROPOLITAN WASTEWATER TREATMENT PLANT TO ALLOW FOR DISINFECTION OF TREATED WASTEWATER DISCHARGE TO THE PACIFIC OCEAN THROUGH THE POINT LOMA OCEAN OUTFALL SAN DIEGO COUNTY

- 2. Finding 3 has been modified as such:
  - 3. By letter dated November 13, 2007, the City of San Diego requested Regional Board approval to initiate operation of a prototype effluent disinfection system at the PLMWTP. Sodium hypochlorite solution, used for disinfection, will be applied as determined by the City of San Diego at a feed point immediately downstream of the sedimentation tanks. The request was made because of a recent interpretation by USEPA that bacterial water quality objectives in the San Diego Region apply surface to bottom, up to three nautical miles from shore. USEPA's interpretation of the applicability of bacterial objectives will be incorporated into the requirements of the currentnext NPDES permit for the Point Loma Ocean Outfall (PLOO) discharge by this Aaddendum. The City of San Diego proposes to demonstrate compliance with bacterial objectives at all its monitoring stations, points surface to bottom, within 3up to three nautical miles from shore in the San Diego Region.
- 3. Items 1 and 2 have been modified as such:
  - 1. Section F.15.a of the Fact Sheet Order shall contain the following additional text:
    - Toxicity re-screening shall also be performed upon initiation of chlorination.
  - 2. Table 1. Influent and Effluent Sampling and Analysis Requirements of the monitoring and reporting requirements shall include the following constituent and footnotes from

the 2005 California Ocean Plan Table B parameters for protection of marine aquatic life:

			Sampling frequency		
			Influent	Effluent	Emergency
CONSTITUENT	Units	Sample type	stream	stream	connection
Total Chlorine Residual <sup>12</sup>	μg/l	Grab	-	4 per day <sup>13</sup>	-

<sup>&</sup>lt;sup>12</sup> Per Table II, Required Containers, Preservation Techniques, and Holding Times, in 40 CFR 136, total chlorine residual samples are required to be analyzed immediately. Holding time must not exceed 15 minutes.

<sup>&</sup>lt;sup>13</sup> Samples must be collected at equal time intervals throughout on-site ELAP-accredited laboratory working hours (i.e., every six hours).