

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN DIEGO REGION

ERRATA SHEET
ITEM NO. 9

Tentative Order No. R9-2009-0005: Master Reclamation Permit For Ramona Municipal Water District, San Vicente Wastewater Treatment Plant, San Diego County

1. Page 6 , Prohibition A.4

Replace Prohibition A.4 with the following:

“A 30-day average flowrate from the San Vicente Wastewater Treatment Plant in excess of 0.80 mgd is prohibited unless the discharger obtains revised waste discharge requirements for the proposed increased flow.”

2. Page 8, Table 3

a. Replace Discharge Specification in the heading with 12-Month Average.

b. Delete the Discharge Specification for Nitrate as N

3. Page 9, Recycled Water Purveyance Requirements

Add the following to paragraph C.1.b.

“The assessment of compliance at recycled water reuse sites shall include an evaluation of the measures being taken to account for the nitrogen and other nutrient content in recycled water in the management of fertilizer application.

4. Page 32, M&RP Table 1

Replace footnote (d) of Table 1 of the Monitoring and Reporting Program with the following:

“Calculated CT (chlorine concentration multiplied by modal contact time) values shall be determined and recorded continuously. The daily minimum CT value shall be reported quarterly. The Discharger shall report quarterly the date, value, time, and duration when the CT value falls below 450 mg-min/L, and/or the modal contact time falls below 90 minutes.”

5. Page 32 M&RP Table 2

Add the following footnote (e) to Sampling Frequency for Total Dissolved Solids in Table 2 of the Monitoring and Reporting Program:

“e. The Recycled Water Agency shall conduct continuous conductivity measurements to determine if the composite sample collected for total dissolved solids is representative of the secondary effluent.”