

**ERRATA SHEET
TENTATIVE ADDENDUM NO. 1 TO ORDER NO. R9-2009-0005**

**AN ADDENDUM TO INCORPORATE REQUIREMENTS FOR THE DISCHARGE OF
BRINE AND TO CLARIFY EXISTING REQUIREMENTS**

**RAMONA MUNICIPAL WATER DISTRICT
SAN VICENTE WASTEWATER TREATMENT PLANT
SAN DIEGO COUNTY**

The following changes have been made to tentative Addendum No. 1 to Order No. R9-2009-0005. Some of the corrections below are shown in bold and underline or strikethrough format to indicate added or removed language, respectively:

Errata Item No.	Section	Revision
1.	Finding 6.a.iii	Revise the following language to read: <u>Polyvinyl chloride membrane (PVC)</u> -20-mil high-density polyethylene geomembrane (containment layer)
2.	Finding 7	Revise the following language to read: The Recycled Water Agency proposes to maintain six inches of freeboard in the evaporation pond <u>section 13</u> . This minimum freeboard is reasonable and appropriate for the protection of water quality because 1) each section of the pond is designed to gravity flow to the downgradient section, 2) the pond is required to be operated and maintained in accordance with a water balance plan, and 3) the Recycled Water Agency will utilize a submersible pump to serve as a fail safe mechanism to prevent overflow from the pond. In addition, the Recycled Water Agency has viable alternative methods of disposal for the brine. <u>The Recycled Water Agency is required to maintain emergency storage capacity equivalent to a 25-year, 24-hour storm.</u>
3.	Paragraph I.A.3.b (Evaporation Pond Facility and Design Specification H.3.b)	Revise the following language to read: Maintain a minimum of six inches of freeboard in each <u>pond</u> section <u>13</u> at all times. <u>In addition, the evaporation pond, must have a depth marker that clearly indicates the minimum capacity necessary to contain the direct precipitation on the pond attributed to a 25-year, 24-hour storm. The Recycled Water Agency shall maintain this capacity for emergency storage.</u>
4.	Paragraph II.A.1.a(2) (Evaporation Pond	Revise the following language to read:

Errata Sheet
Tentative Addendum No. 1 to Order No. R9-2009-0005

Errata Item No.	Section	Revision
	Monitoring Requirement J.1.a.ii)	A summary of observations of the pond. The Recycled Water Agency shall observe each pond daily, determine each pond section 13 's freeboard, and enter observations into a permanent log. The log shall be made available to the San Diego Water Board upon request.
5.	Paragraph I.A.3.e (Evaporation Pond Facility and Design Specification H.3.e)	Revise the following language to read: Remove s Solids buildup shall be removed annually, as-needed, sufficiently by October 31 st of each year to provide adequate storage capacity prior to the anticipated rainy season.
6.	Paragraph II.A.2.b (Evaporation Pond Monitoring Requirement J.2.b)	Revise the following language to read: The observation ports above the HDPE PVC containment liner shall be monitored for significant increases in specific conductance levels in the LCRS sump...
7.	Paragraph II.A.2.c (Evaporation Pond Monitoring Requirement J.2.c)	Revise the following language to read: The observation ports below the HDPE PVC containment liner shall be monitored for significant increases in specific conductance levels in the LCRS sump...
8.	Paragraph III.B.1.b (Effluent Monitoring Requirement C.1.b)	Revise the following language to read: Compliance with Prohibition A.4 of Order No. R9-2009-0005 shall be determined by comparing the arithmetic mean of daily flow rates during any thirty-day period with the 0.08 0.80 million gallons per day (mgd) prohibition.