

**Prince of Peace Abbey Onsite
Wastewater Treatment System
Order WQ 2014-0153-DWQ**

**Mo. Lahsaie, Ph.D.; REHS
Environmental Officer
City of Oceanside
August 10, 2016**

Site Information

- **Discharge of wastewater for treatment was first permitted on June 30, 1960 with direct discharge to two Oxidation ponds.**
- **130 acre site with 23 on-site permanent staff, a retreat facility for 45 overnight guests, and mass is offered daily.**

Prince of Peace Abbey's Proposal


The proposed OWTS consists of a 10,000-gallon capacity septic tank followed by a subsurface flow wetlands treatment System.

City of Oceanside's Major Concerns

- **Current Bacteria TMDL mandate for San Luis Rey River watershed.**
- **Potential bacteria source for both surface and groundwater resources.**
- **Potential to negatively impact REC-1 beneficial uses.**

Prince of Peace Abbey Wastewater Upgrade

GIS data from City of Oceanside, Water Utilities GIS Division, along with data derived, modified, reduced, and/or processed from SanGIS downloadable data - www.sangis.org Copyright SanGIS2015.



City of Oceanside's Recommendations

- Install a fully designed Septic System on the mesa with a leach-field & septic tank, or
- Connect to the City's existing sewer system approx. 1,560 feet down gradient from the site.