IN THE MATTER OF)
) NOTICE OF VIOLATION
	NO. R9-2009-0095
County of San Diego)
5555 Overland Ave., Suite 2188) In reply refer to:
San Diego, CA 92123-1295) 255440:chenning

Order No. 94-004 for Waste Discharge Requirements for Southeastern California Conference Seventh-Day Adventist, San Pasqual Academy, San Diego County

Site: San Pasqual Academy, 17701 San Pasqual Valley Road, Escondido, CA

92025

YOU ARE HEREBY NOTIFIED THAT:

The County of San Diego (Discharger) is in violation of Order No. 94-004, issued by the California Regional Water Quality Control Board, San Diego Region (Regional Board) for the treatment and disposal of domestic wastewater from an onsite wastewater treatment system at San Pasqual Academy. These violations subject the Discharger to possible further enforcement action by the Regional Board, including administrative enforcement orders requiring you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative civil liability in amounts of up to \$5,000 per day per violation; referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The Regional Board reviewed the following semiannual and annual monitoring reports required by Waste Discharge Requirements (WDR) Order No. 94-004:

PERIOD	REPORT DATE	DATE RECEIVED
January - June 2008	July 30, 2008	July 31, 2008
July - December 2008	January 30, 2009	January 30, 2009
January - December 2008	January 30, 2009	January 30, 2009

A total of 25 effluent violations were noted in the above reports.

¹ Under authority of California Water Code section 13350.

Summary of Violations

- 1. The 30-day average for total suspended solids (30 milligrams per liter [mg/L]) was exceeded in the month of October 2008 with a reported value of 38.9 mg/L.
- The 30-day average for total dissolved solids (800 mg/L) was exceeded in the months of November and December 2008, with the reported values of 844 and 804 mg/L, respectively.
- 3. The 30-day average for chlorine (130 mg/L) was exceeded in the months of January, February, March, April, July, August, September, October, November, and December 2008, with the reported values of 157, 160, 179, 160, 176, 173, 194, 180, 182, and 222 mg/L, respectively.
- 4. The daily maximum for chlorine (150 mg/L) was exceeded on January 10, 2008; February 12, 2008; March 11, 2008; April 10, 2008; July 15, 2008; August 11, 2008; in September 2008; October 15, 2008; in November 2008; and December 10, 2008, with the reported values of 157, 160, 179, 160, 176, 173, 194, 180, 182, and 222 mg/L, respectively.
- 5. The 30-day average for sulfate (130 mg/L) was exceeded on December 10, 2008, with the reported value of 136 mg/L.
- 6. The daily maximum for boron (0.5 mg/L) was exceeded on July 15, 2008, with the reported value of 0.55 mg/L.

Questions pertaining to the issuance of this Notice of Violation are to be directed to Ms. Cathryn Henning at (858) 636-3161 or via e-mail at chenning@waterboards.ca.gov. Written correspondence should be directed to the following address:

Ms. Julie Chan
Supervising Engineering Geologist
California Regional Water Quality Control Board, San Diego Region
9174 Sky Park Court, Suite 100
San Diego, CA 92123-4340

بالالإسilie Chan, P.G.

Supervising Engineering Geologist

Groundwater Basins Branch