



# California Regional Water Quality Control Board San Diego Region



Linda S. Adams  
Secretary for  
Environmental Protection

Over 50 Years Serving San Diego, Orange, and Riverside Counties  
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

Arnold Schwarzenegger  
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353  
(858) 467-2952 • Fax (858) 571-6972  
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

April 19, 2010

In reply refer to:  
245555:adai

Mr. Ramon G. Zuniga  
Rainbow Municipal Water District  
4747 Oakcrest Rd  
Fallbrook, CA 92028

Dear Mr. Zuniga:

**SUBJECT: REVIEW OF MONITORING REPORT FOR ORDER NO. 93-69  
OAK CREST MOBILE ESTATES, INC.**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the June-December 2009 semiannual monitoring report submitted by Rainbow Municipal Water District in accordance with Monitoring and Reporting Program No. 93-69.

The following violations of Discharge Specification B.1 of Order No. 93-69 were identified in the reports submitted:

1. The effluent total dissolved solids (TDS) concentration was reported as 740 milligrams per liter (mg/L) on December 2, 2009. This value exceeded the supply water TDS concentration by more than 300 mg/L. Discharge Specification B.1 specifies that the daily effluent TDS concentration shall not exceed the supply water TDS concentration by more than 300 mg/L.
2. The effluent sulfate concentration was reported as 230 mg/L on December 2, 2009. This value exceeded the supply water sulfate concentration by more than 100 mg/L. Discharge Specification B.1 specifies that the daily effluent TDS concentration shall not exceed the supply water concentration by more than 300 mg/L.

Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability

**California Environmental Protection Agency**

in amounts of up to \$5,000 per day per violation;<sup>1</sup> referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report required to be submitted is the January-June 2010 annual report, which is due by July 30, 2010.

In the subject line of any response, please include the requested "In reply refer to:" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or [adai@waterboards.ca.gov](mailto:adai@waterboards.ca.gov).

Sincerely,

*Robert Morris*

Robert W. Morris, P.E.  
Senior Water Resource Control Engineer  
Ground Water Branch

---

<sup>1</sup> Under authority of California Water Code section 13350.