

California Regional Water Quality Control Board

San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



9174 Sky Park Court, Suite 100, San Diego, California 92123-4353 (858) 467-2952 • Fax (858) 571-6972 http://www.waterboards.ca.gov/sandiego

October 26, 2010

In reply refer to: 240177:adai

Mr. Dennis Lamb General Manager Vallecitos Water District 201 Vallecitos de Oro San Marcos, CA 92069-1453

Dear Mr. Lamb:

SUBJECT: REVIEW OF MONITORING REPORTS FOR MEADOWLARK WATER RECLAMATION PLANT (WRP)

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the June and July 2010 monthly monitoring reports submitted by the Vallecitos Water District (District) in accordance with Monitoring and Reporting Program No. R9-2007-0018.

The San Diego Water Board identified the following violations of Order No. R9-2007-0018:

1. The minimum modal chlorine contact time of Facility Design and Operation Specification C.6, established at 90 minutes, was not met on June 8 and 9, 2010 with a reported value of 89 and 87 minutes, respectively.


Please be aware these violations subject the District to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation; 1 referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report to be submitted is the September 2010 monthly monitoring report due by November 1, 2010.

¹ Under authority of California Water Code section 13350.







For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or via email at adai@waterboards.ca.gov.

-2-

PLEASE INCLUDE "240177:ADAI" IN THE SUBJECT LINE OF FUTURE CORRESPONDANCE.

Sincerely,

Robert Morris, P.E.

Senior Water Resource Control Engineer

Cleanup and Land Disposal Branch

Regulatory Measure #: 376312

Robert Marris

CIWQS Violation ID: 883328, 883329