

California Regional Water Quality Control Board

San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties

Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

Edmund G. Brown, Jr.

Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353 (858) 467-2952 • Fax (858) 571-6972 http://www.waterboards.ca.gov/sandiego

December 12, 2011

Mr. Glenn Pruim General Manager Carlsbad Municipal Water District 5950 El Camino Real Carlsbad, CA 92008 In reply refer to: 382295:ccannova

Dear Mr. Pruim:

SUBJECT: REVIEW OF MONITORING REPORTS FOR THE CARLSBAD WATER RECYCLING FACILITY


The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the March-October 2011 monthly monitoring reports, and the April-June 2011 and July-September 2011 quarterly monitoring reports submitted by the Carlsbad Municipal Water District (District) in accordance with Monitoring and Reporting Program No. 2001-0352.

The following violations of Order No. R9-2003-0123 were identified in Section B (Discharge Specifications) of Order No. R9-2001-0123:

- The daily average effluent turbidity concentration established at 2 NTU (nephelometric turbidity units), was exceeded on April 27, 2011 with a reported value of 2.29 NTU.
- 2. The daily maximum effluent limitation for iron, established at 0.4 mg/L, was exceeded on September 2 and September 14, 2011 with reported values of 0.54 and 0.70 milligrams per liter (mg/L) respectively.
- 3. The daily maximum effluent limitation for manganese, established at 0.06 mg/L, was exceeded 32 times between the dates of April 5, 2011 and September 29, 2011, with reported values reaching a high of 0.09 mg/L.

Please be informed that the San Diego Water Board will be considering adoption of Tentative Order No. R9-2011-0067 (tentative Order) at its board meeting on February 8, 2012, which, if adopted, would modify the discharge specifications for iron and manganese specified in Order No. R9-2001-0123. A copy of the tentative Order was mailed to the District on November 29, 2011. Consequently, the San Diego Water

California Environmental Protection Agency



| ここのことには、このでは

Board is not planning to take any further enforcement action regarding the iron and manganese effluent violations noted above at this time.

The next monitoring report required to be submitted is the November 2011 monthly monitoring report, which is due by January 1, 2012.

In the subject line of any response, please include the requested "In refer to" information located in the heading of this letter. Please contact Ms. Catherine Cannova at (858) 627-3977 or at ccannova@waterboards.ca.gov if you have any questions on this matter.

Sincerely,

Brian Kelley

Senior WRC Engineer

Cleanup and Land Discharge Branch

CC: Kevin M. Hardy, General Manager Encina Wastewater Authority 6200 Avenida Encinas Carlsbad, CA 92011-1095

Regulatory Measure ID: 382295

Violation ID: 1) 913438 2) 913435,913436 3) 913433