



California Regional Water Quality Control Board

San Diego Region



Linda S. Adams
Acting Secretary for
Environmental Protection

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

Edmund G. Brown, Jr.
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

January 4, 2011

Mr. Tom Rosales
General Manager
South Orange County Wastewater Authority
34156 Del Obispo St.
Dana Point, CA 92629

In reply refer to:
257850:adai

Dear Mr. Rosales:

SUBJECT: REVIEW OF MONITORING REPORTS SUBMITTED BY THE SOUTH ORANGE COUNTY WASTEWATER AUTHORITY (MULTIPLE FACILITIES)

The California Regional Water Quality Control Board San Diego Region (San Diego Water Board) has reviewed the November 2010 monthly monitoring report. These reports were submitted by the South Orange County Water Authority (SOCWA) in accordance with the Monitoring and Reporting Program of Order No. 97-52.

The following violations of Order No. 97-52 were identified in the submitted reports:

Moulton Niguel Water District, Regional Plant

1. The 12-month average discharge specification for manganese, established at 0.05 milligrams per liter (mg/L), was exceeded for November 2010 with a reported value of 0.06 mg/L.
2. The daily maximum discharge specification for manganese, established at 0.06 mg/L, was exceeded on November 1, 2010 with a reported value of 0.08 mg/L.

South Coast Water District, Coastal Treatment Plant

3. The daily maximum discharge specification for manganese, established at 0.06 mg/L, was exceeded on November 1, 2010 with a reported value of 0.09 mg/L.
4. The 12-month average discharge specification for manganese, established at 0.05 mg/L, was exceeded for November 2010 with a reported value of 0.08 mg/L.

Please take steps to implement follow-up actions necessary to ensure that the violations noted do not occur in the future. These violations subject SOCWA to possible further

enforcement action by the San Diego Water Board including administrative enforcement orders requiring SOCWA to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report required to be submitted is the December 2010 monthly monitoring report, which is due by January 30, 2011.

For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or via email at adai@waterboards.ca.gov.

PLEASE INCLUDE "257850:ADAI" IN THE SUBJECT LINE OF FUTURE CORRESPONDANCE.

Sincerely,



Fisayo Osibodu
WRC Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID	142903
Place ID	257850 241053
Enforcement ID	377060
Violation ID	888064
	888065
	888066
	888067

¹ Under authority of California Water Code section 13350.