



California Regional Water Quality Control Board, San Diego Region

April 9, 2012

In reply refer to: CIWQS Place 769449: WGhoram WDID No. 9 000002314

Mr. Steve Donlon, Owners Representative Ariel Suites, L.P. 850 East Desert Inn Road Las Vegas, Nevada, 89109

SUBJECT: REVIEW OF SELF MONITORING REPORTS; ORDER NO. R9-2007-

0034; NPDES NO. CAG919001

ARIEL SUITES CONSTRUCTION DEWATERING PROJECT, 735 WEST FACILITY:

BEECH STREET, SAN DIEGO, CALIFORNIA

Mr. Donlon:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the following report:

MONITORING REPORTS REVIEWED FOR ORDER NO R9-2007-0034		
PERIOD	REPORT DATE	DATE RECEIVED
March 2012	March 28, 2012	April 2, 2012
	PERIOD	PERIOD REPORT DATE


Based upon our review of the information contained in the March 2012 monthly monitoring report, the San Diego Water Board has the following comments:

Copper exceeded effluent limitations with concentrations of 36.2, 12.8, 29.9 and 5.44 ug/L vs. the 2.9 ug/L AMEL and 5.8 ug/L MDEL effluent limitations.

Nickel exceeded effluent limitations with concentrations of 14.5 and 7.07 ug/L vs. the 6.8 ug/L AMEL effluent limitation.

Tetrachloroethylene exceeded effluent limitations with concentrations of 17.8, 19.5, and 35.2 ug/L vs. the 2.0 ug/L AMEL effluent limitation.

GRANT DESTACHE, CHAIR | DAVID GIBSON, EXECUTIVE OFFICER







Total Suspended Solids exceeded effluent limitations with concentrations of 52.0, 38.0 and 44.0 mg/L vs. the 30.0 mg/L AMEL and 50.0 mg/L instantaneous maximum effluent limitations.

Acute Toxicity exceeded the effluent limitation with concentrations of 0.53 TUa vs. the MDEL of 0.3 TUa.

Chronic Toxicity exceeded the effluent limitation with concentrations of <1.65 TUc for the kelp and sea urchin portions of the test vs. the MDEL of 1.0 TUc.

NOTE: AMEL= average monthly effluent limitation, MDEL= maximum daily effluent limitation.

These exceedances are violations of Order No. R9-2007-0034. Please take immediate corrective actions to reduce the concentrations of these constituents and prevent additional effluent limitation violations and enforcement action.

The California Water Code (CWC) includes provisions for a variety of enforcement actions for violations of the terms and conditions of Order No. R9-2007-0034, the CWC, and the Clean Water Act. Violations of Order No. R9-2007-0034 may subject Ariel Suites, L.P. to further enforcement including Cleanup and Abatement Orders, Cease and Desist Orders, Administrative Assessment of Liability, and/or termination of enrollment under Order No. R9-2007-0034. Liability could be administratively imposed to a maximum of \$10,000 per violation plus \$10 per gallon of waste discharged. In addition, pursuant to the CWC sections 13385 (h) and (i), some violations of effluent limitations may be subject to Mandatory Minimum Penalties (MMP) of \$3,000 for each violation. The San Diego Water Board will notify you of any violations that are determined to be subject to MMPs.

Please review the monitoring and reporting schedule of Order No. R9-2007-0034 and ensure that monitoring reports are received at the San Diego Water Board office by the due dates indicated in the Order.

Respectfully,


Euri J Berham

ERIC S. BECKER, P.E.

Senior Water Resource Control Engineer

Southern Watershed Unit





Cc:

Mr. Donald Sturgeon, Whitson CM Contracting & Management, Inc., 11021 Via Frontera, Suite E, San Diego, CA 92127

Ms. Nida Saleem, CPESC, QSD, Storm Water Compliance Manager, Whitson CM Contracting & Management, Inc., 11021 Via Frontera, Suite E, San Diego, CA 92127

Mr. Daniel Lottermoser, City of San Diego, Transportation & Storm Water Department, Storm Water Division, 9370 Chesapeake Drive, Suite 100, MS 1900, San Diego, CA 92123