

California Regional Water Quality Control Board

San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



9174 Sky Park Court, Suite 100, San Diego, California 92123-4353 (858) 467-2952 • Fax (858) 571-6972 http:// www.waterboards.ca.gov/sandiego

March 13, 2012

In reply refer to: 382760:ccannova

Mr. Steve Meyer, Deputy Director Metropolitan Wastewater Division City of San Diego 2392 Kincaid Road San Diego, CA 92101-2309

Dear Mr. Meyer

SUBJECT: REVIEW OF MONITORING REPORTS FOR NORTH CITY WATER RECLAMATION PLANT

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the December 2011-January 2012 monthly, October-December 2011 quarterly, and January-December 2011 annual monitoring reports submitted by the City of San Diego (City) in accordance with the Monitoring and Reporting Program of Order No. 97-03.

The following violations of the Order No. 97-03 were identified in the submitted monitoring reports:

The 12-month average effluent limitation for manganese of Discharge Specification A.2, established at 0.05 milligrams per liter (mg/L), was exceeded in the month of December 2011 and January 2012 with reported values of 0.071 and 0.074 mg/L, respectively.

Please be aware these violations subject the City to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the City to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ and referral to the State Attorney General for injunctive relief.

The next monitoring report to be submitted is the February 2012 monthly monitoring report due by March 28, 2012.

California Environmental Protection Agency

10 Decualed Paner

¹ Under authority of California Water Code section 13350.

Mr. Meyer

In the subject line of any response, please include the requested "In refer to" information located in the heading of this letter. Please contact Ms. Catherine Cannova at (858) 627-3977 or at <u>ccannova@waterboards.ca.gov</u> if you have any questions on this matter.

1.1.1.1.1.1.

-11-

÷ ;

Sincerely,

rion D. Kelley

Brian D. Kelley, P.E. Senior Water Resource Control Engineer Cleanup and Land Discharge Branch

Regulatory Measure ID: 383716 Violation ID: 920673, 920674

California Environmental Protection Agency

1 Denualad Danar

e'