



San Diego Regional Water Quality Control Board

October 12, 2015

Mr. Mark Kaveney Water Reclamation Manager Rancho California Water District 42135 Winchester Road P.O. Box 9017 Temecula, Ca 92589 In reply refer to / attn: 403068: abuck

## Subject: Review of Monitoring Reports for the Santa Rosa Water Reclamation Facility, Order No. 94-92

Mr. Kaveney:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the November 2014 through July 2015 monthly monitoring reports, the October-December 2014 quarterly recycled water users report, and the January-December 2014 annual report.

The effluent 12 month average discharge specification for Total Dissolved Solids (TDS), established at 750 milligrams per liter (mg/L)<sup>1</sup> was exceeded in April and July 2015 with reported concentrations of 751 and 754 mg/L respectively.

Please take the steps to implement follow-up actions necessary to ensure that the effluent violations noted above do not occur in the future. These violations may subject Rancho California WD to possible further enforcement action by the San Diego Water Board including but not limited to: administrative enforcement orders requiring the discharger to cease and desist from violations, or administrative assessments of civil liabilities in amounts of up to \$5,000 per day per violation; referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

In the subject line of any response, please include reference 403068: **abuck**. Please contact Mr. Aaron Buck at 619-521-8045, or at <u>buck.aaron@waterboards.ca.gov</u> if you have any questions or comments.

Respectfully,

John R. Odermatt, P.G, Senior Engineering Geologist Land Discharge Unit

HENRY ABARBANEL, PH.D, CHAIR | DAVID GIBSON, EXECUTIVE OFFICER

2375 Northside Drive, Suite 100, San Diego, California 92108-2700 | www.waterboards.ca.gov/sandiego

<sup>&</sup>lt;sup>1</sup> Section B.3 of Order No. 94-92 specifies that the effluent 12 month average TDS concentration shall not exceed 750 mg/L.

.

.

JRO: oo: ab

.

.

Tech Staff Info & Use	
Place ID	255735
Reg. Measure ID	403068
Violation ID	997327, 997328