



San Diego Regional Water Quality Control Board

Sent Via Email Only

September 30, 2015

Dr. Peter Vroom
Deputy Director
City of San Diego
pvroom@sandiego.gov

In reply refer to: 248796:JLLim

Subject:

Staff Enforcement Letter for Point Loma Ocean Outfall, Order No. R9-2009-0001,

NPDES Permit No. CA0107409

Dr. Vroom:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has noted the following violations for Point Loma Ocean Outfall:

Violation - Effluent Exceedance, Section IV.A.1.b

- 1. The chronic toxicity maximum daily limit of 205 TUc was exceeded on May 12, 2015 with a reported value of 370.4 TUc at Monitoring Location EFF-001.
- 2. The chronic toxicity maximum daily limit of 205 TUc was exceeded on June 2, 2015 with a reported value of 666.7 TUc at Monitoring Location EFF-001.

Pursuant to the California Water Code (CWC), the violation noted is subject to additional enforcement action(s) by the San Diego Water Board including a time schedule order, cease and desist order, cleanup and abatement order, imposition of administrative civil liability, referral to the district attorney for criminal prosecution, or referral to the attorney general. Administrative civil liability amounts that may be imposed by the San Diego Water Board under authority of CWC Section 13385 include up to \$10,000 per day, or up to \$10 per gallon for each gallon of waste discharged.

In the subject line of any response, please include the reference "Place ID 248796:JLLim". For questions or concerns regarding this letter, please contact Joann Lim at 619-521-3362 or joann.lim@waterboards.ca.gov.

Respectfully

Dat Quach, P.E.

Water Resource Control Engineer

Source Regulatory Unit

Tech Staff Info & Use	
Order No.	R9-2009-0001
Party IDs	8709 (SDCMWD), 547282 (Vroom)
WDID	9 000000275
NPDES No.	CA0107409
Reg. Measure IDs	374769 (R9-2009-0001), 402615 (SEL)
PIN	248796
Violation IDs	
1a.	993302
1b.	994007
	·