

San Diego Regional Water Quality Control Board

By Email Only

June 21, 2016

Mr. Steve Wagner
President
Stone Brewing Company
1999 Citracado Pkway.
Escondido, CA 92029
steve.wagner@stonebrewing.com

In reply refer to / attn:
772583:DQuatch

Subject: Staff Enforcement Letter for Stone Brewing Company, Order No. R9-2012-0006, Waste Discharge Requirements for Stone Brewing Company, NPDES Permit No. CA0109258

Mr. Wagner:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the following self-monitoring reports (SMRs) submitted between January 2015 and December 2015 for Stone Brewing Company:

- Semi Annual SMRs – July 2015 through December 2015
- Annual SMRs – January 2015 through December 2015

The following is a summary of the San Diego Water Board's findings:

1. Violation – Effluent Limitation, Attachment E, Section IV.A

On September 2, 2015, the pH was reported as 5.59 SU, which is less than the instantaneous minimum limitation of 6.00 SU at Monitoring Location EFF-001.

Pursuant to the California Water Code (CWC), the violation noted is subject to additional enforcement action(s) by the San Diego Water Board including a time schedule order, cease and desist order, cleanup and abatement order, imposition of administrative civil liability, referral to the district attorney for criminal prosecution, or referral to the attorney general. Administrative civil liability amounts that may be imposed by the San Diego Water Board under authority of CWC section 13385 include up to \$10,000 per day or up to \$10 per gallon for each gallon of waste discharged.

In the subject line of any response, please include the reference "772583:DQuatch ". For questions or concerns regarding this letter, please contact Dat Quach at 619-521-5899 or Dat.Quach@waterboards.ca.gov.

Respectfully,



Dat Quach, P.E.
Water Resource Control Engineer
Source Control Regulatory Unit

cc: Timothy A. Suydam, Water Operations Manager, tim.suydam@stonebrewing.com
Thomas Modifica Jr., Water Operations Manager, tom.modifica@stonebrewing.com

Tech Staff Info & Use	
Order No.	R9-2012-0006
Party IDs	772583 (Stone Brewing Company)
WDID	9 000002380
NPDES No.	CA0109258
Reg. Measure IDs	382281 (R9-2012-0015), 406336 (SEL)
PIN	772583
Violation ID	
1	1001971