



San Diego Regional Water Quality Control Board

January 5, 2017

Ms. Cari Dale Water Utilities Director City of Oceanside 5950 El Camino Real Carlsbad, CA 92028 cdale@ci.oceanside.ca.us Sent Via Email Only

In reply refer to / attn: 245795:DQuach

Subject:

Staff Enforcement Letter for the City of Oceanside, Oceanside Ocean Outfall, Order No. R9-2011-0016, NPDES Permit No. CA0107433

Ms. Dale:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the following self-monitoring reports (SMRs) for the City of Oceanside's facilities associated with the Oceanside Ocean Outfall:

- Monthly SMRs June 2016 through October 2016
- Quarterly SMRs April 2016 through September 2016
- Semi-annual SMR January 2016 through June 2016

The following is a summary of the San Diego Water Board's findings:

1. Violation - Effluent Limitation, Section IV.A

On August 31, 2016, the total suspended solids (TSS) monthly mean was reported as 63.3 mg/L, exceeding the average monthly effluent limitation of 60.0 mg/L at Monitoring Location No. M-003.

2. Violation - Deficient Monitoring, Attachment E, Section IV.A.2, Table E-4

On August 3, 2016, the City of Oceanside failed to monitor for pH at Monitoring Location M-003.

3. Violation - Deficient Reporting, Attachment E, Section X.B.3, Table E-16

The Third Quarter SMR was due on November 1, 2016; the report was submitted on November 16, 2016.

4. Comments - Surface Water Limitations, Section V.A.

- a. On September 12, 2016, the fecal coliform density was reported to be 430 MPN/100mL at Monitoring Location No. A5-mid-depth, exceeding the receiving water limitation of 400 per 100mL.
- b. On September 12, 2016, the total coliform density was reported to be 1,100 MPN/100mL at Monitoring Location No. A5-mid-depth, exceeding the receiving water limitation of 1,000 per 100mL.
- c. On September 12, 2016, the fecal coliform density was reported to be 1,100 MPN/100mL at Monitoring Location No. A2-mid-depth, exceeding the receiving water limitation of 400 per 100mL.
- d. On September 12, 2016, the fecal coliform density was reported to be 430 MPN/100mL at Monitoring Location No. A5-mid-depth, exceeding the receiving water limitation of 400 per 100mL.
- e. On October 25, 2016, the fecal coliform density was reported to be 2,100 MPN/100mL at Monitoring Location No. S3, exceeding the receiving water limitation of 400 per 100mL.
- f. On October 25, 2016, the total coliform density was reported to be 5,400 MPN/100mL at Monitoring Location No. A2-mid-depth, exceeding the receiving water limitation of 1,000 per 100mL.

Pursuant to the California Water Code (CWC), the violations noted are subject to additional enforcement action(s) by the San Diego Water Board including a time schedule order, cease and desist order, cleanup and abatement order, imposition of administrative civil liability, referral to the district attorney for criminal prosecution, or referral to the attorney general. Administrative civil liability amounts that may be imposed by the San Diego Water Board under authority of CWC section 13385 include up to \$10,000 per day or up to \$10 per gallon for each gallon of waste discharged.

In the subject line of any response, please include the reference "245795:DQuach". For questions or concerns regarding this letter, please contact me by phone at 619-521-5899 or by email at Dat.Quach@waterboards.ca.gov.

Respectfully,

Dat Quach, P.E.

Water Resources Control Engineer

Source Control Unit

cc by email:

Joann Lim, San Diego Water Board, <u>Joann.Lim@waterboards.ca.gov</u> Chiara Clemente, San Diego Water Board, <u>Chiara.Clemente@waterboards.ca.gov</u>

	Tech Staff Info & Use		
Order No. Party IDs WDID NPDES No. Reg. Measure IDs PIN	R9-2011-0016 32483 (Oceanside City), 357824 (Dale) 9 000000146 CA0107433 377272 (R9-2011-0016), 411272 (SEL) 245795		
Violation IDs			
1 2 3	1013341 1016945 1017540		