



## San Diego Regional Water Quality Control Board

August 17, 2018

Mr. Scott Pastore Plant Manager Rancho Santa Fe Community Service District 605 Third Street Encinitas, California, 92024 In reply refer to / attn: 251714:BBushnell

Subject: Review of Monitoring Reports for Order No. 92-04, Rancho Santa Fe Water Pollution Control Facility

Mr. Pastore:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the monitoring reports Listed in Table 1 below. The Rancho Santa Fe Community Service (Discharger) submitted the monitoring reports as required by the Monitoring and Reporting Program No. 92-04.

Table 1. List of Monitoring Reports Reviewed

Report Type	Report Date
Quarterly Monitoring Reports	January-March 2017, July-September 2017
	October-December 2017, January-March
•	2018 and April-June 2018
Annual Monitoring Reports	2017

The following violations of Discharge Specifications in Order No. 92-04 Section B. 1 were identified in the monitoring reports and are listed below:

1. The discharge specification for the monthly average concentration of manganese is established at 0.15 milligrams per liter (mg/L) and was exceeded on the following dates:

Table 2. Exceedances of Monthly Average Manganese Discharge Specification

Dates	Value in mg/L
April 4, 2017	0.46
July 11, 2017	0.25
January 2, 2017	0.23
April 3, 2018	0.28

TOMAS MORALES, CHAIR DAVID GIBSON, EXECUTIVE OFFICER

2. The discharge specification for the daily maximum concentration for manganese is established at 0.20 mg/L and was exceeded on the following dates:

Table 3. Exceedances of Monthly Average Manganese Discharge Specification

Dates	Value in mg/L
April 4, 2017	0.46
July 11, 2017	0.25
January 2, 2017	0.23
April 3, 2018	0.28

- 3. The discharge specification for the daily maximum concentration of chloride, established at 500 mg/L, was exceeded on April 3, 2018 at a reported concentration of 540 mg/L
- 4. The discharge specification for the daily maximum concentration of Total Dissolved Solids (TDS), established at 1,500 mg/L, was exceeded on January 3, 2017 at a reported concentration of 1,556 mg/L.

According to Addendum 1 of Order No. 92-04, the discharger is required to submit monthly monitoring reports. Please begin reporting monthly starting with the month of October 2018. The next monitoring report due is the June-August quarterly report which is due by **October 30, 2018**.

In the subject line of any response, please include reference **251714:BBushnell**. Please contact Mr. Brandon Bushnell at 619-521-8044, or at <a href="mailto:brandon.bushnell@waterboards.ca.gov">brandon.bushnell@waterboards.ca.gov</a> if you have any questions or comments.

Respectfully,

John R. Odermatt, P.G., Senior Engineering Geologist

**Groundwater Protection Unit** 

JRO: bb

Tech Staff Info & Use		
Place ID Reg. Measure ID SEL Reg. Measure ID Violation ID	142398	