



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

San Diego Regional Water Quality Control Board

July 19, 2018

Ms. Margie Davis
San Diego Zoological Society
15500 San Pasqual Valley Road,
Escondido, CA 92027

In reply refer to / attn:
255446:BBushnell

**Subject: Review of Monitoring Reports for Order No. 99-04, San Diego Wild
Animal Park**

Ms. Davis:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the monitoring reports listed in the Table 1 below. The Zoological Society of San Diego (Discharger) submitted the monitoring reports as required by the Monitoring and Reporting Program of Order No. 99-04.

Table 1. List of Monitoring Reports Reviewed

Report Type	Report Date
Monthly Monitoring Reports	February 2017 through May 2018
Quarterly Monitoring Reports	April-June 2017, July-September 2017, October-December 2017 and January-March 2018
Annual Monitoring Report	2017


The following violations of Discharge and Operation Specifications in Order No. 99-04 section B.4 were identified in the monitoring reports:

1. Order No. 99-04 requires that the effluent total coliform bacteria concentration shall not exceed 240 MPN/100 mL in more than one sample in a 30-day period. The total coliform bacteria concentration limit was exceeded on October 12, 2017 and October 13, 2017 with reported values of 900 and 240 MPN/100 mL, respectively.
2. Order No. 99-04 requires that effluent chloride concentration shall not exceed 400 mg/L. The chloride concentration limit was exceeded on July 15, 2017 with a reported value of 2,503 mg/L.

The next monitoring report required to be submitted is the June monthly monitoring report, which is due by August 1, 2018.

In the subject line of any response, please include reference **255446:BBushnell**. Please contact Mr. Brandon Bushnell at 619-521-8044, or at brandon.bushnell@waterboards.ca.gov if you have any questions or comments.

Respectfully,



John R. Odermatt, P.G., Senior Engineering Geologist
Groundwater Protection Unit

JRO: ac: bb

cc (via email): Ms. Margie Davis, office@wqscs.com

Tech Staff Info & Use	
Place ID	255446
Reg. Measure ID	143551
SEL Reg. Measure ID	421445
Violation ID	1040551, 1040556