

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION

STAFF SUMMARY REPORT (Derek Whitworth)
MEETING DATE: August 8, 2007

ITEM **11 A & B**

SUBJECT: **City and County of San Francisco, San Francisco International Airport, Mel Leong Treatment Plant, Industrial Plant, and North Bayside System Unit, San Mateo County—Reissuance of NPDES Permit (11A) and Hearing to Consider Cease and Desist Order (CDO) for Discharge in Violation of Waste Discharge Requirements (11B)**

CHRONOLOGY: March 2002—Permit reissued

DISCUSSION: The City and County of San Francisco owns and operates the Mel Leong Treatment Plant, Industrial Plant, at San Francisco International Airport. The Industrial Plant treats industrial wastewater from facilities at the airport (e.g., maintenance shops, car washing) as well as first flush storm water runoff from industrial areas. Effluent from the Industrial Plant is combined with effluent from the Airport's Sanitary Plant (see Item 10) and pumped to a deepwater outfall that is shared with two other municipal treatment plants.

This item reissues the Airport's NPDES permit for the Industrial Plant and establishes more stringent effluent limits for a number of toxic pollutants with which the Airport cannot immediately comply. To address these potential violations we have developed a CDO to be considered in conjunction with the permit. The CDO establishes tasks and time schedules for the Airport to address potential violations.

The Airport commented on a tentative permit and a tentative CDO circulated for public comment in June. The Airport's concerns are nearly identical to those for the Sanitary Plant (Item 10). For completeness, comments on the Sanitary Plant and our responses are also included in this package.

**RECOMMEN-
DATION:** Adoption of the Revised Tentative Order and the Revised Cease and Desist Order.

FILE NUMBER: 2179.7033

APPENDICES:

- A. Revised Tentative Order
- B. Revised Tentative Cease and Desist Order
- C. Comments
- D. Responses to Comments

A. Revised Tentative Order



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board

San Francisco Bay Region

1515 Clay Street, Suite 1400
(510) 622-2300 • Fax (510) 622-2460
<http://www.waterboards.ca.gov/sanfranciscobay>



Arnold Schwarzenegger
Governor

TENTATIVE ORDER NO. R2-2007-00XX NPDES NO. CA0028070

The following Discharger is subject to waste discharge requirements as set forth in this Order.

Table 1. Discharger Information

| | |
|-------------------------|--|
| Dischargers | City and County of San Francisco and North Bayside System Unit (NBSU) |
| Name of Facility | San Francisco International Airport, Mel Leong Treatment Plant, Industrial Plant |
| Facility Address | 676 McDonnell Road, San Francisco, San Mateo County California 94128 |

The discharge by the City and County of San Francisco, San Francisco International Airport (SFIA), Mel Leong Treatment Plant, Industrial Plant, from the discharge point identified below is subject to waste discharge requirements as set forth in this Order.

Table 2. Discharge Location

| Sampling Points | Effluent Description | Discharge Point Latitude | Discharge Point Longitude | Receiving Water |
|--------------------------------|--|--------------------------|---------------------------|-------------------------|
| EFF-001-Ind, EFF-100A, EFF-002 | Treated industrial wastewater and storm water runoff | 37° 39' 55" N | 122° 21' 41" W | Lower San Francisco Bay |
| 003 through 010 and 013 | Storm water runoff | Not defined | Not defined | Lower San Francisco Bay |

Table 3. Administrative Information

| | |
|--|---------------------------|
| This Order was adopted by the Regional Water Board on: | |
| This Order shall become effective on: | October 1, 2007 |
| This Order shall expire on: | September 30, 2012 |
| The U.S. Environmental Protection Agency (USEPA) and the Regional Water Board have classified this discharge as a major discharge. | |
| The Discharger shall file a Report of Waste Discharge in accordance with Title 23, California Code of Regulations, not later than 180 days in advance of this Order expiration date as application for issuance of new waste discharge requirements. | |

IT IS HEREBY ORDERED, that this Order supersedes Order No. R2-2002-0045 except for enforcement purposes, and, in order to meet the provisions contained in Division 7 of the Water Code (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal Clean Water Act (CWA) and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

I, Bruce H. Wolfe, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on _____, 2007.

Bruce H. Wolfe, Executive Officer

Table of Contents

| | |
|---|----|
| I. Facility Information..... | 4 |
| II. Findings | 4 |
| III. Discharge Prohibitions | 12 |
| IV. Effluent Limitations and Discharge Specifications..... | 13 |
| A. Effluent Limitations – Discharge Point 001 | 13 |
| B. Effluent Limitations – Discharge Point 002 | 17 |
| C. Mercury Mass Emission Limitation..... | 18 |
| D. Reclamation Specifications | 18 |
| V. Receiving Water Limitations | 19 |
| A. Surface Water Limitations..... | 19 |
| B. Groundwater Limitations | 19 |
| VI. Provisions | 20 |
| A. Standard Provisions..... | 20 |
| B. Monitoring and Reporting Program (MRP) Requirements | 20 |
| C. Special Provisions..... | 20 |
| 1. Re-opener Provisions | 20 |
| 2. Special Studies, Technical Reports and Additional Monitoring Requirements | 21 |
| 3. Best Management Practices and Pollution Minimization | 22 |
| 4. Requirement to Assure Compliance with Final Limits..... | 26 |
| 5. Construction, Operation and Maintenance Specifications | 27 |
| 6. Special Provisions for POTWs..... | 28 |
| 7. Other Special Provisions | 28 |
| c. Cyanide Action Plan..... | 31 |
| d. Copper Action Plan | 31 |
| VII. Compliance Determination..... | 32 |
| a. Cyanide Action Plan..... | 58 |
| b. Copper Action Plan | 58 |

List of Tables

| | |
|--|----|
| Table 1. Discharger Information | 1 |
| Table 2. Discharge Location | 1 |
| Table 3. Administrative Information | 1 |
| Table 4. Facility Information..... | 4 |
| Table 5. Basin Plan Beneficial Uses of Lower San Francisco Bay | 8 |
| Table 6. Effluent Limitations – Conventional Pollutants at sampling point EFF-001-Ind..... | 13 |
| Table 7. Effluent Limitations - Toxic Pollutants | 14 |
| Table 8. Effluent Limitations – Discharge Point 002 | 17 |
| Table 9. Requirements to Assure Compliance with Final Limitations | 26 |

Attachments

Attachment A – DefinitionsA-1
Attachment B – Topographic MapB-1
Attachment C – Flow Schematic.....C-1
Attachment D – Federal Standard Provisions.....D-1
Attachment E – Monitoring and Reporting Program (MRP).....E-1
Attachment F – Fact Sheet.....F-1
Attachment G – The following documents are part of this Order, but are not physically attached due to volume. They are available on the internet at www.waterboards.ca.gov/sanfranciscobay/
- Self-Monitoring Program, Part A, adopted August 1993
- Standard Provisions and Reporting Requirements, August 1993
- August 6, 2001 Staff Letter: *Requirement for Priority Pollutant Monitoring in Receiving Water and Wastewater Discharges*

I. FACILITY INFORMATION

The following Discharger is subject to the waste discharge requirements as set forth in this Order:

Table 4. Facility Information

| | |
|---|--|
| Dischargers | City and County of San Francisco and North Bayside System Unit (NBSU) |
| Name of Facility | San Francisco International Airport, Mel Leong Treatment Plant, Industrial Plant |
| Facility Address | 676 McDonnell Road |
| | San Francisco, California 94128 |
| | San Mateo County |
| Facility Contact, Title, and Phone | Mark Costanzo, Utility Manager, (650) 821-7809, Mark.costanzo@flysfo.com |
| Mailing Address | P.O. Box 8097, San Francisco, CA 94128 |
| Type of Facility | Industrial Wastewater Treatment Facility |
| Facility Design Flow | 1.2 million gallons per day |

II. FINDINGS

The California Regional Water Quality Control Board, San Francisco Bay Region (hereinafter the Regional Water Board), finds:

A. Background. The City and County of San Francisco, San Francisco International Airport (SFIA), Mel Leong Treatment Plant, Industrial Plant is currently discharging under Order No. R2-2002-0045 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0028070. The Discharger submitted a Report of Waste Discharge, dated December 1, 2006 and applied for an NPDES permit renewal to discharge up to 1.2 million gallons per day (MGD) of treated wastewater from the Industrial Plant. .

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

B. Facility Description. The Discharger owns and operates the SFIA Mel Leong Treatment Plant. This includes an Industrial Wastewater Treatment Plant and a Sanitary Wastewater Treatment Plant. The Industrial Plant treats industrial wastewater from facilities at SFIA (e.g., maintenance shops, car washing), as well as first flush storm water runoff from industrial areas. The Sanitary Plant consists of a secondary wastewater treatment plant and its collection and conveyance system. It treats sanitary wastewater from airplanes and other various facilities (e.g., terminal restrooms, hangars, restaurants, shops) at the airport. The Industrial Plant is also occasionally used to treat sanitary wastewater when flows exceed the capacity of the Sanitary Plant or there are operational problems at the Sanitary Plant. Storm water runoff from terminals, taxiways, tarmacs, and aircraft and vehicle parking is collected in four detention ponds (the North Oxidation Pond, the South Oxidation Pond, the West Field Detention Basin, and the East Pond). The storm water runoff stored

JULY 27, 2007

in these ponds and basins is pumped to the Industrial Plant for treatment. The detention ponds and basins and storm drain canals hold up to a total of 9.55 million gallons. When the detention basins are filled, the collected runoff is discharged directly to San Francisco Bay through one of 11 storm water outfalls. Runoff from a few active areas at SFIA is not collected in basins and is either pumped directly to the Industrial Plant or discharged to the Bay. During the term of the previous Order, the Industrial Plant discharged an average flow of approximately 0.65 million gallons per day (MGD); the highest reported flow was 3.31 MGD, which occurred on May 9, 2005. The dry weather capacity of the Industrial Plant is 1.2 MGD.

Attachment B provides a map of the area around the facility. Attachment C provides a flow schematic of the Facility.

1. Industrial Wastewater Discharges. Influent to the Industrial Plant is initially stored in an equalization tank. From the equalization tank, industrial wastewater and storm water undergo flocculation, dissolved air floatation (DAF), pH adjustment (as needed), aerobic biological treatment via trickling filter, secondary clarification, and disinfection by chlorination. The Discharger has the capability to divert up to 0.72 MGD of the effluent from chlorination to tertiary filters and then on-site reclamation use for irrigation or utility water make-up.

After chlorination, treated wastewater is directed to a pumping station where it is combined with treated effluent from the Sanitary Plant, and then discharged to the North Bayside System Unit (NBSU) South San Francisco/San Bruno Water Quality Control Plant. The NBSU is operated by a joint powers authority of the same name and is responsible for operation of certain shared transport, treatment, and disposal facilities. NBSU member organizations include Millbrae, Burlingame, South San Francisco, San Bruno, and SFIA. The plant is located at 195 Belle Air Road, South San Francisco, CA 94080. The plant manger is currently David Castagnola who may be contacted at 650 829 3844.

Dechlorination takes place in the NBSU outfall before the combined effluent is discharged. Effluent from the NBSU force main discharges into Lower San Francisco Bay, a water of the State and United States, northeast of Point San Bruno, through a submerged diffuser approximately 5,300 feet offshore at a depth of 20 feet below mean lower low water (latitude 37°, 39', 55" North and longitude 122°, 21', 41" West).

For purposes of this Order, two Discharge Points are defined for effluent from the Industrial Plant. Discharge Point 001 represents treated effluent from the Mel Leong Industrial Treatment Plant. As described further in the Monitoring and Reporting Program (Attachment E), two different monitoring locations have been established for Discharge Point 001. Monitoring Location EFF-001-Ind is used to collect samples from the Industrial Plant. This treated waste water is then combined with the treated waste water from the Sanitary Plant and samples of the combined flow collected at monitoring location EFF-001A. Samples from this location represent the total wastewater discharge from the Mel Leong Treatment Plant prior to discharge into the NBSU. Samples are also collected from Discharge Point 002, which is a point in the NBSU after dechlorination.

JULY 27, 2007

2. Storm Water Discharges. Based on the Discharger's request for coverage under an individual NPDES permit for storm water discharges, this Order addresses all discharges of storm water associated with industrial and construction activity in addition to the discharge from the Industrial Plant. In addition, all storm water discharges associated with industrial activity at the Airport are also currently covered by the statewide General Order. Storm water discharges associated with construction activity at the Airport are currently covered under a separate State General Order, CAS000002. Several tenant areas at the Airport (including but not limited to the United Maintenance Facility and Fuel Tank Farm) have their own storm water discharges and are separately covered under CAS000001. These discharges are not addressed by this Order.

The Discharger has jurisdiction over and/or maintenance responsibility for the storm drain systems at SFIA. Discharges into the system consist of the surface runoff associated with various activities conducted by the Discharger and/or its tenants. Tenant conduct is governed by contract, permits, Airport Rules and Regulations, and the Tenant Improvement Guide. Storm water from tarmac areas at SFIA in exceedence of the detention basin capacity is discharged directly to San Francisco Bay via Discharge Points E003 through E013. Industrial activities at SFIA include aircraft, vehicle, and equipment fueling, maintenance, and washing, and very limited aircraft de-icing. Descriptions of each of Discharge Points E003 through E013 follow:

- a. Discharge Point E003.** Consists of storm water runoff (as well as Bay water infiltration) that exceeds the capacity of the 0.84 million gallon South Detention Pond. The South Detention Pond receives runoff from the United Airlines cargo and surface facilities, Boarding Areas A through F, and TWA service areas. Discharge Point E003 also receives runoff from runway areas along the southeast corner of the property that do not drain to the South Detention Pond and discharge directly through the discharge point. Discharge Point E003 discharges to San Francisco Bay.
- b. Discharge Point E004.** Consists of storm water runoff (as well as Bay water infiltration) that exceeds the capacity of the 6.0 million gallon West Field Detention Basin, the 0.3 million gallon East Detention Basin, and the 0.77 million gallon United Airlines Detention Basin. These ponds collect runoff from activities/facilities along the northwest side of the terminal as well as portions of the United Airlines Maintenance Facility. The discharge point also receives runoff directly from the United States Coast Guard Facility. Discharge Point E004 discharges to the Seaplane Harbor, which flows into San Francisco Bay.
- c. Discharge Point E005.** Consists of storm water runoff (as well as Bay water infiltration) from runway and taxiway areas south of Runway 28L. No aircraft, vehicle, or equipment fueling, maintenance, or washing occurs in this area. Runoff is not collected in a detention pond and is discharged directly into San Francisco Bay.
- d. Discharge Point E006.** Consists of storm water runoff (as well as Bay water infiltration) from the area north of Runway 28R. No aircraft, vehicle, or equipment

- fueling, maintenance, or washing occurs in this area. Runoff is not collected in a detention pond and is discharged directly into San Francisco Bay.
- e. Discharge Point E007.** Consists of storm water runoff (as well as Bay water infiltration) from the area northwest of Runway 19R. No aircraft, vehicle, or equipment fueling, maintenance, or washing occurs in this area. Runoff is not collected in a detention pond and is discharged directly into San Francisco Bay.
 - f. Discharge Point E008.** Consists of storm water runoff (as well as Bay water infiltration) from the taxiway, ramp, and roof areas of the eastern section of the Superbay Hangar area. Runoff is not collected in a detention pond; however, some runoff and infiltration is pumped from this area to the Industrial Plant. Otherwise, runoff is discharged directly into San Francisco Bay.
 - g. Discharge Point E009.** Consists of storm water runoff (as well as Bay water infiltration) from the taxiway, ramp, and roof areas of the western section of the Superbay Hangar area. Runoff is not collected in a detention pond and is discharged directly into San Francisco Bay.
 - h. Discharge Point E010.** Consists of storm water runoff (as well as Bay water infiltration) from the western area of the North Cargo Facility and areas around the North Access Road. Runoff is not collected in a detention pond and flows via gravity through storm drains into San Francisco Bay.
 - i. Discharge Point E013.** Consists of storm water runoff from taxiways and ramps around the North Cargo Facility that exceeds the capacity of the 0.425 million gallon North Field Detention Basin. Discharge Point E013 discharges into San Francisco Bay.
- C. Legal Authorities.** This Order is issued pursuant to CWA section 402 and implementing regulations adopted by the USEPA and Chapters 5.5, Division 7 of the California Water Code (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to Article 4, Chapter 4, Division 7 of the Water Code (commencing with section 13260).
- D. Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for Order requirements, is hereby incorporated into this Order and constitutes part of the Findings for this Order. Attachments A through E and G are also incorporated into this Order.
- E. California Environmental Quality Act (CEQA).** Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA.
- F. Technology-based Effluent Limitations.** NPDES regulations at 40 CFR 122.44 (a) require that permits include applicable technology-based limitations and standards. This

Order includes technology-based effluent limitations based on Secondary Treatment Standards at 40 CFR Part 133 and Best Professional Judgment (BPJ) in accordance with 40 CFR 125.3. The Regional Water Board has considered the factors associated with these requirements when developing all effluent limitations. A detailed discussion of the technology-based effluent limitations development is included in the Fact Sheet.

G. Water Quality-based Effluent Limitations. 40 CFR 122.44 (d) requires that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) may be established: (1) using USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) on an indicator parameter for the pollutant of concern; or (3) using a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state’s narrative criterion, supplemented with other relevant information, as provided at 40 CFR 122.44(d)(1)(vi).

H. Water Quality Control Plans. The Water Quality Control Plan for the San Francisco Bay Basin (Basin Plan) is the Board's master water quality control planning document. It designates beneficial uses and water quality objectives for waters of the State, including surface waters and groundwater. It also includes programs of implementation to achieve water quality objectives. The Basin Plan was duly adopted by the Water Board and approved by the State Water Resources Control Board, U.S. EPA, and the Office of Administrative Law where required. Beneficial uses applicable to Lower San Francisco Bay are as follows.

Table 5. Basin Plan Beneficial Uses of Lower San Francisco Bay

| Discharge Point | Receiving Water Name | Beneficial Uses |
|-------------------------|-------------------------|---|
| 002 through 010 and 013 | Lower San Francisco Bay | Industrial Service Supply (IND) Navigation (NAV) Water Contact Recreation (REC1) Non-Contact Water Recreation (REC2) Ocean Commercial and Sport Fishing (COMM) Wildlife Habitat (WILD) Preservation of Rare and Endangered Species (RARE) Fish Migration (MIGR) Shellfish Harvesting (SHELL) Estuarine Habitat (EST) |

The Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which establishes state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply (MUN). Because of the marine influence on receiving waters of the San Francisco Bay, total dissolved solids levels in the Bay commonly (and often significantly) exceed 3,000 mg/l and thereby meet an exception to State Water Board

Resolution No. 88-63. Therefore, the designation MUN is not applicable to Lower San Francisco Bay.

Requirements of this Order implement the Basin Plan.

- I. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995, and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the State. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants.
- J. **State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000 with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- K. **Compliance Schedules and Interim Requirements.** Section 2.1 of the SIP provides that, based on a Discharger's request and demonstration that it is infeasible for an existing Discharger to achieve immediate compliance with an effluent limitation derived from a CTR criterion, compliance schedules may be allowed in an NPDES permit. Unless an exception has been granted under section 5.3 of the SIP, a compliance schedule may not exceed 5 years from the date that the permit is issued or reissued, nor may it extend beyond 10 years from the effective date of the SIP (or May 18, 2010). Where a compliance schedule for a final effluent limitation exceeds one year, a permit must include interim numeric limitations for that constituent or parameter. Where allowed by the Basin Plan, compliance schedules and interim effluent limitations or discharge specifications may also be granted to allow time to implement a new or revised water quality objective. This Order does include compliance schedules and interim effluent limitations. A detailed discussion of the basis for the compliance schedule(s) and interim effluent limitation(s) is included in the Fact Sheet.
- L. **Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards become effective for CWA purposes. [40 CFR §131.21; 65 Fed. Reg. 24641 (April 27, 2000)]. Under the revised regulation (also known as the Alaska rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000 may be used for CWA purposes, whether or not approved by USEPA.

JULY 27, 2007

- M. Stringency of Requirements for Individual Pollutants.** This Order contains restrictions on individual pollutants that are no more stringent than required by the federal CWA. Individual pollutant restrictions consist of technology-based restrictions and water quality-based effluent limitations. The technology-based effluent limitations consist of restrictions on 5-day biochemical oxygen demand (BOD₅), total suspended solids (TSS), pH, oil and grease, and chlorine residual. Restrictions on these pollutants are specified in federal regulations as discussed in the Fact Sheet (Attachment F). WQBELs have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR 131.38. The scientific procedures for calculating the individual WQBELs are based on the CTR-SIP, which was approved by USEPA on May 18, 2000. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless “applicable water quality standards for purposes of the CWA” pursuant to 40 CFR 131.21 (c)(1). Collectively, this Order’s restrictions on individual pollutants are no more stringent than required to implement the technology-based requirements of the CWA and the applicable water quality standards for purposes of the CWA.
- N. Antidegradation Policy.** 40 CFR 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California’s antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Regional Water Board’s Basin Plan implements, and incorporates by reference, both the state and federal antidegradation policies. As discussed in detail in the Fact Sheet, the permitted discharge is consistent with the antidegradation provision of 40 CFR 131.12 and State Water Board Resolution No. 68-16.
- O. Anti-Backsliding Requirements.** CWA Sections 402(o)(2) and 303(d)(4) of and NPDES regulations at 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous Order, with some exceptions where limitations may be relaxed. All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order.
- P. Monitoring and Reporting.** 40 CFR 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorizes the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. This Monitoring and Reporting Program is provided in Attachment E.

JULY 27, 2007

- Q. Standard and Special Provisions.** Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR 122.42, are provided in Attachment D. The Discharger must comply with all standard provisions and with those additional conditions that are applicable under 40 CFR 122.42. The Regional Water Board has also included in this Order special provisions applicable to the Discharger. A rationale for the special provisions contained in this Order is provided in the attached Fact Sheet.
- R. Provisions and Requirements Implementing State Law.** The provisions/requirements in subsections IV.B, IV.E and V.B of this Order are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations.
- S. Notification of Interested Parties.** The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe Waste Discharge Requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet of this Order.
- T. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet of this Order.

JULY 27, 2007

III. DISCHARGE PROHIBITIONS

- A. Discharge of treated wastewater at a location or in a manner different from that described in this Order is prohibited.
- B. Discharge at any point at which the treated wastewater does not receive an initial dilution of at least 10:1 is prohibited.
- C. The bypass of untreated or partially treated wastewater to waters of the United States is prohibited, except as provided for in the conditions stated in 40 CFR 122.41(m)(4) and in A.12 of the *Standard Provisions and Reporting Requirements for NPDES Surface Water Discharge Permits*, August 1993 (**Attachment G**).
- D. Discharge of non-storm water (materials other than storm water) into the storm drain systems and watercourses is prohibited, except in compliance with Special Provision VI.C.6.a of this Order. NPDES permitted discharges are exempt from this prohibition.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations – Discharge Point 001

1. Effluent Limitations for Conventional Pollutants

- a. The Discharger shall maintain compliance with the following effluent limitations at Discharge Point 001 with compliance measured at Monitoring Location EFF-001-Ind as described in the attached MRP (Attachment E).

Table 6. Effluent Limitations – Conventional Pollutants at sampling point EFF-001-Ind

| Parameter | Units | Effluent Limitations | | | | |
|---|----------------|----------------------|----------------|---------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| Biochemical Oxygen Demand (5-day @ 20 Deg. C) (BOD ₅) | mg/l | 30 | 45 | -- | -- | -- |
| Total Suspended Solids (TSS) | mg/l | 30 | 45 | -- | -- | -- |
| Oil and Grease | mg/l | 10 | -- | 20 | -- | -- |
| pH ⁽¹⁾ | standard units | -- | -- | -- | 6.0 | 9.0 |

- (1) If the Discharger monitors pH continuously, pursuant to 40 CFR 401.17, the Discharger shall be in compliance with the pH limitation specified herein, provided that both of the following conditions are satisfied: (i) the total time during which the pH values are outside the required range of pH values shall not exceed 7 hours and 26 minutes in any calendar month; and (ii) no individual excursion from the range of pH values shall exceed 60 minutes.
- (2) This requirement is defined as below the limit of detection in standard test methods, as defined in the latest edition of Standard Methods for the Examination of Water and Wastewater. For total residual chlorine (TRC) detection levels, the Discharger shall use a method for analysis of TRC that is identified as approved by USEPA for analysis of wastewaters at 40 CFR Part 136. The method of analysis shall achieve a method detection limit (MDL) at least as low as that achieved by the Amperometric Titration Method (4500-Cl D from *Standard Methods for Examination of Water and Wastewater*, Edition 20). The State Water Board is considering a statewide policy on chlorine residual. This Order may be reopened in the future to reflect any changes relating to chlorine residual.

- b. **BOD₅ and TSS 85 Percent Removal:** The average monthly percent removal of BOD₅ and TSS, by concentration, based on samples from the inflow (INF-001-Ind) and outflow (EFF-001-Ind) shall not be less than 85 percent. The arithmetic mean of only those samples with a BOD₅ influent concentration of greater than 45 mg/l will be used to determine compliance with the monthly BOD₅ 85 percent removal requirement.

- c. **Fecal Coliform Bacteria:** The treated wastewater, from samples collected from sampling point EFF-001A, shall meet the following limitations of bacteriological quality:

- (1) The 5-day geometric mean fecal coliform density shall not exceed a Most Probable Number (MPN) of fecal coliform bacteria of 200 MPN/100 ml; and
- (2) The 90th percentile value of the last ten fecal coliform density values shall not exceed 400 MPN/100 ml.

- d. Enterococci Bacteria:** The monthly geometric mean enterococci bacteria density, from samples collected from sampling point EFF-001A, shall not exceed 35 colonies/100 ml.

2. Effluent Limitations for Toxics Pollutants

- a. The Discharger shall maintain compliance with the following effluent limitations at Monitoring Location EFF-001A (except for cyanide, measured at Monitoring Location EFF-002) as described in the attached MRP (**Attachment E**):

Table 7. Effluent Limitations - Toxic Pollutants

| Parameter | Units | Effluent Limitations ⁽¹⁾⁽²⁾ | | | | |
|-----------------------------------|-------|--|----------------|------------------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| Copper ⁽³⁾ | µg/l | 54 | -- | 110 | -- | -- |
| Lead | µg/l | 64 | -- | 130 | -- | -- |
| Mercury ⁽⁴⁾ | µg/l | 0.020 | -- | 0.041 | -- | -- |
| Nickel | µg/l | 76 | -- | 150 | -- | -- |
| Dioxin-TEQ ⁽⁴⁾ | µg/l | 1.4 x 10 ⁻⁸ | -- | 2.8 x 10 ⁻⁸ | -- | -- |
| Aldrin | µg/l | 0.00014 | -- | 0.00028 | -- | -- |
| Alpha-BHC | µg/l | 0.13 | -- | 0.26 | -- | -- |
| Beta-BHC | µg/l | 0.46 | -- | 0.92 | -- | -- |
| 4,4-DDT ⁽⁴⁾ | µg/l | 0.00059 | -- | 0.0012 | -- | -- |
| 4,4-DDE | µg/l | 0.00059 | -- | 0.0012 | -- | -- |
| Dieldrin | µg/l | 0.00014 | -- | 0.00028 | -- | -- |
| Endrin | µg/l | 0.019 | -- | 0.037 | -- | -- |
| Heptachlor ⁽⁴⁾ | µg/l | 0.0020 | -- | 0.0041 | -- | -- |
| Heptachlor Epoxide ⁽⁴⁾ | µg/l | 0.00089 | -- | 0.0018 | -- | -- |
| Ammonia | mg/l | 120 | | 310 | | |
| Tributyltin | µg/l | 0.061 | -- | 0.12 | -- | -- |

- (1) (a) Limitations apply to the average concentration of all samples collected during the averaging period (daily = 24-hour period; monthly = calendar month).
 (b) All metals limitations are expressed as total recoverable metal.
- (2) A daily maximum or average monthly value for a given constituent shall be considered noncompliant with the effluent limitations only if it exceeds the effluent limitation and the Reporting Level for that constituent. As outlined in Section 2.4.5 of the SIP, the table below indicates the Minimum Level (ML) upon which the Reporting Level is based for compliance determination purposes. In addition, in order to perform reasonable potential analysis for future permit reissuance, the Discharger shall use methods with MLs lower than the applicable water quality objectives or water quality criteria (e.g., copper). A ML is the concentration at which the entire analytical system must give a recognizable signal and the acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Table: Minimum Levels for Pollutants with Effluent Limitations

| Parameter | Minimum Level, µg/l |
|-----------|---------------------|
| Copper | 2 |
| Lead | 2 |
| Mercury | 0.0005 |

JULY 27, 2007

| Parameter | Minimum Level, µg/l |
|------------------------|--|
| Nickel | 5 |
| Cyanide | 5 |
| Dioxin-TEQ | ½ the USEPA specified MLs for Method 1613 |
| Aldrin | 0.005 |
| Alpha-BHC | 0.01 |
| Beta-BHC | 0.005 |
| 4,4-DDT | 0.01 |
| 4,4-DDE | 0.05 |
| Dieldrin | 0.01 |
| Endrin | 0.01 |
| Heptachlor | 0.01 |
| Heptachlor Epoxide | 0.01 |
| Ammonia ⁽⁵⁾ | 100 |
| Tributyltin | 0.001 |

| Isomer Group | Minimum Level, pg/l |
|------------------------|---------------------|
| 2,3,7,8-TetraCDD | 5 |
| 1,2,3,7,8-PentaCDD | 25 |
| 1,2,3,4,7,8-HexaCDD | 25 |
| 1,2,3,6,7,8-HexaCDD | 25 |
| 1,2,3,7,8,9-HexaCDD | 25 |
| 1,2,3,4,6,7,8-HeptaCDD | 25 |
| OctaCDD | 50 |
| 2,3,7,8-TetraCDF | 5 |
| 1,2,3,7,8-PentaCDF | 25 |
| 2,3,4,7,8-PentaCDF | 25 |
| 1,2,3,4,7,8-HexaCDF | 25 |
| 1,2,3,6,7,8-HexaCDF | 25 |
| 1,2,3,7,8,9-HexaCDF | 25 |
| 2,3,4,6,7,8-HexaCDF | 25 |
| 1,2,3,4,6,7,8-HeptaCDF | 25 |
| 1,2,3,4,7,8,9-HeptaCDF | 25 |
| OctaCDF | 50 |

⁽³⁾ Alternate Effluent Limitations for Copper:

- a. If a copper SSO for the receiving water becomes legally effective, resulting in adjusted saltwater Criterion Continuous Concentration (CCC) of 2.5 µg/l and Criterion Maximum Concentration (CMC) of 3.9 µg/l as documented in the *North of Dumbarton Bridge Copper and Nickel Site-Specific Objective (SSO) Derivation (Clean Estuary Partnership*

JULY 27, 2007

December 2004), upon its effective date, the following limitations shall supersede those copper limitations listed in Table 7.

AMEL of 42 µg/l, and MDEL of 84 µg/l.

- b. If a different copper SSO for the receiving water is adopted, the alternate WQBELs based on the SSO will be determined after the SSO effective date.

⁽⁴⁾ Limits for these pollutants become effective according to the compliance schedules described in VI.C.4.

⁽⁵⁾ Measured as N in total ammonia

3. Acute Toxicity:

- a. Representative samples of the effluent at Discharge Point 001 (Monitoring Location EFF-001-IND, collected before chlorination) shall meet the following limitations for acute toxicity. Bioassays shall be conducted in compliance with Section V.A of the Monitoring and Reporting Program (MRP, **Attachment E**).

The survival of organisms in undiluted combined effluent shall be an eleven (11) sample median value of not less than 90 percent survival, and an eleven (11) sample 90 percentile value of not less than 70 percent survival.

- b. These acute toxicity limitations are further defined as follows:

11 sample median: A bioassay test showing survival of less than 90 percent represents a violation of this effluent limit, if five or more of the past ten or fewer bioassay tests show less than 90 percent survival.

90th percentile: A bioassay test showing survival of less than 70 percent represents a violation of this effluent limit, if one or more of the past ten or fewer bioassay tests show less than 70 percent survival.

- c. Bioassays shall be performed using the most up-to-date USEPA protocol and the most sensitive species as specified in writing by the Executive Officer based on the most recent screening test results. Bioassays shall be conducted in compliance with "Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms," currently 5th Edition (EPA-821-R-02-012), with exceptions granted to the Discharger by the Executive Officer and the Environmental Laboratory Accreditation Program (ELAP) upon the Discharger's request with justification.
- d. If the Discharger can demonstrate to the satisfaction of the Executive Officer that toxicity exceeding the levels cited above is caused by ammonia and that the discharge is in compliance with the effluent limits, then such toxicity does not constitute a violation of this effluent limitation.

4. Chronic Toxicity

- a. Compliance with the Basin Plan narrative chronic toxicity objective shall be demonstrated according to the following tiered requirements based on results

from representative samples of the treated final effluent at Discharge Point 001 (Monitoring Location EFF-001A) meeting test acceptability criteria and Section V.B of the MRP (**Attachment E**). Failure to conduct the required toxicity tests or a TRE within a designated period shall result in the establishment of effluent limitations for chronic toxicity.

- (1) Conduct routine monitoring.
- (2) Accelerate monitoring after exceeding a three sample median value of 10 chronic toxicity units (TUC) or a single sample maximum of 20 TUC or greater. Accelerated monitoring shall consist of monthly monitoring.
- (3) Return to routine monitoring if accelerated monitoring does not exceed the “trigger” in (2), above.
- (4) If accelerated monitoring confirms consistent toxicity above either “trigger” in (2), above, initiate toxicity identification evaluation/toxicity reduction evaluation (TIE/TRE) in accordance with a workplan submitted in accordance with Section V.B.3 of the MRP (Attachment E), and that incorporates any and all comments from the Executive Officer.
- (5) Return to routine monitoring after appropriate elements of TRE workplan are implemented and either the toxicity drops below “trigger” levels in (2), above, or, based on the results of the TRE, the Executive Officer authorizes a return to routine monitoring.

b. Test Species and Methods

The Discharger shall conduct routine monitoring with the test species and protocols specified in Section V.B of the MRP (**Attachment E**). The Discharger shall also perform Chronic Toxicity Screening Phase monitoring as described in the Appendix E-1 of the MRP (**Attachment E**). Chronic Toxicity Monitoring Screening Phase Requirements, Critical Life Stage Toxicity Tests and definitions of terms used in the chronic toxicity monitoring are identified in **Appendices E-1 and E-2** of the MRP (**Attachment E**).

B. Effluent Limitations – Discharge Point 002

1. The Discharger shall maintain compliance with the following effluent limitations at Discharge Point 002 with compliance measured at Monitoring Location EFF-002 as described in the attached MRP (**Attachment E**).

Table 8. Effluent Limitations – Discharge Point 002

| Parameter | Units | Effluent Limitations | | | | |
|---|-------|----------------------|----------------|---------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| Chlorine, Total Residual ⁽¹⁾ | mg/l | -- | -- | -- | -- | 0.0 |

| | | | | | | |
|---------|------|----|----|----|----|----|
| Cyanide | µg/l | 20 | -- | 44 | -- | -- |
|---------|------|----|----|----|----|----|

(1) This requirement is defined as below the limit of detection in standard test methods, as defined in the latest edition of Standard Methods for the Examination of Water and Wastewater. For total residual chlorine (TRC) detection levels, the Discharger shall use a method for analysis of TRC that is identified as approved by USEPA for analysis of wastewaters at 40 CFR Part 136. The method of analysis shall achieve a method detection limit (MDL) at least as low as that achieved by the Amperometric Titration Method (4500-Cl D from *Standard Methods for Examination of Water and Wastewater*, Edition 20). The State Water Board is considering a statewide policy on chlorine residual. This Order may be reopened in the future to reflect any changes relating to chlorine residual.

C. Mercury Mass Emission Limitation

Until Total Maximum Daily Load (TMDL) and Waste Load Allocation (WLA) efforts for mercury provide enough information to establish a different WQBEL, the Discharger shall demonstrate that the total mercury mass loading from Discharge Point 001 (Monitoring Location EFF-001A) to Lower San Francisco Bay via the NBSU has not increased by complying with the following:

1. Mass Emission Limit: The mass emission limit for mercury is 0.0041 kilograms per month (kg/month). The total mercury mass load shall not exceed this limit.
2. Compliance with this limit shall be evaluated using a running annual average mass load. Running annual averages shall be calculated by taking the arithmetic average of the current monthly mass loading value (see sample calculation below) and the previous 11 months of values. Sample calculation:

Flow (MGD) = Average of monthly plant effluent flows in MGD.

Constituent Concentration (µg/l) = Average of monthly effluent concentration measurements in µg/l. If more than one measurement is obtained in a calendar month, the average of these measurements is used as the monthly value for that month. If test results are less than the method detection limit used, the measurement value is assumed to be equal to the method detection limit.

Mass Loading (kg/month) = (Flow) x (Constituent Concentration) x 0.1151.

This mass emission limit will be superseded upon implementation, through amendment of this Order or issuance of a separate permit, of a TMDL and WLA for mercury. According to the antibacksliding rule in the Clean Water Act, Section 402(o), the Order may be modified to include a less stringent requirement following completion of a TMDL and WLA.

D. Reclamation Specifications

Not Applicable

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

1. Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharges shall not cause the following in Lower San Francisco Bay:
 - a. Floating, suspended, or deposited macroscopic particulate matter or foams;
 - b. Bottom deposits or aquatic growths to the extent that such deposits or growths cause nuisance or adversely affect beneficial uses;
 - c. Alteration of temperature, turbidity, or apparent color beyond present natural background levels;
 - d. Visible, floating, suspended, or deposited oil and other products of petroleum origin; and
 - e. Toxic or other deleterious substances to be present in concentrations or quantities which will cause deleterious effects on wildlife, waterfowl, or other aquatic biota, or which render any of these unfit for human consumption, either at levels created in the receiving waters or as a result of biological concentration.
2. The discharge of waste shall not cause the following limitations to be exceeded in waters of the State within one foot of the water surface:
 - a. Dissolved Oxygen 5.0 mg/l, minimum

The median dissolved oxygen concentration for any three consecutive months shall not be less than 80% of the dissolved oxygen content at saturation. When natural factors cause concentrations less than that specified above, the discharge shall not cause further reduction in ambient dissolved oxygen concentrations.

- b. Dissolved Sulfide Natural background levels
- c. pH Within 6.5 and 8.5
- d. Nutrients Waters shall not contain biostimulatory substances in concentrations that promote aquatic growths to the extent that such as growths cause nuisance or adversely affect beneficial uses.

B. Groundwater Limitations

Not Applicable

VI. PROVISIONS

A. Standard Provisions

1. The Discharger shall comply with Federal Standard Provisions included in **Attachment D** of this Order.
2. The Discharger shall comply with all applicable items of the *Standard Provisions and Reporting Requirements for NPDES Surface Water Discharge Permits, August 1993 (Attachment G)*, including any amendments thereto. Where provisions or reporting requirements specified in this Order are different from equivalent or related provisions or reporting requirements given in the Standard Provisions, the specifications of this Order shall apply. Duplicative requirements in the federal Standard Provisions in VI.A.1, above (**Attachment D**) and the regional Standard Provisions (**Attachment G**) are not separate requirements. A violation of a duplicative requirement does not constitute two separate violations.

B. Monitoring and Reporting Program (MRP) Requirements

The Discharger shall comply with the MRP, and future revisions thereto, in **Attachment E** of this Order. The Discharger shall also comply with the requirements contained in *Self Monitoring Programs, Part A, August 1993 (Attachment G)*.

C. Special Provisions

1. Re-opener Provisions

The Regional Water Board may modify or reopen this Order prior to its expiration date in any of the following circumstances as allowed by law:

- a. If present or future investigations demonstrate that the discharge(s) governed by this Order will have, or will cease to have, a reasonable potential to cause or contribute to adverse impacts on water quality and/or beneficial uses of the receiving waters.
- b. If new or revised WQOs or TMDLs come into effect for the San Francisco Bay estuary and contiguous water bodies (whether statewide, regional, or site-specific). In such cases, effluent limitations in this Order will be modified as necessary to reflect updated WQOs and waste load allocations in TMDLs. Adoption of effluent limitations contained in this Order is not intended to restrict in any way future modifications based on legally adopted WQOs, TMDLs, or as otherwise permitted under Federal regulations governing NPDES permit modifications.
- c. If translator or other water quality studies provide a basis for determining that a permit condition(s) should be modified.

- d. If administrative or judicial decision on a separate NPDES permit or WDR that addresses requirements similar to this discharge.
- e. Or as otherwise authorized by law.

The Discharger may request permit modification based on the above. The Discharger shall include in any such request an antidegradation and antibacksliding analysis.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

a. Effluent Characterization for Selected Constituents

The Discharger shall monitor and evaluate the discharge from Discharge Point 001 (measured at monitoring location EFF-001A) for the constituents listed in Enclosure A of the Regional Water Board's August 6, 2001 Letter, according to the sampling frequency specified in the attached MRP (Attachment E). Compliance with this requirement shall be achieved in accordance with the specifications stated in the Regional Water Board's August 6, 2001 Letter under Effluent Monitoring for Major Dischargers.

The Discharger shall, on an annual basis, evaluate if concentrations of any constituent increase over past performance. The Discharger shall investigate the cause of the increase. The investigation may include, but need not be limited to, an increase in the effluent monitoring frequency, monitoring of internal process streams, and monitoring of influent sources. This may be satisfied through identification of these constituents as "Pollutants of Concern" in the Discharger's Pollutant Minimization Program described in Provision C.3.b, below. A summary of the annual evaluation of data and source investigation activities shall also be reported in the annual self-monitoring report.

A final report that presents all the data shall be submitted to the Regional Water Board no later than 180 days prior to the Order expiration date. This final report shall be submitted with the application for permit reissuance.

b. Ambient Background Receiving Water Study

The Discharger shall collect or participate in collecting background ambient receiving water monitoring for priority pollutants that is required to perform RPA and to calculate effluent limitations. The data on the conventional water quality parameters (pH, salinity, and hardness) shall also be sufficient to characterize these parameters in the receiving water at a point after the discharge has mixed with the receiving waters. This provision may be met through monitoring through the Collaborative Bay Area Clean Water Agencies (BACWA) Study, or a similar ambient monitoring program for San Francisco Bay. This Order may be reopened, as appropriate, to incorporate effluent limitations or other requirements based on Regional Water Board review of these data.

The Discharger shall submit a final report that presents all the data to the Regional Water Board 180 days prior to Order expiration. This final report shall be submitted with the application for permit reissuance.

c. Optional Mass Offset

If the Discharger can demonstrate that further net reductions of the total mass loadings of 303(d)-listed pollutants to the receiving water cannot be achieved through economically feasible measures such as aggressive source control, wastewater reuse, and treatment plant optimization, but only through a mass offset program, the Discharger may submit to the Regional Water Board for approval a mass offset plan to reduce 303(d)-listed pollutants to the same watershed or drainage basin. The Regional Water Board may modify this Order to allow an approved mass offset program.

3. Best Management Practices and Pollution Minimization

a. Pollution Minimization Program

The Discharger shall continue to improve, in a manner acceptable to the Executive Officer, its existing Pollutant Minimization Program to reduce pollutant loadings to the treatment plant and therefore to the receiving waters. The Discharger shall implement any applicable additional pollutant minimization measures described in Basin Plan implementation requirements associated with the copper SSO and cyanide SSO if and when each of those SSOs become effective and alternate limitations take effect.

b. Annual Pollution Minimization Report

The Discharger shall submit an annual report, acceptable to the Executive Officer, no later than February 28th of each calendar year. The annual report shall cover January through December of the preceding year. Each annual report shall include at least the following information:

- (1) *A brief description of its treatment plant, treatment plant processes and service area.*
- (2) *A discussion of the current pollutants of concern.* Periodically, the Discharger shall determine which pollutants are currently a problem and/or which pollutants may be potential future problems. This discussion shall include the reasons why the pollutants were chosen.
- (3) *Identification of sources for the pollutants of concern.* This discussion shall include how the Discharger intends to estimate and identify pollutant sources. The Discharger should also identify sources or potential sources not directly within the ability or authority of the Discharger to control, such as pollutants in the potable water supply and air deposition.

JULY 27, 2007

- (4) *Identification of tasks to reduce the sources of the pollutants of concern.* This discussion shall identify and prioritize tasks to address the Discharger's pollutants of concern. The Discharger may implement the tasks themselves or participate in group, regional, or national tasks that will address its pollutants of concern whenever it is efficient and appropriate to do so. A time line shall be included for the implementation of each task.
- (5) *Outreach to employees.* The Discharger shall inform its employees about the pollutants of concern, potential sources, and how they might be able to help reduce the discharge of these pollutants. The Discharger may provide a forum for employees to provide input to the program.
- (6) *Continuation of Public Outreach Program.* The Discharger shall prepare a public outreach program to communicate pollution minimization measures to its service area. Outreach may include participation in existing community events such as county fairs, initiating new community events such as displays and contests during Pollution Prevention Week, conducting school outreach programs, conducting plant tours, and providing public information in various media. Information shall be specific to target audiences. The Discharger shall coordinate with other agencies as appropriate.
- (7) *Discussion of criteria used to measure Program's and tasks' effectiveness.* The Discharger shall establish criteria to evaluate the effectiveness of its Pollution Minimization Program. This discussion shall include of the specific criteria used to measure the effectiveness of each of the tasks in item b(3), b(4), b(5), and b(6).
- (8) *Documentation of efforts and progress.* This discussion shall detail all of the Discharger's activities in the Pollution Minimization Program during the reporting year.
- (9) *Evaluation of Program's and tasks' effectiveness.* The Discharger shall use the criteria established in b. to evaluate the Program's and tasks' effectiveness.
- (10) *Identification of specific tasks and time schedules for future efforts.* Based on the evaluation, the Discharger shall detail how it intends to continue or change its tasks to more effectively reduce the amount of pollutants to the treatment plant and subsequently its effluent.

c. Pollutant Minimization Program for Reportable Priority Pollutants

The Discharger shall develop and conduct a Pollutant Minimization Program (PMP) as further described below when there is evidence (e.g., sample results reported as DNQ when the effluent limitation is less than the MDL, sample results from analytical methods more sensitive than those methods required by this Order, presence of whole effluent toxicity, health advisories for fish

JULY 27, 2007

consumption, results of benthic or aquatic organism tissue sampling) that a priority pollutant is present in the effluent above an effluent limitation and either:

- (1) A sample result is reported as DNQ and the effluent limitation is less than the RL; or
- (2) A sample result is reported as ND and the effluent limitation is less than the MDL, using definitions described in the SIP.

d. Requirements of a Pollutant Minimization Study

If triggered by the reasons in c. above, the Discharger's PMP shall include, but not be limited to, the following actions and submittals acceptable to the Regional Water Board:

- (1) An annual review and semi-annual monitoring of potential sources of the reportable priority pollutant(s), which may include fish tissue monitoring and other bio-uptake sampling, or alternative measures approved by the Executive Officer when it is demonstrated that source monitoring is unlikely to produce useful analytical data;
- (2) Quarterly monitoring for the reportable priority pollutant(s) in the influent to the wastewater treatment system, or alternative measures approved by the Executive Officer, when it is demonstrated that influent monitoring is unlikely to produce useful analytical data;
- (3) Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable priority pollutant(s) in the effluent at or below the effluent limitation;
- (4) Implementation of appropriate cost-effective control measures for the reportable priority pollutant(s), consistent with the control strategy; and
- (5) The annual report required by 3.b. above, shall specifically address the following items:
 - i. All PMP monitoring results for the previous year;
 - ii. A list of potential sources of the reportable priority pollutant(s);
 - iii. A summary of all actions undertaken pursuant to the control strategy; and
 - iv. A description of actions to be taken in the following year.

e. Storm Water Pollution Prevention Plan

- (1) The Discharger shall implement control measures and best management practices (BMPs) to reduce pollutants in storm water discharges to the maximum extent practicable. The industrial and construction Storm Water

JULY 27, 2007

Pollution Prevention Plans (SWPPPs) shall serve as the framework for identification, assignment and implementation of such control measures/BMPs.

- (2) Within 6 months from the date of adoption for this Order, the Discharger shall update and thereafter maintain its SWPPPs to include control measures and measurable goals that address the following program elements:
- i. Tenant/Construction contractor education and outreach
 - ii. Tenant/Construction contractor participation/involvement
 - iii. Illicit discharge detection and elimination
 - iv. Construction site runoff control
 - v. Post-Construction runoff control
 - vi. Pollution Prevention/Good Housekeeping
 - vii. Maintenance of Airport facilities (including street or lot sweeping and stormdrain inlet inspection and cleanup)

BMPs define the level of implementation necessary to demonstrate the reduction of pollutants in storm water to the maximum extent practicable.

The industrial SWPPP shall identify control measures/BMPs appropriate to reduce or prevent pollutants in storm water associated with industrial activities conducted at SFIA. The construction SWPPP shall contain control measures/BMPs to ensure that improvement projects conducted at SFIA which disturb 1 acre of soil or more include storm water quality control measures during and after construction, as appropriate for each project, and that contractors comply with storm water quality control requirements during construction activities, as enforced by routine inspections conducted by the Discharger.

The Discharger will continue to implement the seven minimum control measures and develop new or improved BMPs to achieve the reduction of pollutants in storm water discharges to the maximum extent practicable. Discharges of storm water associated with industrial or construction activities conducted by the Discharger are authorized and permitted by this Order prior to update of the SWPPPs, if they are in accordance with the Discharger's current SWPPPs and thereafter, if they are in accordance with the conditions of this provision and the SWPPPs.

- (3) The Discharger shall review and update the SWPPPs to include any appropriate revisions, modifications, and improvements to reduce pollutants in storm water discharges to the maximum extent practicable following the initial update. The Discharger shall incorporate newly developed or updated

BMPs, acceptable to the Executive Officer, into the SWPPPs and adhere to implementation of the new/revised control measure(s).

4. Requirement to Assure Compliance with Final Limits

In an effort to assure compliance with final effluent limitations for dioxin-TEQ, aldrin, alpha-BHC, beta-BHC, 4,4-DDT, endrin, heptachlor, and heptachlor epoxide, the Discharger shall comply with the following tasks and dates:

Table 9. Requirements to Assure Compliance with Final Limitations

| Task | Dioxin compliance | Pesticide compliance |
|--|-------------------|----------------------|
| 1. Submit a plan for identifying all dioxins, and Pesticides sources to the discharge. Examples of potential pesticide sources include stored pesticides and pesticide-treated soils near sewer lines. The plan shall, at a minimum, include sampling influent waste streams to identify and quantify pollutant sources. | April 1, 2008 | April 1, 2008 |
| 2. Implement the plan developed in action "2" within 30 days of the deadline for action "2," and submit by the deadline for this action a report that contains an inventory of the pollutant sources. | August 1, 2008 | August 1, 2008 |
| 3. Submit a report documenting development and initial implementation of a program to reduce and prevent the pollutants of concern in the discharge. The program shall consist, at a minimum, of the following elements: (i) Maintain a list of sources of pollutants of concern. (ii) Investigate each source to assess the need to include it in the program. (iii) Identify and implement targeted actions to reduce or eliminate discharges from each source in the program. (iv) Develop and distribute, as appropriate, educational materials regarding the need to prevent sources to the sewer system. | October 1, 2008 | October 1, 2008 |

| | | |
|---|---|---|
| <p>4. Continue to implement the program described in action “3” and submit annual status reports that evaluate its effectiveness and summarize planned changes. Report whether the program has successfully brought the discharge into compliance with the final effluent limits. If not, identify and implement additional measures to further reduce discharge.</p> | <p>Annually each February 28 in Best Management Practices and Pollutant Minimization Report required by Permit Provision VI.C.3</p> | <p>Annually each February 28 in Best Management Practices and Pollutant Minimization Report required by Permit Provision VI.C.3</p> |
| <p>5. Full compliance with IV Effluent Limitations and District Specifications IV.A.2.a for aldrin, 4,4-DDT, heptachlor, and heptachlor epoxide.</p> | <p>Not applicable</p> | <p>May 18, 2010</p> |
| <p>6. Full compliance with IV Effluent Limitations and District Specifications IV.A.2.a for dioxin-TEQ. Alternatively, the Discharger may comply with this limit through implementation of a mass offset strategy for dioxin-TEQ in accordance with policies in effect at that time.</p> | <p>September 30, 2017</p> | |

5. Construction, Operation and Maintenance Specifications

a. Wastewater Facilities, Review and Evaluation, and Status Reports

- (1) The Discharger shall operate and maintain its wastewater collection, treatment, and disposal facilities in a manner to ensure that all facilities are adequately staffed, supervised, financed, operated, maintained, repaired, and upgraded as necessary, in order to provide adequate and reliable transport, treatment, and disposal of all wastewater from both existing and planned future wastewater sources under the Discharger’s service responsibilities.
- (2) The Discharger shall regularly review and evaluate its wastewater facilities and operation practices in accordance with section a.1. above. Reviews and evaluations shall be conducted as an ongoing component of the Discharger’s administration of its wastewater facilities.
- (3) The Discharger shall provide the Executive Officer, upon request, a report describing the current status of its wastewater facilities and operation practices, including any recommended or planned actions and an estimated time schedule for these actions. The Discharger shall also include, in each annual self-monitoring report, a description or summary of review and evaluation procedures, and applicable wastewater facility programs or capital improvement projects.

b. Operations and Maintenance (O&M) Manual, Review and Status Reports

- (1) The Discharger shall maintain an O&M Manual as described in the findings of this Order for the Discharger's wastewater facilities. The O&M Manual shall be maintained in usable condition and be available for reference and use by all applicable personnel.

- (2) The Discharger shall regularly review, revise, or update, as necessary, the O&M Manual(s) to ensure that the document(s) may remain useful and relevant to current equipment and operation practices. Reviews shall be conducted annually, and revisions or updates shall be completed as necessary. For any significant changes in treatment facility equipment or operation practices, applicable revisions shall be completed within 90 days of completion of such changes.
- (3) The Discharger shall provide the Executive Officer, upon request, a report describing the current status of its O&M manual, including any recommended or planned actions and an estimated time schedule for these actions. The Discharger shall also include, in each annual self-monitoring report, a description or summary of review and evaluation procedures and applicable changes to its operations and maintenance manual.

c. Contingency Plan, Review and Status Reports

- (1) The Discharger shall maintain a Contingency Plan as required by Regional Water Board Resolution No. 74-10 (**Attachment G**) and as prudent in accordance with current municipal facility emergency planning. The discharge of pollutants in violation of this Order where the Discharger has failed to develop and/or adequately implement a Contingency Plan will be the basis for considering such discharge a willful and negligent violation of this Order pursuant to Section 13387 of the California Water Code.
- (2) The Discharger shall regularly review and update, as necessary, the Contingency Plan so that the plan may remain useful and relevant to current equipment and operation practices. Reviews shall be conducted annually, and updates shall be completed as necessary.
- (3) The Discharger shall provide the Executive Officer, upon request, a report describing the current status of its Contingency Plan review and update. The Discharger shall also include, in each annual self-monitoring report, a description or summary of review and evaluation procedures and applicable changes to its Contingency Plan.

6. Special Provisions for POTWs

Not Applicable

7. Other Special Provisions

a. Storm Water Discharges

- (1) Exempted Discharges - The following non-storm water discharges are unconditionally permitted unless they are identified by the Discharger or the Executive Officer as sources of pollutants to receiving waters: water line flushing; landscape irrigation; diverted stream flows; rising ground waters; uncontaminated ground water infiltration (as defined at 40 CFR 35.2005(20));

uncontaminated pumped ground water; water pumped from utility manholes and tunnels; Bay water infiltration; discharges from potable water sources; foundation drains; air drains; final rinse water drips from rental car washing; flows from riparian habitats and wetlands; residual street wash water; window wash water; water from parking garage surface washing; and discharges or flows from fire fighting activities.

If any of these categories of discharges, or sources of such discharges, are identified by the Discharger or the Executive Officer as sources of pollutants to receiving waters, then such categories or sources shall be addressed as conditionally exempted discharges in accordance with Provision (2) below.

(2) Conditionally Exempted Discharges - If any of the non-storm water discharges described in 6.a(1) above are identified by the Discharger or the Executive Officer as sources of pollutants to receiving water, such discharges are nevertheless permitted if they:

- i. Are infeasible to eliminate;
- ii. Comply with BMPs as described in the SWPPPs designed to (1) prevent or reduce the contact of non-storm water discharges with significant materials or equipment and (2) minimize, to the extent practicable, the flow or volume of non-storm water discharges;
- iii. Do not contain significant quantity of pollutants; and
- iv. Do not cause or contribute to a violation of water quality standards.

(3) Permit Authorization for Exempted Discharges

- i. Discharges of non-storm water from sources owned or operated by the Discharger are authorized and permitted by this Order if they are in accordance with the monitoring conditions established in **Attachment E** (Monitoring and Reporting Program) unless disapproved by the Executive Officer. Non-storm water discharges other than the Discharger's that are in compliance with the conditions of this provision and the Discharger's SWPPP may also be accepted by the Discharger and are not subject to Discharge Prohibition III.D.
- ii. The Discharger may include, as part of its annual or other updates to the SWPPPs, additional categories of non-storm water discharges to be included in the exemption to Discharge Prohibition III.D. Such proposals are subject to approval by the Board.

b. Sludge Management Practices Requirements

JULY 27, 2007

- (1) All sludge generated by the Discharger must be disposed of in a municipal solid waste landfill, reused by land application, or disposed of in a sludge-only landfill in accordance with 40 CFR Part 503. If the Discharger desires to dispose of sludge by a different method, a request for permit modification must be submitted to USEPA 180 days before start-up of the alternative disposal practice. All the requirements in 40 CFR Part 503 are enforceable by USEPA whether or not they are stated in an NPDES permit or other permit issued to the Discharger. The Regional Water Board should be copied on relevant correspondence and reports forwarded to USEPA regarding sludge management practices.
- (2) Sludge treatment, storage and disposal or reuse shall not create a nuisance, such as objectionable odors or flies, or result in groundwater contamination.
- (3) The Discharger shall take all reasonable steps to prevent or minimize any sludge use or disposal which has a likelihood of adversely affecting human health or the environment.
- (4) The discharge of sludge shall not cause waste material to be in a position where it is or can be carried from the sludge treatment and storage site and deposited in waters of the State.
- (5) The sludge treatment and storage site shall have facilities adequate to divert surface runoff from adjacent areas, to protect boundaries of the site from erosion, and to prevent any conditions that would cause drainage from the materials in the temporary storage site. Adequate protection is defined as protection from at least a 100-year storm and protection from the highest possible tidal stage that may occur.
- (6) For sludge that is applied to the land, placed on a surface disposal site, or fired in a sludge incinerator as defined in 40 CFR Part 503, the Discharger shall submit an annual report to USEPA and the Regional Water Board containing monitoring results and pathogen and vector attraction reduction requirements as specified by 40 CFR Part 503, postmarked February 15 of each year, for the period covering the previous calendar year.
- (7) Sludge that is disposed of in a municipal solid waste landfill must meet the requirements of 40 CFR Part 258. In the annual self-monitoring report, the Discharger shall include the amount of sludge disposed of and the landfill(s) to which it was sent.
- (8) Permanent on-site sludge storage or disposal activities are not authorized by this Order. A report of Waste Discharge shall be filed and the site brought into compliance with all applicable regulations prior to commencement of any such activity by the Discharger.

JULY 27, 2007

(9) Sludge Monitoring and Reporting Provisions of this Regional Water Board's Standard Provisions (**Attachment G**), apply to sludge handling, disposal and reporting practices.

(10) The Regional Water Board may amend this Order prior to expiration if changes occur in applicable state and federal sludge regulations.

c. Cyanide Action Plan

The Discharger shall initiate implementation of an action plan for cyanide as described in Appendix I of "Staff Report on Proposed Site-Specific Water Quality Objectives for Cyanide for San Francisco Bay", December 4, 2006.

d. Copper Action Plan

If and when the copper alternate limits in IV become effective, the Discharger shall initiate implementation of an action plan for copper, consistent with the copper SSO Basin Plan Amendment.

VII. COMPLIANCE DETERMINATION

Compliance with the effluent limitations contained in section IV of this Order will be determined as specified below:

A. General

Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined in the MRP, Attachment A and Section VI of the Fact Sheet of this Order. For purposes of reporting and administrative enforcement by the Regional and State Water Boards, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).

B. Multiple Sample Data

When determining compliance with an AMEL or MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:

1. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
2. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

ATTACHMENT A – DEFINITIONS

Arithmetic Mean (μ), also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

Arithmetic mean = $\mu = \Sigma x / n$ where: Σx is the sum of the measured ambient water concentrations, and n is the number of samples.

Average Monthly Effluent Limitation (AMEL): the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL): the highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Bioaccumulative pollutants are those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic pollutants are substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV) is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge: Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the Order), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ) are those sample results less than the RL, but greater than or equal to the laboratory's MDL.

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effluent Concentration Allowance (ECA) is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in USEPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Estimated Chemical Concentration is the estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inland Surface Waters are all surface waters of the State that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation: the highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation: the lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL) means the highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged

over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median is the middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Method Detection Limit (MDL) is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in title 40 of the Code of Federal Regulations, Part 136, Attachment B, revised as of July 3, 1999.

Minimum Level (ML) is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

Not Detected (ND) are those sample results less than the laboratory's MDL.

Ocean Waters are the territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program (PMP) means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product

JULY 27, 2007

reformulation (as defined in Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State or Regional Water Board.

Reporting Level (RL) is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Satellite Collection System is the portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

Source of Drinking Water is any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

Standard Deviation (σ) is a measure of variability that is calculated as follows:

$$\sigma = (\sum[(x - \mu)^2]/(n - 1))^{0.5}$$

where:

- x is the observed value;
- μ is the arithmetic mean of the observed values; and
- n is the number of samples.

Toxicity Reduction Evaluation (TRE) is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

ATTACHMENT B - MAP



USGS HUNTERS POINT (CA)
1:24,000
Current: 1993
7.5 minute

JULY 27, 2007

JULY 27, 2007

ATTACHMENT C – SFIA Mel Leong Treatment Plant, Industrial Plant:

- 1. Flow schematic**
- 2. Aerial view of the treatment plant showing sampling points.**

INDUSTRIAL WASTEWATER PROCESS

There are two different sources of industrial waste at the airport. The first is point source waste from specific areas such as maintenance shops or car washing. The point source wastewater is collected by the industrial wastewater collection system and pumped to the Industrial Waste Treatment Plant. The other type are non-point sources which is surface runoff. During a storm, wastes such as small fuel spills, hydraulic fluid spills, etc., are washed from the airport service areas and collected by the storm drainage system and first flush ponds. After the rain, the areas have been washed clean and the runoff is free from pollutants and is discharged directly to the Bay. The first part of the runoff (first flush) is collected either at the north, south, east or west first flush ponds. The ponds and storm drain canals hold up to a total of 9.55 million gallons (MG) of runoff. The collected runoff is then pumped at a controlled rate to the Industrial Waste Treatment Plant.

1 I. Preliminary Treatment

Equalization Tank

The industrial wastewater is pumped and stored in the Equalization Tank. The Equalization Tank provides mixing and detention time for dampening the effect of wide fluctuation in wastewater quality and quantity. The Equalization Tank can be isolated to remove any large amounts of floating oil. The wastewater flows by gravity from the Equalization Tank into the process area. The Preliminary Treatment is complete.

2 II. Primary Treatment

Rapid Mix Basin No. 1

The controlled influent flow of wastewater continues to the Rapid Mix Basin No. 1. This process is used to flash mix liquid alum with the wastewater. Caustic is added for pH adjustment if necessary. Polymers are added for assisting coagulation.

8 IV. Disinfection

Chlorine Contact Basin

Treated water from the Clarifiers is directed into the Chlorine Contact Basin where it is mixed with chlorine solution which provides disinfection. This Chlorine Contact Basin is separate from the treated domestic wastewater basin.

9 V. Dechlorination

Pump Station

The chlorinated effluent from both the Industrial Waste Treatment Plant and Water Quality Control Plant flows to the combined effluent pumping station. The combined effluent is pumped to the North Bayside System Unit outfall, where the treated water is combined with effluent from South San Francisco, Millbrae, and Burlingame. Dechlorination takes place in the shared outfall before the effluent is discharged into the Bay.

3 Flocculation Tank

After the wastewater has been mixed with the alum and polymer, it flows to the Flocculation Tank for slow mixing. The flocculation process stirs the wastewater slowly to allow large particles to form. The effluent from the Flocculation tank flows to the two Dissolved Air Flotation (DAF) units.

11 Solid Disposal

S1 Industrial Waste Sludge Beds

The sludge and scum collected by the Clarifiers and DAF Units are pumped to the sludge beds for dewatering. A clay pipe underdrain system has been provided to collect the filtrate drained from the sludge. The filtrate flows back to the trickling filter for further treatment. Note that the dewatering and disposal of the sludge from the industrial wastewater is separate from that of the domestic wastewater.

4 Dissolved Air Flotation (DAF)

The Dissolved Air Flotation units provide removal of grease and oil and suspended solids from the waste stream. Recycled effluent is saturated with air pressurized to release microscopic bubbles, which attach themselves to the oil and suspended particles. Consequently, the particles form a sludge layer at the surface where they are removed by the top scrapers. The sludge flows by gravity to the waste sludge wet well.

5 Rapid Mix Basin No. 2

The effluent from both of the DAF units flows to the Rapid Mix Basin No. 2. Final pH adjustment, if necessary, takes place here by the addition of caustic. This ends the Primary Treatment.


6 III. Secondary Treatment

Trickling Filter

After the chemical treatment and pH adjustment, the partially treated wastewater is pumped to the trickling filter for an aerobic biological treatment. The trickling filter consists of a cylindrical tank containing a bed of plastic media covered with microorganisms. Wastewater is applied at a controlled rate. As the wastewater trickles through the opening of the media, organic matter is removed by contact with the microorganisms. The treated water is then collected by an underdrain system.

7 Clarifiers

The trickling filter effluent flows from the underdrain system and is split between the two final Clarifiers. Some effluent is recycled back to the trickling filter to maintain the bacteria culture. The treated water is held in the quiescent clarifier tanks long enough for the gravitational effects to result in the sludge settling to the tank bottom, while the clarified effluent overflows the top of the Clarifier. A rotating blade pushes the surface scum into a trough, which leads into a scum pit. The collected scum and sludge are pumped to the sludge wet well. The secondary treatment is complete.





10 Recycling

R1 Water Reclamation

A portion of the treated industrial wastewater is pumped from the Combined Effluent Pump Station to the Water Reclamation System. The treated water passes through filters and is pumped to a storage tank. This reclaimed water is pumped to different parts of the airport for irrigation.

JULY 27, 2007



LEGEND

- STORM DRAINS
- CATCH BASINS
- MAN HOLES
- PUMP STATION
- FLOW DIRECTION

- DRAINS TO WEST FIELD DETENTION BASIN, EXCESS DRAINS TO SDPS* 2 (E004)
 - DRAINS TO MOC DETENTION BASIN, EXCESS DRAINS TO SDPS 2 (E004)
 - DRAINS TO SOUTH DETENTION BASIN, EXCESS DRAINS TO SDPS 1 (E003)
 - DRAINS TO
 - OUTFALLS E011 AND E012
 - DRAINS TO
 - OUTFALLS E008 & E009
 - DRAINS TO SDPS 1-C (E007)
 - DRAINS TO SDPS 1-B (E006)
 - DRAINS TO SDPS 1-A (E005)
 - DRAINS TO NORTH FIELD DETENTION BASIN, EXCESS DRAINS TO OUTFALL E013
 - DRAINS TO OUTFALL E010
 - DRAINS TO SDPS 1 (E003)
 - DRAINS TO EAST DETENTION BASIN, EXCESS DRAINS TO SDPS 2 (E004)
 - DRAINS TO NORTH SLOUGH - MOC (Under separate permit)
 - DRAINS TO WEST OF U.S. ROUTE 101 WETLAND
 - U.S. COAST GUARD AREA DRAINS TO SDPS 2 (E004)
- * Storm Drainage Pump Station

| NO. | DATE | DESCRIPTION | BY |
|------------------|------|-------------|----|
| REVISIONS | | | |
| | | | |

Copyright YEAR by the City and County of San Francisco. These construction documents are the sole property of the City and County of San Francisco and are protected by the Copyright and other laws of the United States and the State of California. Any reproduction or use of these documents without the express written consent of the San Francisco Airport Commission is prohibited.

NOTE: If this drawing is not 24" x 36", it has been revised from its original size. Scales noted on drawings/details are no longer applicable.

PROJECT TITLE

IWSWPPP

Annual Industrial SWPPP
Report for Sept. 2006

SHEET TITLE

Drainage Areas and Storm
Water Discharge Points at SFIA

DATE
9/2006

SCALE
AS SHOWN

FIGURE 1-1

- ① INFLUENT SANITARY PROCESS: INF-001 SAN
- ② INFLUENT INDUSTRIAL WASTE: INF-001 IND
- ③ EFFLUENT SANITARY PROCESS: EFF-001 SAN
- ④ EFFLUENT INDUSTRIAL WASTE: EFF-001 IND
- ⑤ COMBINED EFFLUENT PUMP STATION: EFF-001 A



SAN FRANCISCO INTERNATIONAL AIRPORT
MEL LEONG TREATMENT PLANT

ATTACHMENT D –STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (40 C.F.R. § 122.41(a).)
2. The Discharger shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 C.F.R. § 122.41(a)(1).)

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 C.F.R. § 122.41(c).)

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 C.F.R. § 122.41(d).)

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order (40 C.F.R. § 122.41(e)).

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 C.F.R. § 122.41(g).)
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 C.F.R. § 122.5(c).)

F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (40 C.F.R. § 122.41(i); Wat. Code, § 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (40 C.F.R. § 122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (40 C.F.R. § 122.41(i)(2));
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (40 C.F.R. § 122.41(i)(3)); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (40 C.F.R. § 122.41(i)(4).)

G. Bypass

1. Definitions
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 C.F.R. § 122.41(m)(1)(i).)
 - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 C.F.R. § 122.41(m)(1)(ii).)
2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 C.F.R. § 122.41(m)(2).)
3. Prohibition of bypass. Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless (40 C.F.R. § 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 C.F.R. § 122.41(m)(4)(i)(A));

JULY 27, 2007

- b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 C.F.R. § 122.41(m)(4)(i)(B)); and
 - c. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 C.F.R. § 122.41(m)(4)(i)(C).)
 4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 C.F.R. § 122.41(m)(4)(ii).)
5. Notice
 - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 C.F.R. § 122.41(m)(3)(i).)
 - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 C.F.R. § 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 C.F.R. § 122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 C.F.R. § 122.41(n)(2).)
2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 C.F.R. § 122.41(n)(3)):

JULY 27, 2007

- a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 C.F.R. § 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 C.F.R. § 122.41(n)(3)(ii));
 - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 C.F.R. § 122.41(n)(3)(iii)); and
 - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 C.F.R. § 122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 C.F.R. § 122.41(n)(4).)

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 C.F.R. § 122.41(f).)

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 C.F.R. § 122.41(b).)

C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of this Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the Water Code. (40 C.F.R. § 122.41(l)(3); § 122.61.)

III. STANDARD PROVISIONS – MONITORING

- A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 C.F.R. § 122.41(j)(1).)
- B. Monitoring results must be conducted according to test procedures under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503 unless other test procedures have been specified in this Order. (40 C.F.R. § 122.41(j)(4); § 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS – RECORDS

- A. Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by Part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 C.F.R. § 122.41(j)(2).)
- B. Records of monitoring information shall include:
1. The date, exact place, and time of sampling or measurements (40 C.F.R. § 122.41(j)(3)(i));
 2. The individual(s) who performed the sampling or measurements (40 C.F.R. § 122.41(j)(3)(ii));
 3. The date(s) analyses were performed (40 C.F.R. § 122.41(j)(3)(iii));
 4. The individual(s) who performed the analyses (40 C.F.R. § 122.41(j)(3)(iv));
 5. The analytical techniques or methods used (40 C.F.R. § 122.41(j)(3)(v)); and
 6. The results of such analyses. (40 C.F.R. § 122.41(j)(3)(vi).)
- C. Claims of confidentiality for the following information will be denied (40 C.F.R. § 122.7(b)):
1. The name and address of any permit applicant or Discharger (40 C.F.R. § 122.7(b)(1)); and
 2. Permit applications and attachments, permits and effluent data. (40 C.F.R. § 122.7(b)(2).)

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 C.F.R. § 122.41(h); Wat. Code, § 13267.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 C.F.R. § 122.41(k).)
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 C.F.R. § 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 C.F.R. § 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 C.F.R. § 122.22(b)(2)); and
 - c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 C.F.R. § 122.22(b)(3).)
4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 C.F.R. § 122.22(c).)
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware

JULY 27, 2007

that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 C.F.R. § 122.22(d).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 C.F.R. § 122.22(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices. (40 C.F.R. § 122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board. (40 C.F.R. § 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 C.F.R. § 122.41(l)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 C.F.R. § 122.41(l)(5).)

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 C.F.R. § 122.41(l)(6)(i).)
2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 C.F.R. § 122.41(l)(6)(ii)):
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(A).)

- b. Any upset that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(B).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 C.F.R. § 122.41(l)(6)(iii).)

F. Planned Changes

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 C.F.R. § 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 C.F.R. § 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (40 C.F.R. § 122.41(l)(1)(ii).)
3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 C.F.R. § 122.41(l)(1)(iii).)

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements. (40 C.F.R. § 122.41(l)(2).)

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 C.F.R. § 122.41(l)(7).)

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information. (40 C.F.R. § 122.41(l)(8).)

VI. STANDARD PROVISIONS – ENFORCEMENT

- A. The Regional Water Board is authorized to enforce the terms of this Order under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387.

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 C.F.R. § 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 C.F.R. § 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of this Order. (40 C.F.R. § 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 C.F.R. § 122.42(b)(3).)

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Table of Contents

I. General Monitoring Provisions 2

II. Monitoring Locations 3

III. Influent Monitoring Requirements 4

 A. Monitoring Location INF-001 4

IV. Effluent Monitoring Requirements 5

 A. Monitoring Location EFF-001 5

 B. Monitoring Location EFF-001A 6

 C. Monitoring Location EFF-002 7

 D. Monitoring Locations EFF-003, and EFF-005 through EFF-013 8

 E. Monitoring Location EFF-004 9

V. Whole Effluent Toxicity Testing Requirements 10

VI. Land Discharge Monitoring Requirements 14

VII. Reclamation Monitoring Requirements 14

VIII. Receiving Water Monitoring Requirements – Surface Water and Groundwater 14

 A. Regional Monitoring Program 14

IX. Legend for MRP Tables 14

X. Other Monitoring Requirements 15

 A. Monitoring Location – Overflows and Bypasses (OV-1 thru OV-n) 15

 B. Sludge Monitoring 16

XI. Reporting Requirements 16

 A. General Monitoring and Reporting Requirements 16

 B. Self Monitoring Reports (SMRs) 17

 C. Discharge Monitoring Reports (DMRs) 19

 D. Other Reports 20

Tables

Table E-1. Test Methods and Minimum Levels for Pollutants with Reasonable Potential 3

Table E-2. Monitoring Station Locations 4

Table E-3. Influent Monitoring 5

Table E-4. Effluent Monitoring – Monitoring Location EFF-001-Ind 5

Table E-5. Effluent Monitoring – Monitoring Location EFF-001A 6

Table E-6. Effluent Monitoring – Monitoring Location EFF-002 7

Table E-7. Effluent Monitoring – Monitoring Locations EFF-003, and EFF-005 through
EFF-013 8

Table E-8. Effluent Monitoring – Monitoring Location EFF-004 9

Table E-9. Overflows and Bypasses Monitoring Requirements 15

Table E-10. Monitoring Periods and Reporting Schedule 18

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

NPDES regulations at 40 CFR 122.48 require that all NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Regional Water Board) to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements, which implement the federal and California regulations.

I. GENERAL MONITORING PROVISIONS

- A. The Discharger shall comply with the MRP for this Order as adopted by the Regional Water Board, and with all of the Self-Monitoring Program, Part A, adopted August 1993 (SMP). If any discrepancies exist between the MRP and SMP, the MRP prevails.
- B. Sampling is required during the entire year when discharging. All analyses shall be conducted using current USEPA methods, or that have been approved by the USEPA Regional Administrator pursuant to 40 CFR 136.4 and 40 CFR 136.5, or equivalent methods that are commercially and reasonably available, and that provide quantification of sampling parameters and constituents sufficient to evaluate compliance with applicable effluent limitations and to perform reasonable potential analysis. Equivalent methods must be more sensitive than those specified in 40 CFR 136, must be specified in the permit, and must be approved for use by the Executive Officer, following consultation with the State Water Quality Control Board's Quality Assurance Program.
- C. Sampling and analysis of additional constituents is required pursuant to Table 1 of the Regional Water Board's August 6, 2001 Letter entitled, *Requirement for Monitoring of Pollutants in Effluent and Receiving Water to Implement New Statewide Regulations and Policy (Attachment G)*.
- D. *Minimum Levels*. For compliance and reasonable potential monitoring, analyses shall be conducted using the commercially available and reasonably achievable detection levels that are lower than applicable water quality objectives or criteria, or the effluent limitations, whichever is lower. The objective is to provide quantification of constituents sufficient to allow evaluation of observed concentrations with respect to the Minimum Levels (MLs) given below.

MLs are the concentrations at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed. All MLs are expressed as µg/l.

Table E-1 lists the test methods the Discharger may use for compliance and reasonable potential monitoring for the pollutants with effluent limitations.

Table E-1. Test Methods and Minimum Levels for Pollutants with Reasonable Potential

| CTR # | Constituent | Types of Analytical Methods ⁽¹⁾ | | | | | | | | | | | |
|-------|----------------------------|--|------|----|-------|-----|------|-----|-------|--------|---------|--------|-----|
| | | Minimum Levels (µg/l) | | | | | | | | | | | |
| | | GC | GCMS | LC | Color | FAA | GFAA | ICP | ICPMS | SPGFAA | HYDRIDE | CVAF | DCP |
| 6 | Copper | | | | | 25 | 5 | 10 | 0.5 | 2 | | | |
| 7 | Lead | | | | | 20 | 5 | 5 | 0.5 | 2 | | | |
| 8 | Mercury ⁽²⁾ | | | | | | | | | | | 0.0005 | |
| 9 | Nickel | | | | | 50 | 5 | 20 | 1 | 5 | | | |
| 14 | Cyanide | | | | 5 | | | | | | | | |
| 16a | Dioxin-TEQ ⁽³⁾ | | | | | | | | | | | | |
| 102 | Aldrin | 0.005 | | | | | | | | | | | |
| 103 | Alpha-BHC | 0.01 | | | | | | | | | | | |
| 104 | Beta-BHC | 0.005 | | | | | | | | | | | |
| 108 | 4,4-DDT | 0.01 | | | | | | | | | | | |
| 109 | 4,4-DDE | 0.05 | | | | | | | | | | | |
| 111 | Dieldrin | 0.01 | | | | | | | | | | | |
| 115 | Endrin | 0.01 | | | | | | | | | | | |
| 117 | Heptachlor | 0.01 | | | | | | | | | | | |
| 118 | Heptachlor Epoxide | 0.01 | | | | | | | | | | | |
| | Ammonia ⁽⁴⁾ | | | | | | | | | | | | |
| -- | Tributyltin ⁽⁵⁾ | 0.005 | | | | | | | | | | | |

(1) Analytical Methods / Laboratory techniques are defined as follows:

- Color = Colorimetric
- CVAF = Cold Vapor Atomic Fluorescence
- DCP = Direct Current Plasma
- FAA = Furnace Atomic Absorption
- GC = Gas Chromatography
- GCMS = Gas Chromatography Mass Spectroscopy
- GFAA = Graphite Furnace Atomic Absorption
- ICP = Inductively Coupled Plasma
- ICPMS = Inductively Coupled Plasma/Mass Spectrometry
- LC = Liquid Chromatography
- SPGFAA = Stabilized Platform Graphite Furnace Atomic Absorption (i.e. EPA 200.9)

(2) Mercury: Use ultra-clean sampling (USEPA 1669) to the maximum extent practicable, and ultra-clean analytical methods (USEPA 1631) for mercury monitoring. The Discharger may use alternative methods of analysis (such as USEPA 245), if the alternative method has an ML of 0.0005 µg/l or less.

(3) Use USEPA Method 1613

(4) Ammonia-N measured by Ammonia Selective Electrode Method, Reference SM 4500-NH3 F (18th Edition), minimum detection level, 0.1 mg/l.

(5) To determine tributyltin, the Discharger shall use GC-FPD, GC/MS or an USEPA approved method; the method shall be capable of speciating organotins and detecting concentrations at low limits on the order of 5 ng/l. Alternative methods of analysis must be approved by the Executive Officer.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order: These locations are shown on the site map included in Appendix C of the Order.

Table E-2. Monitoring Station Locations

| Type of Sampling Location | Monitoring Location Name | Monitoring Location Description |
|---------------------------|--------------------------|---|
| Influent Station | INF-001-Ind | Formerly Sampling Station A-001, at any point in the Industrial Plant treatment facilities upstream of the flocculation tank at which all waste tributary to the treatment system is present, and preceding any phase of treatment. |
| Plant Effluent Station | EFF-001-Ind | Formerly Sampling Station E-001, at any point in the Industrial Plant after disinfection and prior to combining with effluent from the SFIA Sanitary Plant in the pumping station (the combined forcemain-outfall). |
| Plant Effluent Station | EFF-001A | A new monitoring location, at a point (37° 38', 15" N and 122° 23', 3" W) after treated effluent from the Sanitary Plant and Industrial Plant are combined in the SFIA Mel Long Treatment Plant pumping station prior to discharge into the North Bayside System Unit (NBSU). |
| Plant Effluent Station | EFF-002 | Formerly Sampling Station E-002, at any point in the NBSU combined outfall after dechlorination between the point of discharge into San Francisco Bay and the point at which all waste tributary to the NBSU combined outfall is present. |
| Storm Water | EFF-003 | Formerly Sampling Station E-003, at the point of discharge from Pump Station No. 1. |
| Storm Water | EFF-004 | Formerly Sampling Station E-004, at the point of discharge from Pump Station No. 2. |
| Storm Water | EFF-005 | Formerly Sampling Station E-005, at the point of discharge from Pump Station No. 1-A. |
| Storm Water | EFF-006 | Formerly Sampling Station E-006, at the point of discharge from Pump Station No. 1-B. |
| Storm Water | EFF-007 | Formerly Sampling Station E-007, at the point of discharge from Pump Station No. 1-C. |
| Storm Water | EFF-008 | Formerly Sampling Station E-008, at the point of discharge from Pump Station No. 17. |
| Storm Water | EFF-009 | Formerly Sampling Station E-009, at the point of discharge from Pump Station No. 18. |
| Storm Water | EFF-010 | Formerly Sampling Station E-010, at the point of discharge from the western area of the North Cargo Facility Area. |
| Storm Water | EFF-013 | Formerly Sampling Station E-013, at the point of discharge from Pump Station No. 6. |

III. INFLUENT MONITORING REQUIREMENTS

A. Monitoring Location INF-001

1. The Discharger shall monitor influent to the facility at INF-001-Ind as follows.

Table E-3. Influent Monitoring

| Parameter | Units | Minimum Sampling Frequency | | Required Analytical Test Method |
|---|-------|----------------------------|--|---------------------------------|
| | | C-24 ⁽²⁾ | | |
| Conventional Pollutants | | | | |
| Flow rate ⁽¹⁾ | MGD | Cont/D | | meter |
| Biochemical Oxygen Demand (5-day @ 20 Deg. C) (BOD ₅) | mg/l | 3/W | | (3) |
| Total Suspended Solids (TSS) | mg/l | 5/W | | (3) |

(1) Monitoring Reports shall include the following information:

- Daily: Total Daily Flow Volume (MG)
- Daily: Daily Average Flow (MGD)
- Monthly: Monthly Average Flow (MGD)
- Monthly: Maximum Daily Flow (MGD)
- Monthly: Minimum Daily Flow (MGD)
- Monthly: Total Flow Volume (MG)

(2) Composite samples of influent shall be collected on varying days selected at random and shall not include any plant recirculation or other side stream waste. Deviation from this must be approved by the Executive Officer.

(3) Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136.

IV. EFFLUENT MONITORING REQUIREMENTS

A. Monitoring Location EFF-001

1. The Discharger shall monitor treated effluent from the facility at EFF-001 as follows.

Table E-4. Effluent Monitoring – Monitoring Location EFF-001-Ind

| Parameter | Units | Minimum Sampling Frequency | | | Required Analytical Test Method |
|------------------------------------|--------------|----------------------------|-------------------|---------|---------------------------------|
| | | Continuous | 24 hour composite | Grab | |
| Flow ⁽²⁾ | MGD | Cont/D | | | meter |
| BOD ₅ ⁽³⁾ | mg/l, kg/day | | 3/Week | | (1) |
| TSS ⁽³⁾ | mg/l, kg/day | | 5/Week | | (1) |
| Oil and Grease ⁽⁴⁾ | mg/l | | | 2/Month | (1) |
| pH ⁽⁵⁾ | s.u. | | | 3/Week | (1) |
| Visual Observations ⁽⁶⁾ | | | | Daily | |

(1) Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136.

(2) Flows shall be monitored continuously and the following shall be reported in monthly self-monitoring reports:

- a. Total Daily Flow Volume (MG)
- b. Daily Average Flow (MGD)
- c. Monthly Average Flow (MGD)
- d. Monthly total flow (MG)
- e. Average daily maximum and average daily minimum flow rates (MGD) in a month
- f. Intake duration in days and hours

(3) The percent removal for BOD₅ and TSS shall be reported for each calendar month.

(4) Each oil and grease sampling event shall consist of a composite sample comprised of three grab samples taken at equal intervals during the sampling date, with each grab sample being collected in a glass container. Each glass container used

JULY 27, 2007

for sample collection or mixing shall be thoroughly rinsed with solvent rinsings as soon as possible after use, and the solvent rinsings shall be added to the composite sample for extraction and analysis.

- (5) If pH is monitored continuously the minimum and maximum pH values for each day shall be reported in monthly self-monitoring reports.
- (6) In conducting the effluent sampling, visual observations shall be made. A log shall be kept of the effluent conditions. Notes on effluent conditions shall be summarized in the monitoring report. Attention shall be given to:
 - a. The presence or absence of floating or suspended material of waste origin, including oil, grease, algae, and other macroscopic particulate matter,
 - b. Odor: Presence or absence, characterization, source, distance of travel.

B. Monitoring Location EFF-001A

1. The Discharger shall monitor effluent at EFF-001A as follows.

Table E-5. Effluent Monitoring – Monitoring Location EFF-001A

| Parameter | Units | Minimum Sampling Frequency | | | Required Analytical Test Method |
|---|-----------------|---|-------------------|---------|---------------------------------|
| | | Continuous | 24 hour composite | Grab | |
| Flow ⁽²⁾ | MGD | Cont/D | | | meter |
| Temperature | °C | | | 3/Week | (1) |
| Dissolved Oxygen | mg/l | | | 3/Week | (1) |
| pH ⁽³⁾ | s.u. | | | 3/Week | (1) |
| Fecal Coliform Bacteria | MPN/100 ml | | | 2/Week | (1) |
| Enterococci Bacteria ⁽⁴⁾ | colonies/100 ml | | | Monthly | (1) |
| Acute Toxicity ⁽⁵⁾ | % survival | Cont/D | | | (1) |
| Chronic Toxicity ⁽⁶⁾ | TUc | | 2/Year | | (1) |
| Copper | µg/l | | Monthly | | (1) |
| Lead | µg/l | | Monthly | | (1) |
| Mercury ⁽⁷⁾ | µg/l, kg/mo | | | Monthly | (1) |
| Nickel | µg/l | | Monthly | | (1) |
| Dioxin-TEQ ⁽⁸⁾ | µg/l | | | 2/Year | (1) |
| Aldrin | µg/l | | | 2/Year | (1) |
| alpha-BHC | µg/l | | | 2/Year | (1) |
| beta-BHC | µg/l | | | 2/Year | (1) |
| 4,4-DDT | µg/l | | | 2/Year | (1) |
| 4,4-DDE | µg/l | | | 2/Year | (1) |
| Dieldrin | µg/l | | | 2/Year | (1) |
| Endrin | µg/l | | | 2/Year | (1) |
| Heptachlor | µg/l | | | 2/Year | (1) |
| Heptachlor Epoxide | µg/l | | | 2/Year | (1) |
| Ammonia | mg/l | | | Monthly | (1) |
| Tributyltin ⁽⁹⁾ | µg/l | | | 2/Year | (1) |
| CTR Priority Pollutants ⁽¹⁰⁾ | µg/l | 1/Year and in accordance with the August 6, 2001 Letter | | | (1) |
| Visual Observations ⁽¹¹⁾ | | | | Daily | |

- (1) Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136. For priority pollutants, the methods must meet the lowest minimum levels (MLs) specified in Attachment 4 of the SIP. Where no methods are specified for a given pollutant, the methods must be approved by this Regional Water Board or the State Board.
- (2) Flows shall be monitored continuously and the following shall be reported in monthly self-monitoring reports:
 - a. Total Daily Flow Volume (MG)
 - b. Daily Average Flow (MGD)
 - c. Monthly Average Flow (MGD)
 - d. Monthly total flow (MG)
 - e. Average daily maximum and average daily minimum flow rates (MGD) in a month
 - f. Intake duration in days and hours
- (3) If pH is monitored continuously the minimum and maximum pH values for each day shall be reported in monthly self-monitoring reports.
- (4) The Discharger shall monitor for enterococci using USEPA's Membrane Filter Test Method 1600 or an EPA approved method such as Enterolert.
- (5) Acute bioassay tests shall be performed in accordance with Section V.A of this MRP. A combination of prechlorinated effluent flows from EFF-001-SAN and EF-001-IND is to be used for this test. The flows are to be mixed in proportion to the actual flows from the two plants.
- (6) Critical Life Stage Toxicity Test shall be performed and reported in accordance with the Chronic Toxicity Requirements specified in Sections V.B of the MRP.
- (7) Mercury: The Discharger may, at its option, sample effluent mercury either as grab or as 24-hour composite samples. The Discharger shall use ultra-clean sampling (U.S. EPA 1669) to the maximum extent practicable and ultra-clean analytical methods (USEPA 1631) for mercury monitoring. The Discharger shall only use alternative methods if the method has an ML of 0.5 ng/l or less, and approval is obtained from the Executive Officer prior to conducting the monitoring.
- (8) Dioxin-TEQ analyzed by USEPA Method 1613 using ½ USEPA specified MLs.
- (9) To determine tributyltin, the Discharger shall use GC-FPD, GC/MS or an USEPA approved method; the method shall be capable of speciating organotins and detecting concentrations at low limits on the order of 5 ng/l. Alternative methods of analysis must be approved by the Executive Officer.
- (10) Those pollutants identified as Compound Nos. 1 – 126 by the California Toxics Rule at 40 CFR 131.38 (b)(1).
- (11) In conducting the effluent sampling, visual observations shall be made. A log shall be kept of the effluent conditions. Notes on effluent conditions shall be summarized in the monitoring report. Attention shall be given to:
 - a. The presence or absence of floating or suspended material of waste origin, including oil, grease, algae, and other macroscopic particulate matter,
 - b. Odor: Presence or absence, characterization, source, distance of travel.

2. The Discharger may use the data generated in accordance with the monitoring requirements in Section IV.B.1 above to determine compliance with the water quality-based effluent limitations for the Sanitary Plant.

C Monitoring Location EFF-002

1. The Discharger shall monitor treated effluent from the facility at EFF-002 as follows:

Table E-6. Effluent Monitoring – Monitoring Location EFF-002

| Parameter | Units | Minimum Sampling Frequency | | | Required Analytical Test Method |
|--------------------------|--------------|----------------------------|-------------------|------|---------------------------------|
| | | Continuous | 24 hour composite | Grab | |
| Chlorine, Total Residual | mg/l, kg/day | Grab sample every 2 h | | | (1) |

| | | | | | |
|------------------------------------|------|--|--|---------|-----|
| Visual Observations ⁽²⁾ | | | | Daily | |
| Cyanide ⁽³⁾ | µg/l | | | Monthly | (1) |

- (1) All disinfection process monitoring shall be conducted on the combined NBSU flow, as the dechlorination occurs on this particular flow. During all times when chlorination is used for disinfection of the effluent, effluent chlorine residual concentrations shall be monitored continuously, or by grab samples taken every 2 hours. Grab samples may be taken by hand or by automated means using in-line equipment such as three-way valves and chlorine residual analyzers. Chlorine residual concentrations shall be monitored and reported for sampling points both prior to and following dechlorination. Chlorine dosage (kg/day) shall be recorded on a daily basis and dechlorination chemical dosage and/or residual (if desired to demonstrate chlorine exceedances are false positives).
- TRC Detection Levels: Discharger shall use a method for analysis of TRC that is identified as approved by USEPA for analysis of wastewaters at 40 CFR 136. The method of analysis shall achieve a method detection limit (MDL) at least as low as that achieved by the Amperometric Titration Method (4500-Cl D from *Standard Methods for Examination of Water and Wastewater*, Edition 20).
- (2) In conducting the effluent sampling, visual observations shall be made. A log shall be kept of the effluent conditions. Notes on effluent conditions shall be summarized in the monitoring report. Attention shall be given to:
- The presence or absence of floating or suspended material of waste origin, including oil, grease, algae, and other macroscopic particulate matter,
 - Odor: Presence or absence, characterization, source, distance of travel.
- (3) The Discharger may analyze for cyanide as Weak Acid Dissociable Cyanide using protocols specified in Standard Methods Part 4500-CN-I, USEPA Method OI 1677, or an equivalent alternative as specified in the latest edition of Standard Methods for Analysis of Water and Wastewater. Alternative methods of analysis must be approved by the Executive Officer.

2. The Discharger may use the data generated in accordance with the monitoring requirements in Section IV.C.1 above to determine compliance with the water quality-based effluent limitations for the Sanitary Plant.

D. Monitoring Locations EFF-003 and EFF-005 through EFF-013

- The Discharger shall monitor storm water discharges from the facility at Monitoring Locations EFF-003 and EFF-005 through EFF-013 as follows.

Table E-7. Effluent Monitoring – Monitoring Locations EFF-003 and EFF-005 through EFF-010 and EFF-013

| Parameter | Units | Minimum Sampling Frequency | | | Required Analytical Test Method |
|--|------------|----------------------------|-------------------|--------|---------------------------------|
| | | Continuous | 24 hour composite | Grab | |
| BOD ₅ | mg/l | | | 2/Year | (1) |
| TSS | mg/l | | | 2/Year | (1) |
| Oil and Grease ⁽¹⁾ | mg/l | | | 2/Year | (1) |
| pH ⁽²⁾ | s.u. | | | 2/Year | (1) |
| Fecal Coliform Bacteria | MPN/100 ml | | | 2/Year | (1) |
| Ammonia Nitrogen and Unionized Ammonia | mg/l | | | 2/Year | (1) |
| Specific Conductance | µmhos/cm | | | 2/Year | (1) |
| Total Organic Carbon | mg/l | | | 2/Year | (1) |

| Parameter | Units | Minimum Sampling Frequency | | | Required Analytical Test Method |
|------------------------------------|-------|----------------------------|-------------------|--------|---------------------------------|
| | | Continuous | 24 hour composite | Grab | |
| Cadmium | µg/l | | | 2/Year | (1) |
| Copper | µg/l | | | 2/Year | (1) |
| Lead | µg/l | | | 2/Year | (1) |
| Mercury ⁽³⁾ | µg/l | | | 2/Year | (1) |
| Nickel | µg/l | | | 2/Year | (1) |
| Zinc | µg/l | | | 2/Year | (1) |
| PCBs | µg/l | | | 2/Year | (1) |
| Visual Observations ⁽⁴⁾ | | | | 2/Year | |

- (1) Each oil and grease sampling event shall consist of a composite sample comprised of three grab samples taken at equal intervals during the sampling date, with each grab sample being collected in a glass container. Each glass container used for sample collection or mixing shall be thoroughly rinsed with solvent rinsings as soon as possible after use, and the solvent rinsings shall be added to the composite sample for extraction and analysis.
- (2) If pH is monitored continuously the minimum and maximum pH values for each day shall be reported in monthly self-monitoring reports.
- (3) Mercury: The Discharger may, at its option, sample effluent mercury either as grab or as 24-hour composite samples. The Discharger shall use ultra-clean sampling (U.S. EPA 1669) to the maximum extent practicable and ultra-clean analytical methods (USEPA 1631) for mercury monitoring. The Discharger may only use alternative methods if the method has an ML of 0.5 ng/l or less, and approval is obtained from the Executive Officer prior to conducting the monitoring.
- (4) In conducting the effluent sampling, visual observations shall be made. A log shall be kept of the effluent conditions. Notes on effluent conditions shall be summarized in the monitoring report. Attention shall be given to:
 - a. The presence or absence of floating or suspended material of waste origin, including oil, grease, algae, and other macroscopic particulate matter,
 - b. Odor: Presence or absence, characterization, source, distance of travel.

E Monitoring Location EFF-004

1. The Discharger shall monitor storm water discharges from the facility at Monitoring Location EFF-004 as follows:

Table E-8. Effluent Monitoring – Monitoring Location EFF-004

| Parameter | Units | Minimum Sampling Frequency | | | Required Analytical Test Method |
|--|------------|----------------------------|-------------------|---------|---------------------------------|
| | | Continuous | 24 hour composite | Grab | |
| BOD ₅ | mg/l | | | Monthly | (1) |
| TSS | mg/l | | | Monthly | (1) |
| Oil and Grease ⁽¹⁾ | mg/l | | | Monthly | (1) |
| pH ⁽²⁾ | s.u. | | | Monthly | (1) |
| Fecal Coliform Bacteria | MPN/100 mL | | | Monthly | (1) |
| Ammonia Nitrogen and Unionized Ammonia | mg/l | | | Monthly | (1) |
| Specific Conductance | µmhos/cm | | | Monthly | (1) |

| Parameter | Units | Minimum Sampling Frequency | | | Required Analytical Test Method |
|------------------------------------|-------|----------------------------|-------------------|---------|---------------------------------|
| | | Continuous | 24 hour composite | Grab | |
| Total Organic Carbon | mg/l | | | Monthly | (1) |
| Cadmium | µg/l | | | Monthly | (1) |
| Copper | µg/l | | | Monthly | (1) |
| Lead | µg/l | | | Monthly | (1) |
| Mercury ⁽³⁾ | µg/l | | | Monthly | (1) |
| Nickel | µg/l | | | Monthly | (1) |
| Zinc | µg/l | | | Monthly | (1) |
| PCBs | µg/l | | | Monthly | (1) |
| Visual Observations ⁽⁴⁾ | | | | Monthly | |

- (1) Each oil and grease sampling event shall consist of a composite sample comprised of three grab samples taken at equal intervals during the sampling date, with each grab sample being collected in a glass container. Each glass container used for sample collection or mixing shall be thoroughly rinsed with solvent rinsings as soon as possible after use, and the solvent rinsings shall be added to the composite sample for extraction and analysis.
- (2) If pH is monitored continuously the minimum and maximum pH values for each day shall be reported in monthly self-monitoring reports.
- (3) Mercury: The Discharger may, at its option, sample effluent mercury either as grab or as 24-hour composite samples. The Discharger shall use ultra-clean sampling (USEPA 1669) to the maximum extent practicable and ultra-clean analytical methods (USEPA 1631) for mercury monitoring. The Discharger may only use alternative methods if the method has an ML of 0.5 ng/l or less, and approval is obtained from the Executive Officer prior to conducting the monitoring.
- (4) In conducting the effluent sampling, visual observations shall be made. A log shall be kept of the effluent conditions. Notes on effluent conditions shall be summarized in the monitoring report. Attention shall be given to:
 - a. The presence or absence of floating or suspended material of waste origin, including oil, grease, algae, and other macroscopic particulate matter,
 - b. Odor: Presence or absence, characterization, source, distance of travel.

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

The Discharger shall monitor acute and chronic toxicity at Monitoring Location EFF-001-IND, prior to chlorination, as follows:

A. Whole Effluent Acute Toxicity

1. Compliance with the acute toxicity effluent limitations of this Order shall be evaluated by measuring survival of test organisms exposed to 96-hour continuous flow-through bioassays.
2. Test organisms shall be the fathead minnow (*Pimephales promelas*) unless specified otherwise in writing by the Executive Officer.
3. All bioassays shall be performed according to the most up-to-date protocols in 40 CFR Part 136, currently in "Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms," 5th Edition.

JULY 27, 2007

4. The Discharger is authorized to adjust the effluent pH to below 6.6 in order to suppress the level of unionized (free) ammonia. This adjustment shall be achieved by continuously monitoring test tank pH and automatic addition of 1.0 normal hydrochloric acid as needed, using a combination of continuous pH-sensor/analyzer and pump. If other specific identifiable substances in the discharge can be demonstrated by the Discharger as being rapidly rendered harmless upon discharge to the receiving water, compliance with the acute toxicity limit may be determined after the test samples are adjusted to remove the influence of those substances. Written approval from the Executive Officer must be obtained to authorize such an adjustment.
5. Monitoring of the bioassay water shall include, on a daily basis, the following parameters: pH, dissolved oxygen, ammonia (if toxicity is observed), temperature, hardness, and alkalinity. These results shall be reported. If the fish survival rate in the effluent is less than 70 per cent of if the control fish survival rate is less than 90 percent, the bioassay test shall be restarted with new batches of fish and shall continue back to back until compliance is demonstrated.

B. Whole Effluent Chronic Toxicity

1. Chronic Toxicity Monitoring Requirements

- a. *Sampling.* The Discharger shall collect 24-hour composite samples of the effluent at the compliance point station specified in a table above, for critical life stage toxicity testing as indicated below. For toxicity tests requiring renewals, 24-hour composite samples collected on consecutive days are required.
- b. *Test Species.* *Strongylocentrotus purpuratus* and *Dendraster excentricus*. The Executive Officer may change to another test species if data suggest that another test species is more sensitive to the discharge.
- c. *Methodology.* Sample collection, handling and preservation shall be in accordance with USEPA protocols. In addition, bioassays shall be conducted in compliance with the most recently promulgated test methods, as shown in **Appendix E-1**. These are "Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms," currently third edition (EPA-821-R-02-014), and "Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms," currently fourth Edition (EPA-821-R-02-013), with exceptions granted the Discharger by the Executive Officer and the Environmental Laboratory Accreditation Program (ELAP).
- d. *Dilution Series.* The Discharger shall conduct tests at 40%, 20%, 10%, 5%, and 2%. The "%" represents percent effluent as discharged. The Discharger may use a buffer only after obtaining written approval from the Executive Officer.

2. Chronic Toxicity Reporting Requirements

- a. *Routine Reporting.* Toxicity test results for the current reporting period shall include, at a minimum, for each test:
- (1) Sample date(s)
 - (2) Test initiation date
 - (3) Test species
 - (4) End point values for each dilution (e.g., number of young, growth rate, percent survival)
 - (5) NOEC value(s) in percent effluent
 - (6) IC15, IC25, IC40, and IC50 values (or EC15, EC25 ... etc.) as percent effluent
 - (7) TUc values (100/NOEC, 100/IC25, or 100/EC25)
 - (8) Mean percent mortality (\pm s.d.) after 96 hours in 100% effluent (if applicable)
 - (9) NOEC and LOEC values for reference toxicant test(s)
 - (10) IC50 or EC50 value(s) for reference toxicant test(s)
 - (11) Available water quality measurements for each test (pH, D.O., temperature, conductivity, hardness, salinity, ammonia)
- b. *Compliance Summary.* The results of the chronic toxicity testing shall be provided in the self-monitoring report and shall include a summary table of chronic toxicity data from at least eleven of the most recent samples. The information in the table shall include items listed above under 2.a, specifically item numbers (1), (3), (5), (6) (IC25 or EC25), (7), and (8).

3. Chronic Toxicity Reduction Evaluation (TRE)

- a. *Prepare Generic TRE Work Plan.* To be ready to respond to toxicity events, the Discharger shall prepare a generic TRE work plan within 90 days of the effective date of this Order. The Discharger shall review and update the work plan as necessary to remain current and applicable to the discharge and discharge facilities.
- b. *Submit Specific TRE Work Plan.* Within 30 days of exceeding either trigger for accelerated monitoring, the Discharge shall submit to the Regional Water Board a TRE work plan, which should be the generic work plan revised as appropriate for this toxicity event after consideration of available discharge data.

JULY 27, 2007

- c. *Initiate TRE.* Within 30 days of the date of completion of the accelerated monitoring tests observed to exceed either trigger, the Discharger shall initiate a TRE in accordance with a TRE work plan that incorporates any and all comments from the Executive Officer.
- d. The TRE shall be specific to the discharge and be prepared in accordance with current technical guidance and reference materials, including USEPA guidance materials. The TRE shall be conducted as a tiered evaluation process, such as summarized below:
 - i. Tier 1 consists of basic data collection (routine and accelerated monitoring).
 - ii. Tier 2 consists of evaluation of optimization of the treatment process, including operation practices and in-plant process chemicals.
 - iii. Tier 3 consists of a toxicity identification evaluation (TIE).
 - iv. Tier 4 consists of evaluation of options for additional effluent treatment processes.
 - v. Tier 5 consists of evaluation of options for modifications of in-plant treatment processes.
 - vi. Tier 6 consists of implementation of selected toxicity control measures, and follow-up monitoring and confirmation of implementation success.
- e. The TRE may be ended at any stage if monitoring finds there is no longer consistent toxicity (complying with requirements of Section IV.B.3 of this Order).
- f. The objective of the TIE shall be to identify the substance or combination of substances causing the observed toxicity. All reasonable efforts using currently available TIE methodologies shall be employed.
- g. As toxic substances are identified or characterized, the Discharger shall continue the TRE by determining the source(s) and evaluating alternative strategies for reducing or eliminating the substances from the discharge. All reasonable steps shall be taken to reduce toxicity to levels consistent with chronic toxicity evaluation parameters.
- h. Many recommended TRE elements parallel required or recommended efforts of source control, pollution prevention and storm water control programs. TRE efforts should be coordinated with such efforts. To prevent duplication of efforts, evidence of complying with requirements or recommended efforts of such programs may be acceptable to comply with TRE requirements.
- i. The Regional Water Board recognizes that chronic toxicity may be episodic and identification of causes of and reduction of sources of chronic toxicity may not be successful in all cases. Consideration of enforcement action by the Regional

Water Board will be based in part on the Discharger's actions and efforts to identify and control or reduce sources of consistent toxicity.

C. Use of Monitoring Data

The Discharger may use the data generated in accordance with the monitoring requirements in Sections V.A and V.B above to determine compliance with the water quality-based effluent limitations for the Sanitary Plant.

VI. LAND DISCHARGE MONITORING REQUIREMENTS

Not Applicable

VII. RECLAMATION MONITORING REQUIREMENTS

Not Applicable

VIII. RECEIVING WATER MONITORING REQUIREMENTS – SURFACE WATER AND GROUNDWATER

A. Regional Monitoring Program

The Discharger shall continue to participate in the Regional Monitoring Program, which involves collection of data on pollutants and toxicity in water, sediment and biota of the Estuary. The Discharger's participation and support of the RMP is used in consideration of the level of receiving water monitoring required by this Order.

- B.** With each annual self-monitoring report, the Discharger shall document how it complies with Receiving Water Limitations. This may include discharge characteristics (e.g. mass balance with effluent data and closest RMP station), receiving water data, or a combination of both.

IX. LEGEND FOR MRP TABLES

Types of Samples

- C-24 = composite sample, 24 hours
(includes continuous sampling, such as for flows)
C-X = composite sample, X hours
G = grab sample

Frequency of Sampling

- Cont. = Continuous

- Cont/D = Continuous monitoring & daily reporting
- H = once each hour (at about hourly intervals)
- W = once each week
- 2/Week = twice each week
- 3/Week = three times each week
- 4/Week = four times each week
- 5/Week = five times each week
- Monthly = once each month
- 2/Month = twice each month
- Q = once each calendar quarter (at about three month intervals)
- 1/Year = once each calendar year
- 2/Year = twice each calendar year (at about 6 months intervals, once during dry season, once during wet season)

Parameter and Unit Abbreviations

- BOD = Biochemical Oxygen Demand
- D.O. = Dissolved Oxygen
- Est. V = Estimated Volume (gallons)
- Metals = multiple metals; See SMP Section VI.G.
- PAHs = Polycyclic Aromatic Hydrocarbons; See SMP Section VI.H.
- TSS = Total Suspended Solids
- MGD = million gallons per day
- mg/l = milligrams per liter
- ml/l-hr = milliliters per liter, per hour
- µg/l = micrograms per liter
- µmhos/cm = micromhos per centimeter
- kg/d = kilograms per day
- kg/mo = kilograms per month
- MPN/100 ml = Most Probable Number per 100 milliliters

X. OTHER MONITORING REQUIREMENTS

A. Monitoring Location – Overflows and Bypasses (OV-1 thru OV-n)

1. The Discharger shall monitor bypasses and sewer overflows and report the estimated volume of each overflow or bypass event, the duration of the event, and the corrective action measures taken.

Table E-9. Overflows and Bypasses Monitoring Requirements

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|-------------------------|----------------|-------------|----------------------------|---------------------------------|
| Flow and Total Volume | MGD | Continuous | 1/Day | (1) |
| CBOD ₅ | mg/l; kg/day | Grab | 1/Day | (1) |
| TSS | mg/l; kg/day | Grab | 1/Day | (1) |
| Enterococci Bacteria | Colonies/100ml | Grab | 1/Day | (1) |
| Fecal Coliform Bacteria | MPN/100 ml | Grab | 1/Day | (1) |
| Total Coliform | MPN/100 ml | Grab | 1/Day | (1) |

| Parameter | Units | Sample Type | Minimum Sampling Frequency | Required Analytical Test Method |
|-----------------------|-------|-------------|----------------------------|---------------------------------|
| Standard Observations | -- | Observation | Each Occurrence | -- |

(1) Pollutants shall be analyzed using the analytical methods described in 40 CFR Part 136.

B. Sludge Monitoring

The Discharger shall adhere to sludge monitoring requirements required by 40 CFR Part 503.

XI. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.

B. Modifications to Part A of Self-Monitoring Program (Attachment G)

1. If any discrepancies exist between SMP Part A, August 1993 (**Attachment G**) and this MRP, this MRP prevails.
2. Sections C.3. and C.5 are satisfied by participation in the Regional Monitoring Program.
3. Modify Section F.4 as follows:

Self-Monitoring Reports

For each calendar month, a self-monitoring report (SMR) shall be submitted to the Regional Water Board in accordance with the requirements listed in Self-Monitoring Program, Part A. The purpose of the report is to document treatment performance, effluent quality and compliance with waste discharge requirements prescribed by this Order, as demonstrated by the monitoring program data and the Discharger's operation practices.

[And add at the end of Section F.4 the following:]

- g. If the Discharger wishes to invalidate any measurement, the letter of transmittal will include a formal request to invalidate the measurement; the original measurement in question, the reason for invalidating the measurement, all relevant documentation that supports the invalidation (e.g., laboratory sheet, log entry, test results, etc.), and discussion of the corrective actions taken or planned (with a time schedule for completion), to prevent recurrence of the sampling or

JULY 27, 2007

measurement problem. The invalidation of a measurement requires the approval of Water Board staff and will be based solely on the documentation submitted at that time.

h. Reporting Data in Electronic Format

The Discharger has the option to submit all monitoring results in an electronic reporting format approved by the Executive Officer. If the Discharger chooses to submit SMRs electronically, the following shall apply:

- 1) Reporting Method: The Discharger shall submit SMRs electronically via the process approved by the Executive Officer in a letter dated December 17, 1999, Official Implementation of Electronic Reporting System (ERS) and in the Progress Report letter dated December 17, 2000, or in a subsequently approved format that the Permit has been modified to include.
- 2) Monthly or Quarterly Reporting Requirements: For each reporting period (monthly or quarterly as specified in SMP Part B), an electronic SMR shall be submitted to the Regional Water Board in accordance with Section F.4.a-g. above. However, until USEPA approves the electronic signature or other signature technologies, Dischargers that are using the ERS must submit a hard copy of the original transmittal letter, an ERS printout of the data sheet, a violation report, and a receipt of the electronic transmittal.
- 3) Annual Reporting Requirements: Dischargers who have submitted data using the ERS for at least one calendar year are exempt from submitting an annual report electronically, but a hard copy of the annual report shall be submitted according to Section F.5 below.

C. Self Monitoring Reports (SMRs)

1. At any time during the term of this Order, the State or Regional Water Board may notify the Discharger to electronically submit Self-Monitoring Reports (SMRs) using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). Until such notification is given, the Discharger shall submit hard copy SMRs. The CIWQS Web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.
2. The Discharger shall submit monthly Self-Monitoring Reports including the results of all required monitoring using USEPA approved test methods or other test methods specified in this Order for each calendar month. Monthly SMRs shall be due on the 30th day following the end of each calendar month, covering samples collected during that calendar month; Annual Reports shall be due on February 1 following each calendar year.
3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Table E-10. Monitoring Periods and Reporting Schedule

| Sampling Frequency | Monitoring Period Begins On... | Monitoring Period |
|---------------------|--|---|
| Continuous | Day after permit effective date | All |
| Hourly | Day after permit effective date | Hourly |
| 1/Day | Day after permit effective date | Midnight through 11:59 PM or any 24-hour period that reasonably represents a calendar day for purposes of sampling. |
| X/Week | Sunday following permit effective date or on permit effective date if on a Sunday | Sunday through Saturday |
| 1/Month | First day of calendar month following permit effective date or on permit effective date if that date is first day of the month | 1 st day of calendar month through last day of calendar month |
| 1/Quarter | Closest of January 1, April 1, July 1, or October 1 following (or on) permit effective date | January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31 |
| 2/Year | Closest of January 1 or July 1 following (or on) permit effective date | January 1 through June 30 July 1 through December 31 |
| 1/Year | January 1 following (or on) permit effective date | January 1 through December 31 |
| Per Discharge Event | Anytime during the discharge event or as soon as possible after aware of the event | At a time when sampling can characterize the discharge event |

4. Reporting Protocols. The Discharger shall report with each sample result the applicable Reporting Level (RL) and the current Method Detection Limit (MDL), as determined by the procedure in 40 CFR Part 136.

The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may be shortened to "Est. Conc."). The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (\pm a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.
 - d. Dischargers are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from *extrapolation* beyond the lowest point of the calibration curve.
5. The Discharger shall submit SMRs in accordance with the following requirements:
- a. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations. The Discharger is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format within the system, the Discharger shall electronically submit the data in a tabular format as an attachment.
 - b. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the WDRs; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.
 - c. SMRs must be submitted to the Regional Water Board, signed and certified as required by the Standard Provisions (Attachment D), to the address listed below:

Executive Officer
California Regional Water Quality Control Board
San Francisco Bay Region
1515 Clay Street, Suite 1400
Oakland, CA 94612
ATTN: NPDES Wastewater Division

C. Discharge Monitoring Reports (DMRs)

1. As described in Section X.B.1 above, at any time during the term of this Order, the State or Regional Water Board may notify the Discharger to electronically submit SMRs that will satisfy federal requirements for submittal of Discharge Monitoring Reports (DMRs). Until such notification is given, the Discharger shall submit DMRs in accordance with the requirements described below.
2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Discharge shall submit the original DMR and one copy of the DMR to the address listed below:

JULY 27, 2007

| Standard Mail | FedEx/UPS/Other Private Carriers |
|--|--|
| State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000 | State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 th Floor Sacramento, CA 95814 |

3. All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated or modified cannot be accepted.

D. Other Reports

Annual Reports. By February 1st of each year, the Discharger shall submit an annual report to the Regional Water Board covering the previous calendar year. The report shall contain the items described in Standard Provisions and Reporting Requirements, and SMP Part A, August 1993 (**Attachment G**).

APPENDIX E-1 CHRONIC TOXICITY DEFINITION OF TERMS AND SCREENING PHASE REQUIREMENTS

I. Definition of Terms

- A. No observed effect level (NOEL) for compliance determination is equal to IC_{25} or EC_{25} . If the IC_{25} or EC_{25} cannot be statistically determined, the NOEL shall be equal to the NOEC derived using hypothesis testing.
- B. Effective concentration (EC) is a point estimate of the toxicant concentration that would cause an adverse effect on a quantal, "all or nothing," response (such as death, immobilization, or serious incapacitation) in a given percent of the test organisms. If the effect is death or immobility, the term lethal concentration (LC) may be used. EC values may be calculated using point estimation techniques such as probit, logit, and Spearman-Kärber. EC_{25} is the concentration of toxicant (in percent effluent) that causes a response in 25 percent of the test organisms.
- C. Inhibition concentration (IC) is a point estimate of the toxicant concentration that would cause a given percent reduction in a nonlethal, nonquantal biological measurement, such as growth. For example, an IC_{25} is the estimated concentration of toxicant that would cause a 25 percent reduction in average young per female or growth. IC values may be calculated using a linear interpolation method such as USEPA's Bootstrap Procedure.
- D. No observed effect concentration (NOEC) is the highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specific time of observation. It is determined using hypothesis testing.

II. Chronic Toxicity Screening Phase Requirements

- A. The Discharger shall perform screening phase monitoring:
 - 1. Subsequent to any significant change in the nature of the effluent discharged through changes in sources or treatment, except those changes resulting from reductions in pollutant concentrations attributable to source control efforts, or
 - 2. Prior to permit reissuance. Screening phase monitoring data shall be included in the NPDES permit application for reissuance. The information shall be as recent as possible, but may be based on screening phase monitoring conducted within 5 years before the permit expiration date.
- B. Design of the screening phase shall, at a minimum, consist of the following elements:
 - 1. Use of test species specified in **Appendix E-2**, attached, and use of the protocols referenced in those tables, or as approved by the Executive Officer.
 - 2. Two stages:

JULY 27, 2007

- a. Stage 1 shall consist of a minimum of one battery of tests conducted concurrently. Selection of the type of test species and minimum number of tests shall be based on **Appendix E-2** (attached).
 - b. Stage 2 shall consist of a minimum of two test batteries conducted at a monthly frequency using the three most sensitive species based on the Stage 1 test results and as approved by the Executive Officer.
3. Appropriate controls.
 4. Concurrent reference toxicant tests.
 5. Dilution series 100%, 50%, 25%, 10%, 5%, 0 %, where “%” is percent effluent as discharged, or as otherwise approved the Executive Officer.
- C. The Discharger shall submit a screening phase proposal acceptable to the Executive Officer. The proposal shall address each of the elements listed above. If within 30 days, the Executive Officer does not comment, the Discharge shall commence with screening phase monitoring.

**APPENDIX E-2
 SUMMARY OF TOXICITY TEST SPECIES REQUIREMENTS**

Critical Life Stage Toxicity Tests for Estuarine Waters

| Species | (Scientific Name) | Effect | Test Duration | Reference |
|---|--|--|----------------------|------------------|
| Alga | <i>(Skeletonema costatum)</i> <i>(Thalassiosira pseudonana)</i> | Growth rate | 4 days | 1 |
| Red alga | <i>(Champia parvula)</i> | Number of cystocarps | 7–9 days | 3 |
| Giant kelp | <i>(Macrocystis pyrifera)</i> | Percent germination; germ tube length | 48 hours | 2 |
| Abalone | <i>(Haliotis rufescens)</i> | Abnormal shell development | 48 hours | 2 |
| Oyster Mussel | <i>(Crassostrea gigas)</i> <i>(Mytilus edulis)</i> | Abnormal shell development; percent survival | 48 hours | 2 |
| Echinoderms - Urchins Sand dollar | <i>(Strongylocentrotus purpuratus, S. franciscanus)</i> <i>(Dendraster excentricus)</i> | Percent fertilization | 1 hour | 2 |
| Shrimp | <i>(Mysidopsis bahia)</i> | Percent survival; growth | 7 days | 3 |
| Shrimp | <i>(Holmesimysis costata)</i> | Percent survival; growth | 7 days | 2 |
| Topsmelt | <i>(Atherinops affinis)</i> | Percent survival; growth | 7 days | 2 |
| Silversides | <i>(Menidia beryllina)</i> | Larval growth rate; percent survival | 7 days | 3 |

Toxicity Test References:

1. American Society for Testing Materials (ASTM). 1990. Standard Guide for Conducting Static 96-Hour Toxicity Tests with Microalgae. Procedure E 1218-90. ASTM, Philadelphia, PA.
2. Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to West Coast Marine and Estuarine Organisms. EPA/600/R-95/136. August 1995.
3. Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to Marine and Estuarine Organisms. EPA/600/4-90/003. July 1994.

Critical Life Stage Toxicity Tests for Fresh Waters

| Species | (Scientific Name) | Effect | Test Duration | Reference |
|----------------|------------------------------------|---------------------------|----------------------|------------------|
| Fathead minnow | <i>(Pimephales promelas)</i> | Survival; growth rate | 7 days | 4 |
| Water flea | <i>(Ceriodaphnia dubia)</i> | Survival; number of young | 7 days | 4 |
| Alga | <i>(Selenastrum capricornutum)</i> | Cell division rate | 4 days | 4 |

Toxicity Test Reference:

4. Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, third edition. EPA/600/4-91/002. July 1994.

Toxicity Test Requirements for Stage One Screening Phase

| Requirements | Receiving Water Characteristics | | |
|--|-------------------------------------|--|-------------------------------------|
| | Discharges to Coast | Discharges to San Francisco Bay ^[2] | |
| | Ocean | Marine/Estuarine | Freshwater |
| Taxonomic diversity | 1 plant 1 invertebrate 1 fish | 1 plant 1 invertebrate 1 fish | 1 plant 1 invertebrate 1 fish |
| Number of tests of each salinity type: Freshwater ^[1] | 0 | 1 or 2 | 3 |
| Marine/Estuarine | 4 | 3 or 4 | 0 |
| Total number of tests | 4 | 5 | 3 |

[1] The freshwater species may be substituted with marine species if:

- (a) The salinity of the effluent is above 1 part per thousand (ppt) greater than 95 percent of the time, or
- (b) The ionic strength (TDS or conductivity) of the effluent at the test concentration used to determine compliance is documented to be toxic to the test species.

- [2] (a) Marine/Estuarine refers to receiving water salinities greater than 1 ppt at least 95 percent of the time during a normal water year.
- (b) Fresh refers to receiving water with salinities less than 1 ppt at least 95 percent of the time during a normal water year.

ATTACHMENT F – FACT SHEET

Table of Contents

| | | |
|------|---|----|
| I. | Permit Information..... | 3 |
| II. | Facility Description..... | 4 |
| | A. Description of Wastewater Treatment or Controls | 4 |
| | B. Storm Water Discharges..... | 5 |
| | C. Discharge Points and Receiving Waters..... | 7 |
| | D. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data | 7 |
| | E. Compliance Summary..... | 9 |
| | F. Planned Changes | 10 |
| III. | Applicable Plans, Policies, and Regulations | 10 |
| | A. Legal Authorities | 10 |
| | B. California Environmental Quality Act (CEQA)..... | 11 |
| | C. State and Federal Regulations, Policies, and Plans | 11 |
| | D. Impaired Water Bodies on CWA 303(d) List | 14 |
| | E. Other Plans, Policies and Regulations..... | 15 |
| IV. | Rationale For Effluent Limitations and Discharge Specifications | 16 |
| | A. Discharge Prohibitions | 17 |
| | B. Technology-Based Effluent Limitations..... | 17 |
| | 1. Scope and Authority | 17 |
| | 2. Applicable Technology-Based Effluent Limitations | 18 |
| | 3. Bacteria | 18 |
| | C. Water Quality-Based Effluent Limitations..... | 19 |
| | 1. Scope and Authority | 19 |
| | 2. Applicable Beneficial Uses and Water Quality Criteria and Objectives..... | 20 |
| | 3. Determining the Need for Water Quality Based Effluent Limits (WQBELs) | 22 |
| | 4. Water Quality Based Effluent Limitation (WQBEL) Calculations..... | 31 |
| | 6. Whole Effluent Acute Toxicity | 45 |
| | D. Interim Effluent Limitations and Compliance Schedules | 47 |
| | E. Summary of Final Effluent Limitations..... | 51 |
| | F. Land Discharge Specifications..... | 52 |
| | G. Reclamation Specifications..... | 52 |
| V. | Rationale for Receiving Water Limitations | 53 |
| | A. Surface Water | 53 |
| | B. Groundwater | 53 |
| VI. | Rationale For Monitoring And Reporting Requirements..... | 53 |
| | A. Influent Monitoring | 53 |
| | B. Effluent Monitoring..... | 54 |
| | C. Whole Effluent Toxicity Testing Requirements | 55 |
| | D. Receiving Water Monitoring..... | 55 |
| | 1. Regional Monitoring Program..... | 55 |
| | E. Other Monitoring Requirements..... | 55 |
| VII. | Rationale for Provisions | 56 |
| | A. Standard Provisions (Provision VI.A)..... | 56 |
| | B. Monitoring and Reporting Requirements (Provision VI.B)..... | 56 |
| | C. Special Provisions (Provision VI.C)..... | 56 |

| | |
|---|----|
| 1. Reopener Provisions | 56 |
| 2. Special Studies and Additional Monitoring Requirements | 56 |
| 3. Best Management Practices and Pollution Minimization Program..... | 57 |
| 4. Requirement to Assure Compliance Schedules with Final Limits | 57 |
| 5. Construction, Operation, and Maintenance Specifications | 57 |
| 6. Special Provisions for Municipal Facilities (POTWs Only)..... | 58 |
| 7. Other Special Provisions | 58 |
| VIII. Public Participation | 58 |
| A. Notification of Interested Parties | 59 |
| B. Written Comments | 59 |
| C. Public Hearing | 59 |
| D. Waste Discharge Requirements Petitions..... | 59 |
| E. Information and Copying..... | 60 |
| F. Register of Interested Persons | 60 |
| G. Additional Information | 60 |

List of Tables

| | |
|---|----|
| Table F-1. Facility Information | 3 |
| Table F-2. Outfall Location | 7 |
| Table F-3. Historic Effluent Limitations and Monitoring Data | 8 |
| Table F-4. Historic Effluent Limitations and Monitoring Data for Toxic Pollutants..... | 9 |
| Table F-5: Summary of Effluent Violations | 9 |
| Table F-6. Status of Special Activities in Provisions for Order No. R2-2002-0045 | 10 |
| Table F-7. Basin Plan Beneficial Uses | 11 |
| Table F-8. Summary of Technology-Based Effluent Limitations | 18 |
| Table F-9. Summary of Reasonable Potential Determination for the – Industrial Plant | 25 |
| Table F-10. Summary of Reasonable Potential Determination for the Sanitary Plant | 29 |
| Table F-11. Constituents with Reasonable Potential | 32 |
| Table F-12 Summary of Water Quality Criteria or Objectives for Constituents with Reasonable Potential. | 32 |
| Table F-13. Summary of WQBELs for Constituents with Reasonable Potential | 38 |
| Table F-14. Calculation of WQBELs | 40 |
| Table F-15. Newly Calculated Limits versus Previous Limits..... | 44 |
| Table F-16 Feasibility to Comply | 49 |
| Table F-17. Summary of Effluent Limitations..... | 51 |

ATTACHMENT F – FACT SHEET

As described in Section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Discharger. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

Table F-1. Facility Information

| | |
|---|--|
| WDID | 2 417033001 |
| Dischargers | City and County of San Francisco, North Bayside System Unit (NBSU) |
| Name of Facilities | San Francisco International Airport, Mel Leong Treatment Plant, Industrial Plant |
| Facility Address | 676 McDonnell Road, San Francisco, CA 94128 San Mateo County |
| Facility Contact, Title, Phone | Mark Costanzo, Utility Manager, (650) 821-7809 Mark.costanzo@flysfo.com |
| Authorized Person to Sign and Submit Reports | Ernie Eavis, Deputy Airport Director, (650) 821-7747 |
| Mailing Address | P.O. Box 8097, San Francisco, CA 94128 |
| Billing Address | Same as Mailing Address |
| Type of Facility | Industrial Wastewater Treatment Facility |
| Major or Minor Facility | Major |
| Threat to Water Quality | 1 |
| Complexity | A |
| Pretreatment Program | No |
| Reclamation Requirements | Producer and user |
| Facility Permitted Flow | 1.2 million gallons per day (MGD) |
| Facility Design Flow | 1.2 MGD (current dry weather average design flow) |
| Watershed | San Francisco Bay |
| Receiving Water | Lower San Francisco Bay |
| Receiving Water Type | Marine |

- A.** The City and County of San Francisco is the owner and operator of the San Francisco International Airport, Mel Leong Treatment Plant, Industrial Plant.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B.** The facility discharges treated wastewater into the deep-water channel of Lower San Francisco Bay, a water of the United States, and is currently regulated by Order No. R2-2002-0045 and NPDES Permit No. CA0028070, adopted on March 20, 2002.

The terms and conditions of the current Order have been automatically continued past the Order's original expiration date of February 28, 2007 and remain in effect until new Waste Discharge Requirements and NPDES permit are adopted pursuant to this Order.

- C.** The Discharger filed a Report of Waste Discharge and submitted an application for renewal of its Waste Discharge Requirements (WDRs) and NPDES permit on December 1, 2006. The Discharger submitted supplemental application on January 22, 2007.

II. FACILITY DESCRIPTION

A. Description of Wastewater Treatment or Controls

The Discharger owns and operates the San Francisco International Airport (SFIA), Mel Leong Treatment Plant. The Plant consists of an Industrial Plant and a Sanitary Plant. The Industrial Plant treats industrial wastewater from facilities at SFIA (e.g., maintenance shops, car washing), as well as first flush storm water runoff from industrial areas. The Sanitary Plant consists of a secondary wastewater treatment plant and its collection and conveyance system. It treats domestic wastewater from airplanes and facilities such as terminal restrooms, hangars, restaurants, and shops at the airport. The Industrial Plant is also occasionally used to treat sanitary wastewater when flows exceed the capacity of the Sanitary Plant or there are operational problems at the Sanitary Plant. Storm water runoff from terminals, taxiways, tarmacs, and aircraft and vehicle parking is collected in four detention ponds (the North Oxidation Pond, the South Oxidation Pond, the West Field Detention Basin, and the East Pond). The storm water runoff stored in these ponds and basins is pumped to the Industrial Plant for treatment. The detention ponds and basins and storm drain canals hold up to a total of 9.55 million gallons. When the detention basins are filled up, the collected runoff is discharged directly to San Francisco Bay through one of 11 storm water outfalls. Runoff from a few active areas at SFIA is not collected in basins and is either pumped directly to the Industrial Plant or discharged to the Bay. During the term of the previous Order, the Industrial Plant discharged an average flow of approximately 0.65 million gallons per day (MGD); the highest reported flow was 3.31 MGD, which occurred on May 9, 2005. The dry weather capacity of the Industrial Plant is 1.2 MGD.

Influent to the Industrial Plant is initially stored in an equalization tank. From the equalization tank, industrial wastewater and storm water undergo flocculation, dissolved air flotation (DAF), pH adjustment (as needed), aerobic biological treatment via trickling filter, secondary clarification, and disinfection by chlorination. The Discharger has the capability to divert up to 0.72 MGD of the effluent from chlorination to tertiary filters for on-site reclamation use for irrigation or utility water make-up.

JULY 27, 2007

After chlorination, treated wastewater is directed to a pumping station where it is combined with treated effluent from the Industrial Plant, and then discharged to the North Bayside System Unit (NBSU) South San Francisco/San Bruno Water Quality Control Plant. The NBSU is operated by a joint powers authority of the same name and is responsible for operation of certain shared transport, treatment, and disposal facilities. NBSU member organizations include Millbrae, Burlingame, South San Francisco, San Bruno, and SFIA. The plant is located at 195 Belle Air Road, South San Francisco, CA 94080. The plant manager is currently David Castagnola who may be contacted by phone at 650 829 3844.

Dechlorination takes place in the NBSU outfall before the combined effluent is discharged. Effluent from the NBSU force main discharges into the Lower San Francisco Bay, a water of the State and United States, northeast of Point San Bruno through a submerged diffuser approximately 5,300 feet offshore at a depth of 20 feet below mean lower low water (latitude 37° , 39' , 55" North and longitude 122° , 21' , 41" West).

For purposes of this Order, two Discharge Points are defined for effluent from the Industrial Plant. Discharge Point 001 represents treated effluent from the Mel Leong Industrial Treatment Plant. As described further in the Monitoring and Reporting Program (Attachment E), two different monitoring locations have been established for Discharge Point 001. Monitoring Location EFF-001-Ind is used to collect samples from the Industrial Plant. This treated waste water is then combined with the treated waste water from the Sanitary Plant and samples of the combined flow collected at monitoring location EFF-001A. Samples from this location represents the total wastewater discharge from the Mel Leong Treatment Plant prior to discharge into the NBSU. Samples are also collected from Discharge Point 002, which is a point in the NBSU after dechlorination.

B. Storm Water Discharges

1. Regulation. Federal Regulations for storm water discharges were promulgated by the USEPA on November 19, 1990. The regulations [40 CFR Parts 122, 123, and 124] require specific categories of industrial activity to obtain an NPDES permit and to implement Best Available Technology Economically Available (BAT) and Best Conventional Pollutant Control Technology (BCT) to control pollutants in industrial storm water discharges.

2. Storm Water Discharges. Based on the Discharger's request for coverage under an individual NPDES permit for storm water discharges, this Order addresses all discharges of storm water associated with industrial and construction activity in addition to the discharge from the Industrial Plant. In addition, all storm water discharges associated with industrial activity at the Airport are also currently covered by the statewide General Order. Storm water discharges associated with construction activity at the Airport are currently covered under a separate State general Order, CAS000002. Several tenant areas at the Airport (including but not limited to the United Maintenance Facility and Fuel Tank Farm) have their own storm water discharges and are separately covered under CAS000001. These discharges are not addressed by this Order.

The Discharger has jurisdiction over and/or maintenance responsibility for the storm drain systems at SFIA. Discharges into the system consist of the surface runoff associated with

various activities conducted by the Discharger and/or its tenants. Tenant conduct is governed by contract, permits, Airport Rules and Regulations, and the Tenant Improvement Guide. Storm water from tarmac areas at SFIA in exceedence of the detention basin capacity is discharged directly to the Bay via Discharge Points E003 through E013. Industrial activities at SFIA include aircraft, vehicle, and equipment fueling, maintenance, and washing, and very limited aircraft de-icing. Descriptions of each of Discharge Points E003 through E013 include:

- a. **Discharge Point E003.** Consists of storm water runoff (as well as Bay water infiltration) that exceeds the capacity of the 0.84 million gallon South Detention Pond. The South Detention Pond receives runoff from the United Airlines cargo and surface facilities, Boarding Areas A through F, and TWA service areas. Discharge Point E003 also receives runoff from runway areas along the southeast corner of the property that do not drain to the South Detention Pond and discharge directly through the discharge point. Discharge Point E003 discharges to San Francisco Bay.
- b. **Discharge Point E004.** Consists of storm water runoff (as well as Bay water infiltration) that exceeds the capacity of the 6.0 million gallon West Field Detention Basin, the 0.3 million gallon East Detention Basin, and the 0.77 million gallon United Airlines Detention Basin. These ponds collect runoff from activities/facilities along the northwest side of the terminal as well as portions of the United Airlines Maintenance Facility. The discharge point also receives runoff directly from the United States Coast Guard Facility. Discharge Point E004 discharges to the Seaplane Harbor, which flows into San Francisco Bay.
- c. **Discharge Point E005.** Consists of storm water runoff (as well as Bay water infiltration) from runway and taxiway areas south of Runway 28L. No aircraft, vehicle, or equipment fueling, maintenance, or washing occurs in this area. Runoff is not collected in a detention pond and is discharged directly into San Francisco Bay.
- d. **Discharge Point E006.** Consists of storm water runoff (as well as Bay water infiltration) from the area north of Runway 28R. No aircraft, vehicle, or equipment fueling, maintenance, or washing occurs in this area. Runoff is not collected in a detention pond and is discharged directly into San Francisco Bay.
- e. **Discharge Point E007.** Consists of storm water runoff (as well as Bay water infiltration) from the area northwest of Runway 19R. No aircraft, vehicle, or equipment fueling, maintenance, or washing occurs in this area. Runoff is not collected in a detention pond and is discharged directly into San Francisco Bay.
- f. **Discharge Point E008.** Consists of storm water runoff (as well as Bay water infiltration) from the taxiway, ramp, and roof areas of the eastern section of the Superbay Hangar area. Runoff is not collected in a detention pond; however, some runoff and infiltration is pumped from this area to the Industrial Plant. Otherwise, runoff is discharged directly into San Francisco Bay.

- g. Discharge Point E009.** Consists of storm water runoff (as well as Bay water infiltration) from the taxiway, ramp, and roof areas of the western section of the Superbay Hangar area. Runoff is not collected in a detention pond and is discharged directly into San Francisco Bay.
- h. Discharge Point E010.** Consists of storm water runoff (as well as Bay water infiltration) from the western area of the North Cargo Facility and areas around the North Access Road. Runoff is not collected in a detention pond and flows via gravity through storm drains into San Francisco Bay.
- i. Discharge Point E013.** Consists of storm water runoff from taxiways and ramps around the North Cargo Facility that exceeds the capacity of the 0.425 million gallon North Field Detention Basin. Discharge Point E013 discharges into San Francisco Bay.

C. Discharge Points and Receiving Waters

The location of the NBSU outfall and its receiving water are shown in Table F-2 below.

Table F-2. Outfall Location

| Discharge Point | Effluent Description | Discharge Point Latitude | Discharge Point Longitude | Receiving Water |
|-----------------|---|--------------------------|---------------------------|--|
| 002 | Treated Industrial Wastewater and Storm Water | 37° 39' 55" N | 122° 21' 41" W | Lower San Francisco Bay, via Discharge through the North Bayside System Unit |

Lower San Francisco Bay is located in the South Bay Basin watershed management area, between the Dumbarton Bridge and the San Francisco-Oakland Bay Bridge. The locations of Stormwater outfalls E-003 through E-010 and E-013 are shown on the map included in Appendix C to the Order.

D. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data

Effluent limitations contained in the previous Order (Order No. R2-2002-0045) for discharges to the NBSU and Lower San Francisco Bay and representative monitoring data from the term of the previous Order are as follows:

Table F-3. Historic Effluent Limitations and Monitoring Data

| Parameter | (units) | Effluent Limitations | | | Monitoring Data (From 3/02 – 7/06) | | |
|--|------------|----------------------|----------------|---------------|---------------------------------------|------------------------|-------------------------|
| | | Monthly Average | Weekly Average | Daily Maximum | Highest Monthly Average | Highest Weekly Average | Highest Daily Discharge |
| Biochemical Oxygen Demand (5-day @ 20°C) (BOD ₅) | mg/l | 30 | 45 | -- | 34 | 83 | 140 |
| BOD ₅ | % Removal | 85 | -- | -- | 55 ⁽¹⁾ | -- | -- |
| Total Suspended Solids (TSS) | mg/l | 30 | 45 | -- | 8.5 | 15 | 22 |
| TSS | % Removal | 85 | -- | -- | 82 | -- | -- |
| Oil and Grease | mg/l | 10 | -- | 20 | 11 | -- | 11 |
| Settleable Matter | ml/l-hr | 0.1 | -- | 0.2 | 0 | -- | 0 |
| Total Residual Chlorine (TRC) | mg/l | -- | -- | (2) | -- | -- | NA |
| pH | s.u. | (3) | (3) | (3) | 6.1-8.7 | | |
| Fecal Coliform Bacteria | MPN/100 ml | -- | (4) | (5) | -- | | |
| Acute Toxicity | % Survival | (6) | (7) | -- | 90 | 70 | -- |
| Chronic Toxicity | TUc | (8) | -- | -- | 6.7 | -- | -- |

ND = Non-Detect

NR = Not Reported

NA = Not Applicable

(1) Minimum monthly removal.

(2) For TRC, 0.0 mg/l was established as an instantaneous maximum effluent limitation.

(3) The pH shall not exceed 9.0 nor be less than 6.0.

(4) The 5-day log mean fecal coliform density shall not exceed 200 MPN/100 ml.

(5) The 90th percentile value of the last ten values shall not exceed 400 MPN/100 ml.

(6) An 11-sample median value of not less than 90 percent survival

(7) An 11-sample 90th percentile value of not less than 70 percent survival.

(8) A chronic toxicity effluent limit was not included in Order No. R2-2002-0045. An accelerated monitoring trigger was included after exceeding a three sample median value of 10 chronic toxicity (TUc) or a single sample maximum of 20 TUc or greater.

Table F-4. Historic Effluent Limitations and Monitoring Data for Toxic Pollutants

| Parameter | Units | Water Quality-Based Effluent Limitations (WQBELs) | | Interim Limitations | | Monitoring Data (From 3/02 to 7/06) ⁽¹⁾ |
|----------------------------|----------|---|-----------------|---------------------|-----------------|--|
| | | Daily Maximum | Monthly Average | Daily Average | Monthly Average | Highest Daily Discharge |
| Priority Pollutants | | | | | | |
| Copper | µg/l | -- | -- | 17 | -- | 25 |
| Mercury | µg/l | -- | -- | 1.0 | 0.087 | 0.034 |
| Mercury | kg/month | -- | -- | -- | 0.026 | 0.025 |
| Nickel | µg/l | 70 | 30 | -- | -- | 30 ⁽²⁾ |
| Bromoform | µg/l | 7,200 | 3,600 | -- | -- | 85 |
| Dieldrin | µg/l | 0.00028 | 0.00014 | -- | -- | ND |
| 4,4-DDE | µg/l | 0.00119 | 0.00059 | -- | -- | ND |
| Beta-BHC | µg/l | -- | -- | 0.190 | -- | 0.039 |

(1) Only one data point was collected for each month, so each value represents both the highest monthly average and the highest daily discharge.

(2) Value reported as detected, but not quantified (DNQ).

E. Compliance Summary

1. Compliance with Numeric Effluent Limitations. From March 20, 2002 through July 2006, the Discharger violated effluent limitations contained in Order No. R2-2002-0045 on five occasions, as shown in Table F-5 below:

Table F-5: Summary of Effluent Violations

| Date of Violation | Effluent Limitation Described | Effluent Limit | Reported Value |
|-------------------|---|----------------|----------------|
| 3/31/2002 | BOD ₅ , Monthly Removal | 85% Removal | 81% Removal |
| 4/30/2002 | BOD ₅ , Monthly Removal | 85% Removal | 78% Removal |
| 9/30/2003 | Oil and Grease, Monthly Average | 10 mg/l | 11.3 mg/l |
| 12/6/2004 | Copper | 17 µg/l | 24.5 µg/l |
| 1/31/2005 | Total Suspended Solids, Monthly Removal | 85% Removal | 82% Removal |

Enforcement Order R2-2002-0075 imposed Mandatory Minimum Penalties for violations incurred up until March 31, 2002. Enforcement actions for subsequent violations are pending.

3. Compliance with Permit Provisions. A list of special activities required in the provisions for Order No. R2-2002-0045, and the status of completion, is shown in the table below:

Table F-6. Status of Special Activities in Provisions for Order No. R2-2002-0045

| Provision No. | Description of Activity | Status of Completion |
|----------------------|--|-----------------------------|
| E-2 | Cyanide Study and Schedule for Site-Specific Objective | Submitted January 24, 2006 |
| E-3 | Pollutant Prevention and Minimization Program (PMP) | Submitted June 2, 2005 |
| E-6 | Effluent Characterization – Final Report | Submitted July 31, 2006 |
| E-7 | Ambient Background Receiving Water Study | Submitted February 11, 2005 |
| E-8 | Regional Monitoring Program Participation | Submitted May 1, 2006 |
| E-9 | Update, maintain, and implement a SWPPP | Submitted October 18, 2006 |
| E-10 | Metals and Mercury Study | Submitted May 28, 2003 |
| E-11 | Develop and implement an industrial storm water monitoring program | Submitted October 18, 2006 |
| E-12 | Annual Status Report – dischargers activities during the previous fiscal year | Submitted June 28, 2005 |
| E-18 | Annual Status Reports – Wastewater Facilities, Review and Evaluation; Operations and Maintenance Manual, Review; Contingency Plan, Review (Provisions E.15 through E.17) | Submitted June 30, 2006 |
| E-19 | 303(d)-listed Pollutants Site-Specific Objective and TMDL Status Review | Submitted January 31, 2006 |

F. Planned Changes

Not Applicable

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in the proposed Order are based on the requirements and authorities described in this section.

A. Legal Authorities

This Order is issued pursuant to CWA section 402 and implementing regulations adopted by the USEPA and Chapter 5.5, Division 7 of the California Water Code (CWC) (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from this facility to surface waters. This Order also serves as WDRs pursuant to CWC Article 4, Chapter 4, Division 7 (commencing with section 13260).

B. California Environmental Quality Act (CEQA)

Under CWC section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA.

C. State and Federal Regulations, Policies, and Plans

1. Water Quality Control Plans. The Water Quality Control Plan for the San Francisco Bay Basin (Basin Plan) is the Board's master water quality control planning document. It designates beneficial uses and water quality objectives for waters of the State, including surface waters and groundwater. It also includes programs of implementation to achieve water quality objectives. The Basin Plan was duly adopted by the Water Board and approved by the State Water Resources Control Board, Office of Administrative Law and the U.S. EPA, where required.

Beneficial uses applicable to Lower San Francisco Bay are as follows:

Table F-7. Basin Plan Beneficial Uses

| Discharge Point | Receiving Water Name | Beneficial Use(s) |
|-----------------------|-------------------------|---|
| 002 through 010 & 013 | Lower San Francisco Bay | Industrial Service Supply (IND) Navigation (NAV) Water Contact Recreation (REC1) Non-Contact Water Recreation (REC2) Ocean Commercial and Sport Fishing (COMM) Wildlife Habitat (WILD) Preservation of Rare and Endangered Species (RARE) Fish Migration (MIGR) Shellfish Harvesting (SHELL) Estuarine Habitat (EST) |

The Basin Plan implements State Water Board Resolution No. 88-63, which establishes State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply (MUN). Because of the marine influence on receiving waters of the San Francisco Bay, total dissolved solids levels in the Bay commonly (and often significantly) exceed 3,000 mg/l and thereby meet an exception to State Water Board Resolution No. 88-63. Therefore, the designation MUN will not be applicable to Lower San Francisco Bay.

Requirements of this Order implement the Basin Plan.

2. Thermal Plan. The State Water Board adopted a *Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California* (Thermal Plan) on May 18, 1972, and amended this plan on September 18, 1975. This plan contains WQOs for coastal and interstate surface waters as well as enclosed bays and estuaries. Requirements of this Order implement the Thermal Plan.

- 3. National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, which was amended on May 4, 1995, and November 9, 1999. About 40 water quality criteria (WQC) in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants.
- 4. State Implementation Policy.** On March 2, 2000, State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- 5. Compliance Schedules and Interim Requirements.** Section 2.1 of the SIP provides that, based on a Discharger's request and demonstration that it is infeasible for an existing Discharger to achieve immediate compliance with an effluent limitation derived from a CTR criterion, compliance schedules may be allowed in an NPDES permit. Unless an exception has been granted under section 5.3 of the SIP, a compliance schedule may not exceed 5 years from the date that the permit is issued or reissued, nor may it extend beyond 10 years from the effective date of the SIP (or May 18, 2010). Where a compliance schedule for a final effluent limitation exceeds one year, a permit must include interim numeric limitations for that constituent or parameter. Where allowed by the Basin Plan, compliance schedules and interim effluent limitations or discharge specifications may also be granted to allow time to implement a new or revised water quality objective. This Order includes compliance schedules and interim effluent limitations.
- 6. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes [40 CFR §131.21, 65 Fed. Reg. 24641 (April 27, 2000)]. Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
- 7. Stringency of Requirements for Individual Pollutants.** This Order contains restrictions on individual pollutants that are no more stringent than required by the federal CWA. Individual pollutant restrictions consist of technology-based restrictions and water quality-based effluent limitations. The technology-based effluent limitations

JULY 27, 2007

consist of restrictions on 5-day biochemical oxygen demand (BOD₅), total suspended solids (TSS), pH, oil and grease, and chlorine residual. Water quality-based effluent limitations have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant water quality-based effluent limitations were derived from the CTR, the CTR is the applicable standard pursuant to section 131.38. The scientific procedures for calculating the individual water quality-based effluent limitations are based on the CTR-SIP, which was approved by USEPA on May 18, 2000. All beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to section 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the technology-based requirements of the CWA and the applicable water quality standards for purposes of the CWA.

- 8. Antidegradation Policy.** NPDES regulations at 40 CFR 131.12 required that State water quality standards include an antidegradation policy consistent with the Federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution 68-16, which incorporates the requirements of the Federal antidegradation policy. Resolution 68-16 requires that existing water quality is maintained unless degradation is justified based on specific findings.

The permitted discharge is consistent with the antidegradation provision of 40 CFR §131.12 and State Water Board Resolution 68-16. This Order does not allow for a reduction in the level of treatment. The final limitations in this Order comply with antidegradation requirements because they hold the Discharger to performance levels that will not cause or contribute to water quality impairment or further quality degradation that could result from a reduction in the level of treatment.

For copper, nickel and beta-BHC, the effluent limits are higher than those in the previous permit, but these limits apply to a different compliance point that is used to sample effluent after it has been combined with effluent from the Sanitary Plant. Effluent at this new compliance point is different than effluent at the compliance point in the previous permit; therefore, the limits are not directly comparable. The previous interim limits for these pollutants were based on very limited data. The concentrations of copper, nickel, and beta-BHC are unlikely to change because the Discharger proposes no changes to its treatment process. It would not be able to specifically alter effluent copper, nickel and beta-BHC levels without affecting other constituents with effluent limits. Thus the revised limits for copper, nickel and beta-BHC will not degrade water quality because the level of treatment provided by the plant will not be reduced.

In the case of copper, alternate limits based on site-specific objectives will be higher than the current interim limit if the site-specific objectives for copper become effective during the permit term. However, the standards setting process for copper

JULY 27, 2007

addressed antidegradation and therefore an analysis in this permit is unnecessary. As such there will be no lowering of water quality beyond the current level authorized in the previous permit, which is the baseline by which to measure whether degradation will occur. Moreover, this Order requires implementation of action plans for copper if and when the alternate limits become effective. This measure will maintain existing water quality.

For cyanide, the effluent limits are new. The previous permit did not contain cyanide effluent limits. The new limits will not degrade water quality because the permitted flow will remain unchanged and the level of treatment provided by the plant will not be reduced. The new limits are equivalent to those anticipated in the antidegradation analysis section of the Staff Report supporting the cyanide site-specific objectives. Documentation completed for the standards setting process for cyanide addressed antidegradation. That analysis concluded that these new limits would not likely result in degradation and that any increase would not have a measurable impact on ambient cyanide levels in the Bay. Since the limits anticipated with the site-specific objectives would not degrade the quality of the receiving water, neither will the increased limits in this permit. As such, there will be no lowering of water quality beyond the current level authorized in the previous permit, which is the baseline by which to measure whether degradation will occur. Moreover, this Order requires implementation of action plans for cyanide source identification and pollution prevention. These measures will further ensure that existing water quality is maintained or improved.

The Order continues the status quo with respect to the level of discharge authorized in the previous permit and thus there will be no change in water quality beyond the level that was authorized in the last permit. Findings authorizing degradation are thus unnecessary.

9. **Anti-Backsliding Requirements.** CWA Sections 402(o)(2) and 303(d)(4) and NPDES regulations at 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous Order, with some exceptions in which limitations may be relaxed. All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order.

D. Impaired Water Bodies on CWA 303(d) List

On June 6, 2003, the USEPA approved a revised list of impaired water bodies prepared by the State (hereinafter referred to as the 303(d) list), prepared pursuant to provisions of CWA section 303(d), which requires identification of specific water bodies where it is expected that water quality standards will not be met after implementation of technology-based effluent limitations on point sources. Lower San Francisco Bay is listed as an impaired waterbody. The pollutants impairing Lower San Francisco Bay include chlordane, DDT, diazinon, dieldrin, dioxin compounds, exotic species, furan compounds, mercury, nickel, PCBs, and dioxin-like PCBs. South San Francisco Bay is

also listed as an impaired waterbody for all the same pollutants impairing Lower San Francisco Bay and selenium. The SIP requires final effluent limitations for all 303(d)-listed pollutants to be consistent with total maximum daily loads (TMDLs) and associated waste load allocations.

1. Total Maximum Daily Loads

The Regional Water Board plans to adopt TMDLs for pollutants on the 303(d) list in Lower San Francisco Bay within the next 10 years. Future review of the 303(d) list for Lower San Francisco Bay may provide schedules or result in revision of the schedules for adoption of TMDLs.

2. Waste Load Allocations

The TMDLs will establish waste load allocations (WLAs) for point sources and load allocations (LAs) for non-point sources, and will result in achieving the water quality standards for the waterbodies. Final water quality-based effluent limitations (WQBELs) for 303(d) listed pollutants in this discharge will be based on WLAs contained in the respective TMDLs.

3. Implementation Strategy

The Regional Water Board's strategy to collect water quality data and to develop TMDLs is summarized below:

- a. Data Collection.** The Regional Water Board has given dischargers to the Bay the option to collectively assist in developing and implementing analytical techniques capable of detecting 303(d)-listed pollutants to at least their respective levels of concern or water quality objectives (WQOs)/water quality criteria (WQC). This collective effort may include development of sample concentration techniques for approval by the USEPA. The Regional Water Board will require dischargers to characterize the pollutant loads from their facilities into the water-quality limited waterbodies. The results will be used in the development of TMDLs, and may be used to update or revise the 303(d) list or change the WQOs/WQC for the impaired waterbodies including Lower San Francisco Bay.
- b. Funding Mechanism.** The Regional Water Board has received, and anticipates continuing to receive, resources from federal and State agencies for TMDL development. To ensure timely development of TMDLs, the Regional Water Board intends to supplement these resources by allocating development costs among dischargers through the Regional Monitoring Program or other appropriate funding mechanisms.

E. Other Plans, Policies and Regulations

This Order is also based on the following plans, policies, and regulations:

JULY 27, 2007

1. The Federal *Water Pollution Control Act*, Sections 301 through 305, and 307, and amendments thereto, as applicable (CWA);
2. The State Water Board's March 2, 2000 *Policy for the USEPA's May 18, 2000 Water Quality Standards; Establishment of Numeric Criteria for Priority Toxic Pollutants for the State of California* or CTR, 40 CFR §131.38(b) and amendments.
3. The USEPA's *Quality Criteria for Water* [EPA 440/5-86-001, 1986] and subsequent amendments (the USEPA Gold Book);
4. Applicable Federal Regulations [40 CFR §§122 and 131];
5. 40 CFR §131.36(b) and amendments [Federal Register Volume 60, Number 86, 4 May 1995, pages 22229-22237];
6. USEPA's December 10, 1998 National Recommended Water Quality Criteria compilation [Federal Register Vol. 63, No. 237, pp. 68354-68364];
7. USEPA's December 27, 2002 Revision of National Recommended Water Quality Criteria compilation [Federal Register Vol. 67, No. 249, pp. 79091-79095]; and
8. Guidance provided with State Water Board Orders remanding permits to the Regional Water Board for further consideration.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in the NPDES regulations: 40 CFR 122.44(a) requires that permits include applicable technology-based limitations and standards; and 40 CFR 122.44(d) requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBELs may be established: (1) using USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) on an indicator parameter for the pollutant of concern; or (3) using a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in 40 CFR 122.44(d)(1)(vi).

Several specific factors affecting the development of limitations and requirements in this Order are discussed as follows:

A. Discharge Prohibitions

- 1. Discharge Prohibition III.A. (no discharge other than that described in this Order):** This prohibition is the same as in the previous permit. This prohibition is based on California Water Code section 13260, which requires filing a Report of Waste Discharge before discharges can occur. Discharges not described in the Report of Waste Discharge, and subsequently in the Order, are prohibited.
- 2. Discharge Prohibition III.B. (no discharges receiving less than 10:1 dilution):** This prohibition is the same as the previous permit and is based on Discharge Prohibition No. 1 from Table 4-1 of the Basin Plan, which prohibits discharges that do not receive a minimum 10:1 initial dilution. Furthermore, this Order allows a 10:1 dilution credit in the calculation of some water quality based effluent limitations, and these limitations would not be protective of water quality if the discharge did not actually achieve a 10:1 minimum initial dilution.
- 3. Discharge Prohibition III.C. (no bypasses except under the conditions at 40 CFR 122.41(m)(4)(i)(A), (B) and (C)):** This prohibition is based on 40 CFR 122.41(m)(4).
- 4. Discharge Prohibition III.D. (no discharges of non-stormwater materials into storm drains):** This prohibition is based on the California Water Code section 13260 that requires filing of a report of waste discharge before a permit to discharge can be granted and the discharge commences. The Discharger's application addresses only those discharges addressed in this permit, thus another discharge would not be permitted and must be prohibited.

B. Technology-Based Effluent Limitations

1. Scope and Authority

This Order retains the technology based limits from the previous permit for BOD₅, TSS, oil and grease, and pH. These limits are based on best professional judgment (BPJ) pursuant to 40 CFR §125.3, and meet requirements for best practicable control technology currently available (BPT) and best conventional pollutant control technology (BCT). In setting these limits, the Water Board considered the factors specified in 40 CFR §125.3(d). Existing control equipment and facilities are practicable and capable of meeting the limits. The cost of complying with these limits is reasonable given that the Discharger can comply without modifying its existing operations. No process changes are necessary; therefore, no non-water quality impacts are foreseeable. The limits are similar to those for secondary treatment of municipal wastewater; therefore, the cost is comparable to those for a comparable publicly owned treatment works.

2. Applicable Technology-Based Effluent Limitations

The Order is retaining the following technology based effluent limitations, as shown in Table F-8, applicable to Discharge Point 001, from Order No. R2-2002-0045.

Table F-8. Summary of Technology-Based Effluent Limitations

| Parameter | Units | Effluent Limitations | | | | |
|------------------|-------|----------------------|----------------|---------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| BOD ₅ | mg/l | 30 | 45 | -- | -- | -- |
| TSS | mg/l | 30 | 45 | -- | -- | -- |
| Oil and Grease | mg/l | 10 | -- | 20 | -- | -- |
| pH | s.u. | -- | -- | -- | 6.0 | 9.0 |

In addition to the numeric effluent limitations for BOD₅, and TSS, the 30-day average percent removal shall not be less than 85 percent. Because the Industrial Plant treats predominantly non-sanitary wastewaters, including at times the captured first flush of stormwater runoff, very low concentrations of BOD₅ would be expected in the influent, making compliance with the percent removal difficult. Therefore, this Order retains the condition from the previous Order that stipulates that the arithmetic mean of only those samples with a BOD₅ influent concentration of greater than 45 mg/l be used to determine compliance with the monthly 85 percent removal requirement for BOD₅.

The limitations established for oil and grease are levels attainable by secondary treatment and are required by the Basin Plan (Table 4-2) for all discharges to inland surface waters and enclosed bays and estuaries of the Region.

The pH limitation is retained from the previous Order and is required by USEPA's Secondary Treatment Regulation at 40 CFR Part 133 and by the Basin Plan (Table 4-2) for deep water discharges.

The technology-based effluent limitations for settleable matter are not retained from Order No. R2-2002-0045, as the Regional Water Board has determined that compliance with the Secondary Treatment Regulation at 40 CFR Part 133 and with the Basin Plan (Table 4-2) requirements for all discharges to inland surface waters and enclosed bays and estuaries of the Region will assure removal of settleable solids to acceptably low levels – below 0.1 ml/l/hr (30-day average) and 0.2 ml/l/hr (daily maximum).

3. Bacteria

The Basin Plan, Table 4.2, establishes effluent limitations for total coliform bacteria for all discharges from sewage treatment facilities to inland surface waters and enclosed bays and estuaries of the Region. Fecal coliform limitations may be substituted for the limitations of the Basin Plan “provided it can be conclusively demonstrated through a program approved by the Regional Water Board that such substitution will not result in unacceptable adverse impacts on the beneficial uses of

the receiving water.” Following receiving water impact monitoring studies conducted since 1992, the Regional Water Board amended the Discharger’s NPDES permit with Order No. 98-117.

Order No. 98-117 amended Waste Discharge Requirements for permittees discharging treated effluent through the NBSU, to allow fecal coliform limitations to be substituted for total coliform limitations. The finding relied on previous studies, including the City of San Mateo and SBSA’s 1997 fecal coliform studies that showed no relationship between dischargers’ effluent fecal coliform concentrations and the shoreline concentrations. No impact from these two outfalls on the south Foster City shellfish harvesting beds was found. The San Mateo outfall is $\frac{3}{4}$ mile from the shellfish harvesting beds and the SBSA outfall is approximately two miles away. Since the NBSU outfall is 6.5 miles from the shellfish harvesting beds so it is even less likely to impact shellfish harvesting. Order No. 98-117 identified that there is, however, water contact recreation (board surfing) in the vicinity of the NBSU outfall, and thus effluent limits are set to meet water contact recreation objectives. These are a 5-day geometric mean fecal coliform effluent limitation of 200 MPN/100ml and a 90th percentile fecal coliform effluent limitation of 400 MPN/100ml.

Enterococci bacteria are more closely associated with gastrointestinal disease than fecal coliform bacteria for water contact. Pursuant to the BEACH Act of 2000, USEPA has promulgated enterococci bacteria criteria for water contact recreation in coastal waters that apply to this discharge. The limit for enterococci bacteria established by this Order (geometric mean not to exceed 35 colonies per 100 milliliters) is based on water quality criteria established by the USEPA at 40 CFR 131.41 for coastal recreation waters, including coastal estuaries, in California. These water quality criteria became effective on December 16, 2004. [69 Fed Reg. 67218 (November 16, 2004)].

Although USEPA also established single sample maximum criteria for enterococci bacteria, this Order implements only the geometric mean criterion of 35 colonies per 100 milliliters as an effluent limitation. When these water quality criteria were promulgated, USEPA expected that the single sample maximum values would be used for making beach notification and beach closure decisions. “Other than in the beach notification and closure decision context, the geometric mean is the more relevant value for assuring that appropriate actions are taken to protect and improve water quality because it is a more reliable measure, being less subject to random variation” [69 Fed Reg. 67224 (November 16, 2004)]

C. Water Quality-Based Effluent Limitations

1. Scope and Authority

- a. NPDES regulations at 40 CFR 122.44(d)(1)(i) require permits to include WQBELs for pollutants (including toxicity) that are or may be discharged at levels that cause, have reasonable potential to cause, or contribute to an excursion

above any state water quality standard (Reasonable Potential). The process for determining Reasonable Potential and calculating WQBELs, when necessary, is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable water quality objectives and criteria that are contained in the CTR, NTR, Basin Plan, other State plans and policies.

- b. NPDES regulations and the SIP provide the basis to establish maximum daily effluent limitations (MDELs).
 - 1) **NPDES Regulations.** NPDES regulations at 40 CFR 122.45(d) state: “For continuous discharges all permit effluent limitations, standards, and prohibitions, including those necessary to achieve water quality standards, shall *unless impracticable* be stated as maximum daily and average monthly discharge limitations for all discharges other than publicly owned treatment works.”
 - 2) **SIP.** The SIP (page 8, Section 1.4) requires WQBELs be expressed as MDELs and average monthly effluent limitations (AMELs).
- c. MDELs are used in this Order to protect against acute water quality effects. The MDELs are necessary for preventing fish kills or mortality to aquatic organisms.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

The WQOs and WQC applicable to the receiving waters for this discharge are from the Basin Plan; the CTR, established by USEPA at 40 CFR 131.38; and the NTR, established by USEPA at 40 CFR 131.36. Some pollutants have WQC/WQOs established by more than one of these three sources.

- a. **Basin Plan.** The Basin Plan specifies numeric WQOs for 10 priority toxic pollutants, as well as narrative WQOs for toxicity and bioaccumulation in order to protect beneficial uses. The pollutants for which the Basin Plan specifies numeric objectives are arsenic, cadmium, chromium (VI), copper in freshwater, lead, mercury, nickel, silver, zinc, and cyanide. The narrative toxicity objective states in part that “[a]ll waters shall be maintained free of toxic substances in concentrations that are lethal to or that produce other detrimental responses in aquatic organisms.” The bioaccumulation objective states in part that “[c]ontrollable water quality factors shall not cause a detrimental increase in concentrations of toxic substances found in bottom sediments or aquatic life. Effects on aquatic organisms, wildlife, and human health will be considered.” Effluent limitations and provisions contained in this Order are designed, based on available information, to implement these objectives.
- b. **CTR.** The CTR specifies numeric aquatic life criteria for 23 priority toxic pollutants and numeric human health criteria for 57 priority toxic pollutants. These criteria apply to all inland surface waters and enclosed bays and estuaries of the San Francisco Bay Region, although Tables 3-3 and 3-4 of the Basin Plan include numeric objectives for certain of these priority toxic pollutants, which

JULY 27, 2007

supersede criteria of the CTR (except in the South Bay south of the Dumbarton Bridge).

- c. **NTR.** The NTR establishes numeric aquatic life criteria for selenium, numeric aquatic life and human health criteria for cyanide, and numeric human health criteria for 34 toxic organic pollutants for waters of San Francisco Bay upstream to, and including Suisun Bay and the Delta. These criteria of the NTR are applicable to Lower San Francisco Bay, the receiving water for this Discharger.

d. **Technical Support Document for Water Quality-Based Toxics Controls.**

Where numeric objectives have not been established or updated in the Basin Plan, NPDES regulations at 40 CFR 122.44 (d) require that WQBELs be established based on USEPA criteria, supplemented where necessary by other relevant information, to attain and maintain narrative WQOs to fully protect designated beneficial uses.

To determine the need for and establish WQBELs, when necessary, the Regional Water Board staff has followed the requirements of applicable NPDES regulations, including 40 CFR Parts 122 and 131, as well as guidance and requirements established by the Basin Plan; USEPA's *Technical Support Document for Water Quality-Based Toxics Control* (the TSD, EPA/505/2-90-001, 1991); and the State Water Board's *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (the SIP, 2005).

- e. **Basin Plan Receiving Water Salinity Policy.** The Basin Plan (like the CTR and the NTR) states that the salinity characteristics (i.e., freshwater vs. saltwater) of the receiving water shall be considered in determining the applicable WQC. Freshwater criteria shall apply to discharges to waters with salinities equal to or less than 1 part per thousand (ppt) at least 95 percent of the time. Saltwater criteria shall apply to discharges to waters with salinities equal to or greater than 10 ppt at least 95 percent of the time in a normal water year. For discharges to water with salinities in between these two categories, or tidally influenced freshwaters that support estuarine beneficial uses, the criteria shall be the lower of the salt or freshwater criteria (the latter calculated based on ambient hardness) for each substance.

The receiving water for this discharger, Lower San Francisco Bay, is a salt water environment based on salinity data generated through the San Francisco Estuary Institute's Regional Monitoring Program (RMP) at the Redwood Creek (BA40) and San Bruno Shoal (BB15) sampling stations between 1993 and 2001. In that period, the receiving water's minimum salinity was 11 ppt, its maximum salinity was 31 ppt, and its average salinity was 23 ppt. As salinity was greater than 10 ppt in 100 percent of receiving water samples, the saltwater criteria from the Basin Plan, NTR, and CTR are applicable to this discharge.

- f. **Site-Specific Metals Translators.** Because NPDES regulations at 40 CFR 122.45(c) require effluent limitations for metals to be expressed as total

recoverable metal, and applicable water quality criteria for the metals are typically expressed as dissolved metal, factors or translators must be used to convert metals concentrations from dissolved to total recoverable and vice versa.

In the CTR, USEPA establishes default translators which are used in NPDES permitting activities; however, site-specific conditions such as water temperature, pH, suspended solids, and organic carbon greatly impact the form of metal (dissolved, filterable, or otherwise) which is present and therefore available in the water to cause toxicity. In general, the dissolved form of metals is more available and more toxic to aquatic life than filterable forms. Site-specific translators can be developed to account for site-specific conditions, thereby preventing exceedingly stringent or under protective WQOs.

For deep water discharges to Lower San Francisco Bay, the Regional Water Board staff are using the following translators for copper and nickel, based on recommendations of the Clean Estuary Partnership's *North of Dumbarton Bridge Copper and Nickel Development and Selection of Final Translators* (2005). In determining the need for and calculating WQBELs for all other metals, the Regional Water Board staff has used default translators established by the USEPA in the CTR at 40 CFR 131.38(b)(2), Table 2.

| Copper and Nickel Translators for Deepwater Discharges to Lower San Francisco Bay | Copper | | Nickel | |
|---|------------------|----------------|------------------|----------------|
| | Chronic Criteria | Acute Criteria | Chronic Criteria | Acute Criteria |
| | 0.74 | 0.88 | 0.65 | 0.85 |

g. Interim Limitations and Compliance Schedules

The SIP and the Basin Plan authorize compliance schedules in a permit if an existing Discharger cannot immediately comply with a new and more stringent effluent limitation. Compliance schedules for limitations derived from CTR WQC are based on Section 2.2 of the SIP, and compliance schedules for limitations derived from the Basin Plan WQOs are based on the Basin Plan. Both the SIP and the Basin Plan require the Discharger to demonstrate the infeasibility of achieving immediate compliance with the new limitation to qualify for a compliance schedule.

3. Determining the Need for Water Quality Based Effluent Limits (WQBELs)

NPDES regulations at 40 CFR 122.44(d)(1)(i) require permits to include WQBELs for all pollutants (non-priority or priority) “which the Director determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any narrative or numeric criteria within a State water quality standard” (have Reasonable Potential). Thus, assessing whether a pollutant has Reasonable Potential is the fundamental step in determining whether or not a WQBEL is required. For non-priority pollutants, Regional Water Board staff used available monitoring data, receiving water’s designated uses, and/or previous permit pollutant limitations to determine Reasonable Potential. For priority

pollutants, Regional Water Board staff used the methods prescribed in Section 1.3 of the SIP to determine if the discharge from the Sanitary Plant demonstrates Reasonable Potential.

a. Reasonable Potential Analysis

Using the methods prescribed in Section 1.3 of the SIP, Regional Water Board staff analyzed the effluent data to determine if the discharge from the Sanitary Plant demonstrates Reasonable Potential. The Reasonable Potential Analysis (RPA) compares the effluent data with numeric and narrative Water Quality Objectives (WQOs) in the Basin Plan and numeric Water Quality Criteria (WQC) from the USEPA, the NTR, and the CTR. The Basin Plan objectives and CTR criteria are shown in the Appendices of this Fact Sheet.

As described in the Facility Description, the treated wastewater from the Sanitary Plant is directed to a pumping station where it is combined with treated effluent from the Industrial Plant and then discharged to the NBSU. Either plant may occasionally be used to store or treat flows, spills or overflows from the other to assure that both treatment plants are operated efficiently and that such flows are captured and treated before they can reach receiving waters via the NBSU. Although final effluent flows are combined prior to discharge to the NBSU, the Sanitary Plant and the Industrial Plant are regulated under separate permits to ensure that each plant, independently, is properly operated and maintained by the Discharger.

Although the plants operate under separate permits, whenever possible compliance with WQBELs will be determined from samples collected at one combined discharge monitoring point. This contrasts the previous operations, which had separate compliance monitoring points for each plant. With only one monitoring point, there will be thus one set of WQBELs. This is a reasonable approach since it is the combined discharge that would more closely represent the discharge's effects in the receiving water. This one set of WQBELs covers all the pollutants that showed Reasonable Potential at either plant.

b. Reasonable Potential Methodology

Using the methods and procedures prescribed in Section 1.3 of the SIP, Regional Water Board staff analyzed the effluent and background data and the nature of facility operations to determine if the discharge has reasonable potential to cause or contribute to exceedances of applicable site-specific objectives (SSOs) or WQC. Appendix A of this Fact Sheet shows the stepwise process described in Section 1.3 of the SIP.

The RPA requires the identification of a maximum effluent concentration (MEC) for each pollutant based on existing data, while accounting for a limited data set and effluent variability. There are three triggers in determining Reasonable Potential:

- 1) The first trigger is activated if the MEC is greater than the lowest applicable WQO ($MEC \geq WQC$), which has been adjusted, if appropriate, for pH, hardness, and translator data. If the MEC is greater than the adjusted WQC, then that pollutant has Reasonable Potential, and a WQBEL is required.
- 2) The second trigger is activated if the observed maximum ambient background concentration (B) is greater than the adjusted WQO ($B > WQC$), and the pollutant is detected in any of the effluent samples.
- 3) The third trigger is activated if a review of other information determines that a WQBEL is required to protect beneficial uses, even though both MEC and B are less than the WQC. A limitation may be required under certain circumstances to protect beneficial uses.

c. Effluent Data

The Regional Water Board's August 6, 2001 letter titled *Requirement for Monitoring of Pollutants in Effluent and Receiving Water to Implement New Statewide Regulations and Policy* (hereinafter referred to as the Regional Water Board's August 6, 2001 Letter - available online; see Standard Language and Other References Available Online, below) to all permittees formally required the Discharger (pursuant to Section 13267 of the CWC) to initiate or continue to monitor for the priority pollutants using analytical methods that provide the best detection limits reasonably feasible. Regional Water Board staff analyzed this effluent data and the nature of the Sanitary Plant to determine if the discharge has Reasonable Potential. The analysis was based on the effluent monitoring data collected by the Discharger during the previous permit term (January 2002 through July 2006) for most inorganic constituents (arsenic, cadmium, chromium, copper, lead, mercury, nickel, selenium, silver, zinc, and cyanide). For the remaining inorganic constituents (antimony, beryllium, and thallium), monitoring data was available from March 2004 through March 2006. For most of the organic constituents (CTR numbers 16–126), monitoring data from September 2002 through March 2006 was used.

d. Ambient Background Data

Ambient background values are used in the analysis for the calculation of effluent limitations. Ambient background concentrations are the observed detected water column concentrations. The SIP states that for calculating WQBELs, ambient background concentrations are either the observed maximum ambient water column concentrations or, for criteria/objectives intended to protect human health from carcinogenic effects, the arithmetic mean of observed ambient water concentrations. The Regional Monitoring Program (RMP) station at Yerba Buena Island, located in the Central Bay, has been monitored for most of the inorganic (CTR constituent numbers 1–15) and some of the organic (CTR constituent numbers 16–126) toxic pollutants, and these data were used as background data in performing the RPA for this Discharger. For ammonia, which is a non-persistent pollutant, data from the Oyster Point RMP station were used.

Not all the constituents listed in the CTR have been analyzed by the RMP. These data gaps are addressed by the Regional Water Board's August 6, 2001 Letter that formally requires Dischargers (pursuant to Section 13267 of the CWC) to conduct ambient background monitoring and effluent monitoring for those constituents not currently monitored by the RMP and to provide this technical information to the Regional Water Board.

On May 15, 2003, a group of several San Francisco Bay Region Dischargers (known as the Bay Area Clean Water Agencies, or BACWA) submitted a collaborative receiving water study, entitled the *San Francisco Bay Ambient Water Monitoring Interim Report*. This study includes monitoring results from sampling events in 2002 and 2003 for the remaining priority pollutants not monitored by the RMP. The RPA was conducted and the WQBELs were calculated using RMP data from 1993 through 2003 for inorganics and organics at the Yerba Buena Island RMP station, and additional data from the BACWA *Ambient Water Monitoring: Final CTR Sampling Update Report* for the Yerba Buena Island RMP station.

e. Reasonable Potential Determination for the Industrial Plant

The Maximum Effluent Concentrations (MECs), the most stringent applicable WQOs/WQC, and background concentrations used in the RPA are presented in the following table, along with the RP determination (Yes or No) for each pollutant analyzed. Reasonable Potential was not found for all pollutants, since not all pollutants have applicable WQOs/WQC and for others monitoring data were not available. The details of the RPA for the Industrial Plant are included in Appendix A of this Fact Sheet and are summarized in Table F- 9. The pollutants from the Industrial Plant that exhibit Reasonable Potential are copper, lead, mercury, nickel, cyanide, dioxin-TEQ, alpha-BHC, endrin, heptachlor and ammonia.

Table F-9. Summary of Reasonable Potential Determination for the – Industrial Plant

| CTR # | Priority Pollutants | MEC or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | Governing WQO/WQC (µg/l) | Maximum Background or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | RPA Results ⁽³⁾ |
|-------|------------------------|--|--------------------------|---|----------------------------|
| 1 | Antimony | 3 | 4300 | 1.8 | No |
| 2 | Arsenic | 9.87 | 36 | 2.46 | No |
| 3 | Beryllium | <0.5 | No Criteria | 0.215 | Ud |
| 4 | Cadmium | 2.365 | 9.4 | 0.13 | No |
| 5a | Chromium (III) | No Data | No Criteria | Not Available | Ud |
| 5b | Chromium (VI) | 21.9 | 50 | 4.4 | No |
| 6 | Copper | 41.296 | 4.2 | 2.45 | Yes |
| 7 | Lead | 71.28 | 8.5 | 0.80 | Yes |
| 8 | Mercury (303d listed) | 0.034 | 0.025 | 0.0086 | Yes |
| 9 | Nickel | 29.935 | 12.6 | 3.7 | Yes |
| 10 | Selenium (303d listed) | 1.402 | 5 | 0.39 | No |
| 11 | Silver | 0.305 | 2.2 | 0.052 | No |
| 12 | Thallium | 0.3 | 6.3 | 0.21 | No |
| 13 | Zinc | 56.64 | 86 | 5.1 | No |

| CTR # | Priority Pollutants | MEC or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | Governing WQO/WQC (µg/l) | Maximum Background or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | RPA Results ⁽³⁾ |
|-------|-----------------------------|--|--------------------------|---|----------------------------|
| 14 | Cyanide | 33 | 1.0 | < 0.4 | Yes |
| 15 | Asbestos | No Data | No Criteria | Not Available | Ud |
| 16 | 2,3,7,8-TCDD (303d listed) | <8.23E-07 | 1.4E-08 | Not Available | No |
| | Dioxin-TEQ (303d listed) | 4.74E-07 | 1.4E-08 ⁽⁴⁾ | 7.10E-08 | Yes |
| 17 | Acrolein | <5 | 780 | < 0.5 | No |
| 18 | Acrylonitrile | <5 | 0.66 | 0.03 | No |
| 19 | Benzene | <0.5 | 71 | < 0.05 | No |
| 20 | Bromoform | 85 | 360 | < 0.5 | No |
| 21 | Carbon Tetrachloride | <0.5 | 4.4 | 0.06 | No |
| 22 | Chlorobenzene | <0.5 | 21000 | < 0.5 | No |
| 23 | Chlorodibromomethane | 22 | 34 | < 0.05 | No |
| 24 | Chloroethane | <0.5 | No Criteria | < 0.5 | Ud |
| 25 | 2-Chloroethylvinyl ether | <0.5 | No Criteria | < 0.5 | Ud |
| 26 | Chloroform | 5.6 | No Criteria | < 0.5 | Ud |
| 27 | Dichlorobromomethane | 8.5 | 46 | < 0.05 | No |
| 28 | 1,1-Dichloroethane | <0.5 | No Criteria | < 0.05 | Ud |
| 29 | 1,2-Dichloroethane | <0.5 | 99 | 0.04 | No |
| 30 | 1,1-Dichloroethylene | <0.5 | 3.2 | < 0.5 | No |
| 31 | 1,2-Dichloropropane | <0.5 | 39 | < 0.05 | No |
| 32 | 1,3-Dichloropropylene | <0.5 | 1700 | Not Available | No |
| 33 | Ethylbenzene | 0.407 | 29000 | < 0.5 | No |
| 34 | Methyl Bromide | 0.34 | 4000 | < 0.5 | No |
| 35 | Methyl Chloride | <0.5 | No Criteria | < 0.5 | Ud |
| 36 | Methylene Chloride | 0.383 | 1600 | 0.5 | No |
| 37 | 1,1,2,2-Tetrachloroethane | <0.5 | 11 | < 0.05 | No |
| 38 | Tetrachloroethylene | <0.5 | 8.85 | < 0.05 | No |
| 39 | Toluene | 2.33 | 200000 | < 0.3 | No |
| 40 | 1,2-Trans-Dichloroethylene | <0.5 | 140000 | < 0.5 | No |
| 41 | 1,1,1-Trichloroethane | 0.7 | No Criteria | < 0.5 | Ud |
| 42 | 1,1,2-Trichloroethane | <0.5 | 42 | < 0.05 | No |
| 43 | Trichloroethylene | <0.5 | 81 | < 0.5 | No |
| 44 | Vinyl Chloride | <0.5 | 525 | < 0.5 | No |
| 45 | 2-Chlorophenol | <1.05 | 400 | < 1.2 | No |
| 46 | 2,4-Dichlorophenol | <1.2 | 790 | < 1.3 | No |
| 47 | 2,4-Dimethylphenol | <1 | 2300 | < 1.3 | No |
| 48 | 2-Methyl- 4,6-Dinitrophenol | <1 | 765 | < 1.2 | No |
| 49 | 2,4-Dinitrophenol | <3.89 | 14000 | < 0.7 | No |
| 50 | 2-Nitrophenol | <1.86 | No Criteria | < 1.3 | Ud |
| 51 | 4-Nitrophenol | <1.96 | No Criteria | < 1.6 | Ud |
| 52 | 3-Methyl 4-Chlorophenol | <1 | No Criteria | < 1.1 | Ud |
| 53 | Pentachlorophenol | <1.04 | 7.9 | < 1.0 | No |
| 54 | Phenol | <1 | 4600000 | < 1.3 | No |
| 55 | 2,4,6-Trichlorophenol | <1.88 | 6.5 | < 1.3 | No |
| 56 | Acenaphthene | <0.52 | 2700 | 0.0015 | No |
| 57 | Acenaphthylene | <0.39 | No Criteria | 0.00053 | Ud |
| 58 | Anthracene | <0.02 | 110000 | 0.0005 | No |
| 59 | Benzidine | <2.5 | 0.00054 | < 0.0015 | No |
| 60 | Benzo(a)Anthracene | <0.05 | 0.049 | 0.0053 | No |
| 61 | Benzo(a)Pyrene | <0.05 | 0.049 | 0.00029 | No |
| 62 | Benzo(b)Fluoranthene | <0.1 | 0.049 | 0.0046 | No |
| 63 | Benzo(ghi)Perylene | <0.09 | No Criteria | 0.0027 | Ud |
| 64 | Benzo(k)Fluoranthene | <0.05 | 0.049 | 0.0015 | No |

JULY 27, 2007

| CTR # | Priority Pollutants | MEC or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | Governing WQO/WQC (µg/l) | Maximum Background or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | RPA Results ⁽³⁾ |
|-------|-----------------------------|--|--------------------------|---|----------------------------|
| 65 | Bis(2-Chloroethoxy)Methane | <0.97 | No Criteria | < 0.3 | Ud |
| 66 | Bis(2-Chloroethyl)Ether | <0.97 | 1.4 | < 0.3 | No |
| 67 | Bis(2-Chloroisopropyl)Ether | <0.81 | 170000 | Not Available | No |
| 68 | Bis(2-Ethylhexyl)Phthalate | <0.69 | 5.9 | < 0.5 | No |
| 69 | 4-Bromophenyl Phenyl Ether | <1 | No Criteria | < 0.23 | Ud |
| 70 | Butylbenzyl Phthalate | <0.95 | 5200 | < 0.52 | No |
| 71 | 2-Chloronaphthalene | <1 | 4300 | < 0.3 | No |
| 72 | 4-Chlorophenyl Phenyl Ether | <0.89 | No Criteria | < 0.3 | Ud |
| 73 | Chrysene | <0.9 | 0.049 | 0.0024 | No |
| 74 | Dibenzo(a,h)Anthracene | <0.09 | 0.049 | 0.00064 | No |
| 75 | 1,2-Dichlorobenzene | <0.5 | 17000 | < 0.8 | No |
| 76 | 1,3-Dichlorobenzene | <0.5 | 2600 | < 0.8 | No |
| 77 | 1,4-Dichlorobenzene | <0.5 | 2600 | < 0.8 | No |
| 78 | 3,3 Dichlorobenzidine | <0.9 | 0.077 | < 0.001 | No |
| 79 | Diethyl Phthalate | <1 | 120000 | < 0.24 | No |
| 80 | Dimethyl Phthalate | <1 | 2900000 | < 0.24 | No |
| 81 | Di-n-Butyl Phthalate | <0.87 | 12000 | < 0.5 | No |
| 82 | 2,4-Dinitrotoluene | <1 | 9.1 | < 0.27 | No |
| 83 | 2,6-Dinitrotoluene | <1.29 | No Criteria | < 0.29 | Ud |
| 84 | Di-n-Octyl Phthalate | 2 | No Criteria | < 0.38 | Ud |
| 85 | 1,2-Diphenylhydrazine | <1 | 0.54 | 0.0037 | No |
| 86 | Fluoranthene | <0.1 | 370 | 0.011 | No |
| 87 | Fluorene | <0.1 | 14000 | 0.00208 | No |
| 88 | Hexachlorobenzene | <0.98 | 0.00077 | 0.0000202 | No |
| 89 | Hexachlorobutadiene | <1 | 50 | < 0.3 | No |
| 90 | Hexachlorocyclopentadiene | <1 | 17000 | < 0.31 | No |
| 91 | Hexachloroethane | <1 | 8.9 | < 0.2 | No |
| 92 | Indeno(1,2,3-cd)Pyrene | <0.1 | 0.049 | 0.004 | No |
| 93 | Isophorone | <0.95 | 600 | < 0.3 | No |
| 94 | Naphthalene | <1 | No Criteria | 0.0023 | Ud |
| 95 | Nitrobenzene | <0.71 | 1900 | < 0.25 | No |
| 96 | N-Nitrosodimethylamine | <0.1 | 8.1 | < 0.3 | No |
| 97 | N-Nitrosodi-n-Propylamine | <0.84 | 1.4 | < 0.001 | No |
| 98 | N-Nitrosodiphenylamine | <0.94 | 16 | < 0.001 | No |
| 99 | Phenanthrene | <0.93 | No Criteria | 0.0061 | Ud |
| 100 | Pyrene | <0.1 | 11000 | 0.0051 | No |
| 101 | 1,2,4-Trichlorobenzene | <0.94 | No Criteria | < 0.3 | Ud |
| 102 | Aldrin | <0.005 | 0.00014 | Not Available | No |
| 103 | alpha-BHC | 0.051 | 0.013 | 0.000496 | Yes |
| 104 | beta-BHC | 0.039 | 0.046 | 0.000413 | No |
| 105 | gamma-BHC | <0.005 | 0.063 | 0.0007034 | No |
| 106 | delta-BHC | <0.005 | No Criteria | 0.000042 | Ud |
| 107 | Chlordane (303d listed) | <0.005 | 0.00059 | 0.00018 | No |
| 108 | 4,4'-DDT (303d listed) | <0.01 | 0.00059 | 0.000066 | No |
| 109 | 4,4'-DDE (linked to DDT) | <0.01 | 0.00059 | 0.000693 | No |
| 110 | 4,4'-DDD | <0.03 | 0.00084 | 0.000313 | No |
| 111 | Dieldrin (303d listed) | <0.01 | 0.00014 | 0.000264 | No |
| 112 | alpha-Endosulfan | <0.01 | 0.0087 | 0.000031 | No |
| 113 | beta-Endosulfan | <0.01 | 0.0087 | 0.000069 | No |
| 114 | Endosulfan Sulfate | <0.03 | 240 | 0.0000819 | No |
| 115 | Endrin | 0.01 | 0.0023 | 0.000036 | Yes |
| 116 | Endrin Aldehyde | <0.01 | 0.81 | Not Available | No |

| CTR # | Priority Pollutants | MEC or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | Governing WQO/WQC (µg/l) | Maximum Background or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | RPA Results ⁽³⁾ |
|---------|----------------------------|--|--------------------------|---|----------------------------|
| 117 | Heptachlor | 0.035 | 0.00021 | 0.000019 | Yes |
| 118 | Heptachlor Epoxide | <0.005 | 0.00011 | 0.00002458 | No |
| 119-125 | PCBs sum (303d listed) | 0.47 | 0.00017 | Not Available | No |
| 126 | Toxaphene | <0.5 | 0.0002 | Not Available | No |
| | Ammonia ⁽⁴⁾ | 118,000 | 1,520 | 210 | Yes |
| | Tributyltin ⁽⁵⁾ | <0.005 | 0.061 ⁽⁴⁾ | < 0.005 | No |
| | Total PAHs | <0.02 | 15 | 0.26 | No |

- (1) The Maximum Effluent Concentration (MEC) or maximum background concentration is the actual detected concentration unless there is a "<" sign before it, in which case the value shown is the minimum detection level.
- (2) The MEC or maximum background concentration is "Not Available" when there are no monitoring data for the constituent.
- (3) RPA Results = Yes, if MEC > WQO/WQC, or B > WQO/WQC and MEC is detected;
 = No, if MEC and B are < WQO/WQC or all effluent data are undetected;
 = Undetermined (Ud), if no criteria have been promulgated;
- (4) See Section C.4.b, p F-33 of this Fact Sheet for an explanation of the WQO for ammonia.
- (5) WQC translated from a narrative objective in the Basin Plan. For tributyltin WQC are discussed in EPA 822-R-03-031, December 2003 Ambient Aquatic Life Water Quality Criteria for Tributyltin (TBT) – Final.

(1) Constituents with insufficient monitoring data. The Discharger has performed sampling and analysis for the constituents listed in the CTR. This data set was used to perform the RPA. In some cases, Reasonable Potential cannot be determined because effluent data are limited, or ambient background concentrations are not available. The Discharger will continue to monitor for these constituents in the effluent using analytical methods that provide the best feasible detection limits. When additional data become available, a RPA will be conducted to determine whether to add numeric effluent limitations to this Order or to continue monitoring (VI Provisions C.2.a).

(2) Constituents with no Reasonable Potential. For constituents that do not demonstrate Reasonable Potential, monitoring is still required. If concentrations of these constituents increase significantly, the Discharger will be required to investigate the source(s) of the increase(s). Remedial measures are required if the increases pose a threat to water quality in the receiving water.

f. Reasonable Potential Determination for the Sanitary Plant

There will be one single compliance monitoring point for WQBELs in the discharges from both the Sanitary and Industrial Plants. As a consequence, the discharges will be combined before the monitoring point, EFF-001A. Any constituent shown to have reasonable potential in the discharge from the Sanitary Plant could, in combination with the industrial discharge, have reasonable potential at the combined monitoring point and vice versa.

A reasonable potential analysis for the Sanitary Plant was conducted, as shown in Appendix B of this Fact Sheet and a summary is shown in Table F-10. The

constituents that exhibited Reasonable Potential for the Sanitary Plant are copper, mercury, nickel, cyanide, aldrin, beta-BHC, 4,4-DDT, 4,4-DDE, dieldrin, endrin, heptachlor, heptachlor epoxide, ammonia and tributyltin. Of these constituents, aldrin, beta-BHC, 4,4-DDT, 4,4-DDE, dieldrin, heptachlor epoxide, and tributyltin did not exhibit reasonable potential in the effluent from the Industrial Plant.

Table F-10. Summary of Reasonable Potential Determination for the Sanitary Plant

| CTR # | Priority Pollutants | MEC or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | Governing WQO/WQC (µg/l) | Maximum Background or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | RP Determination ⁽³⁾ |
|-------|----------------------------|--|--------------------------|---|---------------------------------|
| 1 | Antimony | 0.41 | 4300 | 1.8 | No |
| 2 | Arsenic | 5 | 36 | 2.46 | No |
| 3 | Beryllium | <0.5 | No Criteria | 0.215 | Ud |
| 4 | Cadmium | 0.58 | 9.4 | 0.13 | No |
| 5a | Chromium (III) | Not Available | No Criteria | Not Available | Ud |
| 5b | Chromium (VI) | 6.77 | 50 | 4.4 | No |
| 6 | Copper | 13.95 | 4.2 | 2.45 | Yes |
| 7 | Lead | 5 | 8.5 | 0.80 | No |
| 8 | Mercury (303d listed) | 0.0867 | 0.025 | 0.0086 | Yes |
| 9 | Nickel | 14.91 | 12.6 | 3.7 | Yes |
| 10 | Selenium (303d listed) | 1.563 | 5 | 0.39 | No |
| 11 | Silver | 0.6 | 2.2 | 0.052 | No |
| 12 | Thallium | 1.3 | 6.3 | 0.21 | No |
| 13 | Zinc | 71.4 | 86 | 5.1 | No |
| 14 | Cyanide | 15.8 | 1.0 | < 0.4 | Yes |
| 15 | Asbestos | Not Available | No Criteria | Not Available | Ud |
| 16 | 2,3,7,8-TCDD (303d listed) | <9.80E-07 | 1.4E-08 | Not Available | No |
| | Dioxin-TEQ (303d listed) | <0.000000355 | 1.4E-08 ⁽⁴⁾ | 7.10E-08 | No |
| 17 | Acrolein | <5 | 780 | < 0.5 | No |
| 18 | Acrylonitrile | <5 | 0.66 | 0.03 | No |
| 19 | Benzene | <0.5 | 71 | < 0.05 | No |
| 20 | Bromoform | 0.6 | 360 | < 0.5 | No |
| 21 | Carbon Tetrachloride | <0.5 | 4.4 | 0.06 | No |
| 22 | Chlorobenzene | <0.5 | 21000 | < 0.5 | No |
| 23 | Chlorodibromomethane | 1 | 34 | < 0.05 | No |
| 24 | Chloroethane | 0.075 | No Criteria | < 0.5 | Ud |
| 25 | 2-Chloroethylvinyl ether | <0.5 | No Criteria | < 0.5 | Ud |
| 26 | Chloroform | 11 | No Criteria | < 0.5 | Ud |
| 27 | Dichlorobromomethane | 5 | 46 | < 0.05 | No |
| 28 | 1,1-Dichloroethane | <0.5 | No Criteria | < 0.05 | Ud |
| 29 | 1,2-Dichloroethane | <0.5 | 99 | 0.04 | No |
| 30 | 1,1-Dichloroethylene | <0.5 | 3.2 | < 0.5 | No |
| 31 | 1,2-Dichloropropane | <0.5 | 39 | < 0.05 | No |
| 32 | 1,3-Dichloropropylene | <0.5 | 1700 | Not Available | No |
| 33 | Ethylbenzene | <0.5 | 29000 | < 0.5 | No |
| 34 | Methyl Bromide | 0.59 | 4000 | < 0.5 | No |
| 35 | Methyl Chloride | <0.5 | No Criteria | < 0.5 | Ud |
| 36 | Methylene Chloride | 0.485 | 1600 | 0.5 | No |
| 37 | 1,1,2,2-Tetrachloroethane | <0.5 | 11 | < 0.05 | No |
| 38 | Tetrachloroethylene | <0.5 | 8.85 | < 0.05 | No |
| 39 | Toluene | 0.46 | 200000 | < 0.3 | No |
| 40 | 1,2-Trans-Dichloroethylene | <0.5 | 140000 | < 0.5 | No |

JULY 27, 2007

| CTR # | Priority Pollutants | MEC or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | Governing WQO/WQC (µg/l) | Maximum Background or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | RP Determination ⁽³⁾ |
|-------|-----------------------------|--|--------------------------|---|---------------------------------|
| 41 | 1,1,1-Trichloroethane | <0.5 | No Criteria | < 0.5 | Ud |
| 42 | 1,1,2-Trichloroethane | <0.5 | 42 | < 0.05 | No |
| 43 | Trichloroethylene | <0.5 | 81 | < 0.5 | No |
| 44 | Vinyl Chloride | <0.5 | 525 | < 0.5 | No |
| 45 | 2-Chlorophenol | <1.05 | 400 | < 1.2 | No |
| 46 | 2,4-Dichlorophenol | <1.2 | 790 | < 1.3 | No |
| 47 | 2,4-Dimethylphenol | <1 | 2300 | < 1.3 | No |
| 48 | 2-Methyl- 4,6-Dinitrophenol | <1 | 765 | < 1.2 | No |
| 49 | 2,4-Dinitrophenol | <3.89 | 14000 | < 0.7 | No |
| 50 | 2-Nitrophenol | <1.86 | No Criteria | < 1.3 | Ud |
| 51 | 4-Nitrophenol | <1.96 | No Criteria | < 1.6 | Ud |
| 52 | 3-Methyl 4-Chlorophenol | <1 | No Criteria | < 1.1 | Ud |
| 53 | Pentachlorophenol | <1.04 | 7.9 | < 1.0 | No |
| 54 | Phenol | <1 | 4600000 | < 1.3 | No |
| 55 | 2,4,6-Trichlorophenol | <1.88 | 6.5 | < 1.3 | No |
| 56 | Acenaphthene | <0.52 | 2700 | 0.0015 | No |
| 57 | Acenaphthylene | <0.39 | No Criteria | 0.00053 | Ud |
| 58 | Anthracene | <0.02 | 110000 | 0.0005 | No |
| 59 | Benzidine | <2.5 | 0.00054 | < 0.0015 | No |
| 60 | Benzo(a)Anthracene | <0.05 | 0.049 | 0.0053 | No |
| 61 | Benzo(a)Pyrene | <0.05 | 0.049 | 0.00029 | No |
| 62 | Benzo(b)Fluoranthene | <0.1 | 0.049 | 0.0046 | No |
| 63 | Benzo(ghi)Perylene | <0.09 | No Criteria | 0.0027 | Ud |
| 64 | Benzo(k)Fluoranthene | <0.05 | 0.049 | 0.0015 | No |
| 65 | Bis(2-Chloroethoxy)Methane | <0.97 | No Criteria | < 0.3 | Ud |
| 66 | Bis(2-Chloroethyl)Ether | <0.97 | 1.4 | < 0.3 | No |
| 67 | Bis(2-Chloroisopropyl)Ether | <0.81 | 170000 | Not Available | No |
| 68 | Bis(2-Ethylhexyl)Phthalate | <0.69 | 5.9 | < 0.5 | No |
| 69 | 4-Bromophenyl Phenyl Ether | <1 | No Criteria | < 0.23 | Ud |
| 70 | Butylbenzyl Phthalate | <0.26 | 5200 | < 0.52 | No |
| 71 | 2-Chloronaphthalene | <1 | 4300 | < 0.3 | No |
| 72 | 4-Chlorophenyl Phenyl Ether | <0.89 | No Criteria | < 0.3 | Ud |
| 73 | Chrysene | <0.9 | 0.049 | 0.0024 | No |
| 74 | Dibenzo(a,h)Anthracene | <0.09 | 0.049 | 0.00064 | No |
| 75 | 1,2-Dichlorobenzene | <0.5 | 17000 | < 0.8 | No |
| 76 | 1,3-Dichlorobenzene | <0.5 | 2600 | < 0.8 | No |
| 77 | 1,4-Dichlorobenzene | 0.13 | 2600 | < 0.8 | No |
| 78 | 3,3 Dichlorobenzidine | <0.9 | 0.077 | < 0.001 | No |
| 79 | Diethyl Phthalate | <1 | 120000 | < 0.24 | No |
| 80 | Dimethyl Phthalate | <1 | 2900000 | < 0.24 | No |
| 81 | Di-n-Butyl Phthalate | <0.87 | 12000 | < 0.5 | No |
| 82 | 2,4-Dinitrotoluene | <1 | 9.1 | < 0.27 | No |
| 83 | 2,6-Dinitrotoluene | <1.29 | No Criteria | < 0.29 | Ud |
| 84 | Di-n-Octyl Phthalate | 2 | No Criteria | < 0.38 | Ud |
| 85 | 1,2-Diphenylhydrazine | <1 | 0.54 | 0.0037 | No |
| 86 | Fluoranthene | <0.1 | 370 | 0.011 | No |
| 87 | Fluorene | <0.1 | 14000 | 0.00208 | No |
| 88 | Hexachlorobenzene | <0.98 | 0.00077 | 0.0000202 | No |
| 89 | Hexachlorobutadiene | <1 | 50 | < 0.3 | No |
| 90 | Hexachlorocyclopentadiene | <1 | 17000 | < 0.31 | No |
| 91 | Hexachloroethane | <1 | 8.9 | < 0.2 | No |
| 92 | Indeno(1,2,3-cd)Pyrene | <0.1 | 0.049 | 0.004 | No |

JULY 27, 2007

| CTR # | Priority Pollutants | MEC or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | Governing WQO/WQC (µg/l) | Maximum Background or Minimum DL ⁽¹⁾⁽²⁾ (µg/l) | RP Determination ⁽³⁾ |
|---------|----------------------------|--|--------------------------|---|---------------------------------|
| 93 | Isophorone | <0.95 | 600 | < 0.3 | No |
| 94 | Naphthalene | <1 | No Criteria | 0.0023 | Ud |
| 95 | Nitrobenzene | <0.71 | 1900 | < 0.25 | No |
| 96 | N-Nitrosodimethylamine | <0.1 | 8.1 | < 0.3 | No |
| 97 | N-Nitrosodi-n-Propylamine | <0.84 | 1.4 | < 0.001 | No |
| 98 | N-Nitrosodiphenylamine | <0.94 | 16 | < 0.001 | No |
| 99 | Phenanthrene | <0.93 | No Criteria | 0.0061 | Ud |
| 100 | Pyrene | <0.1 | 11000 | 0.0051 | No |
| 101 | 1,2,4-Trichlorobenzene | <0.94 | No Criteria | < 0.3 | Ud |
| 102 | Aldrin | 0.009 | 0.00014 | Not Available | Yes |
| 103 | alpha-BHC | <0.005 | 0.013 | 0.000496 | No |
| 104 | beta-BHC | 0.13 | 0.046 | 0.000413 | Yes |
| 105 | gamma-BHC | 0.036 | 0.063 | 0.0007034 | No |
| 106 | delta-BHC | 0.097 | No Criteria | 0.000042 | Ud |
| 107 | Chlordane (303d listed) | <0.1 | 0.00059 | 0.00018 | No |
| 108 | 4,4'-DDT (303d listed) | 0.053 | 0.00059 | 0.000066 | Yes |
| 109 | 4,4'-DDE (linked to DDT) | 0.05 | 0.00059 | 0.000693 | Yes |
| 110 | 4,4'-DDD | <0.03 | 0.00084 | 0.000313 | No |
| 111 | Dieldrin (303d listed) | 0.014 | 0.00014 | 0.000264 | Yes |
| 112 | alpha-Endosulfan | <0.01 | 0.0087 | 0.000031 | No |
| 113 | beta-Endosulfan | <0.01 | 0.0087 | 0.000069 | No |
| 114 | Endosulfan Sulfate | <0.03 | 240 | 0.0000819 | No |
| 115 | Endrin | 0.021 | 0.0023 | 0.000036 | Yes |
| 116 | Endrin Aldehyde | <0.01 | 0.81 | Not Available | No |
| 117 | Heptachlor | 0.26 | 0.00021 | 0.000019 | Yes |
| 118 | Heptachlor Epoxide | 0.022 | 0.00011 | 0.00002458 | Yes |
| 119-125 | PCBs sum (303d listed) | <0.47 | 0.00017 | Not Available | No |
| 126 | Toxaphene | <0.5 | 0.00020 | Not Available | No |
| | Ammonia ⁽⁴⁾ | 118,000 | 1,520 | 210 | Yes |
| | Tributyltin ⁽⁵⁾ | 0.019 | 0.061 ⁽⁴⁾ | < 0.001 | Yes |
| | Total PAHs | <0.02 | 15 | 0.26 | No |

- (1) The Maximum Effluent Concentration (MEC) or maximum background concentration is the actual detected concentration unless there is a "<" sign before it, in which case the value shown is the minimum detection level.
- (2) The MEC or maximum background concentration is "Not Available" when there are no monitoring data for the constituent.
- (3) RPA Results = Yes, if MEC > WQO/WQC, or B > WQO/WQC and MEC is detected;
 = No, if MEC and B are < WQO/WQC or all effluent data are undetected;
 = Undetermined (Ud), if no criteria have been promulgated.
- (4) See Section C.4.b, page F-33 of this Fact Sheet for an explanation of the WQO for ammonia.
- (5) WQC translated from a narrative objective in the Basin Plan. For tributyltin WQC are discussed in EPA 822-R-03-031, December 2003 Ambient Aquatic Life Water Quality Criteria for Tributyltin (TBT) – Final.

4. Water Quality Based Effluent Limitation (WQBEL) Calculations.

a. Constituents with Reasonable Potential

Reasonable potential analyses were conducted on the discharges from the Industrial and Sanitary Plants. These are shown in detail in Table 3 of

Appendices A and B to this Fact sheet and are summarized in Table F-9 and Table F-10 above. Constituents with reasonable potential that were found in either the discharge from the Industrial Plant or from the Sanitary Plant and thus requiring calculations to determine WQBELs, as shown in Table F-11, are:

Table F-11. Constituents with Reasonable Potential

| CTR # | Constituent |
|-------|--------------------|
| 6 | Copper |
| 7 | Lead |
| 8 | Mercury |
| 9 | Nickel |
| 14 | Cyanide |
| | Dioxin-TEQ |
| 102 | Aldrin |
| 103 | Alpha-BHC |
| 104 | Beta-BHC |
| 108 | 4,4-DDT |
| 109 | 4,4-DDE |
| 111 | Dieldrin |
| 115 | Endrin |
| 117 | Heptachlor |
| 118 | Heptachlor Epoxide |
| | Ammonia |
| | Tributyltin |

The WQBELs are based on appropriate WQOs/WQC and the procedures specified in Section 1.4 of the SIP as explained below.

b. Applicable Water Quality Objectives and Criteria

The WQO or WQC used for each pollutant with reasonable potential is shown in Table F-12. Additional information regarding the derivation of WQOs and WQC is provided for specific pollutants below.

Table F-12 Summary of Water Quality Criteria or Objectives for Constituents with Reasonable Potential.

| CTR # | Pollutant | WQC/WQO µg/l Aquatic life-chronic | WQC/WQO µg/l Aquatic life-acute | WQC/WQO µg/l human health | Basis |
|-------|-----------|-----------------------------------|---------------------------------|---------------------------|---|
| 6 | Copper | 10 | 13 | | Basin Plan and CTR saltwater aquatic life |
| 7 | Lead | 8.5 | 221 | | Basin Plan and CTR saltwater aquatic life |
| 8 | Mercury | 0.025 | 2.1 | 0.051 | Basin Plan saltwater aquatic life and CTR human health |
| 9 | Nickel | 13 | 87 | 4600 | Basin Plan and CTR saltwater aquatic life and CTR human |

| CTR # | Pollutant | WQC/WQO µg/l Aquatic life-chronic | WQC/WQO µg/l Aquatic life-acute | WQC/WQO µg/l human health | Basis |
|-------|--------------------|-----------------------------------|---------------------------------|---------------------------|---|
| | | | | | health |
| 14 | Cyanide | 1 | 1 | 220000 | NTR saltwater aquatic life and human health |
| | Dioxin-TEQ | | | 1.4E-08 | Basin Plan narrative (bioaccumulation) |
| 102 | Aldrin | | 1.3 | 0.00014 | CTR saltwater aquatic life and human health |
| 103 | Alpha-BHC | | | 0.013 | CTR Human health |
| 104 | Beta-BHC | | | 0.046 | CTR Human health |
| 108 | 4,4-DDT | | | 0.00059 | CTR Human health |
| 109 | 4,4-DDE | | | 0.00059 | CTR Human health |
| 111 | Dieldrin | 0.0019 | 0.71 | 0.00014 | CTR saltwater aquatic life and human health |
| 115 | Endrin | 0.0023 | 0.037 | 0.81 | CTR saltwater aquatic life and human health |
| 117 | Heptachlor | 0.0036 | 0.053 | 0.00021 | CTR saltwater aquatic life and human health |
| 118 | Heptachlor Epoxide | 0.0036 | 0.053 | 0.00011 | CTR saltwater aquatic life and human health |
| | Ammonia | 1,500 | 14,000 | | Basin Plan |
| | Tributyltin | 0.0074 | 0.42 | | Basin Plan narrative (toxicity) |

Copper: The salt water acute and chronic objectives from the Basin Plan and the CTR for copper for protection of aquatic life are 13 µg/l and 10 µg/l, respectively. These objectives were determined using site-specific translators of 0.74 (chronic) and 0.88 (acute), as recommended by the Clean Estuary Partnership’s *North of Dumbarton Bridge Copper and Nickel Development and Selection of Final Translators (2005)*. Site-specific translators were applied to the chronic (3.1 µg/l dissolved metal) and acute (4.8 µg/l dissolved metal) criteria of the Basin Plan and the CTR. In addition, a water effects ratio (WER) of 2.4, as recommended by the Clean Estuary Partnership’s *North of Dumbarton Bridge Copper and Nickel Site-Specific Objective (SSO) Derivation (December 2004)*, was applied, in accordance with USEPA guidance – Interim Guidance on Determination and Use of Water Effect Ratios for Metals (EPA-823-B-94-001).

Nickel: The salt water acute and chronic objectives from the Basin Plan and the CTR for nickel for protection of aquatic life are 87 µg/l and 13 µg/l, respectively. These objectives were determined using site-specific translators of 0.65 (chronic) and 0.85 (acute), as recommended by the Clean Estuary Partnership’s *North of Dumbarton Bridge Copper and Nickel Development and Selection of Final Translators (2005)*. Site-specific translators were applied to the chronic (8.2 µg/l dissolved metal) and acute (74 µg/l dissolved metal) criteria of the Basin Plan and the CTR.

JULY 27, 2007

Dioxin-TEQ: The Basin Plan contains a narrative WQO for bioaccumulative substances: “Many pollutants can accumulate on particulates, in sediments, or bioaccumulate in fish and other aquatic organisms. Controllable water quality factors shall not cause a detrimental increase in concentrations of toxic substances found in bottom sediments or aquatic life. Effects on aquatic organism, wildlife and human health will be considered.” This narrative WQO applies to dioxin and furan compounds, based in part on the consensus of the scientific community that these compounds associate with particulates, accumulate in sediments, and bioaccumulate in the fatty tissue of fish and other organisms. USEPA’s 303(d) listing determined that the narrative objective for bioaccumulative pollutants was not met in San Francisco Bay because of the levels of dioxins and furans in fish tissue, and dioxins and furans are controllable water quality factors.

The CTR establishes a numeric human health WQO of 0.014 picogram per liter for 2,3,7,8-tetrachlorinated dibenzo-p-dioxin (2,3,7,8-TCDD) based on consumption of aquatic organisms. The preamble of the CTR states that California NPDES permits should use toxicity equivalents (TEQs) where dioxin-like compounds have a reasonable potential with respect to narrative criteria. In USEPA’s National Recommended WQOs, December 2002, USEPA published the 1998 World Health Organization Toxicity Equivalence Factor (TEF) scheme. In addition, the CTR preamble states USEPA’s intent to adopt revised WQC guidance subsequent to their health reassessment for dioxin-like compounds. Therefore, the narrative bioaccumulation objective is translated into a numeric criterion expressed in 2,3,7,8-TCDD equivalents (or dioxin-TEQ) based on the CTR criterion for 2,3,7,8-TCDD and the application of the Toxic Equivalence Factors (TEFs) for dioxins and furans adopted by the World Health Organization in 1998.

Ammonia: The Basin Plan contains WQOs for un-ionized ammonia (ammonia) of 0.025 mg/l as annual median, 0.16 mg/l as a maximum north of the Golden Gate Channel, and 0.4 mg/l as a maximum south of the Golden Gate Channel. This permit assumes a translation of ammonia to total ammonia concentrations as nitrogen because there are no sampling and laboratory analytical methods that will measure only ammonia. Because the fraction of ammonia in total ammonia depends on pH, salinity, and temperature the equivalent total ammonia concentrations that are protective of beneficial uses will vary throughout the Bay. Therefore the Board recommends using the closest Regional Monitoring Program (RMP) station to an outfall to determine the percentage of total ammonia in a discharge that will be converted to toxic ammonia in the receiving water.

To convert the chronic ammonia WQO to an equivalent total ammonia concentration, the median ammonia fraction is used. To convert the acute ammonia WQO to an equivalent total ammonia concentration, the 90th percentile ammonia fraction is used

JULY 27, 2007

At the nearest Regional Monitoring Program station, Oyster point, for receiving water the observed maximum total ammonia concentration (as N) that includes both ammonia and the ammonium ion is 0.22 mg/l. The observed median concentration at this station was 0.10 mg/l. The WQO for ammonia has been calculated at 1,520 µg/l for chronic toxic effects and 14,450 µg/l for acute toxic effects.

Tributyltin: The Basin Plan contains a narrative WQO for toxicity: “All waters shall be maintained free of toxic substances in concentrations that are lethal to or that produce other detrimental responses in aquatic organisms.” This narrative WQO applies to tributyltin because it is a highly toxic biocide that is a problem in the aquatic environment. USEPA has developed water quality criteria (for freshwater and saltwater) for tributyltin (TBT) through its authority under Section 304(a) of the Clean Water Act [Ambient Aquatic Life Water Quality Criteria for Tributyltin (TBT) – Final EPA-822-031 December 2003]. Therefore the narrative toxicity objective is translated into numeric criteria expressed as 0.0074 µg/l for chronic toxic effects and 0.042 µg/l for acute toxic effects.

c. Factors in Calculating WQBELs

(1) Coefficient of Variation

One factor used to calculate WQBELs for an existing discharge is the coefficient of variation (CV), a statistical parameter reflecting the variability of pollutant concentrations in the discharge. Actual discharge data are typically analyzed to determine CVs. An individual CV could be calculated for each constituent at the Sanitary Plant by itself. However, no sampling data are available for the new combined sampling point EFF-001A. This point reflects the combined flows from both the Sanitary and Industrial Plants. When such data are unavailable, the SIP allows for a default CV of 0.6 to be used in the WQBEL calculations. Therefore, WQBEL calculations for pollutants in the combined outflow use the default CV value of 0.6. CVs for individual constituents at the Sanitary Plant may be greater than 0.6 but combining the Sanitary and Industrial Plants flows should attenuate the variability of the combined discharge concentrations.

For cyanide, however, a different CV has been used. When effluent is chlorinated, experience has shown that the analytical method used for cyanide indicates the false presence of cyanide. Such is the case for samples collected from sampling point EFF-001San or EFF-001A. To avoid this, samples for cyanide analysis are collected after the effluent has been dechlorinated. Dechlorinated samples can be collected from sampling point EFF-002. Unlike sampling point EFF-001A, there are sampling data for cyanide from point EFF-002 and these data were used to calculate the CV (0.76) to determine effluent limits.

(2) Dilution

Credit for dilution of the discharge within the receiving water may be granted if assimilative capacity exists. Pursuant to Section 1.4.2.1 of the SIP, dilution credit may be limited or denied on a pollutant-by-pollutant basis. In response to the State Water Board's Order No. 2001-06, the Regional Water Board has evaluated the assimilative capacity of the receiving water for 303(d)-listed pollutants for which the Discharger has reasonable potential to cause or contribute to an excursion above any State water quality standard in its discharge. The evaluation included a review of RMP data, effluent data, and WQOs/WQC. From this evaluation, it was determined that the assimilative capacity is highly variable because of the complex hydrology of the receiving water. Therefore, there is uncertainty associated with the representative nature of the appropriate ambient background data to conclusively quantify the assimilative capacity of the receiving water.

- (i) For non-bioaccumulative pollutants, except ammonia, a conservative allowance of 10:1 dilution for discharges to the Bay has been assigned for protection of beneficial uses. The basis for limiting dilution to 10:1 is that (1) no more than 10:1 dilution was granted in the previous Order, (2) the Basin Plan's discharge prohibition number 1 generally prohibits discharges without a 10:1 dilution, and (3) SIP Section 1.4.2 allows for limiting the dilution credit. The following further outlines the basis for derivation of the dilution credit.
- A far-field background station is appropriate because the receiving water body is a very complex estuarine system with highly variable and seasonal upstream freshwater inflows and diurnal tidal saltwater inputs.
 - Because of the complex hydrology of the San Francisco Bay, a mixing zone has not been established.
 - Previous dilution studies do not fully account for the cumulative effects of other wastewater discharges to the system.
 - The SIP allows limiting a mixing zone and dilution credit for persistent pollutants (e.g., copper, silver, nickel, and lead).

The main justification for using a 10:1 dilution credit is the uncertainty in accurately determining both ambient background and the mixing zone in a complex estuarine system with multiple wastewater discharges.

- (ii) For certain bioaccumulative pollutants, based on best professional judgment, dilution credit is not included in calculating the final WQBELs. This determination is based on available data on concentrations of these pollutants in aquatic organisms, sediment, and the water column.

The Regional Water Board placed mercury on the CWA Section 303(d) list. USEPA then added dioxin and furan compounds, dieldrin, and 4,4-DDT to the CWA Section 303(d) list (and 4,4-DDE is related to 4,4-DDT). The following

JULY 27, 2007

factors suggest that there is no more assimilative capacity in the Bay for these pollutants. San Francisco Bay fish tissue data show that these pollutants exceed screening levels. The fish tissue data are contained in *Contaminant Concentrations in Fish from San Francisco Bay 1997* (May 1997). Denial of dilution credits for these pollutants is further justified by fish advisories for the San Francisco Bay. The Office of Environmental Health and Hazard Assessment (OEHHA) performed a preliminary review of the data from the 1994 San Francisco Bay pilot study, *Contaminated Levels in Fish Tissue from San Francisco Bay*. The results of the study showed elevated levels of chemical contaminants in the fish tissues. Based on these results, OEHHA issued an interim consumption advisory covering certain fish species from the Bay in December 1994. This interim consumption advice was issued and is still in effect owing to health concerns based on exposure to sport fish from the Bay contaminated with mercury, dioxins, and pesticides (e.g., dieldrin and 4,4-DDT). A dilution credit cannot be granted when there is no assimilative capacity.

Section 2.1.1 of the SIP states that, for bioaccumulative compounds on the 303(d) list, the Regional Water Board should consider whether mass-loading limitations should be limited to current levels. The Regional Water Board finds that mass-loading limitations are warranted for mercury to ensure that this discharge does not contribute further to impairment of the narrative objective for bioaccumulation.

- (iii) For ammonia, a non-persistent pollutant, estimated actual dilution levels have been used to calculate the effluent limit. This is justified because ammonia would be quickly dispersed and degraded to a non-toxic state very rapidly. An engineering study on the actual dilution was performed by the Airfield Development Engineering Consultant on behalf of the NBSU and submitted on December 12, 2000. This was part of a larger study to estimate hydrodynamic impacts on the Bay by the proposed airport runway extension.

The discharge is pumped through a 60" pipe to a 654-ft diffuser section located approximately 5,200 ft offshore, at a depth 20 feet below mean lower low water, from Pt. San Bruno. The diffuser consists of 66 three-inch openings spaced 7-ft apart. At a point in the immediate vicinity of the diffuser a 74:1 instant dilution was calculated using the CORMIX model to estimate mixing of the effluent under tidal conditions. Dilution rates at other points were estimated. At a point approximately 1.5 km from the diffuser into the Bay (to the east), a dilution of 270:1 was estimated. In calculating the water quality based effluent limits (maximum daily and average monthly) the lowest dilution rate, i.e. 74:1, was used.

- (iv) For cyanide, a non-persistent pollutant that quickly disperses and degrades like ammonia, a dilution rate of 73:1 (or $D = 72$) was used to calculate the water quality based effluent limits. Whereas "full" dilution of 74:1 was granted for ammonia, less dilution is granted for cyanide because SIP Section 1.4.2.2 dictates that mixing zones be as small as practicable. Limiting dilution is

equivalent to decreasing the size of the allowed mixing zone. The different approach for cyanide (versus ammonia) reflects the fact that cyanide has been regulated in permits for decades in this region. As a result of past conservative policies and changes in policies and standards, the process for deriving effluent limits for cyanide are more stringent than those for ammonia to comply with antidegradation. In other words, because past policies have resulted in very stringent limitations, to backslide from these limits, CWA 303(d)(4) provides that there must be compliance with antidegradation policies.

Since the background documentation for the proposed cyanide site-specific objectives included an antidegradation analysis, which concluded that certain effluent limitations resulting from implementation of the site-specific objectives (assuming 10:1 dilution) would not degrade water quality, the dilution credit used here is the dilution credit that results in effluent limits no greater than those identified in the site-specific objectives documents for this Discharger. This resultant dilution credit for cyanide is also in compliance with the SIP, which requires the mixing zone be as small as practicable. Additionally, consistent with the site-specific objective conclusion on antidegradation, to further ensure that water quality is not degraded, this Order requires a cyanide action plan similar to that proposed with the site-specific objective.

(d) Calculated QBELs

Table F-13. Summary of QBELs for Constituents with Reasonable Potential

| CTR No. | Pollutant | Average Monthly Effluent Limit (AMEL), µg/l | Maximum Daily Effluent Limit (MDEL), µg/l |
|---------|------------------------|---|---|
| 6 | Copper | 54 | 110 |
| 6 | Copper alternate limit | 42 | 84 |
| 7 | Lead | 64 | 130 |
| 8 | Mercury | 0.020 | 0.041 |
| 9 | Nickel | 76 | 150 |
| 14 | Cyanide | 20 | 44 |
| | Dioxin-TEQ | 1.4E-08 | 2.8E-08 |
| 102 | Aldrin | 0.00014 | 0.00028 |
| 103 | Alpha-BHC | 0.13 | 0.26 |
| 104 | Beta-BHC | 0.46 | 0.92 |
| 108 | 4,4-DDT | 0.00059 | 0.0012 |
| 109 | 4,4-DDE | 0.00059 | 0.0012 |
| 111 | Dieldrin | 0.00014 | 0.00028 |
| 115 | Endrin | 0.019 | 0.037 |
| 117 | Heptachlor | 0.002 | 0.0041 |
| 118 | Heptachlor Epoxide | 0.00089 | 0.0018 |
| | Ammonia | 110,000 | 310,000 |
| | Tributyltin | 0.061 | 0.12 |

These QBELs were calculated following the procedures described in Section 1.4 of the SIP. For dioxin-TEQ and tributyltin, where no numeric water quality

JULY 27, 2007

objectives have been promulgated, these calculations rely on water quality criteria developed to translate the Basin Plan's narrative bioaccumulation and toxicity objectives as required by 40 CFR 122.44(d)(vi). Detailed WQBEL calculations are shown below in Table F-13.

With the exception of the sample collected for cyanide compliance, samples collected for compliance with these limits are taken at sample point EFF-001A. The cyanide sample is collected at sampling point EFF-002.

JULY 27, 2007

Table F-14. Calculation of WQBELs

| PRIORITY POLLUTANTS | Copper | | Lead | Mercury | Nickel |
|--|-----------------------------|-----------------------|-----------------------------|--|---|
| | ug/L | | ug/L | ug/L | ug/L |
| Units | BP & CTR, saltwater aq Life | Alt Limits Using SSOs | BP & CTR saltwater aq. life | BP saltwater aq. life and CTR human health | BP & CTR saltwater aq life & CTR human health |
| Basis and Criteria type | | | | | |
| CTR Criteria - Acute | 5.5 | ----- | 221 | 2.1 | 87 |
| CTR Criteria - Chronic | 4.2 | ----- | 8.5 | 0.025 | 13 |
| SSO Criteria - Acute | ----- | 3.9 | | | |
| SSO Criteria - Chronic | ----- | 2.5 | | | |
| Water Effects Ratio (WER) | 2.4 | 2.4 | 1 | | 1 |
| Lowest WQO | 4.2 | 2.5 | 8.5 | 0.025 | 13 |
| CTR Conv. Factor for Saltwater (Acute & Chronic) | 0.83 | 0.83 | 0.95 | | 0.99 |
| Site-Specific Translator - MDEL | 0.88 | 0.88 | | | 0.85 |
| Site-Specific Translator - AMEL | 0.74 | 0.74 | | | 0.65 |
| Dilution Factor (D) (if applicable) | 9 | 9 | 9 | 0 | 9 |
| No. of samples per month | 4 | 4 | 4 | 4 | 4 |
| Aquatic life criteria analysis required? (Y/N) | Y | Y | Y | Y | Y |
| HH criteria analysis required? (Y/N) | N | N | N | Y | Y |
| Applicable Acute WQO | 13 | 11 | 221 | 2.10 | 87 |
| Applicable Chronic WQO | 10 | 8.1 | 8.5 | 0.025 | 13 |
| HH criteria | ----- | ----- | ----- | 0.051 | 4600 |
| Background (Max. Conc for Aquatic Life calc) | 2.45 | 2.45 | 0.804 | 0.0086 | 3.73 |
| Background (Av. Conc for Human Health calc) | | | | 0.0022 | 1.79 |
| Is pollutant Bioaccumulative(Y/N)? (e.g., Hg) | N | N | N | Y | N |
| ECA acute | 109 | 84 | 2201 | 2.10 | 837 |
| ECA chronic | 78 | 59 | 78 | 0.025 | 93 |
| ECA HH | | | | 0.051 | 45984 |
| CV | 0.60 | 0.60 | 0.60 | 0.60 | 0.60 |
| ECA acute mult99 | 0.32 | 0.32 | 0.32 | 0.32 | 0.32 |
| ECA chronic mult99 | 0.53 | 0.53 | 0.53 | 0.53 | 0.53 |
| LTA acute | 34.95 | 27.07 | 706.69 | 0.67 | 268.75 |
| LTA chronic | 41.40 | 31.13 | 41.11 | 0.01 | 48.83 |
| Minimum of LTAs | 35 | 27 | 41.11 | 0.01 | 49 |
| AMEL mult95 | 1.55 | 1.55 | 1.55 | 1.55 | 1.55 |
| MDEL mult99 | 3.11 | 3.11 | 3.11 | 3.11 | 3.11 |
| AMEL (aq life) | 54.26 | 42.03 | 63.82 | 0.020 | 75.81 |
| MDEL(aq life) | 108.86 | 84.31 | 128.03 | 0.041 | 152.08 |
| MDEL/AMEL Multiplier | 2.01 | 2.01 | 2.01 | 2.01 | 2.01 |
| AMEL (human hlth) | | | | 0.051 | 45984 |
| MDEL (human hlth) | | | | 0.102 | 92252 |
| Minimum of AMEL for Aq. life vs HH | 54 | 42 | 64 | 0.020 | 76 |
| Minimum of MDEL for Aq. Life vs HH | 109 | 84 | 128 | 0.041 | 152 |
| WQBEL - AMEL | 54 | 42 | 64 | 0.020 | 76 |
| WQBEL - MDEL | 110 | 84 | 130 | 0.041 | 150 |

| PRIORITY POLLUTANTS | Cyanide | Dioxin TEQ | Aldrin | Alpha-BHC | Beta-BHC |
|---|--|-----------------------------------|--|------------------------|------------------------|
| Units | ug/L | ug/L | | ug/L | |
| Basis and Criteria type | NTR saltwater aq. Life & human health | BP narrative (bioaccumulation) | CTR saltwater aq. Life and human health | CTR human health | CTR human health |
| CTR Criteria - Acute | 1.0 | ----- | 1.3 | ----- | ----- |
| CTR Criteria - Chronic | 1.0 | ----- | ----- | ----- | ----- |
| SSO Criteria - Acute | | | | | |
| SSO Criteria - Chronic | | | | | |
| Water Effects Ratio (WER) | | | | | |
| Lowest WQO | 1.0 | 1.40E-08 | 0.00014 | 0.013 | 0.046 |
| CTR Conv. Factor for Saltwater (Acute&Chronic) | | | | | |
| Site-Specific Translator - MDEL | | | | | |
| Site-Specific Translator - AMEL | | | | | |
| Dilution Factor (D) (if applicable) | 72 | 0 | 9 | 9 | 9 |
| No. of samples per month | 4 | 4 | 4 | 4 | 4 |
| Aquatic life criteria analysis required? (Y/N) | Y | N | Y | N | N |
| HH criteria analysis required? (Y/N) | Y | Y | Y | Y | Y |
| Applicable Acute WQO | 1.0 | ----- | 1.3 | | ----- |
| Applicable Chronic WQO | 1.0 | ----- | ----- | | ----- |
| HH criteria | 220,000 | 1.40E-08 | 0.00014 | 0.013 | 0.046 |
| Background (Max. Conc for Aquatic Life calc) | 0.4 | 7.10E-08 | No Data | 0.00050 | 0.00041 |
| Background (Av. Conc for Human Health calc) | | 5.00E-08 | | 0.00024 | 0.00014 |
| Is pollutant Bioaccumulative(Y/N)? (e.g., Hg) | N | Y | N | N | N |
| ECA acute | 44.2 | | 1.3 | | |
| ECA chronic | 44.2 | | ----- | | |
| ECA HH | 220000 | 1.40E-08 | 1.40E-04 | 0.128 | 4.56E-01 |
| CV | 0.76 | 0.60 | 0.60 | 0.60 | 0.60 |
| ECA acute mult99 | 0.26 | | 0.32 | | |
| ECA chronic mult99 | 0.46 | | 0.53 | | |
| LTA acute | 11.6 | | 0.42 | | |
| LTA chronic | 20.2 | | | | |
| Minimum of LTAs | 11.6 | | 0.42 | | |
| AMEL mult95 | 1.71 | 1.55 | 1.55 | 1.55 | 1.55 |
| MDEL mult99 | 3.82 | 3.11 | 3.11 | 3.11 | 3.11 |
| AMEL (aq life) | 19.8 | | 0.65 | | |
| MDEL(aq life) | 44.2 | | 1.30 | | |
| MDEL/AMEL Multiplier | 2.23 | 2.01 | 2.01 | 2.01 | 2.01 |
| AMEL (human hlth) | 220000 | 1.40E-08 | 0.00014 | 0.128 | 0.456 |
| MDEL (human hlth) | 491600 | 2.81E-08 | 0.00028 | 0.256 | 0.915 |
| Minimum of AMEL for Aq. life vs HH | 20 | 1.40E-08 | 0.00014 | 0.128 | 0.456 |
| Minimum of MDEL for Aq. Life vs HH | 44 | 2.81E-08 | 0.00028 | 0.256 | 0.915 |
| WQBEL - AMEL | 20 | 1.40E-08 | 0.00014 | 0.128 | 0.46 |
| WQBEL - MDEL | 44 | 2.81E-08 | 0.00028 | 0.256 | 0.92 |

JULY 27, 2007

| PRIORITY POLLUTANTS | 4,4-DDT | 4,4-DDE | Dieldrin | Endrin | Heptachlor | Heptachlor Epoxide | Tributyltin |
|--|------------------|------------------|---------------------------------------|---------------------------------------|---------------------------------------|---------------------------------------|---------------------------------|
| Units | | | | | | | |
| Basis and Criteria type | CTR human health | CTR human health | CTR saltwater aq. life & human health | Basin Plan narrative (toxicity) |
| CTR Criteria - Acute | 0.13 | ----- | 0.71 | 0.037 | 0.053 | 0.053 | ----- |
| CTR Criteria - Chronic | 0.001 | ----- | 0.0019 | 0.0023 | 0.0036 | 0.0036 | ----- |
| SSO Criteria - Acute | | | | | | | |
| SSO Criteria - Chronic | | | | | | | |
| Water Effects Ratio (WER) | | | | | | | |
| Lowest WQO | 0.00059 | 0.00059 | 0.00014 | 0.0023 | 0.00021 | 0.00011 | 0.0074 |
| CTR Conv. Factor for Saltwater (Acute&Chronic) | | | | | | | |
| Site-Specific Translator - MDEL | | | | | | | |
| Site-Specific Translator - AMEL | | | | | | | |
| Dilution Factor (D) (if applicable) | 0 | 0 | 0 | 9 | 9 | 9 | 9 |
| No. of samples per month | 4 | 4 | 4 | 4 | 4 | 4 | 4 |
| Aquatic life criteria analysis required? (Y/N) | Y | N | Y | Y | Y | Y | Y |
| HH criteria analysis required? (Y/N) | Y | Y | Y | Y | Y | Y | N |
| Applicable Acute WQO | 0.13 | ----- | 0.71 | 0.037 | 0.053 | 0.053 | 0.42 |
| Applicable Chronic WQO | 0.001 | ----- | 0.0019 | 0.0023 | 0.0036 | 0.0036 | 0.0074 |
| HH criteria | 0.00059 | 0.00059 | 0.00014 | 0.81 | 0.00021 | 0.00011 | |
| Background (Max. Conc for Aquatic Life calc) | 0.000066 | 0.00069 | 0.00026 | 0.000036 | 0.000019 | 0.000025 | 0 |
| Background (Av. Conc for Human Health calc) | 0.000026 | 0.000069 | 0.000073 | 0.000013 | 0.0000075 | 0.000024 | 0 |
| Is pollutant Bioaccumulative(Y/N)? (e.g., Hg) | Y | Y | Y | N | N | N | N |
| ECA acute | 0.1 | | 0.7 | 0.4 | 0.5 | 0.5 | 4.2 |
| ECA chronic | 0.0 | | 0.0 | 0.0 | 0.0 | 0.0 | .074 |
| ECA HH | 5.90E-04 | 5.90E-04 | 1.40E-04 | 8.10E+00 | 2.03E-03 | 8.87E-04 | |
| CV | 0.60 | 0.60 | 0.60 | 0.60 | 0.60 | 0.60 | 0.60 |
| ECA acute mult99 | 0.32 | | 0.32 | 0.32 | 0.32 | 0.32 | 0.32 |
| ECA chronic mult99 | 0.53 | | 0.53 | 0.53 | 0.53 | 0.53 | 0.53 |
| LTA acute | 0.04 | | 0.23 | 0.12 | 0.17 | 0.17 | |
| LTA chronic | 0.00 | | 0.00 | 0.01 | 0.02 | 0.02 | 0.04 |
| Minimum of LTAs | 0.00 | | 0.00 | 0.01 | 0.02 | 0.02 | 0.04 |
| AMEL mult95 | 1.55 | 1.55 | 1.55 | 1.55 | 1.55 | 1.55 | 1.55 |
| MDEL mult99 | 3.11 | 3.11 | 3.11 | 3.11 | 3.11 | 3.11 | 3.11 |
| AMEL (aq life) | 8.2E-04 | | 1.6E-03 | 0.02 | 0.03 | 0.03 | 0.06 |
| MDEL(aq life) | 1.6E-03 | | 3.1E-03 | 0.04 | 0.06 | 0.06 | 0.12 |
| MDEL/AMEL Multiplier | 2.01 | 2.01 | 2.01 | 2.01 | 2.01 | 2.01 | 2.01 |
| AMEL (human hlth) | 0.00059 | 0.00059 | 0.00014 | 8.1 | 0.0020 | 0.00089 | |
| MDEL (human hlth) | 0.0012 | 0.0012 | 0.00028 | 16 | 0.0041 | 0.0018 | |
| Minimum of AMEL for Aq. life vs HH | 0.00059 | 0.00059 | 0.00014 | 0.019 | 0.0020 | 0.00089 | 0.061 |
| Minimum of MDEL for Aq. Life vs HH | 0.0012 | 0.0012 | 0.00028 | 0.037 | 0.0041 | 0.0018 | 0.12 |
| WQBEL - AMEL | 0.00059 | 0.00059 | 0.00014 | 0.019 | 0.0020 | 0.00089 | 0.061 |
| WQBEL - MDEL | 0.0012 | 0.0012 | 0.00028 | 0.037 | 0.0041 | 0.0018 | 0.12 |

| | Total Ammonia Acute, mg/l | Total Ammonia Chronic, mg/l |
|---|------------------------------|--------------------------------|
| Basis and Criteria type | Basin Plan | Basin Plan |
| CTR Criteria -Acute | 14.45 | |
| CTR Criteria -Chronic | | 1.52 |
| Lowest WQO | 14.45 | 1.52 |
| Dilution Factor (D) (if applicable) | 73 | 73 |
| No. of samples per month | 4 | 30 |
| Aquatic life criteria analysis required? (Y/N) | Y | Y |
| HH criteria analysis required? (Y/N) | N | N |
| Applicable Acute WQO | 14.45 | |
| Applicable Chronic WQO | | 1.52 |
| HH criteria | N | N |
| Background (Maximum Conc for Aquatic Life calc) | 0.21 | 0.1 ⁽¹⁾ |
| Background (Average Conc for Human Health calc) | | |
| Is the pollutant Bioaccumulative(Y/N)? (e.g., Hg) | N | N |
| ECA acute | 1054 | |
| ECA chronic | | 105.2 |
| ECA HH | | |
| No. of data points <10 or at least 80% of data reported non detect? (Y/N) | N | N |
| Avg of effluent data points | | |
| Std Dev of effluent data points | | |
| CV calculated | | |
| CV (Selected) - Final | 0.6 | 0.6 |
| ECA acute mult99 | 0.32 | |
| ECA chronic mult99 | | 0.93 |
| LTA acute | 338.4 | |
| LTA chronic | | 97.8 |
| minimum of LTAs | 338.4 | 97.8 |
| AMEL mult95 | 1.55 | 1.19 |
| MDEL mult99 | 3.11 | 3.11 |
| AMEL (aq life) | 525 | 116 |
| MDEL (aq life) | 1054 | 305 |
| AMEL (human hlth) | | |
| MDEL (human hlth) | | |
| minimum of AMEL for Aq. life vs HH | 525 | 116 |
| minimum of MDEL for Aq. Life vs HH | 1054 | 305 |
| Current limit in permit (30-day average) | ----- | ----- |
| Current limit in permit (daily) | ----- | ----- |
| Final limit - AMEL | 525 | 116 |
| Final limit - MDEL | 1054 | 305 |
| Max Effl Conc (MEC) | 118 | 118 |

⁽¹⁾ Because the Basin Plan chronic un-ionized ammonia objective is an annual median, the median background concentration is used in the reasonable potential analysis.

(e) Alternate Limits for Copper

The Regional Water Board has proposed site-specific objectives for copper. WQBELs based on these objectives would differ from those calculated using existing criteria. Therefore, this Order includes alternative limits to become effective if site specific objectives are adopted. As described in the Clean Estuary Partnership’s North of Dumbarton Bridge Copper and Nickel Site-Specific Objective Determination (December 2004), the Regional Water Board is proposing to develop site-specific criteria for copper in non-ocean, marine waters

of the Region that are 2.5 and 3.9 µg/l as four-day and one-hour average criteria. Final effluent limitations, calculated according to Section 1.4 of the SIP, using a WER of 2.4, would be 52 µg/l (AMEL) and 84 µg/l (MDEL). If the site-specific objectives for copper are adopted, the alternate effluent limits will become effective upon the adoption date, so long as the site-specific objectives and their current justification remain unchanged from those proposed in the December 2004 report.

5. Anti-Backsliding/Antidegradation

The Clean Water Act (33 U.S.C. § 1251(o)) generally prohibits backsliding, i.e., adopting new permit limits that are less stringent than the limits in the permit being replaced, except under special circumstances. Table F-16 compares the newly calculated limits with limits established in the previous permits.

Table F-15 shows that new effluent limits have been established for lead, cyanide, dioxin-TEQ, aldrin, alpha-BHC, 4,4-DDT, endrin, heptachlor, heptachlor epoxide and tributyltin. For mercury, 4,4-DDE and dieldrin, the newly calculated limits are equivalent or more stringent than the limits in the previous permit.

Table F-15. Newly Calculated Limits versus Previous Limits

| CTR # | Pollutant | San Permit 01-045 AMEL, µg/l | San Permit 01-045 MDEL, µg/l | Ind. Permit R2-2002-045 AMEL, µg/l | Ind. Permit R2-2002-045 MDEL, µg/l | New calc. limits AMEL, µg/l | New calc. limits MDEL, µg/l |
|-------|--------------------|------------------------------|------------------------------|------------------------------------|------------------------------------|-----------------------------|-----------------------------|
| 6 | Copper | | 33 (interim) | | 17 (interim) | 54 | 110 |
| 6 | Copper alt. limit | | | | | 42 | 84 |
| 7 | Lead | | | | | 64 | 130 |
| 8 | Mercury | 0.087 (interim) | 1 (interim) | 0.087 (interim) | 1 (interim) | 0.02 | 0.041 |
| 9 | Nickel | | | 30 | 70 | 76 | 150 |
| 14 | Cyanide | | 10 (interim) | | | 20 | 44 |
| | Dioxin-TEQ | | | | | 1.4E-08 | 2.8E-08 |
| 102 | Aldrin | | | | | 0.00014 | 0.00028 |
| 103 | Alpha-BHC | | 0.078 (interim) | | | 0.13 | 0.26 |
| 104 | Beta-BHC | | 0.085 (interim) | | 0.19 (interim) | 0.46 | 0.92 |
| 108 | 4,4-DDT | | | | | 0.00059 | 0.0012 |
| 109 | 4,4-DDE | 0.00059 | 0.0012 | 0.00059 | 0.0012 | 0.00059 | 0.0012 |
| 111 | Dieldrin | 0.00014 | 0.00028 | 0.00014 | 0.00028 | 0.00014 | 0.00028 |
| 115 | Endrin | | | | | 0.019 | 0.037 |
| 117 | Heptachlor | | | | | 0.002 | 0.0041 |
| 118 | Heptachlor Epoxide | | | | | 0.00089 | 0.0018 |
| | Ammonia | | | | | 120,000 | 310,000 |
| | Tributyltin | 0.13 | 0.37 | | | 0.061 | 0.12 |

For copper, nickel, and beta-BHC, the newly calculated limits may appear to be less stringent. However, this is not necessarily the case since a new compliance point is specified in the Order that includes Sanitary Plant effluent. Even if the limits are less stringent, moving the monitoring station is a material and substantial alteration to the permitted facility because it changes the effluent being monitored. Thus, under the Clean Water Act (33USC §1251(o)(2)(A)), less stringent effluent limitations can be established without violating anti-backsliding requirements. Furthermore, the previous permit limits for copper and beta-BHC are interim limits and are not comparable to final limits proposed in this Order. According to the State Water Board's Tosco Order (WQ Order 2002-06), anti-backsliding applies to comparable limits; in other words, interim to interim and final to final.

Section III.C.8 of this Fact Sheet discusses why implementation of the new limits are consistent with antidegradation policies.

6. Whole Effluent Acute Toxicity

- a. *Permit Requirements.* This Order includes effluent limitations for whole-effluent acute toxicity that are unchanged from the previous Order and are based on the Basin Plan (Section 4.5.5.3.1). All bioassays shall be performed according to the USEPA approved method in 40 CFR Part 136, currently "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, 5th Edition." The Discharger is required to use the 5th Edition method for compliance determination upon the effective date of this Order. The previous Order required the Discharger to use the "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, 3rd Edition" from permit adoption until November 30, 2002 using fathead minnows and three-spined sticklebacks. From December 1, 2002 to permit expiration, the Discharger was required to use the "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, 4th Edition" using fathead minnows.
- b. *Compliance History.* The Discharger's acute toxicity monitoring data from 2002 – 2006 show that there were several exceedances of the effluent limitations during the permit term, with fish survival rates ranging between 15 and 100 percent. In particular, there were several exceedances of the 11-sample 90th percentile limit of not less than 70 percent survival; 30 percent survival was reported for 8 months from October 2005 through March 2006. Enforcement actions for these exceedances are pending.
- c. *Ammonia Toxicity.* If acute toxicity is observed in the future and the Discharger believes that it is due to ammonia toxicity, the Discharger must show this through a Toxicity Identification Evaluation (TIE) acceptable to the Executive Officer. If the Discharger demonstrates to the satisfaction of the Executive Officer that

exceedance of the acute toxicity limitations is caused by ammonia and that the discharge is in compliance with the ammonia effluent limits, then such toxicity does not constitute a violation of this effluent limit. If ammonia toxicity is verified in the TIE, the Discharger may utilize an adjustment protocol approved by the Executive Officer for the routine bioassay testing.

7. Whole Effluent Chronic Toxicity

- a. *Permit Requirements.* This Order includes requirements for chronic toxicity monitoring based on the Basin Plan (Section 4.5.5.3.2) and in accordance with USEPA and State Water Board Task Force guidance. This Order includes the Basin Plan narrative toxicity objective as the applicable effluent limit, implemented via monitoring with numeric values as “triggers” to initiate accelerated monitoring and to initiate a chronic toxicity reduction evaluation (TRE) as necessary. The permit requirements for chronic toxicity are also consistent with the CTR and SIP requirements.
- b. *Chronic Toxicity Triggers.* This Order includes chronic toxicity triggers, which are three sample median of 10 chronic toxicity (TUc¹) and a single sample maximum of 20 TUc based on Basin Plan Table 4-6 for dischargers to deepwater environments monitoring semi-annually.
- c. *Monitoring History.* The Discharger’s chronic toxicity monitoring data show that there were no exceedances of the triggers between 2003 and 2006.
- d. *Screening Phase Study.* The Discharger has prepared a chronic toxicity screening phase study plan and the results of this study have been incorporated (Appendix E, Section V.B).
- e. *Permit Re-opener.* The Regional Water Board will consider amending this Order to include numeric toxicity limitations if the Discharger fails to aggressively implement all reasonable control measures included in its approved TRE workplan following detection of consistent significant non-artifactual toxicity.

8. Chlorine

The instantaneous maximum limitation for chlorine of 0.0 mg/l is retained by this Order. This limitation is required by the Basin Plan.

¹ A TUc equals 100 divided by the no observable effect level (NOEL). The NOEL is determined from IC, EC, or NOEC values. Monitoring and TRE requirements may be modified by the Executive Officer in response to the degree of toxicity detected in the effluent or in ambient waters related to the discharge. Failure to conduct the required toxicity tests or a TRE within a designated period shall result in the establishment of effluent limitations for chronic toxicity.

D. Interim Effluent Limitations and Compliance Schedules

The SIP and the Basin Plan authorize compliance schedules in a permit if an existing Discharger cannot immediately comply with a new and more stringent effluent limitation. The SIP and Basin Plan require the following documentation be submitted to the Regional Water Board to support a finding of infeasibility:

- Descriptions of diligent efforts the Discharger has made to quantify pollutant levels in the discharge, sources of the pollutant in the waste stream, and the results of those efforts.
- Descriptions of source control and/or pollutant minimization efforts currently underway or completed.
- Proposed schedule for additional or future source control measures, pollutant minimization, or waste treatment.
- Demonstration that the proposed schedule is as short as practicable.

The Basin Plan provides for a 10-year compliance schedule to implement measures to comply with new standards as of the effective date of those standards. The provision authorizes compliance schedules for new interpretations of other existing standards if the new interpretation results in more stringent limitations. Pursuant to State Water Board Order WQ 2007-0004, this has been limited to new interpretations of narrative standards, not numeric standards.

1. Feasibility Evaluation

On January 11, 2007, the Discharger submitted an Infeasibility Analysis evaluating its ability to comply with proposed final effluent limits. The Infeasibility Study asserted that the Discharger could not immediately comply with WQBELs for mercury, cyanide, dioxin-TEQ, aldrin, alpha-BHC, beta-BHC, 4,4-DDT, 4,4-DDE, dieldrin, endrin, heptachlor, and heptachlor epoxide. After the Infeasibility Study was submitted, the Regional Water Board staff independently evaluated the feasibility of compliance with the revised limits, as described below.

Regional Board staff concurs that immediate compliance with WQBELs for mercury, dioxin-TEQ, aldrin, 4,4-DDT, heptachlor and heptachlor epoxide is infeasible. Except for mercury, this Order establishes compliance schedules for these pollutants. Regional Water Board staff disagrees with the Discharger's assertions for cyanide because the currently proposed limits are higher than those anticipated by the Discharger based on its review of previously drafted limits. The revised limits now relate to a new compliance point and reflect a dilution ratio of 72:1, and compliance is feasible. Regional Water Board staff also disagrees with the Discharger's assertions for alpha-BHC, beta-BHC and endrin because the currently proposed limits are higher than those anticipated by the Discharger based on its review of previously drafted limits. The revised limits now reflect a default coefficient of variation of 0.6 and a dilution ratio of 10:1, and compliance is feasible. Although Regional Water Board staff agrees that the Discharger may have

JULY 27, 2007

difficulty complying with the 4,4-DDE and dieldrin limits, these pollutants were limited in the previous permit with limits identical to those in this Order.

Pursuant to State Water Board Order WQ2007-0004, compliance schedules are not authorized for numeric objectives or criteria that were in effect prior to the SIP. This includes Basin Plan objectives for mercury. Because it is infeasible for the Discharger to immediately comply with final WQBELs for mercury and the pesticides, the Discharger will discharge in violation of this Order. Therefore a Cease and Desist order will be adopted concurrent with this Order. The Cease and Desist Order is necessary to ensure that the Discharge achieves compliance. It establishes time schedules for the Discharger to complete necessary investigative, preventative, and remedial actions to address its imminent and threatened violations..

The Regional Water Board's approach to evaluating the feasibility of compliance is based on comparing maximum effluent concentrations (MECs) at the Sanitary and Industrial wastewater treatment plants with the calculated WQBELs. Because no monitoring data exist for the combined outfall, a more rigorous statistical analysis is impossible.

Table F-16 compares the calculated average monthly and maximum daily effluent limits with the maximum effluent concentrations (MECs) found during monitoring of effluent from the Sanitary and Industrial Plants. Because the new monitoring location (EFF-001A) for this Order is located after the waste streams from the Sanitary and Industrial Plants have been combined, a weighted average (based on actual historical average flows) was used to estimate the MEC in the combined flow. In the future, the actual MECs are likely to be lower because the two plants are unlikely to discharge maximum concentrations simultaneously.

The flow weighted MECs are less than the WQBELs, and therefore compliance is feasible, for copper (with and without the proposed SSO), lead, nickel, alpha-BHC, beta-BHC, endrin and tributyltin. In contrast, the flow weighted MECs exceed the WQBELS, and therefore compliance may be infeasible, for mercury, dioxin-TEQ, aldrin, 4,4-DDT, heptachlor, and heptachlor epoxide. Compliance schedules are granted for dioxin, aldrin, DDT, heptachlor and heptachlor epoxide. Others are subject to a Cease and Desist Order.

Regional Water Board staff concludes that compliance is feasible for cyanide. Although the flow-weighted average MEC may be somewhat greater than the limit, that MEC does not reflect conditions at the NBSU joint outfall, where cyanide compliance is to be determined. The data collected at the Sanitary and Industrial Plants may also reflect analytical interference during the cyanide tests due to chlorination. However, cyanide data exist for the NBSU outfall (which is after dechlorination and thus does not exhibit the analytical challenges found at the Sanitary and Industrial Plant outfalls). There, the MEC is 8.5 ug/L, which is less than the new limits. Therefore, compliance is feasible.

Table F-16 Feasibility to Comply

| CTR | Pollutant | Calculated limits µg/l | | MEC µg/l | | | Feasible to comply? |
|-----|--------------------|------------------------|---------|------------------------|----------------------|-----------------------|---------------------|
| | | AMEL | MDEL | Sanitary | Industrial | Weighted average flow | |
| 6 | Copper | 54 | 110 | 14 | 41 | 26 | Yes |
| 6 | Copper SSO | 42 | 84 | 14 | 41 | 26 | Yes |
| 7 | lead | 64 | 130 | 5 | 71 | 35 | Yes |
| 8 | Mercury | 0.020 | 0.041 | 0.087 | 0.034 | 0.063 | No |
| 9 | Nickel | 76 | 150 | 15 | 30 | 22 | Yes |
| 14 | Cyanide | 20 | 44 | 16 | 33 | 24 | Yes ⁽²⁾ |
| | Dioxin-TEQ | 1.4E-08 | 2.8E-08 | 3.6E-07 ⁽¹⁾ | 4.7E-07 | 4.1E-07 | No |
| 102 | Aldrin | 0.00014 | 0.00028 | 0.0090 | 0.005 ⁽¹⁾ | 0.0072 | No |
| 103 | alpha-BHC | 0.13 | 0.26 | 0.005 ⁽¹⁾ | 0.051 | 0.026 | Yes |
| 104 | Beta-BHC | 0.46 | 0.92 | 0.13 | 0.039 | 0.089 | Yes |
| 108 | 4,4-DDT | 0.00059 | 0.0012 | 0.053 | 0.01 ⁽¹⁾ | 0.034 | No |
| 109 | 4,4-DDE | 0.00059 | 0.0012 | 0.050 | 0.01 ⁽¹⁾ | 0.032 | No |
| 111 | Dieldrin | 0.00014 | 0.00028 | 0.014 | 0.01 ⁽¹⁾ | 0.012 | No |
| 115 | Endrin | 0.019 | 0.037 | 0.021 | 0.010 | 0.016 | Yes |
| 117 | Heptachlor | 0.002 | 0.0041 | 0.26 | 0.035 | 0.16 | No |
| 118 | Heptachlor Epoxide | 0.00089 | 0.0018 | 0.022 | 0.005 | 0.014 | No |
| | Ammonia | 120,000 | 320,000 | 118,000 | 6,900 | 68,000 | Yes |
| | Tributyltin | 0.061 | 0.12 | 0.019 | 0.0046 | 0.013 | Yes |

| Effluent Flow rates, MGD | Sanitary | Industrial | Total |
|--------------------------|----------|------------|-------|
| Average | 0.8 | 0.65 | 1.45 |

⁽¹⁾ Nondetect reported; value shown is minimum method detection limit.

⁽²⁾ Compliance is feasible because the MEC at the compliance point (the NBSU outfall) is 8.5 µg/l, which is less than the calculated limits.

2. Compliance Schedules

This Order establishes schedules for compliance with final effluent limitations for dioxin-TEQ, aldrin, 4,4-DDT, heptachlor, and heptachlor epoxide.

The compliance schedule for dioxin-TEQ extends until June 30, 2017, ten years from the effective date of this Order. This schedule is based on the Basin Plan, because this limit implements the Basin Plan's narrative bioaccumulation objective.

The compliance schedules for aldrin, 4,4-DDT, heptachlor, and heptachlor epoxide extend to May 18, 2010. These schedules are based on the CTR. Because these schedules extend beyond one year, pursuant to the SIP and 40 CFR 122.47, the Regional Water Board must establish interim numeric limitations, if feasible, and interim requirements to control these pollutants. Since

JULY 27, 2007

compliance by May 18, 2010 is unlikely, and the Discharger will then threaten to violate the effluent limitations for these pollutants a Cease and Desist Order for these pollutants has been proposed.

3. Interim Limits

Interim limits for pollutants with compliance schedules may be based on current performance or previous permit limits. A statistical analysis of current performance is not possible because no data exist for the new combined monitoring location and, in the case of the chlorinated pesticides and Dioxin-TEQ, there is insufficient data, because of non-detects, to calculate a performance limit.

Pursuant to 40 CFR 122.44(k)(3), where numerical limits are infeasible, best management practices may be required. Best Management Practices are required in VI.C.4 of the Order.

The SIP suggests that mass limitations should be established for bioaccumulative pollutants that have been included on the 303(d) list for the receiving water. Because mercury is bioaccumulative and is included in the 303(d) list for Lower San Francisco Bay, the previous Order (R2-2002-0045) established a mass emission limit for mercury of 0.026 kilograms per month (kg/month). However, because compliance with WQBELs will be determined after combination of the treated effluent from both the Sanitary and Industrial Plants, the mass emission limitations for the Sanitary Plant, established in the previous Order (01-145) of 0.018 kg/month is added to the limitation for the Industrial Plant to derive the combined mass emission limitation of 0.044 kg/month.

E. Summary of Final Effluent Limitations

- Following, Table F-17, is a summary of the technology-based and water quality-based effluent limitations established by this Order. Except for cyanide and chlorine, samples are collected from Discharge Point 001. Cyanide and chlorine samples are collected from sampling point EFF-002.

Table F-17. Summary of Effluent Limitations

| Parameter | Units | Effluent Limitations | | | | |
|--------------------------|-------|-------------------------|----------------|------------------------|-----------------------|-----------------------|
| | | Average Monthly | Average Weekly | Maximum Daily | Instantaneous Minimum | Instantaneous Maximum |
| CBOD ₅ | mg/l | 25 | 40 | -- | -- | -- |
| TSS | mg/l | 30 | 45 | -- | -- | -- |
| Oil and Grease | mg/l | 10 | -- | 20 | -- | -- |
| pH | s.u. | -- | -- | -- | 6.0 | 9.0 |
| Chlorine, Total Residual | mg/l | --- | --- | --- | --- | 0.0 |
| Copper (1) | µg/l | 54 | -- | 110 | -- | -- |
| Lead | µg/l | 64 | -- | 120 | -- | -- |
| Mercury | µg/l | 0.020 | -- | 0.041 | -- | -- |
| Nickel | µg/l | 76 | -- | 150 | -- | -- |
| Cyanide | µg/l | 20 | -- | 44 | -- | -- |
| Dioxin-TEQ | µg/l | 1.40 x 10 ⁻⁸ | -- | 2.8 x 10 ⁻⁸ | -- | -- |
| Aldrin | µg/l | 0.00014 | -- | 0.00028 | -- | -- |
| alpha-BHC | µg/l | 0.13 | -- | 0.26 | -- | -- |
| beta-BHC | µg/l | 0.46 | -- | 0.92 | -- | -- |
| 4,4-DDT | µg/l | 0.00059 | -- | 0.0012 | -- | -- |
| 4,4-DDE | µg/l | 0.00059 | -- | 0.0012 | -- | -- |
| Dieldrin | µg/l | 0.00014 | -- | 0.00028 | -- | -- |
| Endrin | µg/l | 0.019 | -- | 0.037 | -- | -- |
| Heptachlor | µg/l | 0.0020 | -- | 0.0041 | -- | -- |
| Heptachlor Epoxide | µg/l | 0.00089 | -- | 0.0018 | -- | -- |
| Ammonia | mg/l | 120 | -- | 310 | -- | 1-- |
| Tributyltin | µg/l | 0.061 | -- | 0.12 | -- | -- |

(1) Alternate Effluent Limitations for Copper:

- If a copper SSO for the receiving water becomes legally effective, resulting in adjusted saltwater Criterion Continuous Concentration (CCC) of 2.5 µg/l and Criterion Maximum Concentration (CMC) of 3.9 µg/l as documented in the *North of Dumbarton Bridge Copper and Nickel Site-Specific Objective (SSO) Derivation (Clean Estuary Partnership December 2004)*, upon its effective date, the following limitations shall supersede those copper limitations listed in Table 6c.

AMEL of 42 µg/l, and MDEL of 84 µg/l.

- If a different copper SSO for the receiving water is adopted, the alternate WQBELs based on the SSO will be determined after the SSO effective date.

The Discharger shall also comply with the following effluent limitations.

- BOD and TSS 85 Percent Removal:** The average monthly percent removal of BOD and TSS shall not be less than 85 percent. The arithmetic mean of only those samples with a BOD₅ influent concentration of greater than 45 mg/l will be

used to determine compliance with the monthly BOD₅ 85 percent removal requirement.

- **Fecal Coliform Bacteria:** The treated wastewater shall meet the following limitations of bacteriological quality.

(1) The 5-day log mean fecal coliform density shall not exceed 200MPN/100ml; and

(2) The 90th percentile value of the last 10 values shall not exceed 400 MPN/100 ml.

- **Enterococci Bacteria:** The monthly geometric mean enterococci bacteria density shall not exceed 35 MPN/100 ml.

- **Effluent Limitations for Toxic Pollutants**

- **Acute Toxicity:** The Discharger shall comply with the following limitations for whole effluent acute toxicity.

11 sample median: A bioassay test showing survival of less than 90 percent represents a violation of this effluent limit, if five or more of the past 10 or fewer bioassay tests show less than 90 percent survival.

90th percentile: A bioassay test showing survival of less than 70 percent represents a violation of this effluent limit, if one or more of the past ten or fewer bioassay tests show less than 70 percent survival.

- **Chronic Toxicity:** Basin Plan's narrative toxicity objective.
- **Mercury Mass Emission Limitation:** Until TMDL and Waste Load Allocation (WLA) efforts for mercury provide enough information to establish a different WQBEL, a mass emission of mercury shall not exceed 0.0041 kg/month.

F. Land Discharge Specifications

Not Applicable

G. Reclamation Specifications

Not Applicable

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

A. Surface Water

Although the NBSU is responsible for the discharge to the receiving water, discharges from the Industrial Plant could impact receiving waters. Therefore, receiving water limitations V.A.1 and V.A.2 (conditions to be avoided) are retained from the previous Order but edited to more closely reflect water quality objectives for the physical, chemical, and biological characteristics of receiving waters established in Chapter III of the Basin Plan.

B. Groundwater

Not Applicable

VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

The principal purposes of a monitoring program by a discharger are to:

- Document compliance with waste discharge requirements and prohibitions established by the Regional Water Board,
- Facilitate self-policing by the discharger in the prevention and abatement of pollution arising from waste discharge,
- Develop or assist in the development of limitations, discharge prohibitions, national standards of performance, pretreatment and toxicity standards, and other standards, and
- Prepare water and wastewater quality inventories.

The MRP is a standard requirement in almost all NPDES permits issued by the Regional Water Board, including this Order. It contains definitions of terms, specifies general sampling and analytical protocols, and sets out requirements for reporting of spills, violations, and routine monitoring data in accordance with NPDES regulations, the California Water Code, and Regional Water Board's policies. The MRP also defines the sampling stations and frequency, the pollutants to be monitored, and additional reporting requirements. Pollutants to be monitored include all parameters for which effluent limitations are specified. Monitoring for additional constituents, for which no effluent limitations are established, is also required to provide data for future completion of RPAs for them.

A. Influent Monitoring

Influent monitoring requirements are unchanged and are retained from the previous Order. Periodic monitoring of CBOD₅ and TSS in influent allows determination of compliance with this Order's 85 percent removal requirement.

B. Effluent Monitoring

This previous Order established two effluent monitoring locations, E-001 and E-002. Monitoring location EFF-001-Ind represents effluent from the Industrial Plant after chlorination but prior to discharge into the combined forcemain-outfall. Monitoring location EFF-002 represents any point in the NBSU combined outfall after dechlorination between the point of at which all waste tributary to the NBSU combined outfall is present. The previous Order required effluent monitoring for all constituents, except chlorine residual and standard observations, at location E-001-Ind; monitoring for residual chlorine and standard observations were required at monitoring location E-002.

This Order adds a third monitoring location to represent the combined effluent from the Industrial and Sanitary Plants. The monitoring locations for this Order, including the new naming convention for the treatment plant outfalls, is configured as follows:

- Monitoring Location EFF-001-Ind. This location represents the former monitoring location E-001 from the previous Order. Monitoring for compliance with applicable technology-based effluent limitations and the mercury mass-emission limitation is required at this monitoring location.
- Monitoring Location EFF-001A. This new monitoring location represents the combined effluent from the Sanitary and Industrial Plants. Monitoring for compliance with all WQBELs will be required at this monitoring location (for both the Industrial and Sanitary Plants).
- Monitoring Location EFF-002. This location represents the former monitoring location E-002, at any point in the NBSU combined outfall after dechlorination.

The MRP retains effluent monitoring frequency and sample type requirements from the previous Order for flow rate, CBOD₅, TSS, fecal coliform bacteria, oil and grease, pH, total residual chlorine, acute and chronic toxicity, dissolved oxygen, temperature, toxic metals and organics, and standard observations. The following bulleted text highlights differences in monitoring requirements between the previous Order and the tentative Order.

- Routine monitoring for compliance with effluent limitations for settleable solids, and bromoform as the effluent limitations for these pollutants have not been retained from the previous Order.
- Once per month monitoring for enterococci bacteria using a grab sample has been added to monitor for compliance with the new effluent limitations.
- This Order requires routine monitoring only for those toxic pollutants that have effluent limitations established by this Order. Monitoring for all other toxic, priority pollutants must be conducted according to procedures and schedules established by the Regional Water Board's letter of August 6, 2001 to Permitted Wastewater Dischargers regarding Requirement for Monitoring Pollutants in Effluent and Receiving Water to Implement New Statewide Regulations and Policy.

JULY 27, 2007

- The monitoring location for compliance with WQBELs has been moved to new monitoring location, EFF-001A, representing the total effluent flow from the SFIA Mel Leong Treatment Plant (including flow from both the Sanitary Plant and the Industrial Plant). It should be noted that samples taken at Monitoring Location EFF-001A, and the resulting data, can be used for reporting compliance with WQBELs established in this Order for the Industrial Plant and may be applicable also to an Order established for the Sanitary Plant.
- This Order requires monitoring for total residual chlorine with an EPA approved method that will “achieve a method detection limit (MDL) at least as low as that achieved by the Amperometric Titration Method (4500-Cl D from Standard Methods for Examination of Water and Wastewater, Edition 20).” The Regional Water Board considers this method to be the least sensitive to interferences from color, turbidity, iron, manganese, and nitrite nitrogen, and capable of consistently achieving an MDL of less than 0.1 mg/l.

C. Whole Effluent Toxicity Testing Requirements

1. **Acute Toxicity.** Monthly 96-hour bioassay testing is required to demonstrate compliance with the effluent limitation for acute toxicity.
2. **Chronic Toxicity.** Chronic whole effluent toxicity testing is required two times per year in order to demonstrate compliance with the Basin Plan’s narrative toxicity objective.

D. Receiving Water Monitoring

1. Regional Monitoring Program

On April 15, 1992, the Regional Water Board adopted Resolution No. 92-043 directing the Executive Officer to implement the Regional Monitoring Program (RMP) for the San Francisco Bay. Subsequent to a public hearing and various meetings, Regional Water Board staff requested major permit holders in this region, under authority of section 13267 of California Water Code, to report on the water quality of the estuary. These permit holders responded to this request by participating in a collaborative effort, through the San Francisco Estuary Institute. This effort has come to be known as the San Francisco Bay Regional Monitoring Program for Trace Substances. This Order specifies that the Discharger shall continue to participate in the RMP, which involves collection of data on pollutants and toxicity in water, sediment and biota of the estuary.

2. Certain receiving water limited parameters are not monitored by the RMP or are not monitored close enough to the Discharger’s outfall to assure compliance with Receiving Water limits. This annual assessment is not burdensome and will assure compliance with limits.

E. Other Monitoring Requirements

1. Bypasses or Sewer Overflow Monitoring

JULY 27, 2007

The MRP includes new monitoring requirements to record observations related to bypasses or sanitary sewer overflows.

2. Sludge Monitoring

The Discharger is required to adhere to sludge monitoring requirements required by 40 CFR Part 503.

VII. RATIONALE FOR PROVISIONS

A. Standard Provisions (Provision VI.A)

Standard Provisions, which in accordance with 40 CFR §§122.41 and 122.42 apply to all NPDES discharges and must be included in every NPDES permit, are provided in **Attachments D and H** of this Order.

B. Monitoring and Reporting Requirements (Provision VI.B)

The Discharger is required to conduct monitoring of the permitted discharges in order to evaluate compliance with permit conditions. Monitoring requirements are contained in the MRP (**Attachment E**), Standard Provisions and SMP, Part A (**Attachment G**) of the Permit. This provision requires compliance with these documents and is based on 40 CFR 122.63. The Standard Provisions and SMP, Part A are standard requirements in almost all NPDES permits issued by the Regional Water Board, including this Order. They contain definitions of terms, specify general sampling and analytical protocols, and set out requirements for reporting of spills, violations, and routine monitoring data in accordance with NPDES regulations, the CWC, and Regional Water Board's policies. The MRP contains a sampling program specific for the facility. It defines the sampling stations and frequency, the pollutants to be monitored, and additional reporting requirements. Pollutants to be monitored include all parameters for which effluent limitations are specified. Monitoring for additional constituents, for which no effluent limitations are established, is also required to provide data for future completion of RPAs for them.

C. Special Provisions (Provision VI.C)

1. Reopener Provisions

These provisions are based on 40 CFR Part 123 and allow future modification of this Order and its effluent limitations as necessary in response to updated WQOs that may be established in the future.

2. Special Studies and Additional Monitoring Requirements

- a. Effluent Characterization Study. This Order does not include effluent limitations for the selected constituents addressed in the August 6, 2001 letter that do not demonstrate reasonable potential, but this provision requires the Discharger to continue monitoring for these pollutants as described in the August 6, 2001 letter

- and as specified in the MRP of this Order. If concentrations of these constituents increase significantly, the Discharger will be required to investigate the source of the increases and establish remedial measures if the increases result in reasonable potential to cause or contribute to an excursion above the applicable WQO/WQC. This provision is based on the Basin Plan and the SIP.
- b. Ambient Background Receiving Water Study. This provision is based on the Basin Plan, the SIP, and the August 6, 2001 letter for priority pollutant monitoring. As indicated in the Order, this requirement may be met by participating in the collaborative BACWA study.
 - c. Optional Mass Offset Plan. This option is provided to encourage the Discharger to further implement aggressive reduction of mass loads to Lower San Francisco Bay. If the Discharger wishes to pursue a mass offset program, a mass offset plan for reducing 303(d) listed pollutants to the same receiving water body needs to be submitted for Regional Water Board approval. The Regional Water Board will consider any proposed mass offset plan and amend this Order accordingly.

3. Best Management Practices and Pollution Minimization Program

This provision is based on Chapter 4 of the Basin Plan and Sections 2.2.1 and 2.4.5 of the SIP.

4. Requirement to Assure Compliance Schedules with Final Limits

This provision is based on the Basin Plan (Section 4.7.6 Compliance Schedules) and 40 CFR 122.47(a)(3). Maximum allowable compliance schedules are granted to the Discharger for dioxin-TEQ, aldrin, 4,4-DDT, heptachlor and heptachlor epoxide because of the considerable uncertainty in determining an effective measure such as pollution prevention and treatment plant upgrades that should be implemented to ensure compliance with final limits. It is appropriate to allow the Discharger sufficient time to first explore source control measures before requiring it to propose further actions, such as treatment plant upgrades that are likely to be much more costly. This approach is supported by the Basin Plan (Section 4.13 Pretreatment and Pollution Prevention), which states: "In general, it is often more economical to reduce overall pollutant loading into treatment systems than to install complex and expensive technology at the plant." Finally, because of the ubiquitous nature of the sources of dioxin-TEQ, this provision also allows the Discharger to address compliance with calculated WQBELs through other strategies such as mass offset.

5. Construction, Operation, and Maintenance Specifications

- a. Wastewater Facilities, Review and Evaluation, Status Reports: This provision is based on the previous Order and the Basin Plan. See Section VI.C.5.a of this Order for specific requirements.
- b. Operations and Maintenance Manual, Review and Status Reports: This provision is based on the Basin Plan, the requirements of 40 CFR §122, and the previous Order. See Section VI.C.5.b of this Order for specific requirements.

- c. Contingency Plan, Review and Status Reports: This provision is based on the Basin Plan, the requirements of 40 CFR §122, and the previous Order. See Section VI.C.5.c of this Order for specific requirements.

6. Special Provisions for Municipal Facilities (POTWs Only)

- a. Sludge Management Practice Requirements: This provision is based on the Basin Plan (Chapter 4) and 40 CFR Parts 257 and 503.
- b. Sanitary Sewer Overflows and Sewer System Management Plan: This provision is to explain this Order's requirements as they relate to the Discharger's conveyance system, and to promote consistency with the State Water Resources Control Board adopted Statewide General Waste Discharge Requirements for Sanitary Sewer Overflow (SSO WDRs) and a related Monitoring and Reporting Program (Order No. 2006-0003-DWQ). See Section VI.C.6.b of this Order for specific requirements.

7. Other Special Provisions

a. Cyanide Action Plan

The proposed cyanide site-specific objectives, if approved, will require action plans for source control. Implementation of a similar action plan for cyanide at this time would ensure that any increase in cyanide limits would be consistent limits expected with the site-specific objectives. Therefore, the antidegradation analysis prepared for the site-specific objectives could also apply to these limits, which would therefore comply with antidegradation policies (i.e., increasing the limits would not degrade the quality of the receiving water).

b. Copper Action Plan

The copper SSO Basin Plan Amendment, if approved, will require action plans for source control. Implementation of an action plan for copper is necessary to ensure that any increase in copper limits would be consistent with antidegradation policies (i.e., increasing the limits would not degrade the quality of the receiving water)

VIII. PUBLIC PARTICIPATION

The California Regional Water Quality Control Board, San Francisco Bay Region, is considering the issuance of waste discharge requirements (WDRs) that will serve as a National Pollutant Discharge Elimination System (NPDES) permit for San Francisco International Airport, Mel Leong Treatment Plant, Sanitary Plant. As a step in the WDR adoption process, the Regional Water Board staff has developed tentative WDRs. The Regional Water Board encourages public participation in the WDR adoption process.

JULY 27, 2007

A. Notification of Interested Parties

The Regional Water Board has notified the Dischargers and interested agencies and persons of its intent to prescribe WDRs for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Notification was provided through a public notice in the San Mateo Times on, or around, June 11, 2007.

B. Written Comments

The staff determinations are tentative. Interested persons are invited to submit written comments concerning these tentative WDRs. Comments must be submitted either in person or by mail to the Executive Officer at the Regional Water Board at the address above on the cover page of this Order.

To be fully responded to by staff and considered by the Regional Water Board, written comments should be received at the Regional Water Board offices by 5:00 p.m. on Wednesday July 11, 2007.

C. Public Hearing

The Regional Water Board will hold a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: August 8, 2007
Time: 9:00 AM
Location: Elihu Harris State Office Building
1515 Clay Street, 1st Floor Auditorium
Oakland, CA 94612

Contact: Derek Whitworth, (510) 622-2349, [email DWhitworth@waterboards.ca.gov](mailto:DWhitworth@waterboards.ca.gov)

Interested persons are invited to attend. At the public hearing, the Regional Water Board will hear testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our Web address is <http://www.waterboards.ca.gov/sanfranciscobay> where you can access the current agenda for changes in dates and locations.

D. Waste Discharge Requirements Petitions

Any aggrieved person may petition the State Water Resources Control Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

JULY 27, 2007

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

E. Information and Copying

The Report of Waste Discharge (RWD), related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Regional Water Board by calling 510-622-2300.

F. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

G. Additional Information

Requests for additional information or questions regarding this Order should be directed to Derek Whitworth at 510-622-2349 ([email at DWhitworth@waterboards.ca.gov](mailto:DWhitworth@waterboards.ca.gov)).

JUNE 8, 2007

APPENDIX A

RPA CALCULATIONS - INDUSTRIAL TREATMENT PLANT DATA

| | |
|----------------|--|
| Table 1 | Criteria (Table 1 in RPA spreadsheet) |
| Table 2 | Data Input for RPA (Table 2 in RPA spreadsheet) |
| Table 3 | Reasonable Potential Analysis Results (Table 3 in RPA spreadsheet) |
| Table 4 | Salinity and Hardness Data (Table 6 in RPA spreadsheet) |
| Table 5 | Dioxin-TEQ Data (Table 8 in RPA spreadsheet) |
| Table 6 | Total Metals – electronic version only (Table 9 in RPA spreadsheet) |
| Table 7 | Ammonia-Nitrogen Levels, Monthly average May 2005 – April 2007 |

**SFIA Mel Leong WQCP
Industrial Plant
Table 2 Data Input for RPA**

| CTR No. | Constituent name | EFFLUENT DATA | | | | | BACKGROUND DATA (B) | | | | | 7) Review other information in the SIP page 4. If information is unavailable or insufficient: 8) the RWQCB shall establish interim monitoring requirements. |
|---------|-------------------------------------|--------------------------------|--|--|---|-------------|---------------------|------------------------------|--|--|-------------|---|
| | | Effluent Data Available (Y/N)? | Are all data points non-detects (Y/N)? | If all data points ND Enter the min detection limit (MDL) (ug/L) | Enter the pollutant effluent detected max conc (ug/L) | Input Check | B Available (Y/N)? | Are all B non-detects (Y/N)? | If all data points ND Enter the min detection limit (MDL) (ug/L) | Enter the Detected Maximum Background Conc | Input Check | |
| 1 | Antimony | Y | N | | 3.0 | | Y | N | | 1.8 | | |
| 2 | Arsenic | Y | N | | 9.87 | | Y | N | | 2.46 | | |
| 3 | Beryllium | Y | Y | 0.5 | | | Y | N | | 0.215 | | No Criteria |
| 4 | Cadmium | Y | N | | 2.365 | | Y | N | | 0.1268 | | |
| 5a | Chromium (III) | N | | | | | N | | | | | |
| 5b | Chromium (VI) | Y | N | | 21.9 | | Y | N | | 4.4 | | |
| 6 | Copper | Y | N | | 41.296 | | Y | N | | 2.45 | | |
| 7 | Lead | Y | N | | 71.28 | | Y | N | | 0.8040 | | |
| 8 | Mercury (303d listed) | Y | N | | 0.034 | | Y | N | | 0.0086 | | |
| 9 | Nickel (303d listed) | Y | N | | 29.935 | | Y | N | | 3.73 | | |
| 10 | Selenium | Y | N | | 1.402 | | Y | N | | 0.39 | | |
| 11 | Silver | Y | N | | 0.305 | | Y | N | | 0.052 | | |
| 12 | Thallium | Y | N | | 0.3 | | Y | N | | 0.21 | | |
| 13 | Zinc | Y | N | | 56.64 | | Y | N | | 5.1 | | |
| 14 | Cyanide | Y | N | | 33 | | Y | Y | 0.4 | | | |
| 15 | Asbestos | N | | | | | N | | | | | No Criteria |
| 16 | 2,3,7,8-TCDD (Dioxin) (303d listed) | Y | Y | 8.23E-07 | | | N | | | | | |
| 16-TEQ | Dioxin TEQ (303d listed) | Y | N | | 4.74E-07 | | Y | N | | 7.10E-08 | | |
| 17 | Acrolein | Y | Y | 5 | | | Y | Y | 0.5 | | | |
| 18 | Acrylonitrile | Y | Y | 5 | | | Y | N | | 0.03 | | |
| 19 | Benzene | Y | Y | 0.5 | | | Y | Y | 0.05 | | | |
| 20 | Bromoform | Y | N | | 85 | | Y | Y | 0.5 | | | |
| 21 | Carbon Tetrachloride | Y | Y | 0.5 | | | Y | N | | 0.06 | | |
| 22 | Chlorobenzene | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 23 | Chlorodibromomethane | Y | N | | 22 | | Y | Y | 0.05 | | | |
| 24 | Chloroethane | Y | Y | 0.5 | | | Y | Y | 0.5 | | | No Criteria |
| 25 | 2-Chloroethylvinyl Ether | Y | Y | 0.5 | | | Y | Y | 0.5 | | | No Criteria |
| 26 | Chloroform | Y | N | | 5.6 | | Y | Y | 0.5 | | | No Criteria |
| 27 | Dichlorobromomethane | Y | N | | 8.5 | | Y | Y | 0.05 | | | |
| 28 | 1,1-Dichloroethane | Y | Y | 0.5 | | | Y | Y | 0.05 | | | No Criteria |
| 29 | 1,2-Dichloroethane | Y | Y | 0.5 | | | Y | N | | 0.04 | | |
| 30 | 1,1-Dichloroethylene | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 31 | 1,2-Dichloropropane | Y | Y | 0.5 | | | Y | Y | 0.05 | | | |
| 32 | 1,3-Dichloropropylene | Y | Y | 0.5 | | | N | | | | | |
| 33 | Ethylbenzene | Y | N | | 0.407 | | Y | Y | 0.5 | | | |
| 34 | Methyl Bromide | Y | N | | 0.34 | | Y | Y | 0.5 | | | |
| 35 | Methyl Chloride | Y | Y | 0.5 | | | Y | Y | 0.5 | | | No Criteria |
| 36 | Methylene Chloride | Y | N | | 0.383 | | Y | N | | 0.5 | | |
| 37 | 1,1,2,2-Tetrachloroethane | Y | Y | 0.5 | | | Y | Y | 0.05 | | | |
| 38 | Tetrachloroethylene | Y | Y | 0.5 | | | Y | Y | 0.05 | | | |
| 39 | Toluene | Y | N | | 2.33 | | Y | Y | 0.3 | | | |
| 40 | 1,2-Trans-Dichloroethylene | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 41 | 1,1,1-Trichloroethane | Y | N | | 0.7 | | Y | Y | 0.5 | | | No Criteria |
| 42 | 1,1,2-Trichloroethane | Y | Y | 0.5 | | | Y | Y | 0.05 | | | |
| 43 | Trichloroethylene | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 44 | Vinyl Chloride | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 45 | 2-Chlorophenol | Y | Y | 1.05 | | | Y | Y | 1.2 | | | |
| 46 | 2,4-Dichlorophenol | Y | Y | 1.2 | | | Y | Y | 1.3 | | | |
| 47 | 2,4-Dimethylphenol | Y | Y | 1 | | | Y | Y | 1.3 | | | |
| 48 | 2-Methyl-4,6-Dinitrophenol | Y | Y | 1 | | | Y | Y | 1.2 | | | |
| 49 | 2,4-Dinitrophenol | Y | Y | 3.89 | | | Y | Y | 0.7 | | | |
| 50 | 2-Nitrophenol | Y | Y | 1.86 | | | Y | Y | 1.3 | | | No Criteria |
| 51 | 4-Nitrophenol | Y | Y | 1.96 | | | Y | Y | 1.6 | | | No Criteria |
| 52 | 3-Methyl-4-Chlorophenol | Y | Y | 1 | | | Y | Y | 1.1 | | | No Criteria |
| 53 | Pentachlorophenol | Y | Y | 1.04 | | | Y | Y | 1 | | | |
| 54 | Phenol | Y | Y | 1 | | | Y | Y | 1.3 | | | |
| 55 | 2,4,6-Trichlorophenol | Y | Y | 1.88 | | | Y | Y | 1.3 | | | |
| 56 | Acenaphthene | Y | Y | 0.52 | | | Y | N | | 0.0015 | | |
| 57 | Acenaphthylene | Y | Y | 0.39 | | | Y | N | | 0.00053 | | No Criteria |
| 58 | Anthracene | Y | Y | 0.02 | | | Y | N | | 0.0005 | | |
| 59 | Benzidine | Y | Y | 2.5 | | | Y | Y | 0.0015 | | | |
| 60 | Benzo(a)Anthracene | Y | Y | 0.05 | | | Y | N | | 0.0053 | | |
| 61 | Benzo(a)Pyrene | Y | Y | 0.05 | | | Y | N | | 0.00029 | | |
| 62 | Benzo(b)Fluoranthene | Y | Y | 0.1 | | | Y | N | | 0.0046 | | |
| 63 | Benzo(ghi)Perylene | Y | Y | 0.09 | | | Y | N | | 0.0027 | | No Criteria |
| 64 | Benzo(k)Fluoranthene | Y | Y | 0.05 | | | Y | N | | 0.0015 | | |
| 65 | Bis(2-Chloroethoxy)Methane | Y | Y | 0.97 | | | Y | Y | 0.3 | | | No Criteria |
| 66 | Bis(2-Chloroethyl)Ether | Y | Y | 0.97 | | | Y | Y | 0.3 | | | |
| 67 | Bis(2-Chloroisopropyl)Ether | Y | Y | 0.81 | | | N | | | | | |
| 68 | Bis(2-Ethylhexyl)Phthalate | Y | Y | 0.69 | | | Y | Y | 0.5 | | | |
| 69 | 4-Bromophenyl Phenyl Ether | Y | Y | 1 | | | Y | Y | 0.23 | | | No Criteria |
| 70 | Butylbenzyl Phthalate | Y | Y | 0.95 | | | Y | Y | 0.52 | | | |
| 71 | 2-Chloronaphthalene | Y | Y | 1 | | | Y | Y | 0.3 | | | |
| 72 | 4-Chlorophenyl Phenyl Ether | Y | Y | 0.89 | | | Y | Y | 0.3 | | | No Criteria |
| 73 | Chrysene | Y | Y | 0.9 | | | Y | N | | 0.0024 | | |
| 74 | Dibenzo(a,h)Anthracene | Y | Y | 0.09 | | | Y | N | | 0.00064 | | |
| 75 | 1,2-Dichlorobenzene | Y | Y | 0.5 | | | Y | Y | 0.8 | | | |
| 76 | 1,3-Dichlorobenzene | Y | Y | 0.5 | | | Y | Y | 0.8 | | | |
| 77 | 1,4-Dichlorobenzene | Y | Y | 0.5 | | | Y | Y | 0.8 | | | |
| 78 | 3,3-Dichlorobenzidine | Y | Y | 0.9 | | | Y | Y | 0.001 | | | |
| 79 | Diethyl Phthalate | Y | Y | 1 | | | Y | Y | 0.24 | | | |
| 80 | Dimethyl Phthalate | Y | Y | 1 | | | Y | Y | 0.24 | | | |
| 81 | Di-n-Butyl Phthalate | Y | Y | 0.87 | | | Y | Y | 0.5 | | | |
| 82 | 2,4-Dinitrotoluene | Y | Y | 1 | | | Y | Y | 0.27 | | | |
| 83 | 2,6-Dinitrotoluene | Y | Y | 1.29 | | | Y | Y | 0.29 | | | No Criteria |
| 84 | Di-n-Octyl Phthalate | Y | N | | 2.0 | | Y | Y | 0.38 | | | No Criteria |
| 85 | 1,2-Diphenylhydrazine | Y | Y | 1 | | | Y | N | | 0.0037 | | |
| 86 | Fluoranthene | Y | Y | 0.1 | | | Y | N | | 0.011 | | |
| 87 | Fluorene | Y | Y | 0.1 | | | Y | N | | 0.00208 | | |
| 88 | Hexachlorobenzene | Y | Y | 0.98 | | | Y | N | | 0.0000202 | | |
| 89 | Hexachlorobutadiene | Y | Y | 1 | | | Y | Y | 0.3 | | | |
| 90 | Hexachlorocyclopentadiene | Y | Y | 1 | | | Y | Y | 0.31 | | | |
| 91 | Hexachloroethane | Y | Y | 1 | | | Y | Y | 0.2 | | | |
| 92 | Indeno(1,2,3-cd) Pyrene | Y | Y | 0.1 | | | Y | N | | 0.004 | | |

**SFIA Mel Leong WQCP
Industrial Plant
Table 2 Data Input for RPA**

| CTR No. | Constituent name | EFFLUENT DATA | | | | | BACKGROUND DATA (B) | | | | | 7) Review other information in the SIP page 4. If information is unavailable or insufficient: 8) the RWQCB shall establish interim monitoring requirements. |
|---------|---------------------------|--------------------------------|--|--|---|-------------|---------------------|------------------------------|--|--|-------------|---|
| | | Effluent Data Available (Y/N)? | Are all data points non-detects (Y/N)? | If all data points ND Enter the min detection limit (MDL) (ug/L) | Enter the pollutant effluent detected max conc (ug/L) | Input Check | B Available (Y/N)? | Are all B non-detects (Y/N)? | If all data points ND Enter the min detection limit (MDL) (ug/L) | Enter the Detected Maximum Background Conc | Input Check | |
| 93 | Isophorone | Y | Y | 0.95 | | | Y | Y | 0.3 | | | |
| 94 | Naphthalene | Y | Y | 1 | | | Y | N | | 0.0023 | | No Criteria |
| 95 | Nitrobenzene | Y | Y | 0.71 | | | Y | Y | 0.25 | | | |
| 96 | N-Nitrosodimethylamine | Y | Y | 0.1 | | | Y | Y | 0.3 | | | |
| 97 | N-Nitrosodi-n-Propylamine | Y | Y | 0.84 | | | Y | Y | 0.001 | | | |
| 98 | N-Nitrosodiphenylamine | Y | Y | 0.94 | | | Y | Y | 0.001 | | | |
| 99 | Phenanthrene | Y | Y | 0.93 | | | Y | N | | 0.0061 | | No Criteria |
| 100 | Pyrene | Y | Y | 0.1 | | | Y | N | | 0.0051 | | |
| 101 | 1,2,4-Trichlorobenzene | Y | Y | 0.94 | | | Y | Y | 0.3 | | | No Criteria |
| 102 | Aldrin | Y | Y | 0.005 | | | N | | | | | |
| 103 | alpha-BHC | Y | N | | 0.051 | | Y | N | | 0.000496 | | |
| 104 | beta-BHC | Y | N | | 0.039 | | Y | N | | 0.000413 | | |
| 105 | gamma-BHC | Y | Y | 0.005 | | | Y | N | | 0.0007034 | | |
| 106 | delta-BHC | Y | Y | 0.005 | | | Y | N | | 0.000042 | | No Criteria |
| 107 | Chlordane (303d listed) | Y | Y | 0.005 | | | Y | N | | 0.00018 | | |
| 108 | 4,4-DDT (303d listed) | Y | Y | 0.01 | | | Y | N | | 0.000066 | | |
| 109 | 4,4-DDE | Y | Y | 0.01 | | | Y | N | | 0.000693 | | |
| 110 | 4,4-DDD | Y | Y | 0.03 | | | Y | N | | 0.000313 | | |
| 111 | Dieldrin (303d listed) | Y | Y | 0.01 | | | Y | N | | 0.000264 | | |
| 112 | alpha-Endosulfan | Y | Y | 0.01 | | | Y | N | | 0.000031 | | |
| 113 | beta-Endosulfan | Y | Y | 0.01 | | | Y | N | | 0.000069 | | |
| 114 | Endosulfan Sulfate | Y | Y | 0.03 | | | Y | N | | 0.0000819 | | |
| 115 | Endrin | Y | N | | 0.01 | | Y | N | | 0.000036 | | |
| 116 | Endrin Aldehyde | Y | Y | 0.01 | | | N | | | | | |
| 117 | Heptachlor | Y | N | | 0.035 | | Y | N | | 0.000019 | | |
| 118 | Heptachlor Epoxide | Y | Y | 0.005 | | | Y | N | | 0.00002458 | | |
| 119-125 | PCBs sum (303d listed) | Y | Y | 0.47 | | | N | | | | | |
| 126 | Toxaphene | Y | Y | 0.5 | | | N | | | | | |
| | Ammonia ⁽²⁾ | Y | N | | 118,000 | | Y | N | | 210 | | |
| | Tributyltin | Y | Y | 0.0046 | | | N | | | | | |
| | Total PAHs | Y | Y | 0.02 | | | Y | N | | 0.26 | | |

Notes:

- 1) Background data used for toxics is from monitoring location BC10.
- 2) Background data for ammonia taken from Oyster Point RMP station

SFIA Mel Leong WQCP
Industrial Plant
Table 3 RPA Results

| Beginning | Step 2 | Step 3 | Step 4 | Step 5 | Step 6 | Step 7 & 8 | RPA Result | Reason | | | | | | | | | | |
|------------------|---|-------------------------------------|----------------------------------|-----------------------------------|--|---|--|--|----------------------------|---|--|---|--|---|--|---|---|------------------|
| | | | | | | | | | Step 2 | Step 3 | Step 4 | Step 5 | Step 6 | Step 7 & 8 | | | | |
| Constituent name | C (ug/L) Lowest (most stringent) Criteria (a) (Enter "No Criteria" for no criteria) | Effluent Data Available? | Are all data points non-detects? | Minimum MDL (ug/L) if all data ND | Enter the pollutant effluent detected max conc (ug/L) if all data ND & MinDL < C | If all data points are ND and MinDL < C, interim monitoring is required | Maximum Pollutant Concentration (MEC) (ug/L) | MEC vs. C | Background Data Available? | Are all background data points non-detects? | If all background data points ND, enter the min detection limit (MDL) (ug/L) | Enter the pollutant background detected max conc (ug/L) | If all B is ND, is MDL < C? (If Y, Go To Step 7) | If B-C, effluent limitation is required | Review other information in the SIP page 4. If other information indicates limits are required. If information is unavailable or insufficient, the RWQOCB shall establish interim monitoring requirements. | | | |
| A | B | D | E | F | G | H | I | J | K | L | M | N | O | P | Q | R | S | T |
| 1 | Antimony | 4300 | Y | N | 3 | | 3 | MEC < C, go to Step 5 | Y | | | 1.8 | | B-C, Step 7 | | | | |
| 2 | Arsenic | 36 | Y | N | 9.87 | | 9.87 | MEC < C, go to Step 5 | Y | | | 2.46 | | B-C, Step 7 | | | | |
| 3 | Beryllium | No Criteria | Y | Y | 0.5 | No Criteria | 0.5 | No Criteria | Y | | | 0.215 | | No Criteria | No Criteria | | | Uo - No Criteria |
| 4 | Cadmium | 9.35613682 | Y | | 2.365 | | 2.365 | MEC < C, go to Step 5 | Y | | | 0.1268 | | B-C, Step 7 | | | | |
| 5a | Chromium (III) | No Criteria | N | | 0 | No Effluent Data | | | | | | | | No detected value of B, Step 7 | | | | |
| 5b | Chromium (VI) | 4.189 | Y | N | 41.296 | | 41.296 | MEC < C, go to Step 5 | Y | | | 4.4 | | B-C, Step 7 | | | | |
| 6 | Copper | 8.51735016 | Y | N | 71.28 | | 71.28 | MEC < C, go to Step 5 | Y | | | 0.804 | | B-C, Step 7 | | | | |
| 7 | Lead | 0.025 | Y | N | 0.034 | | 0.034 | MEC < C, go to Step 5 | Y | | | 0.0086 | | B-C, Step 7 | | | | |
| 8 | Mercury (303d listed) | 12.6153346 | Y | N | 29.935 | | 29.935 | MEC < C, go to Step 5 | Y | | | 3.73 | | B-C, Step 7 | | | | |
| 9 | Nickel (303d listed) | 5 | Y | N | 1.402 | | 1.402 | MEC < C, go to Step 5 | Y | | | 0.39 | | B-C, Step 7 | | | | |
| 10 | Selenium | 2.2323412 | Y | N | 0.305 | | 0.305 | MEC < C, go to Step 5 | Y | | | 0.052 | | B-C, Step 7 | | | | |
| 11 | Silver | 6.3 | Y | N | 0.3 | | 0.3 | MEC < C, go to Step 5 | Y | | | 0.21 | | B-C, Step 7 | | | | |
| 12 | Thallium | 85.6236786 | Y | N | 56.64 | | 56.64 | MEC < C, go to Step 5 | Y | | | 5.1 | | B-C, Step 7 | | | | |
| 13 | Zinc | 1 | Y | N | 33 | | 33 | MEC < C, go to Step 5 | Y | Y | 0.4 | | N | No detected value of B, Step 7 | | | | |
| 14 | Cyanide | No Criteria | Y | N | 0 | No Criteria | | No Criteria | Y | | | | | No Criteria | No Criteria | | | |
| 15 | Asbestos | 2,3,7,8-TCDD (Dioxin) (303d listed) | 1.4E-08 | Y | Y | 8.23E-07 | | MDL > C, Interim Monitor, Go To Step 5 | Y | | | 7.10E-08 | | No detected value of B, Step 7 | | | | |
| 16 | Bis(2-Ethylhexyl) Phthalate (303d listed) | 1.4E-08 | Y | N | 5 | 4.74E-07 | | MDL <= C, MDL=MEC | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 17 | Acrolein | 750 | Y | Y | 5 | | | MDL < C, Interim Monitor, Go To Step 5 | Y | | | 0.03 | | B-C, Step 7 | | | | |
| 18 | Azobenzene | 0.66 | Y | Y | 5 | | | MDL < C, MDL=MEC | Y | Y | 0.05 | | N | No detected value of B, Step 7 | | | | |
| 19 | Benzene | 71 | Y | Y | 0.5 | | | MDL < C, MDL=MEC | Y | Y | 0.05 | | N | No detected value of B, Step 7 | | | | |
| 20 | Bromoforn | 360 | Y | N | 85 | | 85 | MEC < C, go to Step 5 | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 21 | Carbon Tetrachloride | 4.4 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.5 | | 0.06 | B-C, Step 7 | | | | |
| 22 | Chlorobenzene | 21000 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 23 | Chlorobromomethane | 34 | Y | N | 22 | | 22 | MEC < C, go to Step 5 | Y | Y | 0.05 | | N | No detected value of B, Step 7 | | | | |
| 24 | Chloroethane | No Criteria | Y | Y | 0.5 | | 0.5 | No Criteria | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 25 | 2-Chloroethylvinyl Ether | No Criteria | Y | Y | 0.5 | | 0.5 | No Criteria | Y | Y | 0.5 | | N | No Criteria | No Criteria | | | Uo - No Criteria |
| 26 | Chloroform | No Criteria | Y | N | 5.6 | | 5.6 | No Criteria | Y | Y | 0.5 | | N | No Criteria | No Criteria | | | Uo - No Criteria |
| 27 | Dichlorobromomethane | 46 | Y | N | 8.5 | | 8.5 | MEC < C, go to Step 5 | Y | Y | 0.05 | | N | No detected value of B, Step 7 | | | | |
| 28 | 1,1-Dichloroethane | No Criteria | Y | Y | 0.5 | | 0.5 | No Criteria | Y | Y | 0.05 | | N | No Criteria | No Criteria | | | Uo - No Criteria |
| 29 | 1,2-Dichloroethane | 99 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.5 | | 0.04 | B-C, Step 7 | | | | |
| 30 | 1,1-Dichloroethylene | 3.2 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 31 | 1,2-Dichloropropane | 39 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.05 | | N | No detected value of B, Step 7 | | | | |
| 32 | 1,3-Dichloropropylene | 1700 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 33 | Ethylbenzene | 29000 | Y | N | 0.407 | | 0.407 | MEC < C, go to Step 5 | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 34 | Methyl Bromide | 4000 | Y | N | 0.34 | | 0.34 | MEC < C, go to Step 5 | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 35 | Methyl Chloride | No Criteria | Y | N | 0.5 | | 0.5 | No Criteria | Y | Y | 0.5 | | N | No Criteria | No Criteria | | | Uo - No Criteria |
| 36 | Methylene Chloride | 1600 | Y | N | 0.383 | | 0.383 | MEC < C, go to Step 5 | Y | Y | 0.5 | | 0.5 | B-C, Step 7 | | | | |
| 37 | 1,1,2,2-Tetrachloroethane | 11 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.05 | | N | No detected value of B, Step 7 | | | | |
| 38 | Tetrachloroethylene | 8.85 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.05 | | N | No detected value of B, Step 7 | | | | |
| 39 | Toluene | 200000 | Y | N | 2.33 | | 2.33 | MEC < C, go to Step 5 | Y | Y | 0.3 | | N | No detected value of B, Step 7 | | | | |
| 40 | 1,2-Trans-Dichloroethylene | 14000 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 41 | 1,1-Trichloroethane | No Criteria | Y | Y | 0.7 | | 0.7 | No Criteria | Y | Y | 0.5 | | N | No Criteria | No Criteria | | | Uo - No Criteria |
| 42 | 1,1,2-Trichloroethane | 42 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.05 | | N | No detected value of B, Step 7 | | | | |
| 43 | Trichloroethylene | 81 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 44 | Vinyl Chloride | 525 | Y | Y | 0.5 | | 0.5 | MDL < C, MDL=MEC | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 45 | 2-Chlorophenol | 400 | Y | Y | 1.05 | | 1.05 | MDL < C, MDL=MEC | Y | Y | 1.2 | | N | No detected value of B, Step 7 | | | | |
| 46 | 2,4-Dichlorophenol | 790 | Y | Y | 1.2 | | 1.2 | MDL < C, MDL=MEC | Y | Y | 1.3 | | N | No detected value of B, Step 7 | | | | |
| 47 | 2,6-Dimethylphenol | 2300 | Y | Y | 1 | | 1 | MDL < C, MDL=MEC | Y | Y | 1.3 | | N | No detected value of B, Step 7 | | | | |
| 48 | 2-Methyl-4,6-Dinitrophenol | 785 | Y | Y | 1 | | 1 | MDL < C, MDL=MEC | Y | Y | 1.2 | | N | No detected value of B, Step 7 | | | | |
| 49 | 2,4-Dinitrophenol | 14000 | Y | Y | 3.89 | | 3.89 | MDL < C, MDL=MEC | Y | Y | 0.7 | | N | No detected value of B, Step 7 | | | | |
| 50 | 2-Nitrophenol | No Criteria | Y | Y | 1.86 | | 1.86 | No Criteria | Y | Y | 1.3 | | N | No Criteria | No Criteria | | | Uo - No Criteria |
| 51 | 4-Nitrophenol | No Criteria | Y | Y | 1.96 | | 1.96 | No Criteria | Y | Y | 1.6 | | N | No Criteria | No Criteria | | | Uo - No Criteria |
| 52 | 3-Methyl-4-Chlorophenol | No Criteria | Y | Y | 1 | | 1 | No Criteria | Y | Y | 1.1 | | N | No Criteria | No Criteria | | | Uo - No Criteria |
| 53 | Pentachlorophenol | 7.9 | Y | Y | 1.04 | | 1.04 | MDL < C, MDL=MEC | Y | Y | 1 | | N | No detected value of B, Step 7 | | | | |
| 54 | Phenol | 4600000 | Y | Y | 1 | | 1 | MDL < C, MDL=MEC | Y | Y | 1.3 | | N | No detected value of B, Step 7 | | | | |
| 55 | 2,4,6-Trichlorophenol | 6.5 | Y | Y | 1.88 | | 1.88 | All ND MDL < C, MDL=MEC | Y | Y | 1.3 | | N | No detected value of B, Step 7 | | | | |
| 56 | Acenaphthene | 2700 | Y | Y | 0.52 | | 0.52 | All ND MDL < C, MDL=MEC | Y | Y | 0.5 | | 0.0015 | B-C, Step 7 | | | | |
| 57 | Acenaphthylene | No Criteria | Y | Y | 0.39 | | 0.39 | No Criteria | Y | Y | 0.0053 | | 0.00053 | No Criteria | No Criteria | | | Uo - No Criteria |
| 58 | Anthracene | 110000 | Y | Y | 0.02 | | 0.02 | All ND MDL < C, MDL=MEC | Y | Y | 0.0005 | | 0.0005 | B-C, Step 7 | | | | |
| 59 | Benzidine | 0.00254 | Y | Y | 2.5 | | 2.5 | MDL > C, Go to Step 5 | Y | Y | 0.0015 | | Y | No detected value of B, Step 7 | | | | |
| 60 | Benzofluoranthene | 0.049 | Y | Y | 0.05 | | 0.05 | MDL < C, Go to Step 5 | Y | Y | 0.0053 | | 0.0053 | B-C, Step 7 | | | | |
| 61 | Benzofluoranthene | 0.049 | Y | Y | 0.05 | | 0.05 | MDL > C, Go to Step 5 | Y | Y | 0.0029 | | 0.0029 | B-C, Step 7 | | | | |
| 62 | Benzofluoranthene | 0.049 | Y | Y | 0.1 | | 0.1 | MDL > C, Go to Step 5 | Y | Y | 0.0046 | | 0.0046 | B-C, Step 7 | | | | |
| 63 | Benzofluoranthene | No Criteria | Y | Y | 0.09 | | 0.09 | No Criteria | Y | Y | 0.0027 | | 0.0027 | No Criteria | No Criteria | | | Uo - No Criteria |
| 64 | Benzofluoranthene | 0.049 | Y | Y | 0.05 | | 0.05 | MDL > C, Go to Step 5 | Y | Y | 0.0015 | | 0.0015 | B-C, Step 7 | | | | |
| 65 | Bis(2-Chloroethyl)Methane | No Criteria | Y | Y | 0.97 | | 0.97 | No Criteria | Y | Y | 0.3 | | N | No Criteria | No Criteria | | | Uo - No Criteria |
| 66 | Bis(2-Chloroethyl)Ether | 1.4 | Y | 0.97 | 0.97 | | 0.97 | All ND MDL < C, MDL=MEC | Y | Y | 0.3 | | N | No detected value of B, Step 7 | | | | |
| 67 | Bis(2-Chloropropyl)Ether | 170000 | Y | Y | 0.81 | | 0.81 | All ND MDL < C, MDL=MEC | Y | Y | 0.81 | | N | No detected value of B, Step 7 | | | | |
| 68 | Bis(2-Ethylhexyl)Phthalate | 5.9 | Y | Y | 0.69 | | 0.69 | All ND MDL < C, MDL=MEC | Y | Y | 0.5 | | N | No detected value of B, Step 7 | | | | |
| 69 | 4-Bromophenyl Phenyl Ether | No Criteria | Y | Y | 1 | | 1 | No Criteria | Y | Y | 0.23 | | N | No Criteria | No Criteria | | | Uo - No Criteria |
| 70 | Butylbenzyl Phthalate | 5200 | Y | Y | 0.95 | | 0.95 | All ND MDL < C, MDL=MEC | Y | Y | 0.52 | | N | No detected value of B, Step 7 | | | | |
| 71 | 2-Chloronaphthalene | 4300 | Y | Y | 1 | | 1 | All ND MDL < C, MDL=MEC | Y | Y | 0.3 | | N | No detected value of B, Step 7 | | | | |
| 72 | 4-Chlorophenyl Phenyl Ether | No Criteria | Y | Y | 0.89 | | 0.89 | No Criteria | Y | Y | 0.3 | | N | No Criteria | No Criteria | | | Uo - No Criteria |
| 73 | Chrysene | 0.049 | Y | Y | 0.9 | | 0.9 | MDL > C, Go to Step 5 | Y | Y | 0.0024 | | 0.0024 | B-C, Step 7 | | | | |

SFIA Mel Leong WQCP
Industrial Plant
Table 3 RPA Results

| Beginning | Constituent name | C (µg/L) Lowest (most stringent) Criteria (a) (Enter "No Criteria" for no criteria) | Step 2 | | Step 3 | | Enter the pollutant effluent detected max conc (µg/L) If all data points are ND and MinDL < C, interim monitoring is required | Maximum Pollutant Concentration (MEC) (µg/L) | Step 4 | | Step 2 | Step 3 | Step 4 | Step 5 | Step 6 | Step 7 & 8 | RPA Result | Reason |
|-----------|---------------------------|---|--------------------------|----------------------------------|------------------------------------|-----------|--|--|---|---|--------|--------|------------|--------|--------------------------------|-------------|-----------------------------------|--|
| | | | Effluent Data Available? | Are all data points non-detects? | Minimum MDL (µg/L) if all data ND. | MEC vs. C | | | (MEC= detected max value; if all ND & MDL < C then MEC = MDL) | Y if MEC >= C, effluent limitation is required; 2. If MEC < C, go to Step 5 | | | | | | | | |
| 84 | Di-n-Octyl Phthalate | No Criteria | Y | N | | 2 | No Criteria | 2 | No Criteria | Y | Y | 0.38 | | N | No Criteria | | Uo - No Criteria | |
| 85 | 1,2-Diphenylhydrazine | 0.54 | Y | Y | 1 | | MDL > C, Interim Monitor, Go To Step 5 | | | Y | | | 0.0037 | | B-C, Step 7 | | Effluent MDL > C, Interim Monitor | |
| 86 | Fluoranthene | 370 | Y | Y | 0.1 | | All ND MDL < C, MDL = MEC | 0.1 | MEC < C, go to Step 5 | Y | | | 0.011 | | B-C, Step 7 | | | |
| 87 | Fluorene | 14000 | Y | Y | 0.1 | | All ND MDL < C, MDL = MEC | 0.1 | MEC < C, go to Step 5 | Y | | | 0.00208 | | B-C, Step 7 | | | |
| 88 | Hexachlorobenzene | 0.00077 | Y | Y | 0.98 | | MDL > C, Go to Step 5 | | | Y | | | 0.0000202 | | B-C, Step 7 | | | |
| 89 | Hexachlorobutadiene | 50 | Y | Y | 1 | | All ND MDL < C, MDL = MEC | 1 | MEC < C, go to Step 5 | Y | Y | 0.3 | | N | No detected value of B, Step 7 | | | |
| 90 | Hexachlorocyclopentadiene | 17000 | Y | Y | 1 | | All ND MDL < C, MDL = MEC | 1 | MEC < C, go to Step 5 | Y | Y | 0.31 | | N | No detected value of B, Step 7 | | | |
| 91 | Hexachloroethane | 8.8 | Y | Y | 1 | | All ND MDL < C, MDL = MEC | 1 | MEC < C, go to Step 5 | Y | Y | 0.2 | | N | No detected value of B, Step 7 | | | |
| 92 | Indeno(1,2,3-cd) Pyrene | 0.049 | Y | Y | 0.1 | | MDL > C, Go to Step 5 | | | Y | | | 0.004 | | B-C, Step 7 | | | |
| 93 | Isophorone | 600 | Y | Y | 0.96 | | All ND MDL < C, MDL = MEC | 0.96 | MEC < C, go to Step 5 | Y | Y | 0.3 | | N | No detected value of B, Step 7 | | | |
| 94 | Naphthalene | No Criteria | Y | Y | 1 | | No Criteria | 1 | No Criteria | Y | | | 0.0023 | | No Criteria | No Criteria | Uo - No Criteria | |
| 95 | Nitrobenzene | 1900 | Y | Y | 0.71 | | All ND MDL < C, MDL = MEC | 0.71 | MEC < C, go to Step 5 | Y | Y | 0.25 | | N | No detected value of B, Step 7 | | | |
| 96 | N-Nitrosodimethylamine | 8.1 | Y | Y | 0.1 | | All ND MDL < C, MDL = MEC | 0.1 | MEC < C, go to Step 5 | Y | Y | 0.3 | | N | No detected value of B, Step 7 | | | |
| 97 | N-Nitrosod-n-Propylamine | 1.4 | Y | Y | 0.84 | | All ND MDL < C, MDL = MEC | 0.84 | MEC < C, go to Step 5 | Y | Y | 0.001 | | N | No detected value of B, Step 7 | | | |
| 98 | N-Nitrosodiphenylamine | 16 | Y | Y | 0.94 | | All ND MDL < C, MDL = MEC | 0.94 | MEC < C, go to Step 5 | Y | Y | 0.001 | | N | No detected value of B, Step 7 | | | |
| 99 | Phenanthrene | No Criteria | Y | Y | 0.93 | | No Criteria | 0.93 | No Criteria | Y | | | 0.0061 | | No Criteria | No Criteria | Uo - No Criteria | |
| 100 | Pyrene | 11000 | Y | Y | 0.1 | | All ND MDL < C, MDL = MEC | 0.1 | MEC < C, go to Step 5 | Y | | | 0.0051 | | B-C, Step 7 | | | |
| 101 | 1,2,4-Trichlorobenzene | No Criteria | Y | Y | 0.94 | | No Criteria | 0.94 | No Criteria | Y | Y | 0.3 | | N | No Criteria | No Criteria | Uo - No Criteria | |
| 102 | Adin | 0.00014 | Y | Y | 0.005 | | MDL > C, Go to Step 5 | | | Y | | | 0.000496 | | No detected value of B, Step 7 | | Y | MEC => C [0.0510 ug/l vs 0.0130 ug/l] |
| 103 | alpha-BHC | 0.013 | Y | N | | 0.051 | | 0.051 | Y | Y | | | 0.000413 | | B-C, Step 7 | | | |
| 104 | beta-BHC | 0.046 | Y | N | | 0.039 | | 0.039 | MEC < C, go to Step 5 | Y | | | 0.0007034 | | B-C, Step 7 | | | |
| 105 | gamma-BHC | 0.063 | Y | Y | 0.005 | | All ND MDL < C, MDL = MEC | 0.005 | MEC < C, go to Step 5 | Y | | | 0.000042 | | B-C, Step 7 | | | |
| 106 | delta-BHC | No Criteria | Y | Y | 0.005 | | No Criteria | 0.005 | No Criteria | Y | | | 0.000018 | | No Criteria | No Criteria | Uo - No Criteria | |
| 107 | Chlordane (303d listed) | 0.00059 | Y | Y | 0.005 | | MDL > C, Go to Step 5 | | | Y | | | 0.000066 | | B-C, Step 7 | | | |
| 108 | 4,4-DDT (303d listed) | 0.00059 | Y | Y | 0.01 | | MDL > C, Go to Step 5 | | | Y | | | 0.000693 | | B-C, Step 7 | | | |
| 109 | 4,4-DDE | 0.00059 | Y | Y | 0.01 | | MDL > C, Go to Step 5 | | | Y | | | 0.000313 | | B-C, Step 7 | | | |
| 110 | 4,4-DDD | 0.00084 | Y | Y | 0.03 | | MDL > C, Go to Step 5 | | | Y | | | 0.000264 | | B-C, Step 7 | | | |
| 111 | Dieldrin (303d listed) | 0.00014 | Y | Y | 0.01 | | MDL > C, Go to Step 5 | | | Y | | | 0.000031 | | B-C, Step 7 | | | |
| 112 | alpha-Endosulfan | 0.0087 | Y | Y | 0.01 | | MDL > C, Interim Monitor, Go To Step 5 | | | Y | | | 0.000069 | | B-C, Step 7 | | | Effluent MDL > C, Interim Monitor |
| 113 | beta-Endosulfan | 0.0087 | Y | Y | 0.01 | | MDL > C, Interim Monitor, Go To Step 5 | | | Y | | | 0.0000819 | | B-C, Step 7 | | | Effluent MDL > C, Interim Monitor |
| 114 | Endosulfan Sulfate | 246 | Y | Y | 0.03 | | All ND MDL < C, MDL = MEC | 0.03 | MEC < C, go to Step 5 | Y | | | 0.000036 | | B-C, Step 7 | | | |
| 115 | Endrin | 0.0023 | Y | N | | 0.01 | | 0.01 | Y | Y | | | 0.000019 | | B-C, Step 7 | | Y | MEC => C [0.0100 ug/l vs 0.0023 ug/l] |
| 116 | Endrin Aldohyde | 0.81 | Y | Y | 0.01 | | All ND MDL < C, MDL = MEC | 0.01 | MEC < C, go to Step 5 | Y | | | 0.00002458 | | No detected value of B, Step 7 | | | |
| 117 | Heptachlor | 0.00021 | Y | N | | 0.035 | | 0.035 | Y | Y | | | 0.000019 | | B-C, Step 7 | | Y | MEC => C [0.0350 ug/l vs 0.00021 ug/l] |
| 118 | Heptachlor Epoxide | 0.00011 | Y | Y | 0.005 | | MDL > C, Go to Step 5 | | | Y | | | 0.00002458 | | B-C, Step 7 | | | |
| 119-125 | PCBs sum (303d listed) | 0.00017 | Y | Y | 0.47 | | MDL > C, Go to Step 5 | | | Y | | | 0.00002458 | | No detected value of B, Step 7 | | | |
| 126 | Toxaphene | 0.0002 | Y | Y | 0.5 | | MDL > C, Go to Step 5 | | | Y | | | 210 | | No detected value of B, Step 7 | | | |
| | Amines | 1.500 | Y | N | | 120.000 | | 118.000 | Y | Y | | | 210 | | B-C, Step 7 | | | |
| | Tributyltin | 0.01 | Y | Y | 0.0046 | | All ND MDL < C, MDL = MEC | 0.0046 | MEC < C, go to Step 5 | Y | | | 210 | | No detected value of B, Step 7 | | Y | MEC => C [120 mg/l vs 1.5 mg/l] |
| | Total PAHs | 15 | Y | Y | 0.02 | | All ND MDL < C, MDL = MEC | 0.02 | MEC < C, go to Step 5 | Y | | | 0.26 | | B-C, Step 7 | | | |

a. The most stringent of saltwater criteria were selected for this analysis.
b. Acronyms in the "Final Result" column:
Uo: No criteria available
IM: Interim monitoring is required

SFIA Mei Leong Plant
Industrial Plant
Table 6, Salinity Hardness data

| | | | | |
|--------------|-----|------|---------|------------|
| 119 ES_WATER | WCT | BA40 | 2000-02 | 02/01/2000 |
| 120 ES_WATER | WCT | BA40 | 2000-07 | 07/11/2000 |
| 121 ES_WATER | WCT | BA40 | 2001-02 | 02/06/2001 |
| 122 ES_WATER | WCT | BA40 | 2001-08 | 07/31/2001 |

| | | | |
|------|----------|-----|--------|
| 25.9 | 0.1 o/oo | 7.8 | 0.0 pH |
| 27.6 | 0.1 o/oo | 7.8 | 0.0 pH |
| 28.3 | 0.2 o/oo | 8.2 | 0.0 pH |
| 29.8 | 0.2 o/oo | 8.0 | 0.0 pH |

**SFIA Mel Leong WQCP
Industrial Plant
Table 8. Dioxin Data**

San Francisco International Airport (SFIA) - Industrial Treatment Facility - Dioxin Data

| <u>Permit or Agency</u> | Analyte | Sample Date | Qualifier | Result | Unit | Reporting Limit | MDL | RDL | CTR No. | EPA Method | TEF | TEQ |
|-------------------------|---------------------|-------------|-----------|--------|------|-----------------|-----|-----|---------|------------|-----|-----|
| SFIA-Industrial | 2,3,7,8-TCDD | 27-Sep-02 | ND | 1.88 | pg/L | 1.88 | | | 16a | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8-PeCDD | 27-Sep-02 | ND | 2.99 | pg/L | 2.99 | | | 16b | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8-HxCDD | 27-Sep-02 | ND | 5.01 | pg/L | 5.01 | | | 16c | 1613 | | |
| SFIA-Industrial | 1,2,3,6,7,8-HxCDD | 27-Sep-02 | ND | 4.89 | pg/L | 4.89 | | | 16d | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8,9-HxCDD | 27-Sep-02 | ND | 4.55 | pg/L | 4.55 | | | 16e | 1613 | | |
| SFIA-Industrial | 1,2,3,4,6,7,8-HpCDD | 27-Sep-02 | ND | 3.60 | pg/L | 3.60 | | | 16f | 1613 | | |
| SFIA-Industrial | OCDD | 27-Sep-02 | ND | 6.00 | pg/L | 6.00 | | | 16g | 1613 | | |
| SFIA-Industrial | 2,3,7,8-TCDF | 27-Sep-02 | ND | 1.34 | pg/L | 1.34 | | | 16h | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8-PeCDF | 27-Sep-02 | ND | 3.12 | pg/L | 3.12 | | | 16i | 1613 | | |
| SFIA-Industrial | 2,3,4,7,8-PeCDF | 27-Sep-02 | ND | 3.20 | pg/L | 3.20 | | | 16j | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8-HxCDF | 27-Sep-02 | ND | 1.46 | pg/L | 1.46 | | | 16k | 1613 | | |
| SFIA-Industrial | 1,2,3,6,7,8-HxCDF | 27-Sep-02 | ND | 1.71 | pg/L | 1.71 | | | 16l | 1613 | | |
| SFIA-Industrial | 2,3,4,6,7,8-HxCDF | 27-Sep-02 | ND | 1.68 | pg/L | 1.68 | | | 16m | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8,9-HxCDF | 27-Sep-02 | ND | 2.10 | pg/L | 2.10 | | | 16n | 1613 | | |
| SFIA-Industrial | 1,2,3,4,6,7,8-HpCDF | 27-Sep-02 | ND | 1.80 | pg/L | 1.80 | | | 16o | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8,9-HpCDF | 27-Sep-02 | ND | 2.38 | pg/L | 2.38 | | | 16p | 1613 | | |
| SFIA-Industrial | OCDF | 27-Sep-02 | ND | 6.46 | pg/L | 6.46 | | | 16q | 1613 | | |
| SFIA-Industrial | WHO TEQ = 0.00 | 27-Sep-02 | ND | 0.00 | pg/L | | | | 16-TEQ | 1613 | | |
| SFIA-Industrial | 2,3,7,8-TCDD | 3-Mar-03 | ND | 1.30 | pg/L | 1.3 | | | 16a | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8-PeCDD | 3-Mar-03 | ND | 2.29 | pg/L | 2.29 | | | 16b | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8-HxCDD | 3-Mar-03 | ND | 3.96 | pg/L | 3.96 | | | 16c | 1613 | | |
| SFIA-Industrial | 1,2,3,6,7,8-HxCDD | 3-Mar-03 | ND | 4.17 | pg/L | 4.17 | | | 16d | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8,9-HxCDD | 3-Mar-03 | ND | 3.40 | pg/L | 3.4 | | | 16e | 1613 | | |
| SFIA-Industrial | 1,2,3,4,6,7,8-HpCDD | 3-Mar-03 | ND | 3.15 | pg/L | 3.15 | | | 16f | 1613 | | |
| SFIA-Industrial | OCDD | 3-Mar-03 | ND | 4.14 | pg/L | 4.14 | | | 16g | 1613 | | |
| SFIA-Industrial | 2,3,7,8-TCDF | 3-Mar-03 | ND | 1.40 | pg/L | 1.4 | | | 16h | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8-PeCDF | 3-Mar-03 | ND | 2.16 | pg/L | 2.16 | | | 16i | 1613 | | |
| SFIA-Industrial | 2,3,4,7,8-PeCDF | 3-Mar-03 | ND | 2.24 | pg/L | 2.24 | | | 16j | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8-HxCDF | 3-Mar-03 | ND | 0.79 | pg/L | 0.786 | | | 16k | 1613 | | |
| SFIA-Industrial | 1,2,3,6,7,8-HxCDF | 3-Mar-03 | ND | 1.02 | pg/L | 1.02 | | | 16l | 1613 | | |
| SFIA-Industrial | 2,3,4,6,7,8-HxCDF | 3-Mar-03 | ND | 1.05 | pg/L | 1.05 | | | 16m | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8,9-HxCDF | 3-Mar-03 | ND | 1.22 | pg/L | 1.22 | | | 16n | 1613 | | |
| SFIA-Industrial | 1,2,3,4,6,7,8-HpCDF | 3-Mar-03 | ND | 1.13 | pg/L | 1.13 | | | 16o | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8,9-HpCDF | 3-Mar-03 | ND | 1.41 | pg/L | 1.41 | | | 16p | 1613 | | |
| SFIA-Industrial | OCDF | 3-Mar-03 | ND | 3.37 | pg/L | 3.37 | | | 16q | 1613 | | |
| SFIA-Industrial | WHO TEQ = 0.00 | 3-Mar-03 | ND | 0.00 | pg/L | | | | 16-TEQ | 1613 | | |
| SFIA-Industrial | 2,3,7,8-TCDD | 25-Jul-03 | ND | 1.95 | pg/L | 1.95 | | | 16a | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8-PeCDD | 25-Jul-03 | ND | 2.55 | pg/L | 2.55 | | | 16b | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8-HxCDD | 25-Jul-03 | ND | 5.21 | pg/L | 5.21 | | | 16c | 1613 | | |
| SFIA-Industrial | 1,2,3,6,7,8-HxCDD | 25-Jul-03 | ND | 5.08 | pg/L | 5.08 | | | 16d | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8,9-HxCDD | 25-Jul-03 | ND | 4.68 | pg/L | 4.68 | | | 16e | 1613 | | |
| SFIA-Industrial | 1,2,3,4,6,7,8-HpCDD | 25-Jul-03 | ND | 3.17 | pg/L | 3.17 | | | 16f | 1613 | | |
| SFIA-Industrial | OCDD | 25-Jul-03 | ND | 4.42 | pg/L | 4.42 | | | 16g | 1613 | | |
| SFIA-Industrial | 2,3,7,8-TCDF | 25-Jul-03 | ND | 1.34 | pg/L | 1.34 | | | 16h | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8-PeCDF | 25-Jul-03 | ND | 3.85 | pg/L | 3.85 | | | 16i | 1613 | | |
| SFIA-Industrial | 2,3,4,7,8-PeCDF | 25-Jul-03 | ND | 3.86 | pg/L | 3.86 | | | 16j | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8-HxCDF | 25-Jul-03 | ND | 0.72 | pg/L | 0.724 | | | 16k | 1613 | | |
| SFIA-Industrial | 1,2,3,6,7,8-HxCDF | 25-Jul-03 | ND | 0.93 | pg/L | 0.926 | | | 16l | 1613 | | |
| SFIA-Industrial | 2,3,4,6,7,8-HxCDF | 25-Jul-03 | ND | 1.05 | pg/L | 1.05 | | | 16m | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8,9-HxCDF | 25-Jul-03 | ND | 1.32 | pg/L | 1.32 | | | 16n | 1613 | | |
| SFIA-Industrial | 1,2,3,4,6,7,8-HpCDF | 25-Jul-03 | ND | 1.33 | pg/L | 1.33 | | | 16o | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8,9-HpCDF | 25-Jul-03 | ND | 2.23 | pg/L | 2.23 | | | 16p | 1613 | | |
| SFIA-Industrial | OCDF | 25-Jul-03 | ND | 5.36 | pg/L | 5.36 | | | 16q | 1613 | | |
| SFIA-Industrial | WHO TEQ = 0.00 | 25-Jul-03 | ND | 0.00 | pg/L | | | | 16-TEQ | 1613 | | |
| SFIA-Industrial | 2,3,7,8-TCDD | 3/30/2004 | ND | 4.20 | pg/L | 4.2 | | | 16a | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8-PeCDD | 3/30/2004 | ND | 8.30 | pg/L | 8.3 | | | 16b | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8-HxCDD | 3/30/2004 | ND | 10.00 | pg/L | 10 | | | 16c | 1613 | | |
| SFIA-Industrial | 1,2,3,6,7,8-HxCDD | 3/30/2004 | ND | 9.60 | pg/L | 9.6 | | | 16d | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8,9-HxCDD | 3/30/2004 | ND | 9.20 | pg/L | 9.2 | | | 16e | 1613 | | |
| SFIA-Industrial | 1,2,3,4,6,7,8-HpCDD | 3/30/2004 | ND | 9.30 | pg/L | 9.3 | | | 16f | 1613 | | |
| SFIA-Industrial | OCDD | 3/30/2004 | ND | 11.00 | pg/L | 11 | | | 16g | 1613 | | |
| SFIA-Industrial | 2,3,7,8-TCDF | 3/30/2004 | ND | 5.40 | pg/L | 5.4 | | | 16h | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8-PeCDF | 3/30/2004 | ND | 5.20 | pg/L | 5.2 | | | 16i | 1613 | | |
| SFIA-Industrial | 2,3,4,7,8-PeCDF | 3/30/2004 | ND | 5.70 | pg/L | 5.7 | | | 16j | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8-HxCDF | 3/30/2004 | ND | 8.60 | pg/L | 8.6 | | | 16k | 1613 | | |
| SFIA-Industrial | 1,2,3,6,7,8-HxCDF | 3/30/2004 | ND | 8.10 | pg/L | 8.1 | | | 16l | 1613 | | |
| SFIA-Industrial | 2,3,4,6,7,8-HxCDF | 3/30/2004 | ND | 6.00 | pg/L | 6 | | | 16m | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8,9-HxCDF | 3/30/2004 | ND | 5.70 | pg/L | 5.7 | | | 16n | 1613 | | |
| SFIA-Industrial | 1,2,3,4,6,7,8-HpCDF | 3/30/2004 | ND | 5.30 | pg/L | 5.3 | | | 16o | 1613 | | |
| SFIA-Industrial | 1,2,3,4,7,8,9-HpCDF | 3/30/2004 | ND | 7.00 | pg/L | 7 | | | 16p | 1613 | | |
| SFIA-Industrial | OCDF | 3/30/2004 | ND | 12.00 | pg/L | 12 | | | 16q | 1613 | | |
| SFIA-Industrial | WHO TEQ = 0.00 | 3/30/2004 | ND | 0.00 | pg/L | | | | 16-TEQ | 1613 | | |
| SFIA-Industrial | 2,3,7,8-TCDD | 8/24/2004 | ND | 2.01 | pg/L | 2.01 | | | 16a | 1613 | | |
| SFIA-Industrial | 1,2,3,7,8-PeCDD | 8/24/2004 | ND | 6.48 | pg/L | 6.48 | | | 16b | 1613 | | |

Table 7

San Francisco International Airport
MEL LEONG TREATMENT PLANT

Ammonia-Nitrogen Levels
 (Monthly Average Values)

| Month | Sanitary | | Industrial | |
|---------------------------------|--------------------------|-------------|--------------------------|------------|
| | <i>M.E.C. = 118 mg/L</i> | | <i>M.E.C. = 6.9 mg/L</i> | |
| | Influent | Effluent | Influent | Effluent |
| May-05 | 92 | 72.8 | 0.6 | 0.2 |
| Jun-05 | 98 | 53.6 | 1.2 | 0.2 |
| Jul-05 | 99 | 33.9 | 3.8 | 0.2 |
| Aug-05 | 98 | 37.6 | 0.8 | 0.3 |
| Sep-05 | 92 | 29.4 | 0.9 | 0.3 |
| Oct-05 | 93 | 51.2 | 1.7 | 0.3 |
| Nov-05 | 92 | 46.0 | 1.0 | 0.1 |
| Dec-05 | 83 | 38.4 | 2.4 | 0.4 |
| Jan-06 | 89 | 47.1 | 0.8 | 0.5 |
| Feb-06 | 85 | 48.1 | 0.3 | 0.1 |
| Mar-06 | 82 | 77.1 | 0.8 | 0.3 |
| Apr-06 | 93 | 85.6 | 2.3 | 1.0 |
| May-06 | 81 | 73.7 | 6.5 | 1.4 |
| Jun-06 | 86 | 56.9 | 1.5 | 0.8 |
| Jul-06 | 86 | 42.1 | 1.5 | 3.0 |
| Aug-06 | 92 | 55.5 | 7.9 | 5.6 |
| Sep-06 | 99 | 60.0 | 2.1 | 0.5 |
| Oct-06 | 98 | 98.0 | 1.4 | 0.4 |
| Nov-06 | 95 | 67.8 | 0.7 | 0.4 |
| Dec-06 | 87 | 74.5 | 0.3 | 0.4 |
| Jan-07 | 97 | 91.4 | 2.6 | 0.7 |
| Feb-07 | 92 | 93.1 | 1.0 | 0.6 |
| Mar-07 | 100 | 96.9 | 0.9 | 1.8 |
| Apr-07 | 103 | 91.1 | 1.0 | 0.9 |
| 2-year Average value | 92.2 | 63.4 | 1.8 | 0.9 |

All values are in **mg/L**

JUNE 8, 2007

APPENDIX B

RPA CALCULATIONS – SANITARY TREATMENT PLANT DATA

| | |
|----------------|---|
| Table 1 | Criteria (Table 1 in RPA spreadsheet) |
| Table 2 | Data Input for RPA (Table 2 in RPA spreadsheet) |
| Table 3 | Reasonable Potential Analysis Results (Table 3 in RPA spreadsheet) |
| Table 4 | Salinity and Hardness Data (Table 6 in RPA spreadsheet) |
| Table 5 | Dioxin-TEQ Data (Table 8 in RPA spreadsheet) |
| Table 6 | Total PAHs (Table 9 in RPA spreadsheet) |
| Table 7 | Ammonia-Nitrogen Levels, Monthly average May 2005 – April 2007 |

SFIA - Mei Leong WQCP
Sanitary Treatment Plant
Table 2. Data Input for RPA

| CTR No. | Constituent name | EFFLUENT DATA | | | | | BACKGROUND DATA (B) | | | | | 7) Review other information in the SIP page 4. If information is unavailable or insufficient: B) the RWQCB shall establish interim monitoring requirements. |
|---------|-----------------------------|--------------------------------|--|--|---|-------------|---------------------|------------------------------|--|--|-------------|---|
| | | Effluent Data Available (Y/N)? | Are all data points non-detects (Y/N)? | If all data points ND Enter the min detection limit (MDL) (ug/L) | Enter the pollutant effluent detected max conc (ug/L) | Input Check | B Available (Y/N)? | Are all B non-detects (Y/N)? | If all data points ND Enter the min detection limit (MDL) (ug/L) | Enter the Detected Maximum Background Conc | Input Check | |
| 1 | Antimony | Y | N | | 0.41 | | Y | N | | 1.8 | | |
| 2 | Arsenic | Y | N | | 5 | | Y | N | | 2.46 | | |
| 3 | Beryllium | Y | Y | 0.5 | | | Y | N | | 0.215 | | No Criteria |
| 4 | Cadmium | Y | N | | 0.58 | | Y | N | | 0.1268 | | |
| 5a | Chromium (III) | N | | | | | N | | | | | |
| 5b | Chromium (VI) | Y | N | | 6.77 | | Y | N | | 4.4 | | |
| 6 | Copper | Y | N | | 13.95 | | Y | N | | 2.45 | | |
| 7 | Lead | Y | N | | 5 | | Y | N | | 0.8040 | | |
| 8 | Mercury (303d listed) | Y | N | | 0.0867 | | Y | N | | 0.0086 | | |
| 9 | Nickel (303d listed) | Y | N | | 14.91 | | Y | N | | 3.73 | | |
| 10 | Selenium | Y | N | | 1.563 | | Y | N | | 0.39 | | |
| 11 | Silver | Y | N | | 0.5 | | Y | N | | 0.052 | | |
| 12 | Thallium | Y | N | | 1.3 | | Y | N | | 0.21 | | |
| 13 | Zinc | Y | N | | 71.4 | | Y | N | | 5.1 | | |
| 14 | Cyanide | Y | N | | 15.8 | | Y | Y | 0.4 | | | |
| 15 | Asbestos | N | | | | | N | | | | | No Criteria |
| 16 | 2,3,7,8-TCDD (303d listed) | Y | Y | 9.80E-07 | | | N | | | | | |
| 16-TEQ | Dioxin TEQ (303d listed) | Y | Y | 3.55E-07 | | | Y | N | | 7.10E-08 | | |
| 17 | Acrolein | Y | Y | 5 | | | Y | Y | 0.5 | | | |
| 18 | Acrylonitrile | Y | Y | 5 | | | Y | N | | 0.03 | | |
| 19 | Benzene | Y | Y | 0.5 | | | Y | Y | 0.05 | | | |
| 20 | Bromoform | Y | N | | 0.6 | | Y | Y | 0.5 | | | |
| 21 | Carbon Tetrachloride | Y | Y | 0.5 | | | Y | N | | 0.06 | | |
| 22 | Chlorobenzene | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 23 | Chlorodibromomethane | Y | N | | 1 | | Y | Y | 0.05 | | | |
| 24 | Chloroethane | Y | N | | 0.075 | | Y | Y | 0.5 | | | No Criteria |
| 25 | 2-Chloroethylvinyl Ether | Y | Y | 20 | | | Y | Y | 0.5 | | | No Criteria |
| 26 | Chloroform | Y | N | | 11 | | Y | Y | 0.5 | | | No Criteria |
| 27 | Dichlorobromomethane | Y | N | | 5 | | Y | Y | 0.05 | | | No Criteria |
| 28 | 1,1-Dichloroethane | Y | Y | 0.5 | | | Y | Y | 0.05 | | | No Criteria |
| 29 | 1,2-Dichloroethane | Y | Y | 0.5 | | | Y | N | | 0.04 | | |
| 30 | 1,1-Dichloroethylene | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 31 | 1,2-Dichloropropane | Y | Y | 0.5 | | | Y | Y | 0.05 | | | |
| 32 | 1,3-Dichloropropylene | Y | Y | 0.5 | | | N | | | | | |
| 33 | Ethylbenzene | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 34 | Methyl Bromide | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 35 | Methyl Chloride | Y | Y | 0.5 | | | Y | Y | 0.5 | | | No Criteria |
| 36 | Methylene Chloride | Y | N | | 0.485 | | Y | N | | 0.5 | | |
| 37 | 1,1,2,2-Tetrachloroethane | Y | Y | 0.5 | | | Y | Y | 0.05 | | | |
| 38 | Tetrachloroethylene | Y | Y | 0.5 | | | Y | Y | 0.05 | | | |
| 39 | Toluene | Y | N | | 0.46 | | Y | Y | 0.3 | | | |
| 40 | 1,2-Trans-Dichloroethylene | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 41 | 1,1,1-Trichloroethane | Y | Y | 0.5 | | | Y | Y | 0.5 | | | No Criteria |
| 42 | 1,1,2-Trichloroethane | Y | Y | 0.5 | | | Y | Y | 0.05 | | | |
| 43 | Trichloroethylene | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 44 | Vinyl Chloride | Y | Y | 0.5 | | | Y | Y | 0.5 | | | |
| 45 | Chlorophenol | Y | Y | 1.05 | | | Y | Y | 1.2 | | | |
| 46 | 2,4-Dichlorophenol | Y | Y | 1.2 | | | Y | Y | 1.3 | | | |
| 47 | 2,4-Dimethylphenol | Y | Y | 1 | | | Y | Y | 1.3 | | | |
| 48 | 2-Methyl-4,6-Dinitrophenol | Y | Y | 1 | | | Y | Y | 1.2 | | | |
| 49 | 2,4-Dinitrophenol | Y | Y | 3.89 | | | Y | Y | 0.7 | | | |
| 50 | 2-Nitrophenol | Y | Y | 1.86 | | | Y | Y | 1.3 | | | No Criteria |
| 51 | 4-Nitrophenol | Y | Y | 1.96 | | | Y | Y | 1.6 | | | No Criteria |
| 52 | 3-Methyl-4-Chlorophenol | Y | Y | 1 | | | Y | Y | 1.1 | | | No Criteria |
| 53 | Pentachlorophenol | Y | Y | 1.04 | | | Y | Y | 1 | | | |
| 54 | Phenol | Y | Y | 1 | | | Y | Y | 1.3 | | | |
| 55 | 2,4,6-Trichlorophenol | Y | Y | 1.88 | | | Y | Y | 1.3 | | | |
| 56 | Acenaphthene | Y | Y | 0.52 | | | Y | N | | 0.0015 | | |
| 57 | Acenaphthylene | Y | Y | 0.39 | | | Y | N | | 0.00053 | | No Criteria |
| 58 | Anthracene | Y | Y | 0.02 | | | Y | N | | 0.0005 | | |
| 59 | Benzidine | Y | Y | 2.5 | | | Y | Y | 0.0015 | | | |
| 60 | Benzo(a)Anthracene | Y | Y | 0.05 | | | Y | N | | 0.0053 | | |
| 61 | Benzo(a)Pyrene | Y | Y | 0.05 | | | Y | N | | 0.00029 | | |
| 62 | Benzo(b)Fluoranthene | Y | Y | 0.1 | | | Y | N | | 0.0046 | | |
| 63 | Benzo(ghi)Perylene | Y | Y | 0.09 | | | Y | N | | 0.0027 | | No Criteria |
| 64 | Benzo(k)Fluoranthene | Y | Y | 0.05 | | | Y | N | | 0.0015 | | |
| 65 | Bis(2-Chloroethoxy)Methane | Y | Y | 0.97 | | | Y | Y | 0.3 | | | No Criteria |
| 66 | Bis(2-Chloroethyl)Ether | Y | Y | 0.97 | | | Y | Y | 0.3 | | | |
| 67 | Bis(2-Chloroisopropyl)Ether | Y | Y | 0.81 | | | N | | | | | |
| 68 | Bis(2-Ethylhexyl)Phthalate | Y | Y | 0.69 | | | Y | Y | 0.5 | | | |
| 69 | 4-Bromophenyl Phenyl Ether | Y | Y | 1 | | | Y | Y | 0.23 | | | No Criteria |
| 70 | Butylbenzyl Phthalate | Y | Y | 0.26 | | | Y | Y | 0.52 | | | |
| 71 | 2-Chloronaphthalene | Y | Y | 1 | | | Y | Y | 0.3 | | | |
| 72 | 4-Chlorophenyl Phenyl Ether | Y | Y | 0.89 | | | Y | Y | 0.3 | | | No Criteria |
| 73 | Chrysene | Y | Y | 0.9 | | | Y | N | | 0.0024 | | |
| 74 | Dibenzo(a,h)Anthracene | Y | Y | 0.09 | | | Y | N | | 0.00064 | | |
| 75 | 1,2-Dichlorobenzene | Y | Y | 0.5 | | | Y | Y | 0.8 | | | |
| 76 | 1,3-Dichlorobenzene | Y | Y | 0.5 | | | Y | Y | 0.8 | | | |
| 77 | 1,4-Dichlorobenzene | Y | N | | 0.13 | | Y | Y | 0.8 | | | |
| 78 | 3,3'-Dichlorobenzidine | Y | Y | 0.9 | | | Y | Y | 0.001 | | | |
| 79 | Diethyl Phthalate | Y | Y | 1 | | | Y | Y | 0.24 | | | |
| 80 | Dimethyl Phthalate | Y | Y | 1 | | | Y | Y | 0.24 | | | |
| 81 | Di-n-Butyl Phthalate | Y | Y | 1 | | | Y | Y | 0.5 | | | |
| 82 | 2,4-Dinitrotoluene | Y | Y | 1 | | | Y | Y | 0.27 | | | |
| 83 | 2,6-Dinitrotoluene | Y | Y | 1.29 | | | Y | Y | 0.29 | | | No Criteria |
| 84 | Di-n-Octyl Phthalate | Y | N | | 2 | | Y | Y | 0.38 | | | No Criteria |
| 85 | 1,2-Diphenylhydrazine | Y | Y | 1 | | | Y | N | | 0.0037 | | |
| 86 | Fluoranthene | Y | Y | 0.1 | | | Y | N | | 0.011 | | |
| 87 | Fluorene | Y | Y | 0.1 | | | Y | N | | 0.00208 | | |
| 88 | Hexachlorobenzene | Y | Y | 0.98 | | | Y | N | | 0.0000202 | | |
| 89 | Hexachlorobutadiene | Y | Y | 1 | | | Y | Y | 0.3 | | | |
| 90 | Hexachlorocyclopentadiene | Y | Y | 1 | | | Y | Y | 0.31 | | | |
| 91 | Hexachloroethane | Y | Y | 1 | | | Y | Y | 0.2 | | | |
| 92 | Indeno(1,2,3-cd) Pyrene | Y | Y | 0.1 | | | Y | N | | 0.004 | | |
| 93 | Isophorone | Y | Y | 0.95 | | | Y | Y | 0.3 | | | |
| 94 | naphthalene | Y | Y | 1 | | | Y | N | | 0.0023 | | |
| 95 | Nitrobenzene | Y | Y | 0.71 | | | Y | Y | 0.25 | | | No Criteria |
| 96 | N-Nitrosodimethylamine | Y | Y | 0.1 | | | Y | Y | 0.3 | | | |
| 97 | N-Nitrosodi-n-Propylamine | Y | Y | 0.84 | | | Y | Y | 0.001 | | | |
| 98 | N-Nitrosodiphenylamine | Y | Y | 0.94 | | | Y | Y | 0.001 | | | |
| 99 | Phenanthrene | Y | Y | 0.93 | | | Y | N | | 0.0061 | | No Criteria |
| 100 | Pyrene | Y | Y | 0.1 | | | Y | N | | 0.0051 | | |
| 101 | 1,2,4-Trichlorobenzene | Y | Y | 0.94 | | | Y | Y | 0.3 | | | No Criteria |
| 102 | Aldrin | Y | N | | 0.009 | | N | | | | | |
| 103 | alpha-BHC | Y | Y | 0.005 | | | Y | N | | 0.000496 | | |
| 104 | beta-BHC | Y | N | | 0.13 | | Y | N | | 0.000413 | | |

**SFIA - Mel Leong WQCP
Sanitary Treatment Plant
Table 2. Data Input for RPA**

| CTR No. | Constituent name | EFFLUENT DATA | | | | BACKGROUND DATA (B) | | | | 7) Review other information in the SIP page 4. If information is unavailable or insufficient: B) the RWQCB shall establish interim monitoring requirements. | |
|---------|-------------------------|--------------------------------|--|--|--|---------------------|--------------------|------------------------------|--|---|--|
| | | Effluent Data Available (Y/N)? | Are all data points non-detects (Y/N)? | If all data points ND Enter the min detection limit (MDL) (ug/L) | Enter the pollutant effluent detected max conc. (ug/L) | Input Check | B Available (Y/N)? | Are all B non-detects (Y/N)? | If all data points ND Enter the min detection limit (MDL) (ug/L) | | Enter the Detected Maximum Background Conc |
| 105 | gamma-BHC | Y | N | | 0.036 | | Y | N | | 0.0007034 | |
| 106 | delta-BHC | Y | N | | 0.097 | | Y | N | | 0.000042 | |
| 107 | Chlordane (303d listed) | Y | Y | 0.1 | | | Y | N | | 0.00019 | No Criteria |
| 108 | 4,4-DDT (303d listed) | Y | N | | 0.053 | | Y | N | | 0.000066 | |
| 109 | 4,4-DDE | Y | N | | 0.05 | | Y | N | | 0.000693 | |
| 110 | 4,4-DDD | Y | Y | 0.03 | | | Y | N | | 0.000313 | |
| 111 | Dieldrin (303d listed) | Y | N | | 0.014 | | Y | N | | 0.000264 | |
| 112 | alpha-Endosulfan | Y | Y | 0.01 | | | Y | N | | 0.000031 | |
| 113 | beta-Endosulfan | Y | Y | 0.01 | | | Y | N | | 0.000069 | |
| 114 | Endosulfan Sulfate | Y | Y | 0.03 | | | Y | N | | 0.0000819 | |
| 115 | Endrin | Y | N | | 0.021 | | Y | N | | 0.000036 | |
| 116 | Endrin Aldehyde | Y | Y | 0.01 | | | N | | | | |
| 117 | Heptachlor | Y | N | | 0.26 | | Y | N | | 0.000019 | |
| 118 | Heptachlor Epoxide | Y | N | | 0.022 | | Y | N | | 0.00002458 | |
| 119-125 | PCBs sum (303d listed) | Y | Y | 0.47 | | | N | | | | |
| 126 | Toxaphene | Y | Y | 0.5 | | | N | | | | |
| | Ammonia ⁽²⁾ | Y | N | | 118,000 | | Y | N | | 210 | |
| | Tributyltin | Y | N | | 0.019 | | N | | | | |
| | Total PAHs | Y | Y | 0.02 | | | Y | N | | 0.26 | |

Notes:

- 1) Background data used for toxics is from monitoring location BC10 (Yerba Buena Island).
- 2) Background data for ammonia taken from Oyster Point RMP station

SFIA - Mel Leong WQCP
Sanitary Treatment Plant
Table 3. Reasonable Potential Analysis Results

| Beginning | Constituent name | C (ug/L) | Step 2 | | Step 3 | | Step 4 | | Step 2 | | Step 3 | | Step 4 | | Step 5 | | Step 6 | | Step 7 & 8 | |
|-----------|-----------------------------|-------------|------------|-------------------------------|------------------------------------|---|---|--|---------------------|----------------------------|---|---|---|--|---|--------------------------------|-------------|-------------------------------------|-----------------------------------|--|
| | | | Available? | Are all data points detected? | Minimum MDL (ug/L) if all data ND. | Enter the pollutant effluent detected max conc (ug/L) | If all data points are ND and MinDL<C, interim monitoring is required | Maximum Pollutant Concentration (MEC) (ug/L) | MEC vs. C | Background Data Available? | Are all background data points non-detects? | If all background data points ND Enter the min detection limit (MDL) (ug/L) | Enter the pollutant background detected max conc (ug/L) | If all B is ND, is MDL<C? (If Y, Go To Step 7) | If B<C, effluent limitation is required | r | s | t | | |
| A | B | C | D | E | F | G | H | I | J | K | L | M | N | O | P | Q | R | S | T | |
| 1 | Antimony | 4300 | Y | N | | 0.41 | | 0.41 | MEC<C, go to Step 5 | Y | | | | 1.8 | | B<C, Step 7 | | | | |
| 2 | Arsenic | 36 | Y | N | | 5 | | 5 | MEC<C, go to Step 5 | Y | | | | 2.46 | | B<C, Step 7 | | | | |
| 3 | Beryllium | No Criteria | Y | Y | 0.5 | | No Criteria | 0.5 | No Criteria | Y | | | | 0.215 | | No Criteria | No Criteria | | Uo - No Criteria | |
| 4 | Cadmium | 9.356136821 | Y | Y | | 0.58 | | 0.58 | MEC<C, go to Step 5 | Y | | | | 0.1268 | | B<C, Step 7 | | | | |
| 5a | Chromium (III) | No Criteria | N | | | 0 | No Effluent Data | | | Y | | | | | | No detected value of B, Step 7 | | | | |
| 5b | Chromium (VI) | 50.35246727 | Y | N | | 6.77 | | 6.77 | MEC<C, go to Step 5 | Y | | | | 4.4 | | B<C, Step 7 | | | | |
| 6 | Copper | 4.189 | Y | N | | 13.95 | | 13.95 | Y | Y | | | | 2.45 | | B<C, Step 7 | Y | MEC => C [13.95 ug/l vs 4.19 ug/l] | | |
| 7 | Lead | 8.517350158 | Y | N | | 5 | | 5 | MEC<C, go to Step 5 | Y | | | | 0.804 | | B<C, Step 7 | | | | |
| 8 | Mercury (303d listed) | 0.025 | Y | N | | 0.0867 | | 0.0867 | Y | Y | | | | 0.0086 | | B<C, Step 7 | Y | MEC => C [0.09 ug/l vs 0.03 ug/l] | | |
| 9 | Nickel (303d listed) | 12.61538462 | Y | N | | 14.91 | | 14.91 | Y | Y | | | | 3.73 | | B<C, Step 7 | Y | MEC => C [14.91 ug/l vs 12.62 ug/l] | | |
| 10 | Selenium | 5 | Y | N | | 1.563 | | 1.563 | MEC<C, go to Step 5 | Y | | | | 0.39 | | B<C, Step 7 | | | | |
| 11 | Silver | 2.235294118 | Y | N | | 0.5 | | 0.5 | MEC<C, go to Step 5 | Y | | | | 0.052 | | B<C, Step 7 | | | | |
| 12 | Thallium | 6.3 | Y | N | | 1.3 | | 1.3 | MEC<C, go to Step 5 | Y | | | | 0.21 | | B<C, Step 7 | | | | |
| 13 | Zinc | 85.62367865 | Y | N | | 71.4 | | 71.4 | MEC<C, go to Step 5 | Y | | | | 5.1 | | B<C, Step 7 | | | | |
| 14 | Cyanide | 1 | Y | N | | 15.8 | | 15.8 | Y | Y | 0.4 | | | N | | No detected value of B, Step 7 | | Y | MEC => C [15.8 ug/l vs 1.0 ug/l] | |
| 15 | Asbestos | No Criteria | N | | | 0 | No Criteria | | No Criteria | | | | | | | No Criteria | No Criteria | | Uo - No Criteria | |
| 16 | 2,3,7,8-TCDD (303d listed) | 0.000000014 | Y | Y | 9.80E-07 | | MDL > C, Interim Monitor, Go To St | | | Y | | | | | | No detected value of B, Step 7 | | | | |
| 16-TEQ | Dioxin TEQ (303d listed) | 0.000000014 | Y | Y | 0.000000355 | | MDL > C, Interim Monitor, Go To St | | | Y | | | | 7.10E-08 | | Y | | | | |
| 17 | Acrolein | 780 | Y | Y | 5 | | MDL<=C, MDL=MEC | 5 | MEC<C, go to Step 5 | Y | Y | 0.5 | | N | | No detected value of B, Step 7 | | | | |
| 18 | Acrylonitrile | 0.66 | Y | Y | 5 | | MDL > C, Interim Monitor, Go To St | | | Y | Y | 0.03 | | N | | B<C, Step 7 | | | Effluent MDL > C, Interim Monitor | |
| 19 | Benzene | 71 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.05 | | N | | No detected value of B, Step 7 | | | | |
| 20 | Bromofom | 360 | Y | N | | 0.6 | | 0.6 | MEC<C, go to Step 5 | Y | Y | 0.5 | | N | | No detected value of B, Step 7 | | | | |
| 21 | Carbon Tetrachloride | 4.4 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.06 | | N | | B<C, Step 7 | | | | |
| 22 | Chlorobenzene | 21000 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.5 | | N | | No detected value of B, Step 7 | | | | |
| 23 | Chlorodibromomethane | 34 | Y | N | | 1 | | 1 | MEC<C, go to Step 5 | Y | Y | 0.05 | | N | | No detected value of B, Step 7 | | | | |
| 24 | Chloroethane | No Criteria | Y | N | | 0.075 | No Criteria | 0.075 | No Criteria | Y | Y | 0.5 | | N | | No Criteria | No Criteria | | Uo - No Criteria | |
| 25 | 2-Chloroethylvinyl Ether | No Criteria | Y | Y | 20 | | No Criteria | 20 | No Criteria | Y | Y | 0.5 | | N | | No Criteria | No Criteria | | Uo - No Criteria | |
| 26 | Chloroform | No Criteria | Y | N | | 11 | No Criteria | 11 | No Criteria | Y | Y | 0.5 | | N | | No Criteria | No Criteria | | Uo - No Criteria | |
| 27 | Dichlorobromomethane | 46 | Y | N | | 5 | | 5 | MEC<C, go to Step 5 | Y | Y | 0.05 | | N | | No detected value of B, Step 7 | | | | |
| 28 | 1,1-Dichloroethane | No Criteria | Y | Y | 0.5 | | No Criteria | 0.5 | No Criteria | Y | Y | 0.05 | | N | | No Criteria | No Criteria | | Uo - No Criteria | |
| 29 | 1,2-Dichloroethane | 99 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.04 | | N | | B<C, Step 7 | | | | |
| 30 | 1,1-Dichloroethylene | 3.2 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.5 | | N | | No detected value of B, Step 7 | | | | |
| 31 | 1,2-Dichloropropane | 39 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.05 | | N | | No detected value of B, Step 7 | | | | |
| 32 | 1,3-Dichloropropylene | 1700 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.05 | | N | | No detected value of B, Step 7 | | | | |
| 33 | Ethylbenzene | 29000 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.5 | | N | | No detected value of B, Step 7 | | | | |
| 34 | Methyl Bromide | 4000 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.5 | | N | | No detected value of B, Step 7 | | | | |
| 35 | Methyl Chloride | No Criteria | Y | Y | 0.5 | | No Criteria | 0.5 | No Criteria | Y | Y | 0.5 | | N | | No Criteria | No Criteria | | Uo - No Criteria | |
| 36 | Methylenes Chloride | 1600 | Y | N | | 0.485 | | 0.485 | MEC<C, go to Step 5 | Y | Y | 0.5 | | 0.5 | | B<C, Step 7 | | | | |
| 37 | 1,1,2,2-Tetrachloroethane | 11 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.05 | | N | | No detected value of B, Step 7 | | | | |
| 38 | Tetrachloroethylene | 8.85 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.05 | | N | | No detected value of B, Step 7 | | | | |
| 39 | Toluene | 200000 | Y | N | | 0.46 | | 0.46 | MEC<C, go to Step 5 | Y | Y | 0.3 | | N | | No detected value of B, Step 7 | | | | |
| 40 | 1,2-Trans-Dichloroethylene | 140000 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.5 | | N | | No detected value of B, Step 7 | | | | |
| 41 | 1,1,1-Trichloroethane | No Criteria | Y | Y | 0.5 | | No Criteria | 0.5 | No Criteria | Y | Y | 0.5 | | N | | No Criteria | No Criteria | | Uo - No Criteria | |
| 42 | 1,1,2-Trichloroethane | 42 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.05 | | N | | No detected value of B, Step 7 | | | | |
| 43 | Trichloroethylene | 81 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.5 | | N | | No detected value of B, Step 7 | | | | |
| 44 | Vinyl Chloride | 525 | Y | Y | 0.5 | | MDL<=C, MDL=MEC | 0.5 | MEC<C, go to Step 5 | Y | Y | 0.5 | | N | | No detected value of B, Step 7 | | | | |
| 45 | Chlorophenol | 400 | Y | Y | 1.05 | | MDL<=C, MDL=MEC | 1.05 | MEC<C, go to Step 5 | Y | Y | 1.2 | | N | | No detected value of B, Step 7 | | | | |
| 46 | 2,4-Dichlorophenol | 790 | Y | Y | 1.2 | | MDL<=C, MDL=MEC | 1.2 | MEC<C, go to Step 5 | Y | Y | 1.3 | | N | | No detected value of B, Step 7 | | | | |
| 47 | 2,4-Dimethylphenol | 2300 | Y | Y | 1 | | MDL<=C, MDL=MEC | 1 | MEC<C, go to Step 5 | Y | Y | 1.3 | | N | | No detected value of B, Step 7 | | | | |
| 48 | 2-Methyl-4,6-Dinitrophenol | 765 | Y | Y | 1 | | MDL<=C, MDL=MEC | 1 | MEC<C, go to Step 5 | Y | Y | 1.2 | | N | | No detected value of B, Step 7 | | | | |
| 49 | 2,4-Dinitrophenol | 14000 | Y | Y | 3.89 | | MDL<=C, MDL=MEC | 3.89 | MEC<C, go to Step 5 | Y | Y | 0.7 | | N | | No detected value of B, Step 7 | | | | |
| 50 | 2-Nitrophenol | No Criteria | Y | Y | 1.86 | | No Criteria | 1.86 | No Criteria | Y | Y | 1.3 | | N | | No Criteria | No Criteria | | Uo - No Criteria | |
| 51 | 4-Nitrophenol | No Criteria | Y | Y | 1.96 | | No Criteria | 1.96 | No Criteria | Y | Y | 1.6 | | N | | No Criteria | No Criteria | | Uo - No Criteria | |
| 52 | 3-Methyl-4-Chlorophenol | No Criteria | Y | Y | 1 | | No Criteria | 1 | No Criteria | Y | Y | 1.1 | | N | | No Criteria | No Criteria | | Uo - No Criteria | |
| 53 | Pentachlorophenol | 7.9 | Y | Y | 1.04 | | MDL<=C, MDL=MEC | 1.04 | MEC<C, go to Step 5 | Y | Y | 1 | | N | | No detected value of B, Step 7 | | | | |
| 54 | Phenol | 4600000 | Y | Y | 1 | | MDL<=C, MDL=MEC | 1 | MEC<C, go to Step 5 | Y | Y | 1.3 | | N | | No detected value of B, Step 7 | | | | |
| 55 | 2,4,6-Trichlorophenol | 6.5 | Y | Y | 1.88 | | AI ND MDL<=C, MDL=MEC | 1.88 | MEC<C, go to Step 5 | Y | Y | 1.3 | | N | | No detected value of B, Step 7 | | | | |
| 56 | Acenaphthene | 2700 | Y | Y | 0.52 | | AI ND MDL<=C, MDL=MEC | 0.52 | MEC<C, go to Step 5 | Y | Y | | | 0.0015 | | B<C, Step 7 | | | | |
| 57 | Acenaphthylene | No Criteria | Y | Y | 0.39 | | No Criteria | 0.39 | No Criteria | Y | Y | | | 0.00053 | | No Criteria | No Criteria | | Uo - No Criteria | |
| 58 | Anthracene | 110000 | Y | Y | 0.02 | | AI ND MDL<=C, MDL=MEC | 0.02 | MEC<C, go to Step 5 | Y | Y | | | 0.0005 | | B<C, Step 7 | | | | |
| 59 | Benzidine | 0.00054 | Y | Y | 2.5 | | MDL > C, Go to Step 5 | | | Y | Y | 0.0015 | | Y | | No detected value of B, Step 7 | | | | |
| 60 | Benzo(a)Anthracene | 0.049 | Y | Y | 0.05 | | MDL > C, Go to Step 5 | | | Y | Y | | | 0.0053 | | B<C, Step 7 | | | | |
| 61 | Benzo(a)Pyrene | 0.049 | Y | Y | 0.05 | | MDL > C, Go to Step 5 | | | Y | Y | | | 0.0029 | | B<C, Step 7 | | | | |
| 62 | Benzo(b)Fluoranthene | 0.049 | Y | Y | 0.1 | | MDL > C, Go to Step 5 | | | Y | Y | | | 0.0046 | | B<C, Step 7 | | | | |
| 63 | Benzo(ghi)Perylene | No Criteria | Y | Y | 0.09 | | No Criteria | 0.09 | No Criteria | Y | Y | | | 0.0027 | | No Criteria | No Criteria | | Uo - No Criteria | |
| 64 | Benzo(k)Fluoranthene | 0.049 | Y | Y | 0.05 | | MDL > C, Go to Step 5 | | | Y | Y | | | 0.0015 | | B<C, Step 7 | | | | |
| 65 | Bis(2-Chloroethoxy)Methane | No Criteria | Y | Y | 0.97 | | No Criteria | 0.97 | No Criteria | Y | Y | 0.3 | | N | | No Criteria | No Criteria | | Uo - No Criteria | |
| 66 | Bis(2-Chloroethyl)Ether | 1.4 | Y | Y | 0.97 | | AI ND MDL<=C, MDL=MEC | 0.97 | MEC<C, go to Step 5 | Y | Y | 0.3 | | N | | No detected value of B, Step 7 | | | | |
| 67 | Bis(2-Chloroisopropyl)Ether | 17000 | Y | Y | 0.81 | | AI ND MDL<=C, MDL=MEC | 0.81 | MEC<C, go to Step 5 | Y | Y | | | N | | No detected value of B, Step 7 | | | | |
| 68 | Bis(2-Ethylhexyl)Phthalate | 5.9 | Y | Y | 0.69 | | AI ND MDL<=C, MDL=MEC | 0.69 | MEC<C, go to Step 5 | Y | Y | 0.5 | | N | | No detected value of B, Step 7 | | | | |

SFIA - Mel Leong WQCP
Sanitary Treatment Plant
Table 3. Reasonable Potential Analysis Results

| Beginning | Constituent name | C (µg/L) Lowest (most stringent) Criteria ^(a) (Enter "No Criteria" for no criteria) | Step 2 | | Step 3 | | Step 4 | | Step 2 | | Step 3 | | Step 4 | | Step 5 | | Step 6 | | Step 7 & 8 | |
|-----------|---------------------------|--|--------------------------|----------------------------------|------------------------------------|---|---|--|-----------------------|---|----------------------------|---|---|---|--|---|---------|---|-------------|---------------------------------------|
| | | | Effluent Data Available? | Are all data points non-detects? | Minimum MDL (µg/L) if all data ND. | Enter the pollutant effluent detected max conc (µg/L) | If all data points are ND and MinDL > C, interim monitoring is required | Maximum Pollutant Concentration (MEC) (µg/L) | MEC vs. C | Y if MEC >= C, effluent limitation is required; 2. If MEC < C, go to Step 5 | Background Data Available? | Are all background data points non-detects? | If all background data points ND Enter the min detection limit (MDL) (µg/L) | Enter the pollutant background detected max conc (µg/L) | If all B is ND, is MDL > C? (If Y, Go To Step 7) | If B > C, effluent limitation is required | B vs. C | 7) Review other information in the SIP page 4. Y if other information indicates limits are required. If information is unavailable or insufficient; 8) the RWQCB shall establish interim monitoring requirements. | RPA Result | Reason |
| 73 | Chrysen | 0.049 | Y | Y | 0.9 | | MDL > C, Go to Step 5 | | Y | | | | | | | | | B-C, Step 7 | | |
| 74 | Dibenz(a,h)Anthracene | 0.049 | Y | Y | 0.09 | | MDL > C, Go to Step 5 | | Y | | | 0.00064 | | | | | | B-C, Step 7 | | |
| 75 | 1,2-Dichlorobenzene | 17000 | Y | Y | 0.5 | | AI ND MDL <= C, MDL=MEC | 0.5 | MEC < C, go to Step 5 | Y | Y | 0.8 | | N | | | | No detected value of B, Step 7 | | |
| 76 | 1,3-Dichlorobenzene | 2600 | Y | Y | 0.5 | | AI ND MDL <= C, MDL=MEC | 0.5 | MEC < C, go to Step 5 | Y | Y | 0.8 | | N | | | | No detected value of B, Step 7 | | |
| 77 | 1,4-Dichlorobenzene | 2600 | Y | N | | | | | MEC < C, go to Step 5 | Y | Y | 0.8 | | N | | | | No detected value of B, Step 7 | | |
| 78 | 3,3'-Dichlorobenzidine | 0.077 | Y | Y | 0.9 | 0.13 | MDL > C, Go to Step 5 | | | Y | Y | 0.001 | | N | | | | No detected value of B, Step 7 | | |
| 79 | Diethyl Phthalate | 120000 | Y | Y | 1 | | AI ND MDL <= C, MDL=MEC | 1 | MEC < C, go to Step 5 | Y | Y | 0.24 | | N | | | | No detected value of B, Step 7 | | |
| 80 | Dimethyl Phthalate | 2900000 | Y | Y | 1 | | AI ND MDL <= C, MDL=MEC | 1 | MEC < C, go to Step 5 | Y | Y | 0.24 | | N | | | | No detected value of B, Step 7 | | |
| 81 | Di-n-Butyl Phthalate | 12000 | Y | Y | 1 | | AI ND MDL <= C, MDL=MEC | 1 | MEC < C, go to Step 5 | Y | Y | 0.5 | | N | | | | No detected value of B, Step 7 | | |
| 82 | 2,4-Dinitrotoluene | 9.1 | Y | Y | 1 | | AI ND MDL <= C, MDL=MEC | 1 | MEC < C, go to Step 5 | Y | Y | 0.27 | | N | | | | No detected value of B, Step 7 | | |
| 83 | 2,6-Dinitrotoluene | No Criteria | Y | Y | 1.29 | | No Criteria | 1.29 | No Criteria | Y | Y | 0.29 | | N | | | | No Criteria | No Criteria | Uo - No Criteria |
| 84 | Di-n-Octyl Phthalate | No Criteria | Y | N | | 2 | No Criteria | 2 | No Criteria | Y | Y | 0.38 | | N | | | | No Criteria | No Criteria | Uo - No Criteria |
| 85 | 1,2-Diphenylhydrazine | 0.54 | Y | Y | 1 | | MDL > C, Interim Monitor, Go To St | | | Y | | | 0.0037 | | | | | B-C, Step 7 | | Effluent MDL > C, Interim Monitor |
| 86 | Fluoranthene | 370 | Y | Y | 0.1 | | AI ND MDL <= C, MDL=MEC | 0.1 | MEC < C, go to Step 5 | Y | | | 0.011 | | | | | B-C, Step 7 | | |
| 87 | Fluorene | 14000 | Y | Y | 0.1 | | AI ND MDL <= C, MDL=MEC | 0.1 | MEC < C, go to Step 5 | Y | | | 0.00208 | | | | | B-C, Step 7 | | |
| 88 | Hexachlorobenzene | 0.00077 | Y | Y | 0.98 | | MDL > C, Go to Step 5 | | | Y | | | 0.0000202 | | | | | B-C, Step 7 | | |
| 89 | Hexachlorobutadiene | 50 | Y | Y | 1 | | AI ND MDL <= C, MDL=MEC | 1 | MEC < C, go to Step 5 | Y | Y | 0.3 | | N | | | | No detected value of B, Step 7 | | |
| 90 | Hexachlorocyclopentadiene | 17000 | Y | Y | 1 | | AI ND MDL <= C, MDL=MEC | 1 | MEC < C, go to Step 5 | Y | Y | 0.31 | | N | | | | No detected value of B, Step 7 | | |
| 91 | Hexachloroethane | 8.9 | Y | Y | 1 | | AI ND MDL <= C, MDL=MEC | 1 | MEC < C, go to Step 5 | Y | Y | 0.2 | | N | | | | No detected value of B, Step 7 | | |
| 92 | Indeno(1,2,3-cd)Pyrene | 0.049 | Y | Y | 0.1 | | MDL > C, Go to Step 5 | | | Y | | | 0.004 | | | | | B-C, Step 7 | | |
| 93 | Isophthalene | 500 | Y | Y | 0.95 | | AI ND MDL <= C, MDL=MEC | 0.95 | MEC < C, go to Step 5 | Y | Y | 0.3 | | N | | | | No detected value of B, Step 7 | | |
| 94 | Isophthalene | No Criteria | Y | Y | 1 | | No Criteria | 1 | No Criteria | Y | | | 0.0023 | | | | | No Criteria | No Criteria | Uo - No Criteria |
| 95 | Nitrobenzene | 1900 | Y | Y | 0.71 | | AI ND MDL <= C, MDL=MEC | 0.71 | MEC < C, go to Step 5 | Y | Y | 0.25 | | N | | | | No detected value of B, Step 7 | | |
| 96 | N-Nitrosodimethylamine | 8.1 | Y | Y | 0.1 | | AI ND MDL <= C, MDL=MEC | 0.1 | MEC < C, go to Step 5 | Y | Y | 0.3 | | N | | | | No detected value of B, Step 7 | | |
| 97 | N-Nitrosodi-n-Propylamine | 1.4 | Y | Y | 0.84 | | AI ND MDL <= C, MDL=MEC | 0.84 | MEC < C, go to Step 5 | Y | Y | 0.001 | | N | | | | No detected value of B, Step 7 | | |
| 98 | N-Nitrosodiphenylamine | 16 | Y | Y | 0.94 | | AI ND MDL <= C, MDL=MEC | 0.94 | MEC < C, go to Step 5 | Y | Y | 0.001 | | N | | | | No detected value of B, Step 7 | | |
| 99 | Phenanthrene | No Criteria | Y | Y | 0.93 | | No Criteria | 0.93 | No Criteria | Y | | | 0.0061 | | | | | No Criteria | No Criteria | Uo - No Criteria |
| 100 | Pyrene | 11000 | Y | Y | 0.1 | | AI ND MDL <= C, MDL=MEC | 0.1 | MEC < C, go to Step 5 | Y | | | 0.0051 | | | | | B-C, Step 7 | | |
| 101 | 1,2,4-Trichlorobenzene | No Criteria | Y | Y | 0.94 | | No Criteria | 0.94 | No Criteria | Y | Y | 0.3 | | N | | | | No Criteria | No Criteria | Uo - No Criteria |
| 102 | Aldrin | 0.00014 | Y | N | | 0.009 | | | Y | | | | | | | | | No detected value of B, Step 7 | Y | MEC => C [0.009 ug/l vs 0.00014 ug/l] |
| 103 | alpha-BHC | 0.013 | Y | Y | 0.005 | | AI ND MDL <= C, MDL=MEC | 0.005 | MEC < C, go to Step 5 | Y | | | 0.000496 | | | | | B-C, Step 7 | | |
| 104 | beta-BHC | 0.046 | Y | N | | 0.13 | | | Y | | | | 0.000413 | | | | | B-C, Step 7 | Y | MEC => C [0.13 ug/l vs 0.046 ug/l] |
| 105 | gamma-BHC | 0.063 | Y | N | | 0.036 | | | MEC < C, go to Step 5 | Y | | | 0.0007034 | | | | | B-C, Step 7 | | |
| 106 | delta-BHC | No Criteria | Y | N | | 0.097 | No Criteria | 0.097 | No Criteria | Y | | | 0.000042 | | | | | No Criteria | No Criteria | Uo - No Criteria |
| 107 | Chlordane (303d listed) | 0.00059 | Y | Y | 0.1 | | MDL > C, Go to Step 5 | | | Y | | | 0.000018 | | | | | B-C, Step 7 | | |
| 108 | 4,4'-DDT (303d listed) | 0.00059 | Y | N | | 0.053 | MDL > C, Go to Step 5 | 0.053 | Y | | | | 0.000066 | | | | | B-C, Step 7 | Y | MEC => C [0.053 ug/l vs 0.00059 ug/l] |
| 109 | 4,4'-DDE | 0.00059 | Y | N | | 0.05 | MDL > C, Go to Step 5 | 0.05 | Y | | | | 0.000693 | | | | | B-C, Step 7 | Y | MEC => C [0.050 ug/l vs 0.00059 ug/l] |
| 110 | 4,4'-DDD | 0.00084 | Y | Y | 0.03 | | MDL > C, Go to Step 5 | | | Y | | | 0.000313 | | | | | B-C, Step 7 | | |
| 111 | Dieldrin (303d listed) | 0.00014 | Y | N | | 0.014 | MDL > C, Go to Step 5 | 0.014 | Y | | | | 0.000264 | | | | | B-C, Step 7 | Y | MEC => C [0.014 ug/l vs 0.00014 ug/l] |
| 112 | alpha-Endosulfan | 0.0087 | Y | Y | 0.01 | | MDL > C, Interim Monitor, Go To St | | | Y | | | 0.000031 | | | | | B-C, Step 7 | | Effluent MDL > C, Interim Monitor |
| 113 | beta-Endosulfan | 0.0087 | Y | Y | 0.01 | | MDL > C, Interim Monitor, Go To St | | | Y | | | 0.000069 | | | | | B-C, Step 7 | | Effluent MDL > C, Interim Monitor |
| 114 | Endosulfan Sulfate | 240 | Y | Y | 0.03 | | AI ND MDL <= C, MDL=MEC | 0.03 | MEC < C, go to Step 5 | Y | | | 0.0000819 | | | | | B-C, Step 7 | | |
| 115 | Endrin | 0.0023 | Y | N | | 0.021 | | | Y | | | | 0.000036 | | | | | B-C, Step 7 | Y | MEC => C [0.0210 ug/l vs 0.0023 ug/l] |
| 116 | Endrin Aldehyde | 0.81 | Y | Y | 0.01 | | AI ND MDL <= C, MDL=MEC | 0.01 | MEC < C, go to Step 5 | Y | | | | | | | | No detected value of B, Step 7 | | |
| 117 | Heptachlor | 0.00021 | Y | N | | 0.26 | MDL > C, Go to Step 5 | 0.26 | Y | | | | 0.000019 | | | | | B-C, Step 7 | Y | MEC => C [0.260 ug/l vs 0.00021 ug/l] |
| 118 | Heptachlor Epoxide | 0.00011 | Y | N | | 0.022 | MDL > C, Go to Step 5 | 0.022 | Y | | | | 0.00002458 | | | | | B-C, Step 7 | Y | MEC => C [0.022 ug/l vs 0.00011 ug/l] |
| 119-125 | PCBs sum (303d listed) | 0.00017 | Y | Y | 0.47 | | MDL > C, Go to Step 5 | | | | | | | | | | | No detected value of B, Step 7 | | |
| 126 | Toxaphene | 0.0002 | Y | Y | 0.5 | | MDL > C, Go to Step 5 | | | | | | | | | | | No detected value of B, Step 7 | | |
| | Ammonia | 1,500 | Y | N | | 118,000 | MDL > C, Go to Step 5 | 118,000 | Y | | | | 210 | | | | | B-C, Step 7 | Y | MEC => C [120 mg/l vs 1.5 mg/l] |
| | Tributyltin | 0.01 | Y | N | | 0.019 | | | Y | | | | | | | | | No detected value of B, Step 7 | Y | MEC => C [0.019 ug/l vs 0.010 ug/l] |
| | Total PAHs | 15 | Y | Y | 0.02 | | AI ND MDL <= C, MDL=MEC | 0.02 | MEC < C, go to Step 5 | Y | | | 0.26 | | | | | B-C, Step 7 | | |

a. The most stringent of salt and fresh water criteria were selected for this analysis.

b. Acronyms in the "Final Result" column:
 Uo: No criteria available
 IM: Interim monitoring is required

SFIA - Mel Leong WQCP
 Sanitary Treatment Plant
 Table 3. Reasonable Potential Analysis Results

| Beginning | | |
|------------------|---------------------------------|--|
| | | |
| Constituent name | | |
| A | B | |
| 1 | Antimony | |
| 2 | Arsenic | |
| 3 | Beryllium | |
| 4 | Cadmium | |
| 5a | Chromium (III) | |
| 5b | Chromium (VI) | |
| 6 | Copper | |
| 7 | Lead | |
| 8 | Mercury (303d listed) | |
| 9 | Nickel (303d listed) | |
| 10 | Selenium | |
| 11 | Silver | |
| 12 | Thallium | |
| 13 | Zinc | |
| 14 | Cyanide | |
| 15 | Asbestos | |
| 16 | 2,3,7,8-TCDD (303d listed) | |
| 16-TEQ | Dioxin TEQ (303d listed) | |
| 17 | Acrolein | |
| 18 | Acrylonitrile | |
| 19 | Benzene | |
| 20 | Bromoform | |
| 21 | Carbon Tetrachloride | |
| 22 | Chlorobenzene | |
| 23 | Chlorodibromomethane | |
| 24 | Chloroethane | |
| 25 | 2-Chloroethylvinyl Ether | |
| 26 | Chloroform | |
| 27 | Dichlorobromomethane | |
| 28 | 1,1-Dichloroethane | |
| 29 | 1,2-Dichloroethane | |
| 30 | 1,1-Dichloroethylene | |
| 31 | 1,2-Dichloropropane | |
| 32 | 1,3-Dichloropropylene | |
| 33 | Ethylbenzene | |
| 34 | Methyl Bromide | |
| 35 | Methyl Chloride | |
| 36 | Methylene Chloride | |
| 37 | 1,1,2,2-Tetrachloroethane | |
| 38 | Tetrachloroethylene | |
| 39 | Toluene | |
| 40 | 1,2-Trans-Dichloroethylene | |
| 41 | 1,1,1-Trichloroethane | |
| 42 | 1,1,2-Trichloroethane | |
| 43 | Trichloroethylene | |
| 44 | Vinyl Chloride | |
| 45 | Chlorophenol | |
| 46 | 2,4-Dichlorophenol | |
| 47 | 2,4-Dimethylphenol | |
| 48 | 2-Methyl-4,6-Dinitrophenol | |
| 49 | 2,4-Dinitrophenol | |
| 50 | 2-Nitrophenol | |
| 51 | 4-Nitrophenol | |
| 52 | 3-Methyl-4-Chlorophenol | |
| 53 | Pentachlorophenol | |
| 54 | Phenol | |
| 55 | 2,4,6-Trichlorophenol | |
| 56 | Acenaphthene | |
| 57 | Acenaphthylene | |
| 58 | Anthracene | |
| 59 | Benzo(a)Anthracene | |
| 60 | Benzo(a)Pyrene | |
| 61 | Benzo(b)Fluoranthene | |
| 62 | Benzo(k)Fluoranthene | |
| 63 | Benzo(ghi)Perylene | |
| 64 | Benzo(a)Fluoranthene | |
| 65 | Bis(2-Chloroethoxy)Methane | |
| 66 | Bis(2-Chloroethyl)Ether | |
| 67 | Bis(2-Chloroisopropyl)Ether | |
| 68 | Bis(2-Ethylhexyl)Phthalate | |
| 69 | 4-tert-Butylphenyl Phenyl Ether | |
| 70 | Butylbenzyl Phthalate | |
| 71 | 2-Chloronaphthalene | |
| 72 | 4-Chlorophenyl Phenyl Ether | |

SFIA - Mel Leong WQCP
 Sanitary Treatment Plant
 Table 3. Reasonable Potential Analysis Results

| Beginning | | |
|-----------|--------------------------------------|--|
| | Constituent name | |
| 73 | Chrysene | |
| 74 | Dibenz(a,h)Anthracene | |
| 75 | 1,2-Dichlorobenzene | |
| 76 | 1,3-Dichlorobenzene | |
| 77 | 1,4-Dichlorobenzene | |
| 78 | 3,3'-Dichlorobenzidine | |
| 79 | Diethyl Phthalate | |
| 80 | Dimethyl Phthalate | |
| 81 | Di-n-Butyl Phthalate | |
| 82 | 2,4-Dinitrotoluene | |
| 83 | 2,6-Dinitrotoluene | |
| 84 | Di-n-Octyl Phthalate | |
| 85 | 1,2-Diphenylhydrazine | |
| 86 | Fluoranthene | |
| 87 | Fluorene | |
| 88 | Hexachlorobenzene | |
| 89 | Hexachlorobutadiene | |
| 90 | Hexachlorocyclopentadiene | |
| 91 | Hexachloroethane | |
| 92 | Indeno(1,2,3-cd) Pyrene | |
| 93 | Isophorone | |
| 94 | naphthalene | |
| 95 | Nitrobenzene | |
| 96 | N-Nitrosodimethylamine | |
| 97 | N-Nitrosodi-n-Propylamine | |
| 98 | N-Nitrosodiphenylamine | |
| 99 | Phenanthrene | |
| 100 | Pyrene | |
| 101 | 1,2,4-Trichlorobenzene | |
| 102 | Aldrin | |
| 103 | alpha-BHC | |
| 104 | beta-BHC | |
| 105 | gamma-BHC | |
| 106 | delta-BHC | |
| 107 | Chlordane (303d listed) | |
| 108 | 4,4-DDT (303d listed) | |
| 109 | 4,4-DDE | |
| 110 | 4,4-DDD | |
| 111 | Dieldrin (303d listed) | |
| 112 | alpha-Endosulfan | |
| 113 | beta-Endosulfan | |
| 114 | Endosulfan Sulfate | |
| 115 | Endrin | |
| 116 | Endrin Aldehyde | |
| 117 | Heptachlor | |
| 118 | Heptachlor Epoxide | |
| 119-125 | PCBs sum (303d listed) | |
| 126 | Toxaphene | |
| | Ammonia | |
| | Tributyltin | |
| | Total PAHs | |
| | a. The most stringent of salt and fr | |
| | b. Acronyms in the "Final Result" | |

SFIA Mel Leong WQCP
Sanitary Treatment Plant
Table 6. Salinity Hardness

| | | | | | | | |
|------------------|------|---------|------------|------|----------|-----|--------|
| 109 ES_WATER WCT | BA40 | 1996-07 | 07/29/1996 | 23.0 | o/oo | 7.9 | 0.0 pH |
| 110 ES_WATER WCT | BA40 | 1997-01 | 01/22/1997 | 11.4 | o/oo | 7.8 | 0.0 pH |
| 111 ES_WATER WCT | BA40 | 1997-04 | 04/16/1997 | | | 8.2 | 0.0 pH |
| 112 ES_WATER WCT | BA40 | 1997-07 | 07/29/1997 | 29.1 | o/oo | 7.7 | 0.0 pH |
| 113 ES_WATER WCT | BA40 | 1998-02 | 01/27/1998 | 19.0 | o/oo | 7.7 | 0.0 pH |
| 114 ES_WATER WCT | BA40 | 1998-04 | 04/22/1998 | 17.3 | o/oo | 8.4 | 0.0 pH |
| 115 ES_WATER WCT | BA40 | 1998-07 | 07/20/1998 | 20.7 | o/oo | 8.0 | 0.0 pH |
| 116 ES_WATER WCT | BA40 | 1999-02 | 02/01/1999 | 25.2 | o/oo | 7.8 | pH |
| 117 ES_WATER WCT | BA40 | 1999-04 | 04/12/1999 | 19.3 | o/oo | 8.3 | pH |
| 118 ES_WATER WCT | BA40 | 1999-07 | 07/13/1999 | 27.7 | o/oo | 8.0 | pH |
| 119 ES_WATER WCT | BA40 | 2000-02 | 02/01/2000 | 25.9 | 0.1 o/oo | 7.8 | 0.0 pH |
| 120 ES_WATER WCT | BA40 | 2000-07 | 07/11/2000 | 27.6 | 0.1 o/oo | 7.8 | 0.0 pH |
| 121 ES_WATER WCT | BA40 | 2001-02 | 02/06/2001 | 28.3 | 0.2 o/oo | 8.2 | 0.0 pH |
| 122 ES_WATER WCT | BA40 | 2001-08 | 07/31/2001 | 29.8 | 0.2 o/oo | 8.0 | 0.0 pH |

**SFIA Mel Leong WQCP
Sanitary Treatment Plant
Table 8. Dioxin Data**

Sort **Dioxin Data from San Francisco International Airport - Municipal Wastewater Treatment Plant**

1
2

| Permit Title | Analyte | Sampled Date | Qualifier | Result, pg/L | Unit in pg/L | Reporting Limit / ML | MDL | CTR No. |
|--|---------------------|--------------|-----------|--------------|--------------|----------------------|-----|---------|
| 4 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDD | 9/27/2002 | ND | 2.64 | pg/L | 2.64 | | 16-01 |
| 5 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDD | 2/28/2003 | ND | 1.77 | pg/L | 1.77 | | 16-01 |
| 6 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDD | 7/25/2003 | ND | 1.72 | pg/L | 1.72 | | 16-01 |
| 7 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDD | 3/30/2004 | ND | 3.9 | pg/L | 3.9 | | 16-01 |
| 8 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDD | 8/24/2004 | ND | 1.32 | pg/L | 2.24 | | 16-01 |
| 9 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDD | 3/22/2005 | ND | 0.543 | pg/L | 2.81 | | 16-01 |
| 10 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDD | 9/19/2005 | ND | 10 | pg/L | 10 | | 16-01 |
| 11 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDD | 3/13/2006 | ND | 0.975 | pg/L | 0.975 | | 16-01 |
| 12 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDD | 9/27/2002 | ND | 3.32 | pg/L | 3.32 | | 16-02 |
| 13 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDD | 2/28/2003 | ND | 2.9 | pg/L | 2.9 | | 16-02 |
| 14 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDD | 7/25/2003 | ND | 3.34 | pg/L | 3.34 | | 16-02 |
| 15 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDD | 3/30/2004 | ND | 11 | pg/L | 11.0 | | 16-02 |
| 16 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDD | 8/24/2004 | ND | 1.97 | pg/L | 4.10 | | 16-02 |
| 17 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDD | 3/22/2005 | ND | 0.771 | pg/L | 2.13 | | 16-02 |
| 18 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDD | 9/19/2005 | ND | 50 | pg/L | 50 | | 16-02 |
| 19 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDD | 3/13/2006 | ND | 0.844 | pg/L | 0.844 | | 16-02 |
| 20 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDD | 9/27/2002 | ND | 4.43 | pg/L | 4.43 | | 16-03 |
| 21 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDD | 2/28/2003 | ND | 3.67 | pg/L | 3.67 | | 16-03 |
| 22 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDD | 7/25/2003 | ND | 4.28 | pg/L | 4.28 | | 16-03 |
| 23 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDD | 3/30/2004 | ND | 11 | pg/L | 11.0 | | 16-03 |
| 24 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDD | 8/24/2004 | ND | 2.86 | pg/L | 5.19 | | 16-03 |
| 25 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDD | 3/22/2005 | ND | 0.845 | pg/L | 2.89 | | 16-03 |
| 26 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDD | 9/19/2005 | ND | 50 | pg/L | 50 | | 16-03 |
| 27 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDD | 3/13/2006 | ND | 0.704 | pg/L | 0.704 | | 16-03 |
| 28 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDD | 9/27/2002 | ND | 4.97 | pg/L | 4.97 | | 16-04 |
| 29 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDD | 2/28/2003 | ND | 4.07 | pg/L | 4.07 | | 16-04 |
| 30 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDD | 7/25/2003 | ND | 4.62 | pg/L | 4.62 | | 16-04 |
| 31 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDD | 3/30/2004 | ND | 10 | pg/L | 10.0 | | 16-04 |
| 32 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDD | 8/24/2004 | ND | 2.82 | pg/L | 5.51 | | 16-04 |
| 33 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDD | 3/22/2005 | ND | 1.05 | pg/L | 3.6 | | 16-04 |
| 34 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDD | 9/19/2005 | ND | 50 | pg/L | 50 | | 16-04 |
| 35 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDD | 3/13/2006 | ND | 0.758 | pg/L | 0.758 | | 16-04 |
| 36 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDD | 9/27/2002 | ND | 4.62 | pg/L | 4.62 | | 16-05 |
| 37 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDD | 2/28/2003 | ND | 3.28 | pg/L | 3.28 | | 16-05 |
| 38 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDD | 7/25/2003 | ND | 4.15 | pg/L | 4.15 | | 16-05 |
| 39 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDD | 3/30/2004 | ND | 10 | pg/L | 10.0 | | 16-05 |
| 40 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDD | 8/24/2004 | ND | 2.68 | pg/L | 5.19 | | 16-05 |
| 41 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDD | 3/22/2005 | ND | 0.91 | pg/L | 3.02 | | 16-05 |
| 42 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDD | 9/19/2005 | ND | 50 | pg/L | 50 | | 16-05 |
| 43 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDD | 3/13/2006 | ND | 0.804 | pg/L | 0.804 | | 16-05 |
| 44 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDD | 9/27/2002 | ND | 5 | pg/L | 5.00 | | 16-06 |
| 45 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDD | 2/28/2003 | ND | 3.14 | pg/L | 3.14 | | 16-06 |
| 46 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDD | 7/25/2003 | ND | 3.85 | pg/L | 3.85 | | 16-06 |
| 47 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDD | 3/30/2004 | ND | 11 | pg/L | 11.0 | | 16-06 |
| 48 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDD | 8/24/2004 | ND | 2.4 | pg/L | 5.98 | | 16-06 |
| 49 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDD | 3/22/2005 | ND | 1.18 | pg/L | 3 | | 16-06 |
| 50 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDD | 9/19/2005 | ND | 50 | pg/L | 50 | | 16-06 |
| 51 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDD | 3/13/2006 | ND | 0.919 | pg/L | 0.613 | | 16-06 |
| 52 S.F. Airport, Water Quality Control Plant | OCDD | 9/27/2002 | ND | 6.26 | pg/L | 6.26 | | 16-07 |
| 53 S.F. Airport, Water Quality Control Plant | OCDD | 2/28/2003 | ND | 5.62 | pg/L | 5.62 | | 16-07 |
| 54 S.F. Airport, Water Quality Control Plant | OCDD | 7/25/2003 | ND | 4.42 | pg/L | 4.42 | | 16-07 |
| 55 S.F. Airport, Water Quality Control Plant | OCDD | 3/30/2004 | ND | 13 | pg/L | 13.0 | | 16-07 |
| 56 S.F. Airport, Water Quality Control Plant | OCDD | 8/24/2004 | ND | 4.89 | pg/L | 9.38 | | 16-07 |
| 57 S.F. Airport, Water Quality Control Plant | OCDD | 3/22/2005 | ND | 2.26 | pg/L | 5.58 | | 16-07 |
| 58 S.F. Airport, Water Quality Control Plant | OCDD | 9/19/2005 | ND | 100 | pg/L | 100 | | 16-07 |
| 59 S.F. Airport, Water Quality Control Plant | OCDD | 3/13/2006 | ND | 2.49 | pg/L | 1.07 | | 16-07 |
| 60 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDF | 9/27/2002 | ND | 1.78 | pg/L | 1.78 | | 16-08 |
| 61 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDF | 2/28/2003 | ND | 1.24 | pg/L | 1.24 | | 16-08 |
| 62 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDF | 7/25/2003 | ND | 1.36 | pg/L | 1.36 | | 16-08 |

**SFIA Mel Leong WQCP
Sanitary Treatment Plant
Table 8. Dioxin Data**

| | | | | | | | |
|---|---------------------|-----------|----|-------|------|-------|-------|
| 63 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDF | 3/30/2004 | ND | 4 | pg/L | 4.0 | 16-08 |
| 64 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDF | 8/24/2004 | ND | 1.01 | pg/L | 1.40 | 16-08 |
| 65 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDF | 3/22/2005 | ND | 0.449 | pg/L | 2.16 | 16-08 |
| 66 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDF | 9/19/2005 | ND | 10 | pg/L | 10 | 16-08 |
| 67 S.F. Airport, Water Quality Control Plant | 2,3,7,8-TCDF | 3/13/2006 | ND | 0.675 | pg/L | 0.675 | 16-08 |
| 68 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDF | 9/27/2002 | ND | 3.19 | pg/L | 3.19 | 16-09 |
| 69 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDF | 2/28/2003 | ND | 3.15 | pg/L | 3.15 | 16-09 |
| 70 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDF | 7/25/2003 | ND | 3.7 | pg/L | 3.70 | 16-09 |
| 71 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDF | 3/30/2004 | ND | 6.5 | pg/L | 6.5 | 16-09 |
| 72 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDF | 8/24/2004 | ND | 1.8 | pg/L | 4.65 | 16-09 |
| 73 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDF | 3/22/2005 | ND | 1.05 | pg/L | 2.11 | 16-09 |
| 74 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDF | 9/19/2005 | ND | 50 | pg/L | 50 | 16-09 |
| 75 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8-PeCDF | 3/13/2006 | ND | 0.95 | pg/L | 0.95 | 16-09 |
| 76 S.F. Airport, Water Quality Control Plant | 2,3,4,7,8-PeCDF | 9/27/2002 | ND | 2.88 | pg/L | 2.88 | 16-10 |
| 77 S.F. Airport, Water Quality Control Plant | 2,3,4,7,8-PeCDF | 2/28/2003 | ND | 2.97 | pg/L | 2.97 | 16-10 |
| 78 S.F. Airport, Water Quality Control Plant | 2,3,4,7,8-PeCDF | 7/25/2003 | ND | 3.28 | pg/L | 3.28 | 16-10 |
| 79 S.F. Airport, Water Quality Control Plant | 2,3,4,7,8-PeCDF | 3/30/2004 | ND | 7.9 | pg/L | 7.9 | 16-10 |
| 80 S.F. Airport, Water Quality Control Plant | 2,3,4,7,8-PeCDF | 8/24/2004 | ND | 1.77 | pg/L | 4.14 | 16-10 |
| 81 S.F. Airport, Water Quality Control Plant | 2,3,4,7,8-PeCDF | 3/22/2005 | ND | 1.08 | pg/L | 2 | 16-10 |
| 82 S.F. Airport, Water Quality Control Plant | 2,3,4,7,8-PeCDF | 9/19/2005 | ND | 50 | pg/L | 50 | 16-10 |
| 83 S.F. Airport, Water Quality Control Plant | 2,3,4,7,8-PeCDF | 3/13/2006 | ND | 0.892 | pg/L | 0.892 | 16-10 |
| 84 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDF | 9/27/2002 | ND | 1.22 | pg/L | 1.22 | 16-11 |
| 85 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDF | 2/28/2003 | ND | 0.871 | pg/L | 0.871 | 16-11 |
| 86 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDF | 7/25/2003 | ND | 0.918 | pg/L | 0.918 | 16-11 |
| 87 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDF | 3/30/2004 | ND | 11 | pg/L | 11.0 | 16-11 |
| 88 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDF | 8/24/2004 | ND | 1 | pg/L | 1.57 | 16-11 |
| 89 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDF | 3/22/2005 | ND | 0.545 | pg/L | 1.01 | 16-11 |
| 90 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDF | 9/19/2005 | ND | 50 | pg/L | 50 | 16-11 |
| 91 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8-HxCDF | 3/13/2006 | ND | 0.567 | pg/L | 0.567 | 16-11 |
| 92 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDF | 9/27/2002 | ND | 1.51 | pg/L | 1.51 | 16-12 |
| 93 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDF | 2/28/2003 | ND | 1.08 | pg/L | 1.08 | 16-12 |
| 94 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDF | 7/25/2003 | ND | 1.09 | pg/L | 1.09 | 16-12 |
| 95 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDF | 3/30/2004 | ND | 9.4 | pg/L | 9.4 | 16-12 |
| 96 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDF | 8/24/2004 | ND | 1.01 | pg/L | 2.13 | 16-12 |
| 97 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDF | 3/22/2005 | ND | 0.355 | pg/L | 0.94 | 16-12 |
| 98 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDF | 9/19/2005 | ND | 50 | pg/L | 50 | 16-12 |
| 99 S.F. Airport, Water Quality Control Plant | 1,2,3,6,7,8-HxCDF | 3/13/2006 | ND | 0.596 | pg/L | 0.596 | 16-12 |
| 100 S.F. Airport, Water Quality Control Plant | 2,3,4,6,7,8-HxCDF | 9/27/2002 | ND | 1.46 | pg/L | 1.46 | 16-13 |
| 101 S.F. Airport, Water Quality Control Plant | 2,3,4,6,7,8-HxCDF | 2/28/2003 | ND | 1.1 | pg/L | 1.1 | 16-13 |
| 102 S.F. Airport, Water Quality Control Plant | 2,3,4,6,7,8-HxCDF | 7/25/2003 | ND | 1.29 | pg/L | 1.29 | 16-13 |
| 103 S.F. Airport, Water Quality Control Plant | 2,3,4,6,7,8-HxCDF | 3/30/2004 | ND | 6.9 | pg/L | 6.9 | 16-13 |
| 104 S.F. Airport, Water Quality Control Plant | 2,3,4,6,7,8-HxCDF | 8/24/2004 | ND | 1.01 | pg/L | 2.04 | 16-13 |
| 105 S.F. Airport, Water Quality Control Plant | 2,3,4,6,7,8-HxCDF | 3/22/2005 | ND | 0.37 | pg/L | 0.884 | 16-13 |
| 106 S.F. Airport, Water Quality Control Plant | 2,3,4,6,7,8-HxCDF | 9/19/2005 | ND | 50 | pg/L | 50 | 16-13 |
| 107 S.F. Airport, Water Quality Control Plant | 2,3,4,6,7,8-HxCDF | 3/13/2006 | ND | 0.58 | pg/L | 0.58 | 16-13 |
| 108 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDF | 9/27/2002 | ND | 1.87 | pg/L | 1.87 | 16-14 |
| 109 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDF | 2/28/2003 | ND | 1.35 | pg/L | 1.35 | 16-14 |
| 110 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDF | 7/25/2003 | ND | 1.55 | pg/L | 1.55 | 16-14 |
| 111 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDF | 3/30/2004 | ND | 6.4 | pg/L | 6.4 | 16-14 |
| 112 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDF | 8/24/2004 | ND | 1.06 | pg/L | 2.98 | 16-14 |
| 113 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDF | 3/22/2005 | ND | 0.476 | pg/L | 1.21 | 16-14 |
| 114 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDF | 9/19/2005 | ND | 50 | pg/L | 50 | 16-14 |
| 115 S.F. Airport, Water Quality Control Plant | 1,2,3,7,8,9-HxCDF | 3/13/2006 | ND | 0.597 | pg/L | 0.597 | 16-14 |
| 116 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDF | 9/27/2002 | ND | 2.73 | pg/L | 2.73 | 16-15 |
| 117 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDF | 2/28/2003 | ND | 1.32 | pg/L | 1.32 | 16-15 |
| 118 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDF | 7/25/2003 | ND | 1.78 | pg/L | 1.78 | 16-15 |
| 119 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDF | 3/30/2004 | ND | 5.1 | pg/L | 5.1 | 16-15 |
| 120 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDF | 8/24/2004 | ND | 1.03 | pg/L | 4.14 | 16-15 |
| 121 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDF | 3/22/2005 | ND | 0.516 | pg/L | 1.56 | 16-15 |
| 122 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDF | 9/19/2005 | ND | 50 | pg/L | 50 | 16-15 |
| 123 S.F. Airport, Water Quality Control Plant | 1,2,3,4,6,7,8-HpCDF | 3/13/2006 | ND | 0.811 | pg/L | 0.811 | 16-15 |
| 124 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8,9-HpCDF | 9/27/2002 | ND | 3.64 | pg/L | 3.64 | 16-16 |
| 125 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8,9-HpCDF | 2/28/2003 | ND | 1.65 | pg/L | 1.65 | 16-16 |
| 126 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8,9-HpCDF | 7/25/2003 | ND | 2.52 | pg/L | 2.52 | 16-16 |

**SFIA Mel Leong WQCP
Sanitary Treatment Plant
Table 8. Dioxin Data**

| | | | | | | | |
|---|---------------------|-----------|----|-------|------|-------|--------|
| 127 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8,9-HpCDF | 3/30/2004 | ND | 7.1 | pg/L | 7.1 | 16-16 |
| 128 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8,9-HpCDF | 8/24/2004 | ND | 1.25 | pg/L | 5.52 | 16-16 |
| 129 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8,9-HpCDF | 3/22/2005 | ND | 0.654 | pg/L | 2.03 | 16-16 |
| 130 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8,9-HpCDF | 9/19/2005 | ND | 50 | pg/L | 50 | 16-16 |
| 131 S.F. Airport, Water Quality Control Plant | 1,2,3,4,7,8,9-HpCDF | 3/13/2006 | ND | 0.912 | pg/L | 0.912 | 16-16 |
| 132 S.F. Airport, Water Quality Control Plant | OCDF | 9/27/2002 | ND | 9.18 | pg/L | 9.18 | 16-17 |
| 133 S.F. Airport, Water Quality Control Plant | OCDF | 2/28/2003 | ND | 5.01 | pg/L | 5.01 | 16-17 |
| 134 S.F. Airport, Water Quality Control Plant | OCDF | 7/25/2003 | ND | 5.04 | pg/L | 5.04 | 16-17 |
| 135 S.F. Airport, Water Quality Control Plant | OCDF | 3/30/2004 | ND | 14 | pg/L | 14.0 | 16-17 |
| 136 S.F. Airport, Water Quality Control Plant | OCDF | 8/24/2004 | ND | 3.97 | pg/L | 9.25 | 16-17 |
| 137 S.F. Airport, Water Quality Control Plant | OCDF | 3/22/2005 | ND | 1.22 | pg/L | 3.5 | 16-17 |
| 138 S.F. Airport, Water Quality Control Plant | OCDF | 9/19/2005 | ND | 100 | pg/L | 100 | 16-17 |
| 139 S.F. Airport, Water Quality Control Plant | OCDF | 3/13/2006 | ND | 1.09 | pg/L | 1.09 | 16-17 |
| 140 S.F. Airport, Water Quality Control Plant | TCDD-TEQ | 9/27/2002 | ND | 1.22 | pg/L | 1.22 | 16-TEQ |
| 141 S.F. Airport, Water Quality Control Plant | TCDD-TEQ | 2/28/2003 | ND | 0.871 | pg/L | 0.871 | 16-TEQ |
| 142 S.F. Airport, Water Quality Control Plant | TCDD-TEQ | 7/25/2003 | ND | 0.918 | pg/L | 0.918 | 16-TEQ |
| 143 S.F. Airport, Water Quality Control Plant | TCDD-TEQ | 3/30/2004 | ND | 3.9 | pg/L | 3.9 | 16-TEQ |
| 144 S.F. Airport, Water Quality Control Plant | TCDD-TEQ | 8/24/2004 | ND | 1 | pg/L | 1 | 16-TEQ |
| 145 S.F. Airport, Water Quality Control Plant | TCDD-TEQ | 3/22/2005 | ND | 0.355 | pg/L | 0.355 | 16-TEQ |
| 146 S.F. Airport, Water Quality Control Plant | TCDD-TEQ | 9/19/2005 | ND | 10 | pg/L | 10 | 16-TEQ |
| 147 S.F. Airport, Water Quality Control Plant | TCDD-TEQ | 3/13/2006 | ND | 0.567 | pg/L | 0.567 | 16-TEQ |

| Permit Title | Pollutant | Date | Value | Unit | ML | MDL | RDL | CTR | Comment |
|--|--|---------|-------|--------|------|------|--------|-----|------------|
| 874 S.F. Airport, Water Quality Control Plant | Acenaphthene | 9/27/02 | ND | 2.3 | ug/l | 4.8 | 2.3 | 56 | 3520C/8310 |
| 875 S.F. Airport, Water Quality Control Plant | Acenaphthene | 2/28/03 | ND | 2.3 | ug/l | 4.7 | 2.3 | 56 | 3520C/8310 |
| 876 S.F. Airport, Water Quality Control Plant | Acenaphthene | 7/25/03 | ND | 2.4 | ug/l | 5 | 2.4 | 56 | 3520C/8310 |
| 877 S.F. Airport, Water Quality Control Plant | Acenaphthene | 3/30/04 | ND | 0.52 | ug/l | 0.52 | 0.11 | 56 | 3520C/8310 |
| 878 S.F. Airport, Water Quality Control Plant | Acenaphthene | 8/24/04 | ND | 0.11 | ug/l | 0.52 | 0.11 | 56 | 3520C/8310 |
| 879 S.F. Airport, Water Quality Control Plant | Acenaphthene | 3/22/05 | ND | 0.11 | ug/l | 0.52 | 0.11 | 56 | 3520C/8310 |
| 880 S.F. Airport, Water Quality Control Plant | Acenaphthene | 9/19/05 | ND | 0.13 | ug/l | 1 | 0.13 | 56 | 3520C/8310 |
| 881 S.F. Airport, Water Quality Control Plant | Acenaphthene | 3/13/06 | ND | 0.13 | ug/l | 1 | 0.13 | 56 | 3520C/8310 |
| 882 S.F. Airport, Water Quality Control Plant | Acenaphthylene | 9/27/02 | ND | 2.4 | ug/l | 4.8 | 2.4 | 57 | 3520C/8310 |
| 883 S.F. Airport, Water Quality Control Plant | Acenaphthylene | 2/28/03 | ND | 2.4 | ug/l | 4.7 | 2.4 | 57 | 3520C/8310 |
| 884 S.F. Airport, Water Quality Control Plant | Acenaphthylene | 7/25/03 | ND | 2.6 | ug/l | 5 | 2.6 | 57 | 3520C/8310 |
| 885 S.F. Airport, Water Quality Control Plant | Acenaphthylene | 3/30/04 | ND | 0.39 | ug/l | 0.39 | 0.07 | 57 | 3520C/8310 |
| 886 S.F. Airport, Water Quality Control Plant | Acenaphthylene | 8/24/04 | ND | 0.07 | ug/l | 0.39 | 0.07 | 57 | 3520C/8310 |
| 887 S.F. Airport, Water Quality Control Plant | Acenaphthylene | 3/22/05 | ND | 0.07 | ug/l | 0.39 | 0.07 | 57 | 3520C/8310 |
| 888 S.F. Airport, Water Quality Control Plant | Acenaphthylene | 9/19/05 | ND | 0.4 | ug/l | 1 | 0.4 | 57 | 3520C/8310 |
| 889 S.F. Airport, Water Quality Control Plant | Acenaphthylene | 3/13/06 | ND | 0.4 | ug/l | 1 | 0.4 | 57 | 3520C/8310 |
| 890 S.F. Airport, Water Quality Control Plant | Anthracene | 9/27/02 | ND | 2.3 | ug/l | 4.8 | 2.3 | 58 | 3520C/8310 |
| 891 S.F. Airport, Water Quality Control Plant | Anthracene | 2/28/03 | ND | 2.3 | ug/l | 4.7 | 2.3 | 58 | 3520C/8310 |
| 892 S.F. Airport, Water Quality Control Plant | Anthracene | 7/25/03 | ND | 2.4 | ug/l | 5 | 2.4 | 58 | 3520C/8310 |
| 893 S.F. Airport, Water Quality Control Plant | Anthracene | 3/30/04 | ND | 0.52 | ug/l | 0.52 | 0.01 | 58 | 3520C/8310 |
| 894 S.F. Airport, Water Quality Control Plant | Anthracene | 8/24/04 | ND | 0.01 | ug/l | 0.02 | 0.01 | 58 | 3520C/8310 |
| 895 S.F. Airport, Water Quality Control Plant | Anthracene | 3/22/05 | ND | 0.01 | ug/l | 0.02 | 0.01 | 58 | 3520C/8310 |
| 896 S.F. Airport, Water Quality Control Plant | Anthracene | 9/19/05 | ND | 0.0083 | ug/l | 0.05 | 0.0083 | 58 | 3520C/8310 |
| 897 S.F. Airport, Water Quality Control Plant | Anthracene | 3/13/06 | ND | 0.0083 | ug/l | 0.05 | 0.0083 | 58 | 3520C/8310 |
| 906 S.F. Airport, Water Quality Control Plant | Benzo(a)Anthracene or 1,2-Benzanthracene | 9/27/02 | ND | 1.2 | ug/l | 4.8 | 1.2 | 60 | 3520C/8310 |
| 907 S.F. Airport, Water Quality Control Plant | Benzo(a)Anthracene or 1,2-Benzanthracene | 2/28/03 | ND | 4.7 | ug/l | 4.7 | 1.2 | 60 | 3520C/8310 |
| 908 S.F. Airport, Water Quality Control Plant | Benzo(a)Anthracene or 1,2-Benzanthracene | 7/25/03 | ND | 1.3 | ug/l | 5 | 1.3 | 60 | 3520C/8310 |
| 909 S.F. Airport, Water Quality Control Plant | Benzo(a)Anthracene or 1,2-Benzanthracene | 3/30/04 | ND | 0.1 | ug/l | 0.1 | 0.02 | 60 | 3520C/8310 |
| 910 S.F. Airport, Water Quality Control Plant | Benzo(a)Anthracene or 1,2-Benzanthracene | 8/24/04 | ND | 0.02 | ug/l | 0.1 | 0.02 | 60 | 3520C/8310 |
| 911 S.F. Airport, Water Quality Control Plant | Benzo(a)Anthracene or 1,2-Benzanthracene | 3/22/05 | ND | 0.02 | ug/l | 0.1 | 0.02 | 60 | 3520C/8310 |
| 912 S.F. Airport, Water Quality Control Plant | Benzo(a)Anthracene or 1,2-Benzanthracene | 9/19/05 | ND | 0.015 | ug/l | 0.05 | 0.015 | 60 | 3520C/8310 |
| 913 S.F. Airport, Water Quality Control Plant | Benzo(a)Anthracene or 1,2-Benzanthracene | 3/13/06 | ND | 0.015 | ug/l | 0.05 | 0.015 | 60 | 3520C/8310 |
| 914 S.F. Airport, Water Quality Control Plant | Benzo(a)Pyrene | 9/27/02 | ND | 0.05 | ug/l | 0.05 | | 61 | 3520C/8310 |
| 915 S.F. Airport, Water Quality Control Plant | Benzo(a)Pyrene | 2/28/03 | ND | 4.7 | ug/l | 4.7 | 2.1 | 61 | 3520C/8310 |
| 916 S.F. Airport, Water Quality Control Plant | Benzo(a)Pyrene | 7/25/03 | ND | 2.2 | ug/l | 5 | 2.2 | 61 | 3520C/8310 |
| 917 S.F. Airport, Water Quality Control Plant | Benzo(a)Pyrene | 3/30/04 | ND | 0.12 | ug/l | 0.12 | 0.02 | 61 | 3520C/8310 |
| 918 S.F. Airport, Water Quality Control Plant | Benzo(a)Pyrene | 8/24/04 | ND | 0.02 | ug/l | 0.12 | 0.02 | 61 | 3520C/8310 |
| 919 S.F. Airport, Water Quality Control Plant | Benzo(a)Pyrene | 3/22/05 | ND | 0.02 | ug/l | 0.12 | 0.02 | 61 | 3520C/8310 |
| 920 S.F. Airport, Water Quality Control Plant | Benzo(a)Pyrene | 9/19/05 | ND | 0.018 | ug/l | 0.05 | 0.018 | 61 | 3520C/8310 |
| 921 S.F. Airport, Water Quality Control Plant | Benzo(a)Pyrene | 3/13/06 | ND | 0.018 | ug/l | 0.05 | 0.018 | 61 | 3520C/8310 |
| 922 S.F. Airport, Water Quality Control Plant | Benzo(b)Fluoranthene or 3,4 Benzo(a)fluoranthene | 9/27/02 | ND | 2.1 | ug/l | 4.8 | 2.1 | 62 | 3520C/8310 |
| 923 S.F. Airport, Water Quality Control Plant | Benzo(b)Fluoranthene or 3,4 Benzo(a)fluoranthene | 2/28/03 | ND | 2.1 | ug/l | 4.7 | 2.1 | 62 | 3520C/8310 |
| 924 S.F. Airport, Water Quality Control Plant | Benzo(b)Fluoranthene or 3,4 Benzo(a)fluoranthene | 7/25/03 | ND | 2.2 | ug/l | 5 | 2.2 | 62 | 3520C/8310 |
| 925 S.F. Airport, Water Quality Control Plant | Benzo(b)Fluoranthene or 3,4 Benzo(a)fluoranthene | 3/30/04 | ND | 0.1 | ug/l | 0.1 | 0.02 | 62 | 3520C/8310 |
| 926 S.F. Airport, Water Quality Control Plant | Benzo(b)Fluoranthene or 3,4 Benzo(a)fluoranthene | 8/24/04 | ND | 0.03 | ug/l | 0.12 | 0.03 | 62 | 3520C/8310 |
| 927 S.F. Airport, Water Quality Control Plant | Benzo(b)Fluoranthene or 3,4 Benzo(a)fluoranthene | 3/22/05 | ND | 0.02 | ug/l | 0.1 | 0.02 | 62 | 3520C/8310 |
| 928 S.F. Airport, Water Quality Control Plant | Benzo(b)Fluoranthene or 3,4 Benzo(a)fluoranthene | 9/19/05 | ND | 0.014 | ug/l | 0.1 | 0.014 | 62 | 3520C/8310 |
| 929 S.F. Airport, Water Quality Control Plant | Benzo(b)Fluoranthene or 3,4 Benzo(a)fluoranthene | 3/13/06 | ND | 0.014 | ug/l | 0.1 | 0.014 | 62 | 3520C/8310 |
| 930 S.F. Airport, Water Quality Control Plant | Benzo(ghi)Perylene | 9/27/02 | ND | 5.9 | ug/l | 9.5 | 5.9 | 63 | 3520C/8310 |
| 931 S.F. Airport, Water Quality Control Plant | Benzo(ghi)Perylene | 2/28/03 | ND | 5.8 | ug/l | 9.4 | 5.8 | 63 | 3520C/8310 |
| 932 S.F. Airport, Water Quality Control Plant | Benzo(ghi)Perylene | 7/25/03 | ND | 6.2 | ug/l | 10 | 6.2 | 63 | 3520C/8310 |
| 933 S.F. Airport, Water Quality Control Plant | Benzo(ghi)Perylene | 3/30/04 | ND | 0.09 | ug/l | 0.09 | 0.02 | 63 | 3520C/8310 |
| 934 S.F. Airport, Water Quality Control Plant | Benzo(ghi)Perylene | 8/24/04 | ND | 0.02 | ug/l | 0.09 | 0.02 | 63 | 3520C/8310 |
| 935 S.F. Airport, Water Quality Control Plant | Benzo(ghi)Perylene | 3/22/05 | ND | 0.02 | ug/l | 0.09 | 0.02 | 63 | 3520C/8310 |
| 936 S.F. Airport, Water Quality Control Plant | Benzo(ghi)Perylene | 9/19/05 | ND | 0.034 | ug/l | 0.1 | 0.034 | 63 | 3520C/8310 |
| 937 S.F. Airport, Water Quality Control Plant | Benzo(ghi)Perylene | 3/13/06 | ND | 0.034 | ug/l | 0.1 | 0.034 | 63 | 3520C/8310 |
| 938 S.F. Airport, Water Quality Control Plant | Benzo(k)Fluoranthene | 9/27/02 | ND | 2.6 | ug/l | 4.8 | 2.6 | 64 | 3520C/8310 |
| 939 S.F. Airport, Water Quality Control Plant | Benzo(k)Fluoranthene | 2/28/03 | ND | 2.5 | ug/l | 4.7 | 2.5 | 64 | 3520C/8310 |
| 940 S.F. Airport, Water Quality Control Plant | Benzo(k)Fluoranthene | 7/25/03 | ND | 2.7 | ug/l | 5 | 2.7 | 64 | 3520C/8310 |
| 941 S.F. Airport, Water Quality Control Plant | Benzo(k)Fluoranthene | 3/30/04 | ND | 0.12 | ug/l | 0.12 | 0.02 | 64 | 3520C/8310 |
| 942 S.F. Airport, Water Quality Control Plant | Benzo(k)Fluoranthene | 8/24/04 | ND | 0.03 | ug/l | 0.12 | 0.03 | 64 | 3520C/8310 |
| 943 S.F. Airport, Water Quality Control Plant | Benzo(k)Fluoranthene | 3/22/05 | ND | 0.03 | ug/l | 0.12 | 0.03 | 64 | 3520C/8310 |
| 944 S.F. Airport, Water Quality Control Plant | Benzo(k)Fluoranthene | 9/19/05 | ND | 0.019 | ug/l | 0.05 | 0.019 | 64 | 3520C/8310 |
| 945 S.F. Airport, Water Quality Control Plant | Benzo(k)Fluoranthene | 3/13/06 | ND | 0.019 | ug/l | 0.1 | 0.019 | 64 | 3520C/8310 |
| 1010 S.F. Airport, Water Quality Control Plant | Chrysene | 9/27/02 | ND | 1 | ug/l | 4.8 | 1 | 73 | 8270C |
| 1011 S.F. Airport, Water Quality Control Plant | Chrysene | 2/28/03 | ND | 1 | ug/l | 4.7 | 1 | 73 | 8270C |
| 1012 S.F. Airport, Water Quality Control Plant | Chrysene | 7/25/03 | ND | 1.1 | ug/l | 5 | 1.1 | 73 | 8270C |
| 1013 S.F. Airport, Water Quality Control Plant | Chrysene | 3/30/04 | ND | 0.9 | ug/l | 0.9 | 0.9 | 73 | 8270C |
| 1014 S.F. Airport, Water Quality Control Plant | Chrysene | 8/24/04 | ND | 0.42 | ug/l | 1 | 0.42 | 73 | 8270C |
| 1015 S.F. Airport, Water Quality Control Plant | Chrysene | 3/22/05 | ND | 0.42 | ug/l | 1 | 0.42 | 73 | 8270C |
| 1016 S.F. Airport, Water Quality Control Plant | Chrysene | 9/19/05 | ND | 0.5 | ug/l | 4.8 | 0.5 | 73 | 8270C |
| 1017 S.F. Airport, Water Quality Control Plant | Chrysene | 3/13/06 | ND | 0.49 | ug/l | 4.7 | 0.49 | 73 | 8270C |
| 1018 S.F. Airport, Water Quality Control Plant | Dibenzo(a,h)Anthracene | 9/27/02 | ND | 3.9 | ug/l | 4.8 | 3.9 | 74 | 3520C/8310 |
| 1019 S.F. Airport, Water Quality Control Plant | Dibenzo(a,h)Anthracene | 2/28/03 | ND | 3.9 | ug/l | 4.7 | 3.9 | 74 | 3520C/8310 |
| 1020 S.F. Airport, Water Quality Control Plant | Dibenzo(a,h)Anthracene | 7/25/03 | ND | 4.1 | ug/l | 5 | 4.1 | 74 | 3520C/8310 |
| 1021 S.F. Airport, Water Quality Control Plant | Dibenzo(a,h)Anthracene | 3/30/04 | ND | 0.09 | ug/l | 0.09 | 0.02 | 74 | 3520C/8310 |
| 1022 S.F. Airport, Water Quality Control Plant | Dibenzo(a,h)Anthracene | 8/24/04 | ND | 0.02 | ug/l | 0.09 | 0.02 | 74 | 3520C/8310 |
| 1023 S.F. Airport, Water Quality Control Plant | Dibenzo(a,h)Anthracene | 3/22/05 | ND | 0.02 | ug/l | 0.09 | 0.02 | 74 | 3520C/8310 |
| 1024 S.F. Airport, Water Quality Control Plant | Dibenzo(a,h)Anthracene | 9/19/05 | ND | 0.011 | ug/l | 0.1 | 0.011 | 74 | 3520C/8310 |
| 1025 S.F. Airport, Water Quality Control Plant | Dibenzo(a,h)Anthracene | 3/13/06 | ND | 0.011 | ug/l | 0.1 | 0.011 | 74 | 3520C/8310 |
| 1114 S.F. Airport, Water Quality Control Plant | Fluoranthene | 9/27/02 | ND | 2 | ug/l | 4.8 | 2 | 86 | 3520C/8310 |
| 1115 S.F. Airport, Water Quality Control Plant | Fluoranthene | 2/28/03 | ND | 1.9 | ug/l | 4.7 | 1.9 | 86 | 3520C/8310 |
| 1116 S.F. Airport, Water Quality Control Plant | Fluoranthene | 7/25/03 | ND | 2 | ug/l | 5 | 2 | 86 | 3520C/8310 |
| 1117 S.F. Airport, Water Quality Control Plant | Fluoranthene | 3/30/04 | ND | 0.19 | ug/l | 0.19 | 0.06 | 86 | 3520C/8310 |
| 1118 S.F. Airport, Water Quality Control Plant | Fluoranthene | 8/24/04 | ND | 0.06 | ug/l | 0.19 | 0.06 | 86 | 3520C/8310 |
| 1119 S.F. Airport, Water Quality Control Plant | Fluoranthene | 3/22/05 | ND | 0.06 | ug/l | 0.19 | 0.06 | 86 | 3520C/8310 |

SFIA Mill Leasing WQCP Sanitary Treatment Plant

Table 9. Total PAHs

| 1 | 2 Permit Title | Pollutant | Date | Value | Unit | ML | MDL | RDL | CTR | Comment |
|------|---|------------------------|---------|-------|------|------|-------|-----|-----|------------|
| 1120 | S.F. Airport, Water Quality Control Plant | Fluoranthene | 9/19/05 | ND | ug/l | 0.1 | 0.031 | | 86 | 3520C/8310 |
| 1121 | S.F. Airport, Water Quality Control Plant | Fluoranthene | 3/13/06 | ND | ug/l | 0.1 | 0.031 | | 86 | 3520C/8310 |
| 1122 | S.F. Airport, Water Quality Control Plant | Fluorene | 9/27/02 | ND | ug/l | 4.8 | 1.8 | | 87 | 3520C/8310 |
| 1123 | S.F. Airport, Water Quality Control Plant | Fluorene | 2/28/03 | ND | ug/l | 4.7 | 1.8 | | 87 | 3520C/8310 |
| 1124 | S.F. Airport, Water Quality Control Plant | Fluorene | 7/25/03 | ND | ug/l | 5 | 1.9 | | 87 | 3520C/8310 |
| 1125 | S.F. Airport, Water Quality Control Plant | Fluorene | 3/30/04 | ND | ug/l | 0.12 | 0.03 | | 87 | 3520C/8310 |
| 1126 | S.F. Airport, Water Quality Control Plant | Fluorene | 8/24/04 | ND | ug/l | 0.03 | 0.12 | | 87 | 3520C/8310 |
| 1127 | S.F. Airport, Water Quality Control Plant | Fluorene | 3/22/05 | ND | ug/l | 0.12 | 0.03 | | 87 | 3520C/8310 |
| 1128 | S.F. Airport, Water Quality Control Plant | Fluorene | 9/19/05 | ND | ug/l | 0.1 | 0.028 | | 87 | 3520C/8310 |
| 1129 | S.F. Airport, Water Quality Control Plant | Fluorene | 3/13/06 | ND | ug/l | 0.1 | 0.028 | | 87 | 3520C/8310 |
| 1162 | S.F. Airport, Water Quality Control Plant | Indeno(1,2,3-cd)Pyrene | 9/27/02 | ND | ug/l | 9.5 | 5.1 | | 92 | 3520C/8310 |
| 1163 | S.F. Airport, Water Quality Control Plant | Indeno(1,2,3-cd)Pyrene | 2/28/03 | ND | ug/l | 9.4 | 5.1 | | 92 | 3520C/8310 |
| 1164 | S.F. Airport, Water Quality Control Plant | Indeno(1,2,3-cd)Pyrene | 7/25/03 | ND | ug/l | 5 | 1.9 | | 92 | 3520C/8310 |
| 1165 | S.F. Airport, Water Quality Control Plant | Indeno(1,2,3-cd)Pyrene | 3/30/04 | ND | ug/l | 0.11 | 0.08 | | 92 | 3520C/8310 |
| 1166 | S.F. Airport, Water Quality Control Plant | Indeno(1,2,3-cd)Pyrene | 8/24/04 | ND | ug/l | 0.11 | 0.03 | | 92 | 3520C/8310 |
| 1167 | S.F. Airport, Water Quality Control Plant | Indeno(1,2,3-cd)Pyrene | 3/22/05 | ND | ug/l | 0.11 | 0.03 | | 92 | 3520C/8310 |
| 1168 | S.F. Airport, Water Quality Control Plant | Indeno(1,2,3-cd)Pyrene | 9/19/05 | ND | ug/l | 0.1 | 0.021 | | 92 | 3520C/8310 |
| 1169 | S.F. Airport, Water Quality Control Plant | Indeno(1,2,3-cd)Pyrene | 3/13/06 | ND | ug/l | 0.1 | 0.021 | | 92 | 3520C/8310 |
| 1178 | S.F. Airport, Water Quality Control Plant | Naphthalene | 9/27/02 | ND | ug/l | 4.8 | 3.4 | | 94 | 8270C |
| 1179 | S.F. Airport, Water Quality Control Plant | Naphthalene | 2/28/03 | ND | ug/l | 4.7 | 3.3 | | 94 | 8270C |
| 1180 | S.F. Airport, Water Quality Control Plant | Naphthalene | 7/25/03 | ND | ug/l | 5 | 3.6 | | 94 | 8270C |
| 1181 | S.F. Airport, Water Quality Control Plant | Naphthalene | 3/30/04 | ND | ug/l | 1.04 | 1.04 | | 94 | 8270C |
| 1182 | S.F. Airport, Water Quality Control Plant | Naphthalene | 8/24/04 | ND | ug/l | 1 | 0.93 | | 94 | 8270C |
| 1183 | S.F. Airport, Water Quality Control Plant | Naphthalene | 3/22/05 | ND | ug/l | 1 | 0.93 | | 94 | 8270C |
| 1184 | S.F. Airport, Water Quality Control Plant | Naphthalene | 9/19/05 | ND | ug/l | 4.8 | 0.82 | | 94 | 8270C |
| 1185 | S.F. Airport, Water Quality Control Plant | Naphthalene | 3/13/06 | ND | ug/l | 4.7 | 0.81 | | 94 | 8270C |
| 1218 | S.F. Airport, Water Quality Control Plant | Phenanthrene | 9/27/02 | ND | ug/l | 4.8 | 2.3 | | 99 | 8270C |
| 1219 | S.F. Airport, Water Quality Control Plant | Phenanthrene | 2/28/03 | ND | ug/l | 4.7 | 2.3 | | 99 | 8270C |
| 1220 | S.F. Airport, Water Quality Control Plant | Phenanthrene | 7/25/03 | ND | ug/l | 5 | 2.5 | | 99 | 8270C |
| 1221 | S.F. Airport, Water Quality Control Plant | Phenanthrene | 3/30/04 | ND | ug/l | 0.93 | 0.93 | | 99 | 8270C |
| 1222 | S.F. Airport, Water Quality Control Plant | Phenanthrene | 8/24/04 | ND | ug/l | 1 | 0.41 | | 99 | 8270C |
| 1223 | S.F. Airport, Water Quality Control Plant | Phenanthrene | 3/22/05 | ND | ug/l | 1 | 0.41 | | 99 | 8270C |
| 1224 | S.F. Airport, Water Quality Control Plant | Phenanthrene | 9/19/05 | ND | ug/l | 4.8 | 0.56 | | 99 | 8270C |
| 1225 | S.F. Airport, Water Quality Control Plant | Phenanthrene | 3/13/06 | ND | ug/l | 4.7 | 0.55 | | 99 | 8270C |
| 1226 | S.F. Airport, Water Quality Control Plant | Pyrene | 9/27/02 | ND | ug/l | 4.8 | 1.3 | | 100 | 3520C/8310 |
| 1227 | S.F. Airport, Water Quality Control Plant | Pyrene | 2/28/03 | ND | ug/l | 4.7 | 1.3 | | 100 | 3520C/8310 |
| 1228 | S.F. Airport, Water Quality Control Plant | Pyrene | 7/25/03 | ND | ug/l | 5 | 1.4 | | 100 | 3520C/8310 |
| 1229 | S.F. Airport, Water Quality Control Plant | Pyrene | 3/30/04 | ND | ug/l | 0.21 | 0.06 | | 100 | 3520C/8310 |
| 1230 | S.F. Airport, Water Quality Control Plant | Pyrene | 8/24/04 | ND | ug/l | 0.21 | 0.06 | | 100 | 3520C/8310 |
| 1231 | S.F. Airport, Water Quality Control Plant | Pyrene | 3/22/05 | ND | ug/l | 0.21 | 0.06 | | 100 | 3520C/8310 |
| 1232 | S.F. Airport, Water Quality Control Plant | Pyrene | 9/19/05 | ND | ug/l | 0.1 | 0.025 | | 100 | 3520C/8310 |
| 1233 | S.F. Airport, Water Quality Control Plant | Pyrene | 3/13/06 | ND | ug/l | 0.1 | 0.025 | | 100 | 3520C/8310 |

Table 7

San Francisco International Airport
MEL LEONG TREATMENT PLANT

Ammonia-Nitrogen Levels
 (Monthly Average Values)

| Month | Sanitary | | Industrial | |
|---------------------------------|--------------------------|-------------|--------------------------|------------|
| | <i>M.E.C. = 118 mg/L</i> | | <i>M.E.C. = 6.9 mg/L</i> | |
| | Influent | Effluent | Influent | Effluent |
| May-05 | 92 | 72.8 | 0.6 | 0.2 |
| Jun-05 | 98 | 53.6 | 1.2 | 0.2 |
| Jul-05 | 99 | 33.9 | 3.8 | 0.2 |
| Aug-05 | 98 | 37.6 | 0.8 | 0.3 |
| Sep-05 | 92 | 29.4 | 0.9 | 0.3 |
| Oct-05 | 93 | 51.2 | 1.7 | 0.3 |
| Nov-05 | 92 | 46.0 | 1.0 | 0.1 |
| Dec-05 | 83 | 38.4 | 2.4 | 0.4 |
| Jan-06 | 89 | 47.1 | 0.8 | 0.5 |
| Feb-06 | 85 | 48.1 | 0.3 | 0.1 |
| Mar-06 | 82 | 77.1 | 0.8 | 0.3 |
| Apr-06 | 93 | 85.6 | 2.3 | 1.0 |
| May-06 | 81 | 73.7 | 6.5 | 1.4 |
| Jun-06 | 86 | 56.9 | 1.5 | 0.8 |
| Jul-06 | 86 | 42.1 | 1.5 | 3.0 |
| Aug-06 | 92 | 55.5 | 7.9 | 5.6 |
| Sep-06 | 99 | 60.0 | 2.1 | 0.5 |
| Oct-06 | 98 | 98.0 | 1.4 | 0.4 |
| Nov-06 | 95 | 67.8 | 0.7 | 0.4 |
| Dec-06 | 87 | 74.5 | 0.3 | 0.4 |
| Jan-07 | 97 | 91.4 | 2.6 | 0.7 |
| Feb-07 | 92 | 93.1 | 1.0 | 0.6 |
| Mar-07 | 100 | 96.9 | 0.9 | 1.8 |
| Apr-07 | 103 | 91.1 | 1.0 | 0.9 |
| 2-year Average value | 92.2 | 63.4 | 1.8 | 0.9 |

All values are in **mg/L**

JUNE 8, 2007

ATTACHMENT G – REGIONAL WATER BOARD ATTACHMENTS

The following documents are part of this Order but are not physically attached due to volume. They are available on the Internet at:

<http://www.waterboards.ca.gov/sanfranciscobay/Download.htm>

- Self-Monitoring Program, Part A (August 1993).
- Standard Provisions and Reporting Requirements, August 1993.
- Regional Water Board Resolution No. 74-10.
- August 6, 2001 Regional Water Board staff letter, “Requirement for Monitoring of Pollutants in Effluent and Receiving Water to Implement New Statewide Regulations and Policy”.

B. Revised Cease & Desist Order

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION**

REVISED CEASE AND DESIST ORDER NO. R2-2007-00XX

**REQUIRING THE CITY AND COUNTY OF SAN FRANCISCO
TO CEASE AND DESIST DISCHARGING PARTIALLY-TREATED WASTEWATER
TO WATERS OF THE STATE**

WHEREAS the California Regional Water Quality Control Board, San Francisco Bay Region (hereinafter “Regional Water Board”), finds that:

1. The City and County of San Francisco (hereinafter “Discharger”) owns and operates the Mel Leong Treatment Plant, Industrial Plant (hereinafter “Industrial Plant”), located at 676 McDonnell Road, San Francisco International Airport, San Mateo County. The Industrial Plant treats industrial wastewater from facilities at SFIA (e.g., maintenance shops, car washing), as well as first flush storm water runoff. The dry weather capacity of the Industrial Plant is 1.2 MGD
2. The Industrial Plant discharge has been regulated by waste discharge requirements in Order No. R2-2002-0045 (NPDES Permit No. CA0028070).
3. Concurrent with the adoption of this Cease and Desist Order, the Regional Water Board adopted Order No. R2-2007-00XX (hereinafter “Permit”), reissuing waste discharge requirements for the Discharger. The Permit contains prohibitions, limitations, and provisions regulating the discharge. The limitations include those listed in Table 1 below, among others.

Table 1: Permit Effluent Limits

| Parameter | Final Effluent Limits in Permit | | Monitoring Station |
|-------------------|---------------------------------------|-------------------------------------|--------------------|
| | Average Monthly Effluent Limit (µg/L) | Maximum Daily Effluent Limit (µg/L) | |
| Mercury | 0.020 | 0.041 | EFF-001A |
| Aldrin | 0.00014 | 0.00028 | EFF-001A |
| 4,4-DDT | 0.00059 | 0.0012 | EFF-001A |
| 4,4-DDE | 0.00059 | 0.0012 | EFF-001A |
| Dieldrin | 0.00014 | 0.00028 | EFF-001A |
| Heptachlor | 0.0020 | 0.0041 | EFF-001A |
| Heptachor epoxide | 0.00089 | 0.0018 | EFF-001A |

4. The Discharger submitted an infeasibility study demonstrating that it cannot comply with the effluent limits listed in Table 1. As stated in the Permit findings, the Regional Water Board concurs with the Discharger because the effluent limits are more stringent than the maximum effluent concentrations estimated for the combined flow from the Industrial Plant and the nearby Sanitary Plant (which contributes to effluent concentrations at the combined monitoring station). The Permit grants compliance schedules for some but not all of these pollutants; therefore, the Discharger will discharge waste in violation of the Permit.
5. Although the Permit contains final effluent limits for aldrin, 4,4-DDT, heptachlor, and heptachlor epoxide, the Permit also provides compliance schedules to meet these effluent limits. The compliance schedules last until May 18, 2010, which is the last day the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy) authorizes compliance schedules for California Toxics Rule pollutants. As stated in the Permit findings, the actions these compliance schedules require are, by themselves, unlikely to result in compliance by May 18, 2010, because this length of time is insufficient to complete all necessary actions. Therefore, when the compliance schedules for these pollutants end, the Discharger threatens to violate the effluent limitations for these pollutants.
6. Water Code § 13301 authorizes the Regional Water Board to issue a Cease and Desist Order when it finds that a waste discharge is taking place, or threatening to take place, in violation of Regional Water Board requirements.
7. Because the Discharger will violate or threatens to violate required effluent limits, this Order is necessary to ensure that the Discharger achieves compliance. This Order establishes time schedules for the Discharger to complete necessary investigative, preventive, and remedial actions to address its imminent and threatened violations. The Permit requires certain actions as conditions of its compliance schedules. This Order continues those efforts once the compliance schedules end so the Discharger will eventually comply with its final effluent limitations.
8. The time schedules in this Order are parameter-specific and intended to be as short as possible. They account for the considerable uncertainty in determining effective measures (e.g., pollution prevention and treatment plant upgrades) necessary to achieve compliance. This Order allows some time to first explore source control measures before requiring further actions, such as treatment plant upgrades, which are likely to be much more costly. The time schedules are based on reasonably expected times needed to implement source identification and upstream source control, evaluate success, identify on-site treatment alternatives if necessary, test and select from among alternatives, and construct plant upgrades. The Regional Water Board may wish to revisit these assumptions as more information becomes available.
9. As part of the time schedules to achieve compliance, this Order requires the Discharger to comply with interim effluent limits, where feasible. These interim limits are intended to ensure that the Discharger maintains at least its existing performance while completing all tasks required during the time schedules. The interim limits are based on past performance or limits in previous orders, whichever are more stringent. If based on past performance, the interim limits represent the 99.87th percentile of actual measured discharge concentrations (three standard deviations from the mean). If insufficient monitoring data exist to derive a reliable performance-based limit, and if no previous order contained a limit, then this Order does not establish an interim limit.
10. This Order is an enforcement action and, as such, is exempt from the provisions of the California Environmental Quality Act (Public Resources Code § 21000 et seq.) in accordance with 14 CCR § 15321.

11. The Regional Water Board notified the Discharger and interested persons of its intent to consider adoption of this Cease and Desist Order, and provided an opportunity to submit written comments and appear at a public hearing. The Regional Water Board, in a public hearing, heard and considered all comments.

IT IS HEREBY ORDERED, in accordance with Water Code §13301, that the Discharger shall cease and desist from discharging and threatening to discharge wastes in violation of its Permit by complying with the following provisions:

1. Prescribed Actions. The Discharger shall comply with the required actions in Table 2 in accordance with the time schedules provided therein to comply with all effluent limits contained in the Permit. All deliverables listed in Table 2 shall be acceptable to the Executive Officer, who will review them for adequacy and compliance with the Table 2 requirements. The Discharger shall further implement all actions set forth in each deliverable, unless the Executive Officer finds the deliverable to be unacceptable.
2. Exceptions. The following exceptions apply to the parameter-specific time schedules and prescribed actions in Table 2.
 - a. *Mercury*. The mercury-related time schedules and prescribed actions shall cease to be in effect upon the effective date of a permit* that supersedes the mercury limits in the Permit.
 - b. *Aldrin, 4,4-DDT, Heptachlor, and Heptachlor Epoxide*. The prescribed actions in Table 2, actions “a,” “b,” “c,” and “d,” shall not apply to aldrin, 4,4-DDT, heptachlor, and heptachlor epoxide because the Permit already requires these actions. Actions “e,” “f,” “g,” and “h” shall apply to aldrin, 4,4-DDT, heptachlor, and heptachlor epoxide beginning May 18, 2010.
3. Reporting Delays. If the Discharger is delayed, interrupted, or prevented from meeting one or more of the time schedules in Table 3 due to circumstances beyond its reasonable control, the Discharger shall promptly notify the Executive Officer, provide the reasons and justification for the delay, and propose time schedules for resolving the delay.
4. Consequences of Non-Compliance. If the Discharger fails to comply with the provisions of this Order, the Executive Officer is authorized to take further enforcement action or to request the Attorney General to take appropriate actions against the Discharger in accordance with Water Code §§ 13331, 13350, 13385, and 13386. Such actions may include injunctive and civil remedies, if appropriate, or the issuance of an Administrative Civil Liability Complaint for Regional Water Board consideration.

* In March 2007, Regional Water Board staff publicly noticed a draft permit that could supersede existing mercury requirements and implement the wasteload allocations for municipal and industrial wastewater discharges identified in the San Francisco Bay Mercury TMDL that the Regional Water Board adopted in August 2006.

Table 2: Time Schedules and Prescribed Actions

| Action | Deadline | |
|---|---------------------------------------|-----------------------|
| | Mercury | Pesticides |
| a. Comply with the following interim effluent limits: Mercury (at Monitoring Station EFF-001A): Average monthly effluent limit = 0.087 µg/L Maximum daily effluent limit = 1.0 µg/L | Upon the effective date of this Order | <i>Not Applicable</i> |
| b. Investigate sample collection, sample handling, and analytical laboratory quality assurance and quality control practices to ensure that analytical results for aldrin, 4,4-DDT, 4,4-DDE, dieldrin, heptachlor, and heptachlor epoxide (hereinafter “Pesticides”) and cyanide are accurately determined and reported. Submit a report by the deadline describing the results of the investigation and any changes in quality assurance and quality control practices implemented. | <i>Not Applicable</i> | January 1, 2008 |
| c. Submit a plan for identifying all mercury, cyanide, and Pesticides sources to the discharge. Examples of potential mercury sources include chemicals used on site, medical devices, laundry services, fluorescent light tubes, and electrical switches. Examples of potential Pesticide sources include stored pesticides and pesticide-treated soils near sewer lines. The plan shall, at a minimum, include sampling influent waste streams to identify and quantify pollutant sources. | June 1, 2008 | June 1, 2008 |
| d. Implement the plan developed in action “c” within 30 days of the deadline for action “c,” and submit by the deadline for this action a report that contains an inventory of the pollutant sources. | October 1, 2008 | October 1, 2008 |
| e. Submit a report documenting development and initial implementation of a program to reduce and prevent the pollutants of concern in the discharge. The program shall consist, at a minimum, of the following elements: i. Maintain a list of sources of pollutants of concern. ii. Investigate each source to assess the need to include it in the program. iii. Identify and implement targeted actions to reduce or eliminate discharges from each source in the program. iv. Develop and distribute, as appropriate, educational materials regarding the need to | December 1, 2008 | December 1, 2008 |

| Action | Deadline | |
|--|--|--------------|
| | Mercury | Pesticides |
| prevent sources to the sewer system. | | |
| f. Continue to implement the program described in action “e” and submit annual status reports that evaluate its effectiveness and summarize planned changes. Report whether the program has successfully brought the discharge into compliance with the effluent limits in the Permit. If not, identify and implement additional measures to further reduce discharges. | Annually each February 28 in Best Management Practices and Pollutant Minimization Report required by Permit Provision VI.C.3 | |
| g. If by February 28, 2011 , discharge data continue to show the discharge is out of compliance (as defined in 2.4.5 of the State Implementation Policy) with the Permit effluent limits, submit a report, by the deadline for this action, identifying more aggressive actions to ensure compliance. These actions shall include, but not be limited to, reviewing options for pretreatment and upgrades to the treatment plant. The report shall identify an implementation schedule for investigating these options, selecting a preferred option, and implementing the chosen option. At a minimum, the report shall plan for the following activities: <ul style="list-style-type: none"> i. Bench scale testing or pilot scale testing or both ii. Development of preliminary design specifications iii. Development of final design specifications iv. Procurement of funding v. Acquisition of necessary permits and approvals vi. Construction | June 1, 2011 | June 1, 2011 |
| h. Implement the plan required in action “g” within 45 days of the deadline for action “g,” and submit annual status reports. | Annually each February 1 in Annual Self-Monitoring Report required by Permit Attachment E, Monitoring and Reporting Program | |
| i. Submit documentation confirming complete plan implementation and comply with effluent limits in the Permit. | June 1, 2015 | June 1, 2015 |

5. Effective Date. This Order shall be effective on the effective date of the Permit.

I, Bruce H. Wolfe, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on _____, 2007.

BRUCE H. WOLFE
Executive Officer

C. Comments

July 11, 2007

Mr. Bruce Wolfe, Executive Officer
Regional Water Quality Control Board
San Francisco Bay Region
1515 Clay Street, Suite 1400
Oakland, CA 94612-1404

Attention: Mr. Derek Whitworth

Via email: dwhitworth@waterboards.ca.gov & Fax: (510) 622-2460

RE: Comments on SFIA Tentative Orders and Cease and Desist Orders
 Reissuing the San Francisco International Airport's for the
 Mel Leong Treatment Plant Sanitary NPDES Permit (CA0038318)
 and Industrial NPDES Permit (CA0028070)

San Francisco International Airport (SFIA) appreciates the opportunity to comment on the Tentative Orders for the San Francisco International Airport's Sanitary and Industrial Plants (generally referred to collectively as "permit").

SFIA is concerned that this permit, unlike prior permits, requires immediate compliance with calculated limits. The Board has provided compliance schedules only as part of enforcement orders, placing SFIA in the untenable position of being in non-compliance immediately upon issuance of the permit. This permit will have a major impact on our operations and future compliance status. It may also likely trigger new construction. We are extremely concerned that the Board has elected to adopt a radically different permitting approach than it has used in the past without first undertaking a broad assessment of the implications this new approach will have on the Bay Area POTWs. This new approach will likely place SFIA in an extremely vulnerable position of significant non-compliance with no reasonable means of coming into compliance. Consequently, SFIA is requesting that the Board consider a general permit moratorium until the current Bay standards issues are resolved (mercury, dioxin, CN, NH3). The risk to SFIA is that the Board's plans to address these pollutants procedurally may not go according to schedule and SFIA will be forced into non-compliance status and possible enforcement action or third party lawsuits because of pollutant limitations that the Board knows should be changed.

Mr. Bruce Wolfe, RWQCB

July 11, 2007

Page 2

In the event that the Board does not issue a moratorium and because this permit represents a fundamentally new approach to permitting, which we did not anticipate, we request that the permit be delayed until we have had an additional 60 days to review the permit. An extension would also enable the Board to use this additional time to reassess its new permitting approach, to identify alternatives that do not lead to substantial non-compliance for Bay Area POTWs, and to generally evaluate the impact this new permitting approach has on Bay Area POTWs.

We have divided our comments into the following sections: comments applicable to both permits and cease and desist orders, sanitary tentative order comments, and industrial waste tentative order comments.

I. Comments Applicable to Both Proposed Permits and C&D Orders

- a. Final Limits will not be achieved.** There is no indication that SFIA will be able to meet the final effluent limits for mercury, aldrin, 4,4'-DDT, 4,4'-DDE, dieldrin, endrin, heptachlor, and heptachlor dioxide. These final limits should be only provided for reference and should not be enforceable. **SFIA requests removal of these final concentration limits.** We are specifically concerned about mercury, which is being addressed through the TMDL program. EPA Region 9 has provided an opinion that TMDLs cannot be used to delay the implementation of a final limit in a permit. This is an opinion of EPA Region 9, this is not a regulation adopted by either the state of California or the USEPA. We strongly object to having final limits and a Cease and Desist Order for mercury when BACWA agencies have worked tirelessly with the Clean Estuary Partnership (CEP), the Regional Water Board and the State Water Board to have a final mercury TMDL adopted. Now BACWA members are being punished because a final TMDL has not been adopted. We urge the Water Board to question EPA Region 9.
- b. SFIA Objects to Including Numeric Final Effluent Limits for Dioxin-TEQ.** SFIA requests that the dioxin-TEQ numeric final effluent limit be removed because there is no approved numeric water quality objective for dioxin-TEQ, and not only is SFIA unable to meet this limit, but there are no analytical methodologies that accurately detect to this level. SFIA believes that the Regional Water Board has discretion to maintain the narrative standard that exists in the San Francisco Bay Basin Plan. There is no value in developing a numerical standard at this time since dioxin at these levels cannot be measured. The recognized source is air emissions and combustion, neither of which SFIA can control or prevent. The Board has identified dioxins as the "unintentional byproducts of combustion and incineration" (1998 report, Dioxin in the Bay Environment). Although an optional offset provision may provide an alternative to compliance with a final effluent limit for dioxin-TEQ, such a program does not currently exist. Even though the Regional Water Board directed Regional Water Board staff to develop such a program, there do not appear to be any plans in place. Until such a program is developed with a feasible implementation strategy, SFIA believes this is not a realistic alternative and it is misleading to expect that such a program would lead to compliance. Lastly, dioxin samples typically cost over \$1,000 each. The sampling required for the mandated source control program will create a substantial burden on SFIA with no commensurate benefit.
- c. Dilution Should be Used for ALL Constituents** – A locally appropriate dilution factor will be used for ammonia but not for other constituents. The SIP specifically allows for the use of dilution credits and also specifically takes precedence over prior Basin Plan policies. Nevertheless the Regional Board has continued with its arbitrary 10:1 cap on the dilution factor. Faced with the bizarre result of ammonia being considered in non-compliance as discharged by a POTW, the Board has now relented and plans to allow actual dilution for this one constituent. If the Board allows dilution for one constituent, then it should be appropriate for all. In addition, the

Board should develop a dilution policy, which specifies the parameters to be used in identifying dilution factors.

- d. **Amend Permit to Clarify Single Violation at New Monitoring Location for Combined Flow** - A violation of an effluent limit from point EFF-001A will result in a MMP violation on both permits. Each exceedance should result in only one permit violation. The permit for each plant should be amended to clarify this point. Otherwise, the Airport will face double jeopardy for a single violation. Alternatively, the Board can combine the permits into a single permit for both plants to eliminate this problem.
- e. **Ammonia** - The Board has elevated ammonia and cyanide as constituents of critical status when previously there has been consensus that these pollutants are unlikely to cause problems when discharged by POTWs. Ammonia limits should be taken out of the cease and desist order. By RWQCB staff's analysis, it is feasible (see page F-48) for SFIA to comply with the limits, even though the limits were derived incorrectly using the RPA instead of the TSD method (see BACWA's comment letter).
- f. **Mercury** - The Regional Water Board has been in the process of developing a mercury total maximum daily load (TMDL) for at least 10 years. The mercury TMDL approved by the Regional Water Board contains requirements that have been developed in a meaningful way throughout the process of its development and deliberation. SFIA is ready to implement the mercury TMDL through activities that will address impairment in San Francisco Bay. This is in contrast to the requirements in the Cease and Desist Order that requires extensive actions, including significant expenditures of public funds, within the next three to six months solely because the State Water Board has not yet approved the mercury TMDL. This timeline is completely unreasonable given the history of the TMDL process, and the insignificant contribution of mercury by municipal wastewater treatment plants to San Francisco Bay. The calculated final limits based on the current Basin Plan standard will be very difficult to meet. The Board should hold the mercury limitation in abeyance until the State Board and the EPA complete their action on the new standard. The Board should not set a limit based on an objective that it has acknowledged is inappropriate and is in the process of vacating. SFIA requests that mercury be taken out of the Cease and Desist Order.
- g. **Cyanide** - The Regional Water Board has adopted a site-specific objective for cyanide that will result in appropriate water quality objectives that are protective, technically feasible, and reasonable. Approval of the cyanide site-specific objective by the State Water Board, which must happen before approval by the Office of Administrative Law and USEPA, is currently stalled because State Water Board staff has been pulled to work on other initiatives. Cyanide is *not* a significant water quality issue for San Francisco Bay. Cyanide has been considered a non-persistent pollutant and generally not of regulatory concern. Cyanide has commonly been omitted from

previous permitting possibly due to the lack of monitoring data with sufficiently low detection levels and a general consensus that it does not present a risk to water quality. Yet the Cease and Desist Order requires significant outlay of public funds on all kinds of activities to reduce cyanide from municipal wastewater effluent. These requirements are a waste of public resources. Until the site-specific objective is adopted, SFIA will not be able to comply with the expected final objective. SFIA propose that the Board hold the limitation in abeyance until the State Board and the EPA complete their action on the new standard. SFIA requests that cyanide be taken out of the Cease and Desist Order.

- h. **Pesticides** – Most if not all of the pesticides listed in the Cease and Desist Order were banned for use as a pesticide in the United State 19 years ago in 1988. Since then many have been banned in many other countries around the world as well. To include nine separate tasks to reduce these pesticides in municipal wastewater effluent when the effluent limit is based on only one non-quantified, non-reproducible data point is an irresponsible use of public resources. Additionally, the East Bay MUD remand order did not limit compliance schedules for constituents other than mercury, cyanide and selenium. SFIA requests that pesticides be taken out of the Cease and Desist Order.
- i. **Eliminate Cease & Desist Orders** - The Cease and Desist orders for both treatment processes should be eliminated as is requested above. If the Board is unwilling to eliminate the Cease & Desist Orders, the action plans in the Orders should remove all activities related to the installation of capital improvements.
- j. **Incorporation of BACWA Comments** - SFIA agrees with and incorporates by reference the comments made by BACWA in its comment letter dated July 10, 2007.

II. Sanitary Tentative Order Comments

- a. **Attachment C.** Wrong Process Schematic used (the industrial system was included instead).
- b. **Page 14.** 3. Acute Toxicity: “Representative samples of the effluent at Discharge Point 001, collected before chlorination, shall meet the following limitations.....”
Need parallel changes to **Page E-8, V.** to read
“The Discharger shall monitor acute and chronic Toxicity at ~~EFF-001A~~ EFF-001-SAN (prior to chlorination)”
- c. **Page E-8, V.A.5.** Delete the sentence “Effluent used for fish bioassays must be dechlorinated prior to testing”.
- d. **Table E-5 (Page E-6** in both T.O.s) shows location EFF-001A to be monitored for Acute Toxicity. We ask to include a footnote, saying that a combination of prechlorinated effluent flows from EFF-001-SAN and EFF-001-IND is to be used for the Acute Toxicity test. The flows are to be mixed in proportion to the actual flow of the 2 plants.

III. Industrial Tentative Order Comments

- a. **Attachment C.** Wrong Process Schematic used (The sanitary system was included instead).
- b. **Page E-8: Monthly** Monitoring for T.S.S. and Fecal Coliform on EFF003, EFF005- EFF010 and EFF013 will be problematic in the dry season when there will not be any flows at all. Samples will certainly not be representative. We request the sampling frequency to be twice a year to match the other parameters.
- c. **Page E-7. Footnote (4):** Add a phrase to include alternative Enterococci method, so the footnote reads: “The Discharger shall monitor for enterococci using USEPA’s Membrane Filter Test Method 1600, **or an EPA approved method such as Enterolert.**” The same phrase was already added to the Sanitary T.O.
- d. **Page F-53,** second bulleted paragraph should read: “Once per month monitoring for enterococci bacteria.....”
- e. **Page 16. 3. Acute Toxicity:** “Representative samples of the effluent at Discharge Point 001 (Monitoring Location EFF-001-Ind, shall meet the following limitations....” Need to add the same phrase “collected before chlorination” to EFF-001-IND. Need parallel changes Page E-10, V. to read, “The Discharger shall monitor acute and chronic Toxicity at ~~EFF-001A~~ EFF-001-IND (prior to chlorination).”
- f. **Page E-10. V.A.5.** Delete the sentence “Effluent used for fish bioassays must be dechlorinated prior to testing.
- g. **Table E-5 (Page E-6** in both T.O.s) shows location EFF-001A to be monitored for Acute Toxicity. We ask to include a footnote, saying that a combination of prechlorinated effluent flows from EFF-001-SAN and EFF-001-IND is to be used for the Acute Toxicity test. The flows are to be mixed in proportion to the actual flow of the 2 plants.

SFIA appreciates the Regional Water Board’s close attention to the comments made herein. Mark Costanzo, of my staff, can meet with you to discuss our comments and concerns in more detail. He can be reached at (650) 821-7809.

Very truly yours,

Ernie Eavis
Deputy Airport Director - Facilities

cc: Michele Pla, BACWA Executive Director
Arleen Navarret, BACWA Permit Committee Chair
Robert Cole, BACWA Permit Committee Chair
BACWA Executive Board



Bay Area Clean Water Agencies

Leading the Way to Protect Our Bay

A Joint Powers Public Agency

P.O. Box 24055, MS 702

Oakland, California 94623

July 10, 2007

VIA EMAIL AND FACSIMILE: (510) 622-2460

Mr. Bruce Wolfe, Executive Officer
San Francisco Bay Regional Water Quality Control Board
1515 Clay Street, Suite 1400
Oakland, CA 94612

RE: Comments on the Tentative Order Reissuing the San Francisco International Airport's Sanitary Plant NPDES Permit (CA0038318)

Dear Mr. Wolfe:

The Bay Area Clean Water Agencies (BACWA) appreciate the opportunity to comment on the Tentative Order for the San Francisco International Airport's Sanitary Plant (SFIA), as well as to make comments on policy issues related to the NPDES permit. BACWA members own and operate publicly-owned treatment works (POTWs) that discharge to San Francisco Bay and its tributaries. Collectively, BACWA's members serve over 6.5 million people in the nine-county Bay Area, treating all domestic, commercial and a significant amount of industrial wastewater. BACWA was formed to develop a region-wide understanding of the watershed protection and enhancement needs through reliance on sound technical, scientific, environmental and economic information and to ensure that this understanding leads to long-term stewardship of the San Francisco Bay Estuary. BACWA member agencies are public agencies, governed by elected officials and managed by professionals who are dedicated to protecting our water environment and the public health.

BACWA hopes that the following comments will result in changes being made to the tentative order prior to issuance of the final NPDES permit for SFIA. Further, in order to avoid repetition, but to preserve these arguments, BACWA supports and incorporates by reference the comments made by SFIA in its comment letters.

1. BACWA Objects to Including Numeric Final Effluent Limits for Dioxin-TEQ.

BACWA requests that the dioxin-TEQ numeric final effluent limit be removed because there is no approved numeric water quality objective for dioxin-TEQ, and not only is SFIA unable to meet this limit, but there are no analytical methodologies that accurately detect to this level. BACWA believes that the Regional Water Board has discretion to maintain the narrative standard that exists in the San Francisco Bay Basin Plan. There is no value in developing a numerical standard at this time since dioxin at these levels cannot be measured. The recognized source is air emissions and combustion, neither of which SFIA, or any BACWA member agency, can control or prevent.

Although an optional offset provision may provide an alternative to compliance with a final effluent limit for dioxin-TEQ, such a program does not currently exist. Even though the Regional Water Board directed Regional Water Board staff to develop such a program, there do not appear to be any plans in place. Until such a program is developed with a feasible implementation strategy, BACWA believes this is not a realistic alternative and it is misleading to expect that such a program would lead to compliance.

2. BACWA Has Concerns About Including Final Effluent Limits in the Permit With Which SFIA Cannot Comply.

The existing permit includes final effluent limits for mercury, aldrin, 4,4'-DDT, 4,4'-DDE, dieldrin, endrin, heptachlor, and heptachlor dioxide. These final limits should be only provided for reference and should not be enforceable. BACWA requests removal of these final concentration limits.

We are specifically concerned about mercury which is being addressed through the TMDL program. EPA Region 9 has provided an opinion that TMDLs cannot be used to delay the implementation of a final limit in a permit. This is an opinion of EPA Region 9, this is not a regulation adopted by either the state of California, nor the USEPA. We strongly object to having final limits and a Cease and Desist Order for mercury when we have worked tirelessly with the Clean Estuary Partnership (CEP), the Regional Water Board and the State Water Board to have a mercury TMDL adopted. Now BACWA members are being punished because a final TMDL has not been adopted. We urge the Water Board to question EPA Region 9's opinion.

3. BACWA Has Legal Concerns with the Mercury Mass Limit.

BACWA incorporates by reference earlier legal arguments made in BACWA petitions for review of Bay Area permits adopted from 2000 through 2003 (e.g. Petition for Review of Central Contra Costa Sanitary District's Permit, Appeal No. OCC A-1399(a)), in order to preserve BACWA's legal rights to challenge the mercury mass limits should the mercury TMDL not be timely adopted or should it be adopted in a manner different than that proposed by the San Francisco Bay Regional Water Board in 2006. BACWA intends to withdraw this comment or any legal action taken to enforce this comment once acceptable mercury TMDL has been timely adopted and implemented.

4. The Technical Support Document (TSD) Should Be Used For the Ammonia Reasonable Potential Analysis.

BACWA appreciates that as a consequence of the ruling of the SWRCB on the EBMUD wet weather permit that the Water Board has responded quickly by including ammonia limits in BACWA member permits. We believe that the application of actual dilution is the correct approach precisely because ammonia is neither a persistent pollutant nor a bioaccumulative pollutant. BACWA commends the Water Board staff for using the best available information

for the SFIA discharge to ensure that the most reasonable dilution factor is applied to this effluent standard. We disagree however with using dilution after the reasonable potential analysis rather than as part of the reasonable potential analysis.

(Page F-43)

The tentative order indicates that the driver for conducting a reasonable potential analysis for ammonia was the adoption of State Water Resources Control Board Order WQ 2007-0004 on May 1, 2007. In that order, the language regarding establishment of reasonable potential for ammonia which forms the basis for the ammonia effluent limits analysis in this tentative order is as follows:

“...the effluent can appropriately be characterized as having reasonable potential to exceed the ammonia objective.⁹⁰ [Footnote 90: See U.S. EPA’s Technical Support Document for Water Quality-based Toxics Control (March 1991), EPA 505 2-90-001, 3.2 at page 50.]”

The State Water Resources Control Board used the Technical Support Document (TSD) to determine that reasonable potential for ammonia existed for Order WQ 2007-0004 (East Bay MUD remand order, upon which the proposed ammonia limits are based). The Regional Water Board has opted to use the State Implementation Policy (SIP) to determine reasonable potential for ammonia in this permit instead. Given that ammonia is not a water quality pollutant of concern in San Francisco Bay, the Regional Water Board is allowed to, and should use, the TSD, a USEPA-supported and SWRCB- supported reasonable potential determination approach.

5. The Compliance Schedule Action Plans in the Permit and in the Cease and Desist Order are Overly Stringent.

This permit includes compliance schedules for pollutants that have been banned for use or for which wastewater treatment plant effluents have been identified as non-significant sources. Additionally, each pollutant is already being addressed through an alternative regulatory strategy that will appropriately resolve beneficial use concerns for the San Francisco Bay. The compliance schedules are overly burdensome for every constituent, as specified below:

- Dioxin - Dioxin congeners are characterized as persistent and stable. The dioxin congeners found in fish tissue samples, which form the basis for the dioxin 303(d) listing, are different than the congeners detected in publicly-owned treatment works. Given that the sources of dioxin are uncontrollable by municipal wastewater treatment plants and are primarily introduced through air deposition, the compliance requirements for dioxin reduction in the effluent will have little if any environmental benefit to reduce the concentrations of dioxin congeners found in fish tissue.
- Mercury - The Regional Water Board has been in the process of developing a mercury total maximum daily load (TMDL) for at least 10 years. The mercury

TMDL approved by the Regional Water board contains requirements that have been developed in a meaningful way throughout the process of its development and deliberation. Bay Area POTWs are ready to implement the mercury TMDL through activities that will address impairment in San Francisco Bay. This is in contrast to the requirements in the Cease and Desist Order that requires extensive actions, including significant expenditures of public funds, within the next three to six months solely because the State Water Board has not yet approved the mercury TMDL. This timeline is completely unreasonable given the history of the TMDL process, and the insignificant contribution of mercury by municipal wastewater treatment plants to San Francisco Bay.

- Cyanide – The Regional Water Board has adopted a site-specific objective for cyanide that will result in appropriate water quality objectives that are protective, technically feasible, and reasonable. Approval of the cyanide site-specific objective by the State Water Board, which must happen before approval by the Office of Administrative Law and USEPA, is currently stalled because State Water Board staff has been pulled to work on other initiatives. Cyanide is *not* a significant water quality issue for San Francisco Bay. Yet the Cease and Desist Order requires significant outlay of public funds on all kinds of activities to reduce cyanide from municipal wastewater effluent. These requirements are a waste of public resources.
- Pesticides – Most if not all of the pesticides listed in the Cease and Desist Order were banned for use as a pesticide in the United State 19 years ago in 1988. Since then many have been banned in many other countries around the world as well. To include nine separate tasks to reduce these pesticides in municipal wastewater effluent is an irresponsible use of public resources.

For these reasons, the action plans should be revised to remove all activities related to installation of capital improvements. In addition, any pollution prevention activities should be identical to resolutions or orders already adopted by the Regional Water Board for specific constituents, such as mercury and cyanide. No new or different activities should be required for those constituents.

If the Regional Water Board is unwilling to remove all requirements related to capital improvements, then at a minimum the initiation of capital improvements should only be triggered if a quantified result, without any quality assurance/quality control issues, of the respective constituent, is observed.

BACWA appreciates the Regional Water Board's close attention to the comments made herein. I would be more than happy to meet with you to discuss our comments and concerns in more detail as you wish.

Respectfully submitted,

A handwritten signature in black ink, appearing to read "Michele Pla". The signature is fluid and cursive, with a large initial "M" and a stylized "P".

Michele Pla
BACWA Executive Director

cc: BACWA Executive Board
Robert Cole, BACWA Permits Committee Chair

D. Responses to Comments

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION**

RESPONSE TO WRITTEN COMMENTS

**ON THE REISSUANCE OF WASTE DISCHARGE REQUIREMENTS AND
ISSUANCE OF CEASE & DESIST ORDERS FOR**

San Francisco International Airport
Mel Leong Treatment Plant – Sanitary Plant and Industrial Plant
676 McDonnell Rd.
San Francisco, CA 94128

The Tentative Orders for reissuance of the San Francisco International Airport Mel Leong Treatment Plant – Sanitary Plant, NPDES Permit No. CA0038318, and the Industrial Plant, NPDES Permit No. CA0028070, and respective Cease and Desist Orders were made available for public comment for 30 days from June 11, 2007, to July 11, 2007. The Regional Water Board received six pages of comments from the San Francisco International Airport. These comments covered both the Sanitary Plant permit and the Industrial Plant permit. We received one email comment from South San Francisco – San Bruno Water Quality Control Plant that also related to both permits. We also received five pages of comments from the Bay Area Clean Water Agencies (BACWA). These comments were directed to the Sanitary Plant, but are relevant to the Industrial Plant as well. To avoid duplication, the responses here apply to both the Sanitary Plant and the Industrial Plant.

San Francisco International Airport, July 11, 2007

P.O. Box 8097
San Francisco, CA 94128
Earnie Eavis, Deputy Airport Director

South San Francisco – San Bruno Water Quality Control Plant, July 3, 2007

195 Belle Air Road,
South San Francisco, CA 94080
David Castagnola, Superintendent

Bay Area Clean Water Agencies (BACWA), July 10, 2007

P.O. Box 24055, MS 702,
Oakland, CA 94623
Michele Pla, Executive Director

Comments were both substantive and editorial. Only substantive comments, those that would change the content of the Order, are addressed in depth. Generally, editorial comments were incorporated into the Revised Tentative Orders and the Cease and Desist Orders.

COMMENTS FROM SAN FRANCISCO INTERNATIONAL AIRPORT (SFIA)

General Comments in the July 11, 2007, Cover Letter referencing the Tentative Orders and Cease and Desist Orders for both the Sanitary Plant and the Industrial Plant. SFIA expressed concern that this permit required immediate compliance with calculated limits and that the SFIA will be in non-compliance upon issue of the permit. SFIA stated its concern that the impacts of the new permit could require new construction both for these plants and for other facilities with similar requirements, and this could have a significant impact on Bay Area POTWs. Giving this reason, SFIA requested a general moratorium until current Bay standards issues are resolved for mercury, dioxin, cyanide and ammonia. SFIA expresses concern that plans to address these constituents may not go as expected and SFIA would be forced into non-compliance and subject to enforcement or third party lawsuits.

Response to Cover Letter:

SFIA's concerns over final effluent limits in the permits with which it cannot comply were also raised in the July 10, 2007, letter from BACWA. Regional Water Board responses to these concerns are described in the Master Response to BACWA Comment 3 (Comment 2 for SFIA) and Comment 6 (Comment 5 for SFIA).

With respect to the requested moratorium, the Regional Water Board disagrees that this is appropriate. Re-issuance of these permits has already been delayed to consider and incorporate recent regulatory actions, specifically SWRCB Order WQ 2007-0004 (May 2007) reviewing the EBMUD Wet Weather Permit. U.S. EPA requires the Regional Water Board to re-issue permits in a timely manner and will not accept unnecessary delays. Existing permits for SFIA were issued more than 5-years ago, the statutory limit for permits.

Comments applicable to both Proposed Permits and both Cease & Desist Orders.

SFIA Comment a: Final Limits will not be achieved. SFIA claims that it will not be able to meet final limits for mercury, aldrin, 4,4'-DDT, 4,4'-DDE, dieldrin, endrin, heptachlor, and heptachlor epoxide and that these limits should be only for reference and not be enforceable. SFIA expresses particular concern over the final limits for mercury which is being addressed through the TMDL program. SFIA proposes that the December 13, 2006, letter from U.S. EPA to the Regional Board that notes final limits are required even if TMDLs are being developed is only an opinion that the Regional Water Board should question.

Response a: We received similar comments from BACWA and our responses to these concerns are provided in the Consolidated Response to BACWA Comment 3 (Comment 2 for SFIA).

SFIA Comment b: SFIA objects to including numeric final effluent limits for dioxin-TEQ. SFIA claims that that final effluent limit should be removed because there is no approved numeric water quality objective for dioxin-TEQ, no analytical method that can detect concentrations as low as the limit, and thus there is no value in developing a numeric limit. In addition, SFIA notes that dioxins in water result from air emissions and asserts that an offset provision should not be included because it is not a realistic alternative. In addition, SFIA comments that analysis for dioxins costs over \$1,000 for each sample and this creates a substantial burden with no compensating benefits.

Response b: We received similar comments from BACWA and our responses to these concerns, are provided in the Consolidated Response to BACWA Comment 2 (Comment 1 for SFIA). As regards the cost of each analysis, the Regional Water Board notes that with the new permit, there is one sampling location for the effluent from both the sanitary and the industrial plants. The monitoring program requires sampling and analysis twice per year, but with the new permit the number of samples is reduced by half. We do not consider these costs to be overly burdensome given the need for dioxins data to monitor compliance and complete reasonable potential analyses for the next permitting cycle.

SFIA Comment c: Dilution should be used for ALL constituents. SFIA notes that a local dilution factor will be used for ammonia but not for other constituents. SFIA interprets the SIP as allowing for dilution credits that could take precedence over Basin Plan policies, which, they claim, has an arbitrary 10:1 cap on the dilution factor. SFIA proposes that since application of the 10:1 dilution factor would have resulted in non-compliance for ammonia, the Regional Board waived this limit and allowed actual dilution for this one constituent. SFIA asserts that based on this, actual dilution should be allowed for all constituents.

Response c: As explained on pages F-35 and F-36 of the Fact Sheet, we granted full dilution for ammonia because the circumstances of ammonia discharge are different from the circumstances of other pollutants that have been given limits. Ammonia is a non-persistent pollutant that is quickly dispersed and rapidly degraded. Since we have background concentrations from samples collected relatively close to the outfall, we can be reasonably confident in accounting for dilution. For other non-bioaccumulative pollutants discharged to the Bay, a more stringent dilution ratio of 10:1 is still required. This 10:1 dilution ratio is considered necessary because most pollutants persist in the Bay. Also SFIA shares its outfall with three other dischargers. In fact more than nine wastewater treatment plants discharge at least 200 million gallons of water per day into the same part of the Bay. Another pollutant, cyanide, like ammonia, also degrades rapidly. In the revised Tentative Order, we revised the effluent limit calculations for cyanide to account for greater dilution, as discussed further in the Consolidated Response to BACWA Comment 6 (Comment 5 for SFIA). For bioaccumulative pollutants, no dilution credit is used in calculating WQBELs when no assimilative capacity exists in the receiving water.

SFIA Comment d: Amend Permit to clarify single violation at new monitoring location for combined flow. *SFIA notes that a violation of an effluent limit from Point EFF-001A would result in a violation of both permits and asserts that an exceedance of an effluent limit should result in only one violation. SFIA proposes that each permit be amended to clarify this point, so that an exceedance would not be counted as violations of two permits. SFIA also suggests that the Board combine the permits into a single permit.*

Response d: To simplify its monitoring efforts and reduce its monitoring costs, SFIA requested permission to monitor effluent from the two treatment plants at a location after the two effluents are combined. By doing so, violations are less likely because pollutant concentrations from one plant could be reduced by dilution from flows from the other plant. However, because there are two permits, each with its own effluent limits, we cannot count violation of these limits as a single violation. Historically, the two treatment plants have been permitted separately and combining the plants under one permit would add an unnecessary level of complexity to the permitting process for no water quality benefit.

SFIA Comment e: Ammonia. *SFIA claims that the Board has assigned ammonia and cyanide as constituents of concern when previously there was consensus that these pollutants were unlikely to cause problems when discharged by POTWs. SFIA asserts that ammonia limits should be taken out of the Cease and Desist Order since SFIA can comply with these limits derived using the RPA.*

Response e: We agree that references to ammonia should be removed from the Cease and Desist Order. Cyanide is addressed in comment g below.

SFIA Comment f: Mercury. *SFIA comments that the Board has been developing a mercury TMDL for at least ten years and states that SFIA has the intention to implement the TMDL when approved. SFIA claims that the Cease and Desist Order requires extensive actions, including expenditures of public funds that would not be needed if the TMDL were in place. SFIA asserts that the Board should not set a limit based on objectives that are inappropriate and requests that mercury be taken out of the Cease and Desist Order.*

Response f: We received similar comments from BACWA and our responses to these concerns are provided in the Consolidated Response to BACWA Comment 6 (Comment 5 for SFIA).

SFIA Comment g: Cyanide. *SFIA comments that the Board has adopted a site-specific objective (SSO) for cyanide but claims this has not been finalized because of State Board inaction. SFIA also claims that cyanide is not a significant water quality issue for the Bay and has been commonly omitted from previous permitting because of a lack of monitoring data and the absence of risk to water quality. SFIA claims that the Cease and*

Desist Order requires significant outlay of public funds to reduce cyanide from wastewater. SFIA asserts that it will not be able to comply with the expected final objective and proposes that the Board hold the limitation in abeyance until the SSO standard is in place and requests that cyanide be taken out of the Cease and Desist Order.

Response g: We removed cyanide from the Cease and Desist Order. We received similar comments from BACWA and our responses to these concerns are provided in the Consolidated Response to BACWA Comment 6 (Comment 5 for SFIA).

SFIA Comment h: Pesticides. SFIA comments that pesticides listed in the Cease and Desist Order have been banned from use in the U.S.A. since 1988. SFIA claims that the permit requires nine separate tasks to reduce these pesticides and that this is inappropriate and could be an irresponsible use of public resources, as the effluent limit was based on only one non-reproducible data point. SFIA notes that pesticides were not included in the EBMUD Remand Order and requests that pesticides be taken out of the Cease and Desist Order.

Response h: We received similar comments from BACWA and our responses to these concerns, are provided in the Consolidated Response to BACWA Comment 6 (Comment 5 for SFIA). Regarding the assertion that the Cease and Desist Order (CDO) should not include pesticides because they were not in the EBMUD remand order, the reason pesticides are in the CDO is not because of the EBMUD remand order. 4,4-DDE and dieldrin are in the CDO because SFIA demonstrated that it cannot comply with the final limits in the previous order. Since final limits were already imposed, no compliance schedule can be authorized. Therefore, a CDO is an appropriate vehicle to bring SFIA into compliance. Aldrin, 4,4-DDT, heptachlor, and heptachlor epoxide are in the CDO because the compliance schedule in the permit must end by May 18, 2010, and we predict SFIA may not be in compliance by that time. Therefore, a CDO is an appropriate mechanism to bring SFIA into compliance as soon as possible.

SFIA Comment i: Eliminate Cease & Desist Orders. SFIA comments that Cease and Desist Orders for both plants should be eliminated, or, if they are not eliminated, they should be modified to remove all requirements that may necessitate capital expenditures.

Response i: The Regional Water Board disagrees. Cease and Desist Orders are one of the enforcement mechanisms used by the Board to get a discharger into compliance with permit requirements. As indicated in the response to the comments in the cover letter, compliance schedules have to be enforceable. This can be achieved by use of a Cease and Desist Order that specifies the outcome required, not the means. References to capital expenditures would involve defining the means and would be inconsistent with Regional Water Board policy. We received similar comments from BACWA and our responses to these concerns are provided in the Consolidated Response to BACWA Comment 6 (Comment 5 for SFIA).

***SFIA Comment j: Incorporation of BACWA Comments.** SFIA states that it incorporates the Comments submitted by BACWA in its July 10, 2007 letter.*

Response j: The Regional Water Board acknowledges the BACWA comments. Our responses to those concerns are provided in the Consolidated Responses to the BACWA Comments.

**COMMENTS FROM OFFICE OF THE SUPERINTENDENT OF WATER
QUALITY CONTROL, CITY OF SOUTH SAN FRANCISCO (SSF)**

***SSF Comment:** The TO for SFIA – Sanitary, Table 8 lists the average monthly limit for cyanide at EFF-002 as 2.8 µg/L. The corresponding CDO, Table 1 lists the limit as 3.2µg/L.*

Response: We have removed cyanide from the Cease and Desist Order; thus, the comment no longer applies.

COMMENTS FROM BAY AREA CLEAN WATER AGENCIES (BACWA)

We received a comment letter from BACWA that specifically addressed the Tentative Order for the Sanitary Plant. At the same time, BACWA sent comment letters on the Tentative Orders and Tentative Cease and Desist Orders, for the Sausalito-Marin City Sanitary District and the Sewerage Authority of Southern Marin. Since there were common elements in the comments one consolidated response document was prepared to address all comments. This is titled Consolidated Response, and is attached.

CONSOLIDATED RESPONSE
Bay Area Clean Water Agencies
Written Comments

Item Nos. 8, 9, and 10
Sausalito-Marín City Sanitary District
Sewerage Agency of Southern Marin
San Francisco International Airport (Sanitary Plant)

The Regional Water Board received three comment letters from the Bay Area Clean Water Agencies (BACWA) regarding the Tentative Orders for the San Francisco International Airport (SFIA) (Sanitary Plant only), the Sausalito-Marín City Sanitary District (SMCSD), and the Sewerage Agency of Southern Marin (SASM), and the accompanying Cease and Desist Orders. Many of BACWA's comments are common to all three dischargers. Therefore, this Master Response replies to all of BACWA's comments here in one document. The comments are paraphrased below in *italics*, followed by our responses. For the full context of the comments, refer to the original comment letters.

BACWA Comment 1
(for SMCSD and SASM only)

An enforceable schedule for blending should not be included in the permit. A no feasible alternative analysis is not legally required. U.S. EPA's national blending policy is only a draft, and even the draft policy does not require an enforceable schedule to reduce the need for blending. These blending requirements should not be imposed in advance of national policy decisions.

Response: We disagree. In our view, requiring enforceable actions to reduce the need for blending is reasonable and consistent with existing federal laws and regulations (see 40 CFR 122.41(m)(4)), which require that dischargers document that there are no feasible alternatives to such bypasses as blending events. U.S. EPA developed draft guidance on this topic, and although the draft guidance is not legally enforceable, we consider it to be a useful tool as we interpret these federal laws and regulations. The provisions in the Tentative Order are necessary because dischargers need to show us the measures they are undertaking to minimize blending events so we can consider whether to allow blending the next time we reissue the permit. The schedules in the Tentative Orders were crafted to provide the dischargers with maximum flexibility in determining their preferred alternatives for minimizing blending events. Since SASM does not have a history of blending-related bypasses, we have removed the blending provisions in that Revised Tentative Order. SASM will nevertheless remain subject to 40 CFR 122.41 and thus will need to provide notice and undertake additional monitoring if blending ever occurs.

BACWA Comment 2 (Comment 1 for SFIA)

BACWA objects to including numeric final effluent limits for dioxin-TEQ. There is no approved numeric water quality objective for dioxin-TEQ, and dischargers are unable to meet the dioxin TEQ limit. Moreover, no analytical methods can accurately detect dioxins at these levels. The dioxin sources are air emissions and combustion, neither of which these dischargers can control. Although an optional offset provision may provide an alternative to compliance with these limits, such a program does not currently exist.

Response: The numeric effluent limits for dioxin-TEQ are reasonable and appropriate. We derived them in accordance with 40 CFR 122.44(d)(1)(vi); they are based on the CTR objective for 2,3,7,8-TCDD and other relevant information. The Tentative Orders include dioxin-TEQ effluent limits because state and federal laws and regulations require them. By adopting the dioxin-TEQ limits, the Regional Water Board is complying with regulations implementing the Clean Water Act at 40 CFR 122.44(d), which require that permits include effluent limits for all pollutants that may be discharged at levels with a reasonable potential to cause or contribute to exceedances of water quality standards, including narrative objectives, such as the Basin Plan’s bioaccumulation objective. The Basin Plan states, “Water quality-based effluent limitations will consist of narrative requirements and, where appropriate, numerical limits for the protection of the most sensitive beneficial uses of the receiving water.”

Dioxin and similar compounds have bioaccumulated in San Francisco Bay fish in violation of the Basin Plan’s narrative bioaccumulation water quality objective. Therefore, a numeric effluent limit is appropriate to protect San Francisco Bay’s beneficial uses, which the bioaccumulation objective is intended to preserve. We used Toxic Equivalency Factors (TEFs) published by U.S. EPA and the World Health Organization, together with the CTR water quality objective for 2,3,7,8-TCDD (the most toxic of the dioxins), to translate the Basin Plan’s narrative bioaccumulation objective into numeric water quality-based effluent limits.

We do not intend to enforce compliance with the dioxins limits in situations where we cannot determine whether the limits are exceeded. However, neither 40 CFR 122.44(d) nor the Basin Plan allows consideration of whether analytical methods can actually measure dioxin-TEQ at concentrations as low as the limits. The Basin Plan states, “...when pollutant concentrations in waters are relatively low, the limits of quantification will be taken into account in determining compliance with, rather than the calculation of, effluent limits.” Following this policy and the State Implementation Policy’s Minimum Level (ML) concept, we developed effluent limits consistent with the water quality objective. We will use analysis-based Minimum Levels for compliance determination and enforcement.

We disagree that dioxins cannot be controlled. U.S. EPA resolved this issue by placing San Francisco Bay on the 303(d) list of impaired waters due to dioxin concentrations in fish and other aquatic organisms. The Basin Plan states, “Controllable water quality

factors are those actions, conditions, or circumstances resulting from human activities that may influence the quality of the waters of the State and that may be reasonably controlled.” Air emissions, which are created through combustion, are a source of dioxins, but wastewater treatment plants are also sources of dioxins. Dioxins in wastewater are primarily a result of human activity and their discharge to waters can be controlled by removing solids from wastewater (dioxins are hydrophobic and bind to particles). Additional dioxin removal could result from plant upgrades. This could be burdensome and may not be cost effective at this time; however, such actions could be necessary in the future.

We acknowledge that a formal mass offset program does not currently exist. The Tentative Order refers to such a program simply as one possible means to overcome any technical infeasibility in meeting the dioxin-TEQ limits.

BACWA Comment 3 (Comment 2 for SFIA)

BACWA has concerns about including final effluent limits in the permit with which dischargers cannot comply. The permits include effluent limits for mercury, selenium, cyanide, and various pesticides, but the dischargers cannot comply with them. Requiring unachievable final limits for compounds that are awaiting TMDLs (mercury, selenium, and certain pesticides) or site-specific objectives (cyanide) is inappropriate. U.S. EPA opines that TMDLs cannot be used to delay implementation of final limits through compliance schedules, but BACWA urges the Water Board to challenge U.S. EPA’s assertion. BACWA objects to having final limits and Cease and Desist Orders for pollutants for which it has worked with the Water Boards to have TMDLs adopted.

Response: We see no basis for removing any final effluent limits from the permits. The State Implementation Policy’s prescriptive measures require that we include these limits because there is reasonable potential for the discharges to contain these pollutants at levels that could adversely affect water quality. The dischargers’ inability to immediately comply with certain water quality-based limits does not obviate the requirement for effluent limitations for pollutants that have a reasonable potential to cause or contribute to exceedances of water quality standards. We recognize that some dischargers will be unable to immediately comply with certain limits. The accompanying Cease and Desist Orders address this foreseeable noncompliance. While the eventual adoption of TMDLs for mercury, selenium, and some pesticides and site-specific objectives for cyanide will likely require the recalculation of limits, we cannot legally delay implementation of existing water quality standards.

In a December 2006 letter to the Regional Water Board, U.S. EPA stated that the purpose of a compliance schedule could not be to allow time for such regulatory actions as TMDLs. Compliance schedules must be crafted to give dischargers time to undertake actions to meet water-quality based effluent limits. State Water Board Order WQ 2007-0004 (May 2007) reinforced U.S. EPA’s position, stating that compliance schedules must contain an enforceable sequence of actions leading to compliance with

effluent limits. The State Water Board specifically noted that U.S. EPA had formally disapproved the State Implementation Policy's provisions on TMDL-based compliance schedules in a October 2006 letter.

Although the Cease and Desist Orders require that the dischargers meet their effluent limits, the Cease and Desist Orders are constructed such that, when applicable TMDLs and site-specific objectives become effective, and the new effluent limits based on them, provisions of the Cease and Desist Orders related to these pollutants will cease to be in effect.

BACWA Comment 4 (Comment 3 for SFIA)

BACWA has legal concerns with the mercury mass limit. BACWA incorporated by reference earlier legal arguments it made in its petitions regarding other San Francisco Bay Region permits to preserve its rights to challenge the mercury mass limits if a mercury TMDL is not adopted as expected. BACWA intends to withdraw this comment once an acceptable mercury TMDL is adopted.

Response: BACWA's reference to prior comments is vague. It lacks the specificity necessary for us to respond in detail. Nevertheless, we stand by our decision to include mercury mass limits. The State Water Board has upheld the Regional Water Board's imposition of mercury mass limits on all four occasions when it reviewed this issue. Specifically, the State Water Board upheld mercury mass limits in its decisions on the permits for Tosco (WQ 2001-06), Napa (WQ 2001-16), Chevron (WQ 2002-0011), and East Bay Municipal Utility District (WQ 2002-0012). Since the State Water Board adopted the Mercury TMDL on July 17, 2007, and we expect the California Office of Administrative Law and U.S. EPA to approve it (U.S. EPA has expressed its support for the TMDL), we consider this comment to be withdrawn.

BACWA Comment 5 (Comment 4 for SFIA)

The Technical Support Document (TSD) should be used for the ammonia reasonable potential analysis. BACWA agrees that dilution should be taken into account in developing ammonia effluent limits because ammonia is neither persistent nor bioaccumulative. However, it disagrees with considering dilution only after the reasonable potential analysis has been completed. The Regional Water Board conducted reasonable potential analyses for ammonia because of State Water Board Order WQ 2007-0004, in which the State Board found, "...the [East Bay Municipal Utilities District] effluent can appropriately be characterized as having reasonable potential to exceed the ammonia objective."⁹⁰ Its reference to footnote 90 cites U.S. EPA's Technical Support Document for Water Quality-based Toxics Control. Because the State Water Board used the Technical Support Document to determine reasonable potential for ammonia in the context of that order, the Regional Water Board should also use it, instead of the State Implementation Policy as done here.

Response: Following the State Implementation Policy (SIP) methodology to evaluate reasonable potential for ammonia makes more sense than using U.S. EPA's Technical Support Document (TSD). The Basin Plan directs us to use the SIP to calculate effluent limits for selected toxic pollutants (e.g., the criteria pollutants). It makes sense that we would take a similar approach for ammonia. Regardless of how we conduct our reasonable potential analyses, the limits are calculated in the same way, taking dilution into account as appropriate. The purpose of the reasonable potential analyses is to determine which (i.e., how many) dischargers need limits.

A reasonable potential analysis can be performed using either the SIP or TSD methodology. The SIP is more conservative than the TSD because the SIP does not account for dilution in its reasonable potential analysis methodology. Therefore, with the SIP, more dischargers get limits. These additional dischargers are relatively less likely to encounter problems complying with their limits. In our view, this approach allows us to better oversee the dischargers and more effectively monitor for any water quality concerns. Moreover, we already use the SIP methodology to complete the reasonable potential analyses for every other pollutant, and we see no reason to use a different method just for ammonia.

We disagree that the State Water Board Order WQ 2007-0004 instructed the Regional Water Board to use the TSD for reasonable potential analyses. The State Water Board referred to the TSD in a footnote to its findings when reaching its conclusion that there was reasonable potential for ammonia at the East Bay Municipal Utilities District wet weather facilities. This was only an example, and Order WQ 2007-0004 does not mandate the use of the TSD for determining reasonable potential for ammonia.

BACWA Comment 6 (Comment 5 for SFIA)

The compliance schedule action plans in the permit and in the Cease and Desist Orders are overly stringent. The permits include compliance schedules for pollutants that have been banned or for which wastewater treatment plants are non-significant sources. Many of these pollutants are already being addressed through alternative regulatory strategies. Therefore, the requirements are overly burdensome.

- *Mercury—Dischargers are ready to implement the mercury TMDL, but the Cease and Desist Order requires extensive actions, including significant expenditures of public funds, within the next three to six months.*
- *Cyanide—Approval of the cyanide site-specific objective by the State Water Board is stalled at the State Water Board. The Cease and Desist Order requires significant outlay of public funds on all kinds of activities to reduce cyanide from municipal wastewater effluent.*

- *Pesticides (SFIA and SMCSD only)—To include nine separate tasks to reduce pesticides in municipal effluent because of only one non-quantified, non-reproducible data point is a waste of public resources.*
- *Dioxin (SFIA and SMCSD only)—The dioxin congeners found in fish tissue samples, which form the basis for the dioxin 303(d) listing, are different than the congeners detected in publicly-owned treatment works. The sources of dioxin are uncontrollable; therefore, the requirements for dioxin reduction will have little environmental benefit.*
- *Selenium (SMCSD only)—The activities being required for selenium are inappropriate because a TMDL for selenium will be developed in the future. Significant studies and capital improvements are premature. Quality control for sampling and analysis should be investigated first and further actions taken only if warranted.*

The required action plans should be revised to remove all activities related to capital improvements. In addition, any pollution prevention activities should be identical to those required through resolutions or orders already adopted by the Regional Water Board for specific constituents, such as mercury and cyanide. At a minimum, the initiation of capital improvements should only be triggered if a quantified result of the respective constituent is observed.

Response: We are not removing the activities related to capital improvements from the Tentative Orders and Cease and Desist Orders. The purpose of these orders is to ensure compliance with final effluent limits by requiring specific tasks that will achieve this goal. These tasks are sequential, and the requirements of each task depend on the outcome of the previous tasks. The time frames are reasonable because they provide time to investigate alternatives to capital improvements before they require consideration of capital improvements. Capital improvements are only required if, by February 2011, other efforts to comply with the effluent limits have been unsuccessful. We are committed to working with the dischargers to implement measures that result in compliance while minimizing unnecessary public expenditures.

We agree that capital improvements should only be required when effluent data clearly exceed effluent limits. For many pollutants, one of the first prescribed actions is to investigate sample collection, sample handling, and analytical laboratory quality assurance and quality control practices to ensure that analytical results are accurately determined and reported. We encourage all dischargers to adopt rigorous sampling and analytical protocols. This would reduce false or questionable results and ensure that reasonable potential analyses, effluent limit calculations, and treatment option selection are based on sound data. We have also revised the Cease and Desist Orders, as follows, to clarify that capital improvements are only required when discharge data continue to show that the discharges are out of compliance:

If by February 28, 2011, discharge data continue to show the discharge is out of compliance (as defined in 2.4.5. of the State Implementation Policy) ~~the above actions have not successfully brought the discharge into compliance~~ with the ~~all~~ Permit effluent limits, submit a report, by the deadline for this action, identifying more aggressive actions to ensure compliance. These actions shall include, but not be limited to, reviewing options for pretreatment and upgrades to the treatment plant....

Responses to the comments on specific pollutants are provided below:

- **Mercury**—The Cease and Desist Orders do not require significant expenditures of public funds related to mercury within the next three to six months. Until 2011, the Cease and Desist Orders require a pollution prevention strategy that entails source identification and reduction. These actions are similar to what will be necessary to implement the Mercury TMDL. We expect the Mercury TMDL to be adopted before 2011. U.S. EPA has indicated that it may approve the Mercury TMDL as soon as April 2008. When it does, we expect that a mercury watershed permit will supersede all the mercury provisions in these permits. The Cease and Desist Orders contain explicit exceptions to all mercury-related requirements in the event that a mercury watershed permit becomes effective. We have adjusted the Cease and Desist Order time schedules slightly to reflect the TMDL timeline, so discharges may not need to complete any of the mercury-related actions in the Cease and Desist Order.
- **Cyanide**—We revised the cyanide limits in the Sausalito-Marín City Sanitary District permit and the two San Francisco International Airport permits. We expect these dischargers to now be able to comply with these new limits; therefore, cyanide-related requirements have been removed from the respective Cease and Desist Orders.

Cyanide is like ammonia in that it is a non-persistent pollutant that quickly disperses and degrades in the receiving water. We granted “full” dilution credit of 74:1 for the Airport and 84:1 for the District when calculating the ammonia limits. In the revised Tentative Orders, we now apply a greater dilution credit for cyanide, too, but the dilution factor is slightly less to reflect a mixing zone that is as small as practicable consistent with the SIP Section 1.4.2.2, and as required by antidegradation policies. The different approach for cyanide (versus ammonia) reflects the fact that cyanide has been regulated in permits for decades in this region. Our approach for cyanide is more stringent than our approach to ammonia to comply with antidegradation policies. Since the background documentation for the proposed cyanide site-specific objectives included an antidegradation analysis, which concluded that certain effluent limitations resulting from implementation of the site-specific objectives would not degrade water quality, the dilution credit now used in the revised Tentative Orders is the dilution credit that results in effluent limits no greater than those identified in the site-specific objectives documents for this Discharger. Moreover, consistent with the site-specific objective conclusion on antidegradation, to further ensure that water quality is not degraded, the Revised Tentative Order requires a cyanide action plan similar to that proposed with the site-specific objective.

We did not change the cyanide limits in the Sewerage Agency of Southern Marin permit, or the cyanide-related requirements of that respective Cease and Desist Order, because it did not provide a dilution study with its application for permit reissuance to justify greater dilution. Nevertheless, its Cease and Desist Order does not require significant expenditures of public funds related to cyanide during the early phases of its time schedule. Until 2011, the Cease and Desist Order requires improvements in sample handling and analysis, and a pollution prevention strategy that entails source identification and reduction. The requirements during this period are substantially similar to actions likely to be required to implement the cyanide site-specific objectives. We expect the cyanide site-specific objectives to be adopted before 2011, at which point the alternative cyanide limits specified in the permit will become effective. The Cease and Desist Order also contains an explicit exception to all cyanide-related requirements in the event that the alternative limits become effective.

- **Pesticides (aldrin, chlordane, 4,4-DDT, 4,4-DDE, dieldrin, heptachlor, and heptachlor epoxide)**—The dischargers’ data demonstrate reasonable potential for several legacy pesticides. Despite their arguments that the data were erroneous, the dischargers have provided no substantive evidence to conclude that their data misrepresent actual concentrations found in their discharge. In any case, the Cease and Desist Orders require improvements in sample handling and analysis, and implementation of a pollution prevention strategy that entails source identification and reduction. Because these pesticides have been banned for many years, we expect that sampling and analysis improvements may be sufficient to demonstrate compliance. If not, source identification and reduction will be very important. The revised Cease and Desist Orders explicitly state that actions related to capital improvements will not be required if the discharger can demonstrate that it is no longer out of compliance by 2011.
- **Dioxin**—The dischargers cite no evidence to support their assertion that the dioxins in San Francisco Bay fish are different (i.e., come from a different source) than the dioxins discharged by wastewater treatment plants. As explained in our response to BACWA Comment 2 (Comment 1 for SFIA), dioxins are controllable. The State Water Board, in its recent East Bay Municipal Utilities District remand order (Order WQ-2007-0004), did not address the Regional Water Board’s approach to final limits and compliance schedules for dioxin-TEQ. These Tentative Orders are consistent with the approach we have taken with recent permits.
- **Selenium**—The SMCSO Cease and Desist Order does not require significant expenditures of public funds related to selenium during the early phases of its time schedule. Until 2011, the Cease and Desist Order requires improvements in sample handling and analysis, and a pollution prevention strategy that entails source identification and reduction. We are proceeding with development of a selenium TMDL. Nevertheless, as discussed above under BACWA Comment 3, we cannot delay implementing the selenium limit solely to accommodate the time needed to complete the TMDL.

**BACWA Comment 7
(for SMCS D and SASM only)**

A pollution prevention program should not be required for this small permittee. SMCS D and SASM do not have Pollution Prevention programs because their flows are less than 5 mgd. The permits should not require regionally developed pollutant minimization programs. Significant pollution prevention activities are already required as part of the compliance schedules and Cease and Desist Orders.

Response: While the level of effort should be less for small dischargers compared to large ones, all municipal wastewater treatment plants should develop and implement pollution prevention programs. We are committed to working with dischargers in this effort and will temper our expectations based on each discharger's size and resources. Additionally, these requirements are not burdensome because they are all narrative and give each discharger wide discretion to identify the pollutants for which it will pursue a pollution prevention program, and the actions it will take for those pollutants. In fact, the only concrete requirement is for the submittal of an annual report. Moreover, with certain pollutants for which the discharger cannot immediately comply, like mercury, the Cease and Desist Order (and, for mercury, the proposed permit implementing the mercury TMDL) also require pollution prevention measures to reduce pollutant discharges. The advantage of having the pollution prevention requirements in the permit is that they provide a consistent structure and format for pollution prevention programs regionally.