

San Francisco Bay Regional Water Quality Control Board

**ORDER No. R2-2017-00XX
NPDES PERMIT No. CAG912002**

**GENERAL WASTE DISCHARGE REQUIREMENTS FOR
Discharge or Reclamation of Extracted and Treated Groundwater Resulting from the Cleanup of
Groundwater Polluted by Volatile Organic Compounds (VOCs), Fuel Leaks, Fuel Additives, and
Other Related Wastes (VOCs and Fuel General Permit)**

Table 1. Administrative Information

This Order was adopted by the California Regional Water Quality Control Board, San Francisco Bay Region (Regional Water Board), on:	
This Order shall become effective on:	January 1, 2018
This Order shall expire on:	December 31, 2022
CIWQS Place Number	790546
CIWQS Regulatory Measure Number	412210
The U.S. Environmental Protection Agency (U.S. EPA) and the Regional Water Board have classified the discharges under this general National Pollutant Discharge Elimination System (NPDES) permit (General Permit) as minor discharges based on the discharges' impact to receiving waters.	
To obtain coverage under this General Permit, prospective Dischargers must submit a Notice of Intent (NOI) form as shown in Attachment B and a filing fee equivalent to the first year's annual fee. If the NOI is complete, the Regional Water Board Executive Officer will issue an Authorization to Discharge. Dischargers enrolled under Order No. R2-2012-0012 that also submitted an NOI at the end of that order's term need not submit a new NOI form to enroll under this Order.	
Authorized Dischargers who wish to continue discharging after this Order's expiration date shall file a new completed NOI form no later than 270 days in advance of this Order's expiration date. Such discharges may become subject to a reissued order upon Executive Officer authorization.	

I, Bruce H. Wolfe, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of the Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on the date indicated above.

Bruce H. Wolfe, Executive Officer

Contents

I. Scope of General Permit.....3

II. Findings3

III. Discharge Prohibitions4

IV. Effluent Limitations and Discharge Specifications4

V. Receiving Water Limitations.....7

VI. Provisions8

 A. Standard Provisions8

 B. Monitoring and Reporting Provisions8

 C. Special Provisions8

 1. Reopener Provisions.....8

 2. Application for General Permit Coverage and Authorization to Discharge9

 4. Construction, Reliability, Operation, and Maintenance Specifications11

 5. No Preemption.....12

Tables

Table 1. Administrative Information 1

Table 2. Effluent Limitations 5

Attachments

Attachment A – Definitions A-1

Attachment B – Notice of Intent FormB-1

Attachment C – Notice of Termination Form.....C-1

Attachment D – Federal Standard Provisions..... D-1

Attachment E – Monitoring and Reporting Program (MRP).....E-1

Attachment F – Fact Sheet..... F-1

Attachment G – Minimum Levels G-1

I. SCOPE OF GENERAL PERMIT

These Waste Discharge Requirements (WDRs) shall serve as an NPDES General Permit for the discharge or reclamation of extracted and treated groundwater resulting from the cleanup of groundwater at active or closed sites, such as service stations or construction sites. These groundwater treatment facilities extract or treat groundwater polluted by VOCs, fuel leaks, fuel additives, or other related wastes (e.g., semi-volatile organic compounds [SVOCs], polycyclic aromatic hydrocarbons [PAHs], and metals).

This Order covers discharges from these facilities to any surface waters, such as creeks, streams, rivers (including flood control channels), lakes, or San Francisco Bay. Such discharges may occur directly to surface waters or through constructed storm drain systems.

This General Permit does not cover:

1. Discharges to sanitary sewer systems;
2. Sewage;
3. Discharges covered under an individual NPDES permit or WDRs;
4. Discharges that combine extracted groundwater with stormwater prior to treatment; or
5. Discharges to the Pacific Ocean.

The Fact Sheet (Attachment F) provides additional information describing covered discharges.

Dischargers typically use aeration or granular activated carbon (GAC) systems, or both, to treat their groundwater prior to discharge. Facilities that employ other types of treatment that effectively remove VOCs, fuel-related pollutants, or other related wastes may also be authorized pursuant to this Order subject to Executive Officer approval.

To obtain coverage under this Order, a Discharger must complete an NOI form (Attachment B) that, among other things, describes the treatment system installed at its facility.

II. FINDINGS

The Regional Water Board finds:

- A. Legal Authorities.** This Order serves as WDRs pursuant to California Water Code article 4, chapter 4, division 7 (commencing with § 13260). This Order is also issued pursuant to federal Clean Water Act (CWA) section 402 and implementing regulations adopted by U.S. EPA and Water Code chapter 5.5, division 7 (commencing with § 13370).
- B. Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information obtained through monitoring and reporting programs and other available information. The Fact Sheet contains background information and rationale for the requirements in this Order and is hereby incorporated into and constitutes findings for this Order. Attachments A through F and G are also incorporated into this Order.
- C. Provisions and Requirements Implementing State Law.** Some discharge prohibitions and provisions; and monitoring and reporting requirements of this Order implement State law only. They are not required under the federal CWA; consequently, violations of these provisions are subject to the enforcement remedies available under the Porter-Cologne Water Quality Control Act.

- D. Notification of Interested Parties.** The Regional Water Board notified prospective enrollees and interested agencies and persons of its intent to prescribe these WDRs and provided an opportunity to submit written comments and recommendations. The Fact Sheet provides details regarding the notification.
- E. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. The Fact Sheet provides details regarding the public hearing.

THEREFORE, IT IS HEREBY ORDERED that Order No. R2-2012-0012 (previous order) is rescinded upon the effective date of this Order, except for enforcement purposes, and in order to meet the provisions of Water Code division 7 (commencing with § 13000) and regulations adopted thereunder, and the provisions of the CWA and regulations and guidelines adopted thereunder, Dischargers authorized to discharge pursuant to this Order shall comply with the requirements in this Order. This action in no way prevents the Regional Water Board from taking enforcement action for past violations of the previous order.

III. DISCHARGE PROHIBITIONS

- A.** Discharge of waste at a location or in a manner different than that described in an NOI and Authorization to Discharge is prohibited.
- B.** Discharge of silt, sand, clay, or other earthen materials in quantities sufficient to cause deleterious bottom deposits, turbidity, or discoloration in surface waters, or to unreasonably affect or threaten to affect beneficial uses, is prohibited.
- C.** Discharge of floating debris, oil, grease, scum, or other floating materials is prohibited.
- D.** Discharges to a storm drain is prohibited if it causes scouring or erosion at the point where the storm drain discharges into the receiving water, or causes or contributes to scouring of banks, excessive sedimentation, or flooding of the storm drain system or receiving water downstream of the point of discharge.
- E.** Discharge of pollutants so as to create pollution, contamination, or nuisance as defined by Water Code section 13050 is prohibited.
- F.** Bypass or overflow of untreated or partially treated groundwater containing VOCs, fuel leaks, fuel additives, or other related wastes to waters of the State or United States from the treatment system, or any collection or transport system or pump station tributary to the treatment system, is prohibited, except as provided for in Attachment D section I.G.
- G.** Water reclamation consisting of recharge or reinjection is prohibited. Any reinjection or recharge must be performed in accordance with a cleanup order approved by the Regional Water Board, or another lead oversight agency.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

- A.** All discharges from each groundwater treatment facility, including discharges to outfalls defined in an NOI and Authorization to Discharge, shall comply with the following effluent limits.

Upon becoming aware of any effluent limitation violation, the Discharger shall contain the effluent in a holding tank or shut down the extraction and treatment system until the violation is corrected. The Discharger shall re-treat the contents of the holding tank to ensure that they comply with this Order. Alternatively, the contents can be discharged to a publicly owned treatment works (POTW). The Discharger shall obtain permission from the POTW for any temporary or permanent discharges to the sanitary sewer.

Table 2. Effluent Limitations

Pollutant	Discharge to Receiving Waters Used as Drinking Water ^[1]		Discharge to Other Receiving Waters	
	Monthly Average (µg/L)	Daily Maximum (µg/L)	Monthly Average (µg/L)	Daily Maximum (µg/L)
pH	Between 6.5 and 8.5 units at all times.			
Antimony, Total Recoverable	--	6.0	4,300	8,600
Arsenic, Total Recoverable	--	10.	30.	59
Cadmium, Total Recoverable	0.90	1.8	0.90	1.8
Chromium III	--	50.	170	340
Chromium VI	--	10.	8.1	16
Copper, Total Recoverable				
<i>Lower or South SF Bay Discharge</i>	10.	20.	10.	20.
<i>Central SF Bay Discharge</i>	5.4	11	5.4	11
<i>Suisun or San Pablo Bay Discharge</i>	7.1	14	7.1	14
<i>Other Discharge</i>	2.9	5.8	2.9	5.8
Lead, Total Recoverable	2.6	5.2	2.6	5.2
Mercury, Total Recoverable	0.050	0.10	0.050	0.10
Nickel, Total Recoverable				
<i>Lower or South SF Bay Discharge</i>	15	31	15	31
<i>Central SF Bay Discharge</i>	10.	21	10.	21
<i>Suisun or San Pablo Bay Discharge</i>	25	50.	25	50.
<i>Other Discharge</i>	6.8	14	6.8	14
Selenium, Total Recoverable	4.1	8.2	4.1	8.2
Silver, Total Recoverable	1.1	2.2	1.1	2.2
Thallium, Total Recoverable	--	2.0	6.3	13
Zinc, Total Recoverable	47	95	47	95
Benzene	--	0.50	--	0.50
Chloroform	--	1.9	--	1.9
1,1-Dichloroethane	--	0.50	--	0.50
1,2-Dichloroethane	0.38	0.50	--	0.50
1,1-Dichloroethylene	0.057	0.11	--	0.50
Ethylbenzene	--	0.50	--	0.50
Tetrachloroethylene	--	0.50	--	0.50
Toluene	--	0.50	--	0.50
Cis-1,2-Dichloroethylene	--	0.50	--	0.50
Trans-1,2-Dichloroethylene	--	0.50	--	0.50
1,4-Dioxane	1.0	2.0	--	--
1,1,1-Trichloroethane	--	0.50	--	0.50
1,1,2-Trichloroethane	--	0.50	--	0.50

Pollutant	Discharge to Receiving Waters Used as Drinking Water ^[1]		Discharge to Other Receiving Waters	
	Monthly Average (µg/L)	Daily Maximum (µg/L)	Monthly Average (µg/L)	Daily Maximum (µg/L)
Trichloroethylene	--	0.65	--	0.65
Vinyl Chloride	--	0.50	--	0.90
Benzo(a)Anthracene	0.0044	0.0088	0.049	0.098
Benzo(a)Pyrene	0.0044	0.0088	0.049	0.098
Benzo(b)Fluoranthene	0.0044	0.0088	0.049	0.098
Benzo(k)Fluoranthene	0.0044	0.0088	0.049	0.098
Chrysene	0.0044	0.0088	0.049	0.098
Dibenzo(a,h)Anthracene	0.0044	0.0088	0.049	0.098
Indeno(1,2,3-cd) Pyrene	0.0044	0.0088	0.049	0.098
Total Xylenes	--	0.50	--	0.50
Methyl Tertiary Butyl Ether	--	0.50	--	0.50
TPH as gasoline	--	50	--	50
TPH as diesel	--	50	--	50
TPH as motor oil	--	100	--	100
Sulfate	250,000	500,000	--	--
Manganese	50	100	--	--
Turbidity	5.0 NTU	10. NTU	--	--
Chlorine, Total Residual	--	0.0 ^[2]	--	0.0 ^[2]

Abbreviations:

µg/L = micrograms per liter

NTU = nephelometric turbidity unit

Footnotes:

- ^[1] Drinking water areas are defined as surface waters with existing or potential beneficial uses of "Municipal and Domestic Supply" or "Groundwater Recharge," or both. Groundwater recharge uses may include recharge areas to maintain salt balance or to halt salt water intrusion into fresh water aquifers.
- ^[2] This limit shall be applied as an instantaneous maximum. There shall be no detectable residual chlorine in the effluent (as explained in MRP section IX.B.5, a non-detect result using a detection level equal or less than 0.1 milligrams per liter [mg/L] will not be considered out of compliance). This limit applies to Dischargers that chlorinate their extracted groundwater.

B. Discharges shall comply with the following acute toxicity limitations, with compliance measured at Monitoring Location EFF-00n as described in the MRP:

1. A 3-sample median value of not less than 90 percent survival.
2. A single sample value of not less than 70 percent survival

These acute toxicity limitations are defined as follows:

- **3- sample median.** A bioassay test showing survival of less than 90 percent represents a violation of this effluent limit if one or more of the past two bioassay tests also show less than 90 percent survival.
- **Single sample.** A bioassay test showing survival of less than 70 percent represents a violation of this effluent limit.

V. RECEIVING WATER LIMITATIONS

A. Discharge shall not cause the following conditions to exist in receiving waters:

1. Floating material, including solids, liquids, foams, and scum, in concentrations that cause nuisance or adversely affect beneficial uses;
2. Alteration of suspended sediment in such a manner as to cause nuisance, or to adversely affect beneficial uses, or to cause detrimental increase in the concentrations of toxic pollutants in sediments or aquatic life;
3. Suspended material in concentrations that cause nuisance or adversely affect beneficial uses;
4. Bottom deposits or aquatic growths to the extent that such deposits or growths cause nuisance or adversely affect beneficial uses;
5. Alteration of temperature beyond present natural background levels;
6. Changes in turbidity that cause nuisance or adversely affect beneficial uses or increases from normal background light penetration or turbidity greater than 10 percent in areas where natural turbidity is greater than 50 nephelometric turbidity units;
7. Coloration that causes nuisance or adversely affects beneficial uses;
8. Visible, floating, suspended, or deposited oil or other products of petroleum origin; or
9. Toxic or other deleterious substances in concentrations or quantities that cause deleterious effects on wildlife, waterfowl, or other aquatic biota, or render any of these unfit for human consumption, either at levels created in the receiving waters or as a result of biological concentration.

B. Discharge shall not cause the following limits to be exceeded in receiving waters within one foot of the water surface:

1. Dissolved Oxygen

a. For San Francisco Bay and tidal waters, the following limitations shall apply:

Downstream of Carquinez Bridge: 5.0 mg/L, minimum

Upstream of Carquinez Bridge: 7.0 mg/L, minimum

b. For non-tidal waters, the following limitations shall apply:

Cold habitat waters: 7.0 mg/L, minimum

Warm habitat waters: 5.0 mg/L, minimum

The median dissolved oxygen concentration for any three consecutive calendar months shall not be less than 80 percent of the dissolved oxygen content at saturation. When natural factors cause concentrations less than those specified above, discharges shall not cause further reduction in ambient dissolved oxygen concentrations.

2. **Dissolved Sulfide.** Dissolved sulfide shall not exceed natural background levels (0.1 mg/L maximum).
 3. **pH.** The pH shall not be depressed below 6.5 nor raised above 8.5, nor cause to vary from normal ambient pH by more than 0.5 pH units.
 4. **Nutrients.** Waters shall not contain biostimulatory substances in concentrations that promote aquatic growths to the extent that such growths cause nuisance or adversely affect beneficial uses.
- C. Discharge shall not cause a violation of any water quality standard for receiving waters adopted by the Regional Water Board or State Water Resources Control Board (State Water Board) as required by the CWA and regulations adopted thereunder.

VI. PROVISIONS

A. Standard Provisions

The Discharger shall comply with the “Standard Provisions” in Attachment D.

B. Monitoring and Reporting Provisions

The Discharger shall comply with the MRP in Attachment E, and future revisions thereto, and applicable sampling and reporting requirements in Attachment E. The Executive Officer may specify additional monitoring requirements in individual Authorizations to Discharge.

C. Special Provisions

1. Reopener Provisions

The Regional Water Board may modify or reopen this Order prior to its expiration date in any of the following circumstances as allowed by law:

- a. If present or future investigations demonstrate that the discharges governed by this Order have or will have, or will cease to have, a reasonable potential to cause or contribute to adverse impacts on water quality or beneficial uses of the receiving waters.
- b. If new or revised water quality standards or total maximum daily loads (TMDLs) come into effect for San Francisco Bay or contiguous waters (whether statewide, regional, or site-specific). In such cases, effluent limitations in this Order may be modified as necessary to reflect the updated water quality standards or TMDL wasteload allocations. Adoption of the effluent limitations in this Order is not intended to restrict in any way future modifications based on legally-adopted water quality standards or TMDLs or as otherwise permitted under federal regulations governing NPDES permit modifications.
- c. If translator, dilution, or other water quality studies provide a basis for determining that a permit condition should be modified.
- d. If State Water Board-precedential decisions, new policies, new laws, or new regulations are adopted.

- e. If an administrative or judicial decision on a separate NPDES permit or WDRs addresses requirements similar to those applicable to these discharges.
- f. A Discharger may request a permit modification based on any of the circumstances above. With any such request, the Discharger shall include antidegradation and anti-backsliding analyses.
- g. Or as otherwise authorized by law.

2. Application for General Permit Coverage and Authorization to Discharge

- a. **Notice of Intent (NOI).** A prospective discharger seeking Authorization to Discharge pursuant to this Order shall complete and submit the NOI form in Attachment B. A prospective discharger seeking coverage for similar discharges at multiple sites may complete one NOI that describes all proposed discharges; however, it shall submit separate fees for each site. Dischargers enrolled under the previous order that also submitted an NOI at the end of the previous order term need not submit new NOI forms to continue their authorization to discharge. The Executive Officer may modify the NOI form in Attachment B or require additional information prior to authorizing any discharge.
- b. **Facility Modifications.** At least 30 days prior to any significant facility modification (e.g., change in flow rate, treatment system design, or outfall location), the Discharger proposing the modification shall submit a modified NOI form (e.g., a mark-up of the original NOI form showing all changes and including a new signature and date). The Discharger shall include a transmittal letter describing the changes, their purpose, when they are to go into effect, and any new or different measures taken or planned to prevent potential non-compliance with this Order's requirements.
- c. **NOI Review.** Upon receipt of a complete NOI application for a proposed discharge, the Executive Officer will review the application to determine whether the proposed Discharger is eligible to discharge under this Order. The application shall document the following:
 - i. The proposed discharge results from the cleanup of groundwater polluted by VOCs, fuel leaks, fuel additives, or other related wastes;
 - ii. The Discharger has satisfied the requirements of Regional Water Board Resolution No. 88-160 (*Regional Water Board Position on the Disposal of Extracted Groundwater from Groundwater Cleanup Projects*); and
 - iii. The proposed treatment system and associated operation, maintenance, and monitoring plans are capable of ensuring that the discharge will meet the prohibitions, effluent limitations, receiving water limitations, and provisions of this Order.
- d. **Authorization to Discharge.** If the Executive Officer concludes that a proposed discharge is eligible for coverage under this Order, the Executive Officer will issue an Authorization to Discharge. Upon the effective date of the Authorization to Discharge, the Discharger shall comply with the requirements of this Order and its attachments. Any non-compliance with this Order's requirements shall constitute a violation of the CWA

- and Water Code and may be grounds for enforcement; termination, revocation and reissuance, or modification of the Authorization to Discharge; issuance of an individual permit; or denial of an application for reissuance.
- e. Application to Extend Coverage.** A Discharger that intends to continue discharging after the expiration date stated on the first page of this Order shall file a new NOI form by April 2, 2022.
 - f. Discharge Termination.** A Discharger may terminate its coverage under this Order by submitting a complete and signed Notice of Termination form (Attachment C) and stating the reason for termination. The Executive Officer may also terminate or revoke coverage under this Order for any of the causes specified for an individual permit as set forth in 40 C.F.R. section 122.28(b)(3). After providing notice and an opportunity for a hearing, coverage under this Order may be terminated or modified for cause, including, but not limited to, the following:
 - i.** Violation of any term or condition of this Order,
 - ii.** Misrepresentation or failure to disclose all relevant facts in obtaining coverage under this Order, or
 - iii.** Change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
 - g. Need for Individual NPDES Permit.** The Executive Officer may require any Discharger authorized to discharge pursuant to this Order to subsequently apply for and obtain an individual NPDES permit in the following circumstances:
 - i.** The Discharger is not in compliance with the Order's requirements,
 - ii.** A change has occurred in the availability of demonstrated technology or practices for the control or abatement of pollutants from the facility,
 - iii.** Effluent limitation guidelines are promulgated for a discharge covered by this Order,
 - iv.** A new or revised water quality control plan containing requirements applicable to a discharge is approved,
 - v.** The requirements of 40 C.F.R. section 122.28(a) (the circumstances under which the Regional Water Board is authorized to issue a general permit) are not met, or
 - vi.** Any other condition specified in 40 C.F.R. section 122.28(b)(3) is met.

3. Water Reclamation Specifications (Water Reclamation only)

- a. Reclamation Activities.** Water reclamation activities shall be described in the Discharger's NOI, including the method of any additional treatment and location and type of water reclamation.

- b. Public Health.** Adequate measures shall be taken to minimize public contact with reclaimed groundwater and to prevent the breeding of flies, mosquitos, and other vectors of public health significance during or after the reclamation process.
- c. Public Awareness.** Public warnings shall be posted to advise the public that the reclaimed water is not suitable for drinking. Signs shall be posted in the area, and all reclamation water valves and outlets shall be visibly labeled.
- d. Cross-connections.** There shall be no cross-connection between the potable water supply and piping containing treated groundwater intended for reclamation.

4. Construction, Reliability, Operation, and Maintenance Specifications

a. Wastewater Facilities Review and Evaluation, and Status Reports

- i.** Dischargers shall retain a professional engineer licensed to practice in the State of California to oversee the design, reliability, operation and maintenance, and monitoring of the treatment system to ensure compliance with this Order.
- ii.** The Discharger shall operate and maintain wastewater treatment facilities in a manner to ensure that all facilities are adequately staffed, supervised, financed, operated, maintained, repaired, and upgraded as necessary to provide adequate and reliable treatment and disposal of all wastewater.
- iii.** The Discharger shall regularly review and evaluate its wastewater facilities and operational practices in accordance with the paragraph above. The Discharger shall conduct these reviews and evaluations as an ongoing component of the administration of its wastewater facilities.
- iv.** The Discharger shall provide the Executive Officer, upon request, a report describing the current status of its wastewater facilities and operational practices, including any recommended or planned actions and a time schedule for these actions.
- v.** The Discharger shall provide a status report in each annual self-monitoring report. The status report shall describe the review and evaluation procedures, results of the review and evaluation, and any capital improvement projects.

b. Operations and Maintenance Manual Review and Status Reports

- i.** The Discharger shall maintain Operation and Maintenance Manuals for its wastewater facilities in usable condition and make them available for reference and use by all relevant personnel and Regional Water Board staff.
- ii.** The Discharger shall regularly review, and revise or update as necessary, its Operation and Maintenance Manuals so they remain useful and relevant to current equipment, operational practices, instrument calibration procedures and schedules, and sampling and analysis procedures. The Discharger shall review its Operation and Maintenance Manuals at least annually. The Discharger shall revise its Operation and

Maintenance Manuals within 90 days of any significant change in treatment facility equipment, operational practices, or sampling and analysis procedures.

- iii. The Discharger shall provide the Executive Officer, upon request, a report describing the current status of its Operation and Maintenance Manuals, including any recommended or planned actions and a time schedule for these actions.
- iv. The Discharger shall describe its review and evaluation procedures, and applicable changes to its Operation and Maintenance Manuals, in each annual self-monitoring report.

5. No Preemption

This Order does not preempt or supersede the authority of municipalities, flood control agencies, or other agencies to prohibit, restrict, or control discharges to storm drain systems or other watercourses subject to their jurisdiction.

ATTACHMENT A – DEFINITIONS

Arithmetic Mean (μ)

Also called the average, the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = \mu = \Sigma x / n \quad \text{where: } \Sigma x \text{ is the sum of the measured ambient water concentrations, and } n \text{ is the number of samples.}$$

Average Monthly Effluent Limitation (AMEL)

The highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Bioaccumulative

Taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic

Known to cause cancer in living organisms.

Coefficient of Variation (CV)

Measure of data variability calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge

Either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit) for a constituent with limitations expressed in units of mass; or (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration). The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day. For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period is considered the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ)

Sample result less than the RL, but greater than or equal to the laboratory's MDL. Sample results reported as DNQ are estimated concentrations.

Dilution Credit

Amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined by conducting a mixing zone study or modeling the discharge and receiving water.

Enclosed Bay

Indentation along the coast that encloses an area of oceanic water within a distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Estimated Chemical Concentration

Concentration that results from the confirmed detection of the substance below the ML value by the analytical method.

Estuaries

Waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars are considered estuaries. Estuarine waters are considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters include, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inland Surface Waters

All surface waters of the state that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation

Highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation

Lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL)

Highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median

Middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of

measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between n/2 and n/2+1).

Method Detection Limit (MDL)

Minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in 40 C.F.R. part 136, Attachment B, revised as of July 3, 1999.

Minimum Level (ML)

Concentration at which the entire analytical system gives a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone

Limited volume of receiving water allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

Not Detected (ND)

Sample results less than the laboratory's MDL.

Persistent Pollutants

Substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollution Prevention

Any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State Water Board or Regional Water Board.

Reporting Level (RL)

The RL is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order, including an additional factor if applicable as discussed herein. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from SIP Appendix 4 in accordance with SIP section 2.4.2 or established in accordance with SIP section 2.4.3. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Source of Drinking Water

Any water designated as having a municipal or domestic supply (MUN) beneficial use.

Standard Deviation (σ)

Measure of variability calculated as follows:

$$\sigma = (\sum[(x - \mu)^2]/(n - 1))^{0.5}$$

where:

x is the observed value;

μ is the arithmetic mean of the observed values; and

n is the number of samples.

ATTACHMENT B – NOTICE OF INTENT FORM

NOTICE OF INTENT must be completed and submitted to apply for Authorization or Reauthorization with NPDES Permit No. CAG912002 (VOC and Fuel General Permit), to discharge or reclaim extracted and treated groundwater resulting from the cleanup of groundwater at active or closed sites, such as service stations or construction sites, to waters of the United States. These facilities are in operation to treat groundwater polluted by volatile organic compounds (VOCs), fuel leaks, fuel additives, and other related wastes (e.g., semi-volatile organic compounds [SVOCs], polycyclic aromatic hydrocarbons [PAHs], and metals).

This Notice of Intent form is for the Groundwater Treatment Facility located at (provide street address):

I. CERTIFICATION

This certification shall be signed in accordance with Attachment D section V.B.2. The Discharger hereby agrees to comply with and be responsible for all the conditions specified in NPDES Permit No. CAG912002.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	
Signature	Date
Printed Name	
Title	
Company / Organization	Land Owner Type (Check One) <input type="checkbox"/> Public <input type="checkbox"/> Private <input type="checkbox"/> Other, specify the type:
Address	
Email	Phone No.

II. APPLICATION FEE AND MAILING INSTRUCTIONS

Submit a check payable to “State Water Resources Control Board” for the appropriate application fee to the following address:

San Francisco Bay Regional Water Quality Control Board
 Attn: NPDES Wastewater Division
 1515 Clay Street, Suite 1400
 Oakland, CA 94612

Submit this form (with signature and attachments) via email to R2NPDES.GeneralPermits@waterboards.ca.gov, or as otherwise indicated at www.waterboards.ca.gov/sanfranciscobay/water_issues/programs/general_permits.shtml. If the form cannot be submitted electronically, submit a hard copy to the address above.

III. DISCHARGE TYPE

Select one: <input type="checkbox"/> This is a new discharge <input type="checkbox"/> This discharge is currently authorized under this Order (VOC and Fuel General Permit) and this NOI is submitted for modification of the current Authorization to Discharge. CIWQS Place ID: _____ <input type="checkbox"/> This discharge is currently authorized under this Order (VOC and Fuel General Permit), which requires authorized dischargers who need to continue discharging after December 31, 2022 to file a completed NOI no later than 270 days prior to the expiration date of this Order. CIWQS Place ID: _____
--

IV. PROJECT INFORMATION

Type of Site or Project: (e.g., closed service station or groundwater cleanup site, short-term construction dewatering project, closed groundwater cleanup site, etc.)
Project Tentative Completion Date:

V. UTILITY INFORMATION

I have contacted the local sanitary sewer agency serving the above named address and determined that discharging to the local sanitary sewer system is not technically and economically feasible. Please check one (if No or Not Applicable, please explain) <input type="checkbox"/> Yes <input type="checkbox"/> No: <input type="checkbox"/> Not Applicable:	
Contact Person's Name and Title	
Contact Person's Email	Contact Person's Phone No.
I have contacted the local agencies having jurisdiction over the use of the storm drain system or watercourse and informed them about this proposed discharge. Please check one (if No or Not Applicable, please explain) <input type="checkbox"/> Yes <input type="checkbox"/> No: <input type="checkbox"/> Not Applicable:	
Contact Person's Name and Title	
Contact Person's Email	Contact Person's Phone No.

VI. FACILITY INFORMATION

A. Facility Name:			
Street Address			
City	State	Zip Code	Phone No.
Contact Person's Name and Title			
Contact Person's Email		Contact Person's Phone No.	
B. Duly Authorized Representative: The following individual (or any individual occupying the position listed below) may act as the facility's duly authorized representative, and may sign and certify submittals in accordance with Attachment D section V.B.3. The individual shall be responsible for the overall operation of the facility or for facility environmental matters. IMPORTANT: See section XI.F.2 below for further instructions.			
Name			
Title			
Company/Organization			
Street Address			
City	State	Zip Code	Phone No.
Email			
C. Billing Information			
Name			
Street Address			
City	State	Zip Code	Phone No.
Email			
D. Design Professional Engineer's Information (see Section XI.F.4 for further instructions)			
Name		California License Number Expiration Date	
Street Address			
City	State	Zip Code	Phone No.
Email			
E. Operation and Maintenance Professional Engineer's Information (see Section XI.F.5 for further instructions)			
Name		California License Number Expiration Date	
Street Address			
City	State	Zip Code	Phone No.
Email			

VII. DISCHARGE LOCATION INFORMATION

<p>Discharge path to Receiving Water - describe the complete path of the discharge from the exit point of the treatment system to the outfall in the receiving water – list streets, land features, and distances as necessary.</p>			
Discharge Points	Latitude¹	Longitude¹	Receiving Water Name
Effluent Monitoring Point (EFF-001 through EFF- <i>n</i>)			Not Applicable
Storm Drain (if applicable)			Not Applicable
Receiving Water (directly or via storm drain system)			
Upstream Receiving Water Monitoring Location (RSW-001U through RSW- <i>n</i> U)	Is access unrestricted? <input type="checkbox"/> Yes <input type="checkbox"/> No If No, provide details:		At a point 50 feet upstream from the point of discharge into the receiving water, or if access is limited, at the first point upstream which is accessible.
Downstream Receiving Water Monitoring Location (RSW-001D through RSW- <i>n</i> D)	Is access unrestricted? <input type="checkbox"/> Yes <input type="checkbox"/> No If No, provide details:		At a point 50 feet downstream from the point of discharge into the receiving water, or if access is limited, at the first point downstream which is accessible.

1. Submit latitude and longitude coordinates in decimal degrees with 5 significant figures to the right of the decimal point.
 Check here if information for additional outfalls is attached to this form.

VIII. TREATMENT SYSTEM INFORMATION

A. General Information	
Groundwater Treatment Design Capacity (gpm) as certified by a Professional Engineer licensed to practice in California.	
Discharge description (describe discharge and potential pollutants of concern. Attach additional sheets if needed):	
Discharge Frequency: <input type="checkbox"/> Continuous <input type="checkbox"/> Daily <input type="checkbox"/> Intermittent <input type="checkbox"/> Emergency (explain):	
Estimated Total Water Reclaimed (%): Provide reasons if reclamation is not technically and economically feasible:	Type of Reclamation (e.g., dust control, etc.):

B. Unit Information		
Type	Number	Description (e.g., depth, size, capacity, dosage, etc.)
Extraction well(s) or sump pump(s)		
Extraction well(s) with dedicated treatment unit(s)		
Settling tank(s) in series		
Settling tank(s) in parallel		
Oil-water separator(s)		
Filter(s) for particulates in groundwater		
Air stripper(s) with air filtration ¹		
Air stripper(s) without air filtration ¹		
Other treatment units (e.g., oxidation systems, ion exchange, reverse osmosis)		
Granular activated carbon (GAC) vessel(s) in series		
Granular activated carbon (GAC) vessel(s) in parallel		
Chemical additive(s) (e.g., coagulants)		
Other tank(s) (e.g., equalization tank)		
Water reclamation tank(s)		

1. Attach applicable copy of approved BAAQMD permit to this form.

IX. DISCHARGE WATER QUALITY

For existing dischargers, summarize influent, discharge and receiving water monitoring data collected during the past five years. Provide a separate data summary table for each discharge point (outfall) and receiving water. New dischargers may estimate future concentrations.

A. INFLUENT DISCHARGE DATA**Conventional and Non-Conventional Pollutants**

Parameter	Units	Average Monthly Effluent Limitation	Maximum Daily Effluent Limitation	Maximum Concentration	Range	Method Detection Limit	Test Method	Number of Samples
pH	s.u.							
Turbidity	NTU							
Total Dissolved Solids (for construction and dewatering projects)	mg/L							
Dissolved Oxygen	mg/L							
Chloride	mg/L							
Chlorine Residual	mg/L							
1,4-Dioxane	µg/L							
Ethylene Dibromide	µg/L							
Trichloro-trifluoroethane	µg/L							

Priority Pollutants

CTR No.	Parameter	Units	Average Monthly Effluent Limitation	Maximum Daily Effluent Limitation	Maximum Concentration	Range	Method Detection Limit	Test Method	Number of Samples
1	Antimony	µg/L							
2	Arsenic	µg/L							
3	Beryllium	µg/L							
4	Cadmium	µg/L							
5a	Chromium (III)	µg/L							
5b	Chromium (VI)	µg/L							
6	Copper	µg/L							
7	Lead	µg/L							
8	Mercury	µg/L							
9	Nickel	µg/L							
10	Selenium	µg/L							
11	Silver	µg/L							
12	Thallium	µg/L							
13	Zinc	µg/L							
14	Cyanide	µg/L							
15	Asbestos	fibers/L							
16	2,3,7,8-TCDD (Dioxin)	µg/L							
17	Acrolein	µg/L							
18	Acrylonitrile	µg/L							
19	Benzene	µg/L							
20	Bromoform	µg/L							
21	Carbon Tetrachloride	µg/L							
22	Chlorobenzene	µg/L							
23	Chlorodibromomethane	µg/L							
24	Chloroethane	µg/L							
25	2-Chloroethylvinyl ether	µg/L							
26	Chloroform	µg/L							
27	Dichlorobromomethane	µg/L							
28	1,1-Dichloroethane	µg/L							

CTR No.	Parameter	Units	Average Monthly Effluent Limitation	Maximum Daily Effluent Limitation	Maximum Concentration	Range	Method Detection Limit	Test Method	Number of Samples
29	1,2-Dichloroethane	µg/L							
30	1,1-Dichloroethylene	µg/L							
31	1,2-Dichloropropane	µg/L							
32	1,3-Dichloropropylene	µg/L							
33	Ethylbenzene	µg/L							
34	Methyl Bromide	µg/L							
35	Methyl Chloride	µg/L							
36	Methylene Chloride	µg/L							
37	1,1,2,2-Tetrachloroethane	µg/L							
38	Tetrachloroethylene	µg/L							
39	Toluene	µg/L							
40	1,2-Trans-Dichloroethylene	µg/L							
41	1,1,1-Trichloroethane	µg/L							
42	1,1,2-Trichloroethane	µg/L							
43	Trichloroethylene	µg/L							
44	Vinyl Chloride	µg/L							
45	2-Chlorophenol	µg/L							
46	2,4-Dichlorophenol	µg/L							
47	2,4-Dimethylphenol	µg/L							
48	2-Methyl- 4,6-Dinitrophenol	µg/L							
49	2,4-Dinitrophenol	µg/L							
50	2-Nitrophenol	µg/L							
51	4-Nitrophenol	µg/L							
52	3-Methyl 4-Chlorophenol	µg/L							
53	Pentachlorophenol	µg/L							
54	Phenol	µg/L							
55	2,4,6-Trichlorophenol	µg/L							
56	Acenaphthene	µg/L							
57	Acenaphthylene	µg/L							
58	Anthracene	µg/L							
59	Benzidine	µg/L							
60	Benzo(a)Anthracene	µg/L							
61	Benzo(a)Pyrene	µg/L							
62	Benzo(b)Fluoranthene	µg/L							
63	Benzo(ghi)Perylene	µg/L							
64	Benzo(k)Fluoranthene	µg/L							
65	Bis(2-Chloroethoxy)Methane	µg/L							
66	Bis(2-Chloroethyl)Ether	µg/L							
67	Bis(2-Chloroisopropyl)Ether	µg/L							
68	Bis(2-Ethylhexyl)Phthalate	µg/L							
69	4-Bromophenyl Phenyl Ether	µg/L							
70	Butylbenzyl Phthalate	µg/L							
71	2-Chloronaphthalene	µg/L							
72	4-Chlorophenyl Phenyl Ether	µg/L							
73	Chrysene	µg/L							
74	Dibenzo(a,h)Anthracene	µg/L							
75	1,2-Dichlorobenzene	µg/L							
76	1,3-Dichlorobenzene	µg/L							
77	1,4-Dichlorobenzene	µg/L							
78	3,3 Dichlorobenzidine	µg/L							
79	Diethyl Phthalate	µg/L							
80	Dimethyl Phthalate	µg/L							
81	Di-n-Butyl Phthalate	µg/L							
82	2,4-Dinitrotoluene	µg/L							
83	2,6-Dinitrotoluene	µg/L							
84	Di-n-Octyl Phthalate	µg/L							
85	1,2-Diphenylhydrazine	µg/L							
86	Fluoranthene	µg/L							

CTR No.	Parameter	Units	Average Monthly Effluent Limitation	Maximum Daily Effluent Limitation	Maximum Concentration	Range	Method Detection Limit	Test Method	Number of Samples
87	Fluorene	µg/L							
88	Hexachlorobenzene	µg/L							
89	Hexachlorobutadiene	µg/L							
90	Hexachlorocyclopentadiene	µg/L							
91	Hexachloroethane	µg/L							
92	Indeno(1,2,3-cd)Pyrene	µg/L							
93	Isophorone	µg/L							
94	Naphthalene	µg/L							
95	Nitrobenzene	µg/L							
96	N-Nitrosodimethylamine	µg/L							
97	N-Nitrosodi-n-Propylamine	µg/L							
98	N-Nitrosodiphenylamine	µg/L							
99	Phenanthrene	µg/L							
100	Pyrene	µg/L							
101	1,2,4-Trichlorobenzene	µg/L							
102	Aldrin	µg/L							
103	alpha-BHC	µg/L							
104	beta-BHC	µg/L							
105	gamma-BHC	µg/L							
106	delta-BHC	µg/L							
107	Chlordane (303d listed)	µg/L							
108	4,4'-DDT (303d listed)	µg/L							
109	4,4'-DDE	µg/L							
110	4,4'-DDD	µg/L							
111	Dieldrin (303d listed)	µg/L							
112	alpha-Endosulfan	µg/L							
113	beta-Endosulfan	µg/L							
114	Endosulfan Sulfate	µg/L							
115	Endrin	µg/L							
116	Endrin Aldehyde	µg/L							
117	Heptachlor	µg/L							
118	Heptachlor Epoxide	µg/L							
119-125	PCBs sum (303d listed)	µg/L							
126	Toxaphene	µg/L							

Other Pollutants

Parameter	Units	Average Monthly Effluent Limitation	Maximum Daily Effluent Limitation	Maximum Concentration	Range	Method Detection Limit	Test Method	Number of Samples
TPH as gasoline	µg/L							
TPH as diesel	µg/L							
TPHs (other than gasoline and diesel)	µg/L							
Sulfate	mg/L							
Foaming Agents	µg/L							
Electric conductivity	mmhos/cm							
Aluminum	mg/L							
Barium	mg/L							
Iron	mg/L							
Manganese	µg/L							
Nitrate (as N)	mg/L							
Nitrate + Nitrite	mg/L as N							
Nitrite	mg/L as N							

B. EFFLUENT DISCHARGE DATA (for existing dischargers only)

Discharge Point No. _____ – Conventional and Non-Conventional Pollutants

Parameter	Units	Average Monthly Effluent Limitation	Maximum Daily Effluent Limitation	Maximum Concentration	Range	Method Detection Limit	Test Method	Number of Samples
pH	s.u.							
Turbidity	NTU							
Total Suspended Solids	mg/L							
Total Dissolved Solids (for construction and dewatering projects)	mg/L							
Dissolved Oxygen	mg/L							
Chloride	mg/L							
Chlorine Residual	mg/L							
Acute Toxicity	% survival							
1,4-Dioxane	µg/L							
Ethylene Dibromide	µg/L							
Trichloro-trifluoroethane	µg/L							

Discharge Point No. _____ – Priority Pollutants

CTR No.	Parameter	Units	Average Monthly Effluent Limitation	Maximum Daily Effluent Limitation	Maximum Concentration	Range	Method Detection Limit	Test Method	Number of Samples
1	Antimony	µg/L							
2	Arsenic	µg/L							
3	Beryllium	µg/L							
4	Cadmium	µg/L							
5a	Chromium (III)	µg/L							
5b	Chromium (VI)	µg/L							
6	Copper	µg/L							
7	Lead	µg/L							
8	Mercury	µg/L							
9	Nickel	µg/L							
10	Selenium	µg/L							
11	Silver	µg/L							
12	Thallium	µg/L							
13	Zinc	µg/L							
14	Cyanide	µg/L							
15	Asbestos	fibers/L							
16	2,3,7,8-TCDD (Dioxin)	µg/L							
17	Acrolein	µg/L							
18	Acrylonitrile	µg/L							
19	Benzene	µg/L							
20	Bromoform	µg/L							
21	Carbon Tetrachloride	µg/L							
22	Chlorobenzene	µg/L							
23	Chlorodibromomethane	µg/L							
24	Chloroethane	µg/L							
25	2-Chloroethylvinyl ether	µg/L							
26	Chloroform	µg/L							
27	Dichlorobromomethane	µg/L							
28	1,1-Dichloroethane	µg/L							
29	1,2-Dichloroethane	µg/L							
30	1,1-Dichloroethylene	µg/L							
31	1,2-Dichloropropane	µg/L							
32	1,3-Dichloropropylene	µg/L							
33	Ethylbenzene	µg/L							
34	Methyl Bromide	µg/L							
35	Methyl Chloride	µg/L							

CTR No.	Parameter	Units	Average Monthly Effluent Limitation	Maximum Daily Effluent Limitation	Maximum Concentration	Range	Method Detection Limit	Test Method	Number of Samples
36	Methylene Chloride	µg/L							
37	1,1,2,2-Tetrachloroethane	µg/L							
38	Tetrachloroethylene	µg/L							
39	Toluene	µg/L							
40	1,2-Trans-Dichloroethylene	µg/L							
41	1,1,1-Trichloroethane	µg/L							
42	1,1,2-Trichloroethane	µg/L							
43	Trichloroethylene	µg/L							
44	Vinyl Chloride	µg/L							
45	2-Chlorophenol	µg/L							
46	2,4-Dichlorophenol	µg/L							
47	2,4-Dimethylphenol	µg/L							
48	2-Methyl- 4,6-Dinitrophenol	µg/L							
49	2,4-Dinitrophenol	µg/L							
50	2-Nitrophenol	µg/L							
51	4-Nitrophenol	µg/L							
52	3-Methyl 4-Chlorophenol	µg/L							
53	Pentachlorophenol	µg/L							
54	Phenol	µg/L							
55	2,4,6-Trichlorophenol	µg/L							
56	Acenaphthene	µg/L							
57	Acenaphthylene	µg/L							
58	Anthracene	µg/L							
59	Benzidine	µg/L							
60	Benzo(a)Anthracene	µg/L							
61	Benzo(a)Pyrene	µg/L							
62	Benzo(b)Fluoranthene	µg/L							
63	Benzo(ghi)Perylene	µg/L							
64	Benzo(k)Fluoranthene	µg/L							
65	Bis(2-Chloroethoxy)Methane	µg/L							
66	Bis(2-Chloroethyl)Ether	µg/L							
67	Bis(2-Chloroisopropyl)Ether	µg/L							
68	Bis(2-Ethylhexyl)Phthalate	µg/L							
69	4-Bromophenyl Phenyl Ether	µg/L							
70	Butylbenzyl Phthalate	µg/L							
71	2-Chloronaphthalene	µg/L							
72	4-Chlorophenyl Phenyl Ether	µg/L							
73	Chrysene	µg/L							
74	Dibenzo(a,h)Anthracene	µg/L							
75	1,2-Dichlorobenzene	µg/L							
76	1,3-Dichlorobenzene	µg/L							
77	1,4-Dichlorobenzene	µg/L							
78	3,3 Dichlorobenzidine	µg/L							
79	Diethyl Phthalate	µg/L							
80	Dimethyl Phthalate	µg/L							
81	Di-n-Butyl Phthalate	µg/L							
82	2,4-Dinitrotoluene	µg/L							
83	2,6-Dinitrotoluene	µg/L							
84	Di-n-Octyl Phthalate	µg/L							
85	1,2-Diphenylhydrazine	µg/L							
86	Fluoranthene	µg/L							
87	Fluorene	µg/L							
88	Hexachlorobenzene	µg/L							
89	Hexachlorobutadiene	µg/L							
90	Hexachlorocyclopentadiene	µg/L							
91	Hexachloroethane	µg/L							
92	Indeno(1,2,3-cd)Pyrene	µg/L							
93	Isophorone	µg/L							
94	Naphthalene	µg/L							
95	Nitrobenzene	µg/L							

CTR No.	Parameter	Units	Average Monthly Effluent Limitation	Maximum Daily Effluent Limitation	Maximum Concentration	Range	Method Detection Limit	Test Method	Number of Samples
96	N-Nitrosodimethylamine	µg/L							
97	N-Nitrosodi-n-Propylamine	µg/L							
98	N-Nitrosodiphenylamine	µg/L							
99	Phenanthrene	µg/L							
100	Pyrene	µg/L							
101	1,2,4-Trichlorobenzene	µg/L							
102	Aldrin	µg/L							
103	alpha-BHC	µg/L							
104	beta-BHC	µg/L							
105	gamma-BHC	µg/L							
106	delta-BHC	µg/L							
107	Chlordane (303d listed)	µg/L							
108	4,4'-DDT (303d listed)	µg/L							
109	4,4'-DDE	µg/L							
110	4,4'-DDD	µg/L							
111	Dieldrin (303d listed)	µg/L							
112	alpha-Endosulfan	µg/L							
113	beta-Endosulfan	µg/L							
114	Endosulfan Sulfate	µg/L							
115	Endrin	µg/L							
116	Endrin Aldehyde	µg/L							
117	Heptachlor	µg/L							
118	Heptachlor Epoxide	µg/L							
119-125	PCBs sum (303d listed)	µg/L							
126	Toxaphene	µg/L							

Discharge Point No. _____ – Other Pollutants

Parameter	Units	Average Monthly Effluent Limitation	Maximum Daily Effluent Limitation	Maximum Concentration	Range	Method Detection Limit	Test Method	Number of Samples
TPH as gasoline	µg/L							
TPH as diesel	µg/L							
TPHs (other than gasoline and diesel)	µg/L							
Sulfate	mg/L							
Foaming Agents	µg/L							
Electric conductivity	mmhos/cm							
Aluminum	mg/L							
Barium	mg/L							
Iron	mg/L							
Manganese	µg/L							
Nitrate (as N)	mg/L							
Nitrate + Nitrite	mg/L as N							
Nitrite	mg/L as N							

X. ENGINEERING CERTIFICATION REPORT

Attach the engineering certification report signed and stamped by the Design Professional Engineer licensed to practice in California and as identified in section VI.D. The Engineering Certification Report shall include a location map, discharge flow path map, process flow diagram, unit spec sheets, and a description of operation and maintenance procedures. Please see the next section, for further details of the documents *required* as part of the Engineering Certification Report and NOI application package.

XI. INSTRUCTIONS FOR NOTICE OF INTENT FORM

These instructions explain how to complete the NOI. Submittal of an NOI indicates a Discharger's commitment to comply with the terms of this Order.

A. Certification

The person certifying the NOI form must meet the requirements described in Attachment D section V.B.2. *Review these requirements carefully.* Specific requirements apply to corporations, partnerships, sole proprietorships, and public agencies.

B. Application Fee and Mailing Instructions

The NOI is incomplete without the applicable permit fee. Submit the fee by sending a check payable to "State Water Resources Control Board" to the Regional Water Board address indicated on the NOI form. A separate fee is required for each effluent discharge point (e.g., EFF-001). At the time of permit reissuance, the application fee was **\$11,877**. The State Water Resources Control Board may modify the fee at any time. For the current fee, see http://www.waterboards.ca.gov/resources/fees/water_quality/#npdes).

Submit this form (with signatures and attachments) [via email to R2NPDES.GeneralPermits@waterboards.ca.gov](mailto:R2NPDES.GeneralPermits@waterboards.ca.gov), or as otherwise indicated at www.waterboards.ca.gov/sanfranciscobay/water_issues/programs/general_permits.shtml.

C. Discharge Type

Select one of the three options to: (1) obtain coverage under this Order as a new discharger, (2) modify the NOI as an existing discharger, or (3) renew permit coverage. Please note that the discharger shall file with the Executive Officer an amended NOI at least 30 days before making any material change in the character, location, or volume of the discharge. Requests to renew permit coverage shall be submitted at least 270 days prior to the expiration date of this Order or no later than April 5, 2022.

D. Project Information

Provide a brief description of the project and activities to be covered by this Order, including its completion date, if any.

E. Utility Information

Provide information of the local utility agencies that were contacted for the proposed discharge. Please note that Resolution NO. 88-160, adopted by the Regional Water Board on October 19, 1988, urges dischargers of extracted groundwater to reclaim their effluent and that when reclamation is not technically and/or economically feasible, to discharge to a POTW.

F. Facility Information

- 1. Facility name.** Provide the name of the treatment facility, street address or a description of the facility location, and information of the contact person for the facility.
- 2. Duly Authorized Representative.** The person described in Attachment D section V.B.2 and signing the certification in section I of the NOI form may designate a duly authorized representative to sign permit-related submittals in accordance with Attachment D section V.B.3. Alternatively, a duly authorized representative may be designated through separate correspondence, particularly if the NOI form language does not sufficiently limit the delegated authority. For applicants, please note that if a duly authorized representative is designated, a written authorization shall be submitted to the Regional Water Board along with the NOI. If any changes occur to the authorization, a new authorization satisfying the requirements under Attachment D section V.B.3 must be submitted to the Regional Water Board prior to or together with any reports, information, or applications signed by a duly authorized representative.
- 3. Billing information.** Indicate to whom the annual permit fee should be billed.
- 4. Design Professional Engineer's Information.** Provide the name and contact information of the professional engineer licensed to practice in California who designed the groundwater treatment system and certified the Engineering Certification Report. The Design Professional Engineer is also responsible for certifying any proposed changes to the groundwater treatment system.
- 5. Operation and Maintenance Professional Engineer's Information.** Provide the name and contact information of the professional engineer licensed to practice in California who is responsible for the operations and maintenance procedures of the treatment facility and certification of its Operations and Maintenance Manual.

G. Discharge Location Information

Provide a brief description of the discharge flow path from the exit point of the treatment system to the outfall(s) in the receiving water(s). Identify all points where the facility discharges wastewater to surface waters or storm drains, and provide latitudes and longitudes (using decimal degrees with at least five decimal places). Identify the receiving waters to which discharges flow into (permitted discharges may flow through storm drains if authorized by storm drain system owners) and confirm if access to the receiving water(s) are unrestricted. Attach additional pages as necessary.

H. Treatment System Information


- 1. General information.** Provide the groundwater treatment design capacity as certified by the Design Professional Engineer licensed to practice in California and as identified in section VI.D. Additionally, provide a narrative description of potential pollutants in the discharge. Finally, specify the frequency of discharge and estimated percentage of total effluent reclaimed for any applicable activities such as dust suppression, soil compaction, irrigation of landscape or agriculture, and industrial water supply. Please note that water reclamation consisting of recharge or reinjection is not authorized under this Order.

- 2. Unit information.** Provide information on the quantity and type of units in the groundwater extraction and treatment system including any applicable characteristics such as size, capacity, ratings, depth, dosages, etc.

I. Engineering Certification Report

The Engineering Certification Report is a comprehensive report detailing the process and components of the groundwater extraction and treatment system. It provides a background of the site project and a narrative summary of environmental investigations regarding groundwater impacts at the site, if any. Description of treatment system components may include dewatering wells, groundwater pumps, conveyance systems, storage tanks, settling tanks, process pumps, filtering vessels, granular activated carbon tanks, chemical injection systems, and pH adjustment equipment (common in concrete pour operations). Additionally, it shall include:

- 1. Location map.** A topographic map (or maps) showing the legal facility boundaries; location of treatment units and processes; intake and discharge point locations; and receiving waters (or storm drains).
- 2. Discharge flow path map.** An aerial map or satellite image illustrating the proposed path of the discharge from the point of exit of the treatment system to the point of discharge in the receiving water. All applicable streets, land features, points of entry in the storm drain system, receiving water(s), and distances should be labeled and displayed on the map.
- 3. Process flow diagram.** A diagram showing the water flow from intake to discharge including all treatment system components and applicable sampling ports (see example below). Indicate how the discharge flows from where it is generated to where it exits the treatment system. Estimate approximate flows, as necessary.



- 4. Unit spec sheets.** Datasheets that provide engineering characteristics of treatment system units.
- 5. Operation and maintenance procedures.** A copy of the Table of Contents from the Operation and Maintenance Manual of the treatment system. Please note that the Operation and Maintenance Manual of the facility shall be submitted in the Start-up Phase Report.

The Engineering Certification Report shall certify that the proposed treatment system will treat the proposed dewatering discharge and comply with the Order's requirements. Finally, as required by the California Business and Professions Code section 6735, the report shall be prepared by, or under the supervision of, a Professional Engineer licensed to practice in California and shall be signed and stamped by the same.

ATTACHMENT C – NOTICE OF TERMINATION

Complete the Notice of Termination Form to request termination of coverage under General Waste Discharge Requirements for Discharge or Reclamation of Extracted and Treated Groundwater Resulting from the Cleanup of Groundwater Polluted by Volatile Organic Compounds (VOCs), Fuel Leaks, and Other Related Wastes (e.g., semi-volatile organic compounds [SVOCs], polycyclic aromatic hydrocarbons [PAHs], and metals. NPDES Permit No. CAG912002 (VOC and Fuel General Permit).

Groundwater Treatment Facility address: _____

CIWQS Place Identification Number: _____

An electronic copy of this form shall be emailed to R2NPDES.GeneralPermits@waterboards.ca.gov and a confirmation email shall be sent to the responsible staff member as indicated at www.waterboards.ca.gov/sanfranciscobay/water_issues/programs/general_permits.shtml.

I. REASON FOR TERMINATION (select one)

<input type="checkbox"/> 1. Completion of temporary groundwater dewatering project (e.g., construction project). <input type="checkbox"/> 2. Groundwater cleanup work has been completed. <input type="checkbox"/> 3. Method of groundwater cleanup has been changed with no need to discharge treated groundwater. <input type="checkbox"/> 4. Groundwater cleanup will be stopped to start groundwater monitoring. Please attach documentation showing that the agency overseeing cleanup has no objection to cessation of groundwater extraction and treatment. <input type="checkbox"/> 5. Other reason. Please specify below (e.g., discharge to POTW has been granted):

II. AGENCY APPROVAL (applicable if items 2, 3 or 4 in Section I are marked)

Name, address, email, and phone number of the agency and agency staff overseeing the cleanup work:	Have you provided a copy of this termination notice to this staff? If No, please explain. <input type="checkbox"/> Yes <input type="checkbox"/> No (explain):
--	---

I, the Discharger, certify under penalty of law that this notice is prepared under my direction or supervision and last/final date of this discharge was _____. I am aware that discharging without a discharge authorization is in violation of California Water Code.

 Name (print) Signature and Date

 Title/Organization (Discharger’s Organization) Address, email and phone number

ATTACHMENT D – STANDARD PROVISIONS**I. STANDARD PROVISIONS – PERMIT COMPLIANCE****A. Duty to Comply**

1. The Discharger must comply with all of the terms, requirements, and conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action; permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof. (40 C.F.R. § 122.41(a); Wat. Code §§ 13261, 13263, 13265, 13268, 13000, 13001, 13304, 13350, 13385.)
2. The Discharger shall comply with effluent standards or prohibitions established under CWA section 307(a) for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 C.F.R. § 122.41(a)(1).)

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 C.F.R. § 122.41(c).)

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 C.F.R. § 122.41(d).)

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order. (40 C.F.R. § 122.41(e).)

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 C.F.R. § 122.41(g).)
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 C.F.R. § 122.5(c).)

F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, U.S. EPA, and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (33 U.S.C. § 1318(a)(4)(B); 40 C.F.R. § 122.41(i); Wat. Code, §§ 13267, 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (33 U.S.C. § 1318(a)(4)(B)(i); 40 C.F.R. § 122.41(i)(1); Wat. Code, §§ 13267, 13383);
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (33 U.S.C. § 1318(a)(4)(B)(ii); 40 C.F.R. § 122.41(i)(2); Wat. Code, §§ 13267, 13383);
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (33 U.S.C. § 1318(a)(4)(B)(ii); 40 C.F.R. § 122.41(i)(3); Wat. Code, §§ 13267, 13383); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (33 U.S.C. § 1318(a)(4)(B); 40 C.F.R. § 122.41(i)(4); Wat. Code, §§ 13267, 13383.)

G. Bypass

1. Definitions

- a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 C.F.R. § 122.41(m)(1)(i).)
- b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 C.F.R. § 122.41(m)(1)(ii).)

2. **Bypass not exceeding limitations.** The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 C.F.R. § 122.41(m)(2).)

3. **Prohibition of bypass.** Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless (40 C.F.R. § 122.41(m)(4)(i)):

- a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 C.F.R. § 122.41(m)(4)(i)(A));
- b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of

- equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 C.F.R. § 122.41(m)(4)(i)(B)); and
- c. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 C.F.R. § 122.41(m)(4)(i)(C).)
- 4. Approval.** The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions—Permit Compliance I.G.3 above. (40 C.F.R. § 122.41(m)(4)(ii).)
- 5. Notice**
- a. **Anticipated bypass.** If the Discharger knows in advance of the need for a bypass, it shall submit prior notice, if possible at least 10 days before the date of the bypass. The notice shall be sent to the Regional Water Board. As of December 21, 2020, a notice shall also be submitted electronically to the initial recipient in Standard Provisions – Reporting V.J below. Notices shall comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22, and 40 C.F.R. part 127. (40 C.F.R. § 122.41(m)(3)(i).)
 - b. **Unanticipated bypass.** The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). The notice shall be sent to the Regional Water Board. As of December 21, 2020, a notice shall also be submitted electronically to the initial recipient defined in Standard Provisions – Reporting V.J below. Notices shall comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22 and 40 C.F.R. part 127.(40 C.F.R. § 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 C.F.R. § 122.41(n)(1).)

1. **Effect of an upset.** An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 C.F.R. § 122.41(n)(2).)
2. **Conditions necessary for a demonstration of upset.** A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 C.F.R. § 122.41(n)(3)):
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 C.F.R. § 122.41(n)(3)(i));

high enough that the method detects and quantifies the level of the pollutant or pollutant parameter in the discharge; or

2. The method has the lowest ML of the analytical methods approved under 40 C.F.R. part 136 or required under 40 C.F.R. chapter 1, subchapter N, for the measured pollutant or pollutant parameter.

In the case of pollutants or pollutant parameters for which there are no approved methods under 40 C.F.R. part 136 or otherwise required under 40 C.F.R. chapter 1, subchapters N, monitoring must be conducted according to a test procedure specified in this Order for such pollutants or pollutant parameters. (40 C.F.R. §§ 122.1.21(e)(3), 122.41(j)(4), 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS—RECORDS

- A. The Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 C.F.R. § 122.41(j)(2).)
- B. Records of monitoring information shall include the following:
 1. The date, exact place, and time of sampling or measurements (40 C.F.R. § 122.41(j)(3)(i));
 2. The individual(s) who performed the sampling or measurements (40 C.F.R. § 122.41(j)(3)(ii));
 3. The date(s) the analyses were performed (40 C.F.R. § 122.41(j)(3)(iii));
 4. The individual(s) who performed the analyses (40 C.F.R. § 122.41(j)(3)(iv));
 5. The analytical techniques or methods used (40 C.F.R. § 122.41(j)(3)(v)); and
 6. The results of such analyses. (40 C.F.R. § 122.41(j)(3)(vi).)
- C. Claims of confidentiality for the following information will be denied (40 C.F.R. § 122.7(b)):
 1. The name and address of any permit applicant or Discharger (40 C.F.R. § 122.7(b)(1)); and
 2. Permit applications and attachments, permits, and effluent data. (40 C.F.R. § 122.7(b)(2).)

V. STANDARD PROVISIONS—REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, State Water Board, or U.S. EPA within a reasonable time, any information which the Regional Water Board, State Water Board, or U.S. EPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or U.S. EPA copies of records required to be kept by this Order. (40 C.F.R. § 122.41(h); Wat. Code, §§ 13267, 13383.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or U.S. EPA shall be signed and certified in accordance with Standard Provisions—Reporting V.B.2, V.B.3, V.B.4, and V.B.5, and V.B.6 below. (40 C.F.R. § 122.41(k).)
2. For a corporation, all permit applications shall be signed by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (i) a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures. (40 C.F.R. § 122.22(a)(1).)

For a partnership or sole proprietorship, all permit applications shall be signed by a general partner or the proprietor, respectively. (40 C.F.R. § 122.22(a)(2).)

For a municipality, state, federal, or other public agency, all permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of U.S. EPA). (40 C.F.R. § 122.22(a)(3).)

3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or U.S. EPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions—Reporting V.B.2 above (40 C.F.R. § 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 C.F.R. § 122.22(b)(2)); and
 - c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 C.F.R. § 122.22(b)(3).)

4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions—Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 C.F.R. § 122.22(c).)
5. Any person signing a document under Standard Provisions—Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 C.F.R. § 122.22(d).)
6. Any person providing electronic signature for documents described in Standard Provisions – V.B.1, V.B.2, or V.B.3 that are submitted electronically shall meet all relevant requirements of Standard Provisions – Reporting V.B, and shall ensure that all relevant requirements of 40 C.F.R. part 3 (Cross-Media Electronic Reporting) and 40 C.F.R part 127 (NPDES Electronic Reporting Requirements) are met for that submission. (40 C.F.R. § 122.22(e).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program in this Order. (40 C.F.R. § 122.22(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board. As of December 21, 2016, all reports and forms must be submitted electronically to the initial recipient defined in Standard Provisions – Reporting V.J and comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22, and 40 C.F.R. part 127. (40 C.F.R. § 122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under 40 C.F.R. part 136, or another method required for an industry-specific waste stream under 40 C.F.R. subchapter N, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR reporting form specified by the Regional Water Board or State Water Board. (40 C.F.R. § 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 C.F.R. § 122.41(l)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 C.F.R. § 122.41(l)(5).)

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written report shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

For noncompliance related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports must include the data described above (with the exception of time discovery) as well as the type of event (i.e., combined sewer overflow, sanitary sewer overflow, or bypass event), type of overflow structure (e.g., manhole, combined sewer overflow outfall), discharge volume untreated by the treatment works treating domestic sewage, types of human health and environmental impacts of the event, and whether the noncompliance was related to wet weather.

As of December 21, 2020, all reports related to combined sewer overflows, sanitary sewer overflows, or bypass events must be submitted to the Regional Water Board and must be submitted electronically to the initial recipient defined in Standard Provisions – Reporting V.J. The reports shall comply with 40 C.F.R. part 3, 40 C.F.R. section 122.22, and 40 C.F.R. part 127. The Regional Water Board may also require the Discharger to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section. (40 C.F.R. § 122.41(l)(6)(i).)

2. The following shall be included as information that must be reported within 24 hours:
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(A).)
 - b. Any upset that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(B).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral and written report has been received within 24 hours. (40 C.F.R. § 122.41(l)(6)(iii).)

F. Planned Changes

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 C.F.R. § 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 C.F.R. section 122.29(b) (40 C.F.R. § 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (Alternatively, for an existing manufacturing, commercial, mining, or silvicultural discharge as referenced in 40 C.F.R. section 122.42(a), this notification applies to pollutants that are subject neither to effluent limitations in this Order nor to notification requirements under 40 C.F.R. section 122.42(a)(1) (see Additional Provisions—Notification Levels VII.A.1).) (40 C.F.R. § 122.41(l)(1)(ii).)

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with this Order's requirements. (40 C.F.R. § 122.41(l)(2).)

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions—Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision—Reporting V.E above. For noncompliance related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports shall contain the information described in Standard Provision – Reporting V.E and the applicable required data in appendix A to 40 C.F.R. part 127. The Regional Water Board may also require the Discharger to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section (40 C.F.R. § 122.41(l)(7).)

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or U.S. EPA, the Discharger shall promptly submit such facts or information. (40 C.F.R. § 122.41(l)(8).)

J. Initial Recipient for Electronic Reporting Data

The owner, operator, or duly authorized representative is required to electronically submit NPDES information specified in appendix A to 40 C.F.R. part 127 to the initial recipient defined in 40 C.F.R. section 127.2(b). U.S. EPA will identify and publish the list of initial recipients on its website and in the Federal Register, by state and by NPDES data group [see 40 C.F.R. § 127.2 (c)]. U.S. EPA will update and maintain this list. (40 C.F.R. § 122.41(l)(9).)

VI. STANDARD PROVISIONS – ENFORCEMENT

- A. The Regional Water Board is authorized to enforce the terms of this Order under several provisions of the Water Code, including, but not limited to, sections 13268, 13350, 13385, 13386, and 13387.

VII. ADDITIONAL PROVISIONS—NOTIFICATION LEVELS**A. Non-Municipal Facilities**

Existing manufacturing, commercial, mining, and silvicultural Dischargers shall notify the Regional Water Board as soon as they know or have reason to believe (40 C.F.R. § 122.42(a)):

1. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following “notification levels” (40 C.F.R. § 122.42(a)(1)):
 - a. 100 micrograms per liter ($\mu\text{g/L}$) (40 C.F.R. § 122.42(a)(1)(i));
 - b. 200 $\mu\text{g/L}$ for acrolein and acrylonitrile; 500 $\mu\text{g/L}$ for 2,4-dinitrophenol and 2-methyl-4,6-dinitrophenol; and 1 milligram per liter (mg/L) for antimony (40 C.F.R. § 122.42(a)(1)(ii));
 - c. Five (5) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge (40 C.F.R. § 122.42(a)(1)(iii)); or
 - d. The level established by the Regional Water Board in accordance with section 122.44(f). (40 C.F.R. § 122.42(a)(1)(iv).)
2. That any activity has occurred or will occur that would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following “notification levels” (40 C.F.R. § 122.42(a)(2)):
 - a. 500 micrograms per liter ($\mu\text{g/L}$) (40 C.F.R. § 122.42(a)(2)(i));
 - b. 1 milligram per liter (mg/L) for antimony (40 C.F.R. § 122.42(a)(2)(ii));
 - c. Ten (10) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge (40 C.F.R. § 122.42(a)(2)(iii)); or
 - d. The level established by the Regional Water Board in accordance with section 122.44(f). (40 C.F.R. § 122.42(a)(2)(iv).)

B. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 C.F.R. § 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to CWA sections 301 or 306 if it were directly discharging those pollutants (40 C.F.R. § 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of this Order. (40 C.F.R. § 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 C.F.R. § 122.42(b)(3).)

San Francisco Bay Regional Water Quality Control Board

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

Contents

I. General Monitoring Provisions	E-2
II. Monitoring Locations	E-2
III. Influent Monitoring Requirements	E-3
IV. Effluent Monitoring Requirements	E-6
V. Acute Toxicity Testing Requirements	E-6
VI. Reclamation Monitoring Requirements	E-7
VII. Receiving Water Monitoring Requirements.....	E-7
VIII. Other Monitoring Requirements	E-7
A. Startup Phase Monitoring	E-7
B. Chemical Additives Monitoring	E-8
C. Standard Observations.....	E-8
D. Minimum Levels	E-10
IX. Reporting	E-10
A. General Reporting Requirements	E-10
B. Self-Monitoring Reports.....	E-10
C. Discharge Monitoring Reports	E-15
D. Violations and Unauthorized Discharges	E-16

Tables

Table E-1. Monitoring Locations.....	E-2
Table E-2. Minimum Monitoring Requirements	E-3
Table E-3. Monitoring Periods and Reporting Schedule	E-14

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

Clean Water Act section 308 and 40 C.F.R. sections 122.41(h), 122.41(j)-(l), 122.44(i), and 122.48 require that all NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 also authorize the Regional Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. This MRP establishes monitoring, reporting, and recordkeeping requirements that implement federal and State laws and regulations.

I. GENERAL MONITORING PROVISIONS

- A.** Dischargers shall comply with this MRP. The Executive Officer may amend this MRP pursuant to 40 C.F.R. sections 122.62, 122.63, and 124.5.
- B.** Dischargers shall conduct all monitoring in accordance with Attachment D, section III. Equivalent test methods must be more sensitive than those specified in 40 C.F.R. part 136 and must be specified in this Order or the Discharger’s Authorization to Discharge. Water and waste analyses shall be performed by a laboratory certified for these analyses in accordance with Water Code section 13176.
- C.** All monitoring instruments, flowmeters, and equipment shall be properly calibrated according to manufacturer’s instructions and maintained to ensure accurate measurements. Flow meters shall be calibrated at least once during this Order’s term.

II. MONITORING LOCATIONS

The Discharger shall establish monitoring locations as set forth below to demonstrate compliance with this Order:

Table E-1. Monitoring Locations

Monitoring Location Type	Monitoring Location Name^[1]	Monitoring Location Description
Influent	INF-001 through INF- <i>n</i> (where <i>n</i> is a sequential number above 001)	A point in the extraction system immediately prior to the treatment unit.
Effluent	EFF-001 through EFF- <i>n</i> (where <i>n</i> is a sequential number above 001)	A point in the discharge line immediately following treatment and before the effluent joins or is diluted by any other waste stream, water body, or other substance. ^[2]
Receiving Water	RSW-001U through RSW- <i>n</i> U (where <i>n</i> is a sequential number above 001) ^[3]	A point 50 feet upstream from the point of discharge into the receiving water or, if access is limited, the first accessible point upstream. ^[4]
	RSW-001D through RSW- <i>n</i> D (where <i>n</i> is a sequential number above 001) ^[3]	A point 50 feet downstream from the point of discharge into the receiving water or, if access is limited, the first accessible point downstream. ^[4]
Reclaimed Water	REC-001 through REC- <i>n</i> (where <i>n</i> is a sequential number above 001)	A point immediately prior to reclamation. ^[5]

Footnotes:

^[1] The previous order used the monitoring location names as follows: INF-001, EFF-001; RSW-001U, RSW-001D, and REU-001.

- [2] If discharge is to a storm drain prior to reaching the receiving water, the monitoring location shall be a point before the discharge commingles with storm drain water.
- [3] If there is only one discharge outfall, the Discharger should use the names RSW-001U and RSW-001D. Otherwise, the Discharger should use RSW-001U and RSW-001D for Discharge Point No. 001, RSW-002U and RSW-002D for Discharge Point No. 002, and so on.
- [4] A Discharger that cannot safely access receiving water within 50 feet of the outfall may collect samples at the nearest safe alternative location after receiving written Executive Officer concurrence.
- [5] Not applicable if effluent is not reclaimed.

III. INFLUENT MONITORING REQUIREMENTS

The Discharger shall monitor facility influent at Monitoring Locations INF-001 through INF-*n* in accordance with the schedule shown in Table E-2. Influent samples shall be collected on varying days selected at random and shall not include any recirculation or other sidestream wastes.

Table E-2. Minimum Monitoring Requirements

Parameter	Units	Analytical Test Method	Sample Type	Influent (INF-00 <i>n</i>) ^[1]	Effluent and Reclaimed Water (EFF- <i>n</i> , REC- <i>n</i>) ^[1]	Receiving Water (RSW- <i>n</i> U, RSW- <i>n</i> D)
Flow	GPM/GPD/ MGM	--	Continuous	--	Continuous ^[2]	--
Electrical Conductivity	S/m	EPA 120.1	Grab	--	SP, then 1/Month	--
pH	standard units	EPA 150.2	Grab	SP, then 1/Month	SP, then 1/Month	[3]
Temperature	°C	--	Grab	--	SP, then 1/Month	--
Turbidity	NTU	EPA 180.1	Grab	--	SP, then 1/Month	--
Total Dissolved Solids	mg/L	--	--	--	SP, then 1/Month	--
Dissolved Oxygen	mg/L	--	--	--	--	[3]
Hardness (as CaCO ₃)	mg/L	EPA 130.1	Grab	--	--	[3]
Salinity	‰	--	Grab	--	--	[3]
Sulfate	mg/L	EPA 375.2	Grab	--	SP, then 1/Quarter, then 1/Year ^[4]	--
Manganese	µg/L	EPA 200.8	Grab	--	SP, then 1/Quarter, then 1/Year ^[4]	--
Total Chlorine Residual ^[5]	mg/L	Field Kit, EPA 330, or SM4500-Cl	Grab	SP, then 1/Quarter	SP, then 1/Month	[3]
Antimony, Total Recoverable	µg/L	EPA 204.2	Grab	[6]	[6]	[3]
Arsenic, Total Recoverable	µg/L	EPA 206.3	Grab	[6]	[6]	[3]
Beryllium, Total Recoverable	µg/L	EPA 200.9	Grab	[6]	[6]	[3]
Cadmium, Total Recoverable	µg/L	EPA 200.9	Grab	[6]	[6]	[3]

Parameter	Units	Analytical Test Method	Sample Type	Influent (INF-00 n) ⁽¹⁾	Effluent and Reclaimed Water (EFF-n, REC- n) ⁽¹⁾	Receiving Water (RSW-nU, RSW-nD)
Chromium III ^[7]	µg/L	SM3500	Grab	[6]	[6]	[3]
Chromium VI ^[7]	µg/L	SM3500	Grab	[6]	[6]	[3]
Copper, Total Recoverable	µg/L	EPA 200.9	Grab	[6]	[6]	[3]
Lead, Total Recoverable	µg/L	EPA 200.9	Grab	[6]	[6]	[3]
Mercury, Total Recoverable ^[8]	µg/L	EPA 1631	Grab	[6]	[6]	[3]
Nickel, Total Recoverable	µg/L	EPA 200.9	Grab	[6]	[6]	[3]
Selenium, Total Recoverable	µg/L	EPA 200.8 or SM 3114B or C	Grab	[6]	[6]	[3]
Silver, Total Recoverable	µg/L	EPA 200.9	Grab	[6]	[6]	[3]
Thallium, Total Recoverable	µg/L	EPA 200.9	Grab	[6]	[6]	[3]
Zinc, Total Recoverable	µg/L	EPA 200.8	Grab	[6]	[6]	[3]
Cyanide, Total	µg/L	SM 4500-CN- C or I	Grab	[6]	[6]	--
Volatile Organic Compounds (VOCs) ^[9]	µg/L	EPA 8260B (full list)	Grab	[6]	[6]	[3]
1,4-dioxane	µg/L	EPA 8270C or EPA 522	Grab	SP, then 1/Quarter	SP, then 1/Month	[3]
Semi-volatile organic compounds (SVOCs) excluding polynuclear aromatic hydrocarbons (PAHs) ^{[5],[10]}	µg/L	EPA 8270C	Grab	SP, then 1/Quarter	SP, then 1/Month	--
PAHs ^[5]	µg/L	EPA 610	Grab	SP, then 1/Quarter	SP, then 1/Month	[3]
TPHs as Gasoline and Diesel ^{[5],[11]}	µg/L	EPA 8015B Modified	Grab	SP, then 1/Quarter	SP, then 1/Month	[3]
TPHs other than Gasoline and Diesel ^{[5],[11]}	µg/L	EPA 8015B Modified	Grab	SP, then 1/Quarter	SP, then 1/Month	[3]

Parameter	Units	Analytical Test Method	Sample Type	Influent (INF-00 n) ⁽¹⁾	Effluent and Reclaimed Water (EFF-n, REC- n) ⁽¹⁾	Receiving Water (RSW-nU, RSW-nD)
Tertiary Amyl Methyl Ether (TAME), DiIsopropyl Ether (DIPE), Ethyl Tertiary Butyl Ether (ETBE), Tertiary Butyl Alcohol (TBA), Ethanol, and Methanol ⁽⁵⁾	µg/L	EPA 1625 Modified	Grab	SP, then 1/Year	SP, then 1/Year	--
All other pollutants such as foaming agents ⁽¹²⁾	various	--	Grab	SP, then 1/Month, then 1/Quarter, then 1/Year ⁽¹³⁾	SP, then 1/Month, then 1/Quarter, then 1/Year ⁽¹³⁾	[3]
Acute Toxicity	% survival	See MRP section V	Grab	--	1/Quarter, then 1/Year ⁽¹⁴⁾	--
Standard Observations	--	--	--	--	SP, then 1/Month ⁽¹⁵⁾	[3]

Abbreviations

- GPM = gallons per minute
- GPD = gallons per day
- MGM = million gallons per month
- NTU = nephelometric turbidity units
- % survival = percent survival
- mg/L = milligrams per liter
- µg/L = micrograms per liter
- ‰ = parts per thousand
- S/m = Siemens per meter
- SM = Standard Method
- SP = Start-up Phase

Footnotes:

- [1] When “Start-up Phase” is indicated, parameters shall be monitored once on the first day of start-up and once on the fifth day of start-up, and then at the frequency indicated.
- [2] Flows shall be measured continuously in gallons per minute (GPM). Flows shall be recorded as gallons per day (GPD), and million gallons per month (MGM). Flows shall be monitored at each outfall or reclamation discharge point by a flow meter or as estimated if no flow meter is in place. The Executive Officer may require the Discharger to install flow meters.
- [3] Receiving water shall be monitored whenever there is an effluent limit violation. Receiving water monitoring shall occur on the same calendar day as effluent confirmation monitoring. Receiving water samples shall be analyzed for each violated effluent parameter.
- [4] After the start-up phase, sulfate shall be monitored quarterly for the first year of operation, and annually thereafter.
- [5] Chlorine residual, SVOCs, PAHs, TPHs (as gasoline, diesel), TPHs other than gasoline and diesel, TAME, DIPE, ETBE, TBA, ethanol, and methanol shall be monitored in influent and effluent if known to be present in the influent.
- [6] VOCs, metals and cyanide shall be monitored as follows:
 - (A) Sites contaminated *only* with VOCs: VOCs shall be monitored at the influent on start-up phase, then quarterly. VOCs shall be monitored at the effluent on start-up phase, then monthly. Metals and cyanide shall be monitored at the influent and effluent on start-up phase, then annually.
 - (B) Sites contaminated with fuel and fuel-related compounds (including fuel-related VOCs): Dischargers shall monitor the influent on start-up phase, then twice per year. Dischargers shall monitor the effluent on start-up phase, then quarterly.
- [7] Analysis for total chromium may be substituted for analysis of chromium (III) and chromium (VI) if the concentration measured is below the lowest hexavalent chromium criterion (11 µg/L).
- [8] If the discharge exceeds the effluent limitation for mercury, the Discharger shall re-sample and analyze using ultra-clean techniques as described in U.S. EPA methods 1669 and 1631 to eliminate the possibility of artefactual contamination of the sample.
- [9] VOCs shall include ethylene dibromide, benzene, toluene, ethylbenzene, total xylenes and methyl tert-butyl ether.

- ^[10] Monitoring of bis(2-ethylhexyl)phthalate shall be performed using ultra clean sampling techniques for re-evaluation during future permit permit reissuance.
- ^[11] TPHs shall be analyzed without silica-gel cleanup.
- ^[12] All other pollutants, such as foaming agents shall be monitored at the influent and effluent if known to be present in the influent
- ^[13] After the start-up phase, parameters shall be monitored monthly for the first year of operation, quarterly for the second year of operation, and annually thereafter.
- ^[14] Acute toxicity shall be monitored quarterly for the first year of operation and annually thereafter.
- ^[15] For reclaimed water only.

IV. EFFLUENT MONITORING REQUIREMENTS

- A.** When discharging, the Discharger shall monitor the discharge at Monitoring Locations EFF-001 through EFF-00n in accordance with Table E-2. Effluent sampling shall occur concurrently (within 30 minutes) with any influent sampling unless the Executive Officer stipulates otherwise.
- B.** Grab samples shall be collected on random days during periods of daytime maximum flow (if flow varies significantly during the day).
- C.** When any type of bypass occurs, grab samples shall be collected daily for the duration of the bypass for all constituents at all affected discharge points that have effluent limits.
- D.** If monitoring results indicate a violation of any effluent limitation, the Discharger shall take a confirmation effluent sample and receiving water samples within 24 hours of becoming aware of the violation. The Discharger must have the confirmation sample analyzed by expedited methods and obtain results within 24 hours of sample collection. If the confirmation sampling results also violate the effluent limit, the Discharger shall cease discharge until it has corrected the cause of the violation. In this case, both the initial and confirmation results are violations. However, if the confirmation sample indicates compliance, only the initial exceedance is a violation and the Discharger may continue discharging. The Discharger shall not discharge when a known violation of effluent limit exists just to comply with receiving water monitoring requirements.

V. ACUTE TOXICITY TESTING REQUIREMENTS

The Discharger shall monitor acute toxicity at Monitoring Locations EFF-001 through EFF-n as follows:

- A.** Compliance with the acute toxicity effluent limitations shall be evaluated by measuring survival of test organisms exposed to 96-hour static renewal bioassays. Samples shall be collected on days coincident with effluent sampling.
- B.** Test species shall be rainbow trout (*Oncorhynchus mykiss*) and sheepshead minnow (*Cyprinodon variegatus*). If the Discharger was enrolled under the previous order, it may use the test species specified at that time until further notice. The Executive Officer may specify a more sensitive species or, if testing a particular species proves unworkable, the most sensitive species available.
- C.** All bioassays shall be performed according to 40 C.F.R. part 136, currently *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, 5th Edition (EPA-821-R-02-012), with exceptions granted in writing by the Executive Officer and the Environmental Laboratory Accreditation Program upon a Discharger request with justification.

- D.** If a Discharger demonstrates that specific identifiable substances in the discharge are rapidly rendered harmless upon discharge to the receiving water, compliance with the acute toxicity limit may be determined after test samples are adjusted to remove the influence of those substances. Written acknowledgement that the Executive Officer concurs with the Discharger's demonstration and that the adjustment will not remove the influence of other substances must be obtained prior to any such adjustment.
- E.** Bioassay water monitoring shall include, on a daily basis, pH, dissolved oxygen, ammonia (if toxicity is observed), temperature, hardness, and alkalinity. These results shall be reported. If final or intermediate results of an acute bioassay test indicate a violation or threatened violation (e.g., the percentage of surviving test organisms is less than 70 percent), the Discharger shall initiate a new test as soon as practical and shall investigate the cause of the mortalities and report its findings in the next self-monitoring report. The Discharger shall repeat the test until a test fish survival rate of 90 percent or greater is observed. If the control fish survival rate is less than 90 percent, the bioassay test shall be restarted with new fish and shall continue as soon as practical until an acceptable test is completed (i.e., the control fish survival rate is 90 percent or greater).

VI. RECLAMATION MONITORING REQUIREMENTS

The Discharger shall monitor reclaimed water at Monitoring Locations REC-001 through REC-*n* as shown in Table E-2.

VII. RECEIVING WATER MONITORING REQUIREMENTS

The Discharger shall monitor receiving waters at Monitoring Locations RSW-001U through RSW-*n*U and RSW-001D through RSW-*n*D as indicated in Table E-2.

- A.** For tidally influenced receiving waters, samples shall be collected within 1 hour following low slack water. Where sampling at lower slack water period is not practical, sampling shall be performed during higher slack water period.
- B.** Samples shall be collected within one foot of the surface of the receiving water body. The Discharger shall explain any deviation from this requirement in each monitoring report if this requirement cannot be met.
- C.** Receiving water monitoring is not required when there is no water in the receiving water other than the discharge.

VIII. OTHER MONITORING REQUIREMENTS

A. Startup Phase Monitoring

During the initial start-up for the treatment system, influent and effluent sampling shall occur on the first and fifth days of operation as set forth in Table E-2 (weekend days may be excluded).

- 1.** On the first day of start-up, the system shall be allowed to run until at least three to five well or sump volumes are removed, and until three consecutive readings for pH, conductivity, and temperature are within five percent of each other. Then, influent and effluent shall be sampled and submitted for analysis. Prior to receiving the results of the initial sampling, all effluent shall be discharged into a holding tank (i.e., contained, not discharged to the

receiving water) or the sanitary sewer until monitoring indicates that the discharge is within the effluent limits set forth in this Order. The treatment system may be shut down after the first day's sampling to await the analytical results and thereby reduce the storage needed. If the treatment system is shut down more than 120 hours during the initial start-up (e.g., awaiting analytical results), the start-up procedures and sampling shall be repeated. If the monitoring results indicate that the discharge would violate the effluent limits set forth in this Order, any stored effluent shall be retreated until monitoring results indicate compliance or be disposed of in accordance with applicable regulations.

2. If the initial sampling indicates compliance, the treatment system shall be operated and discharge to the storm drain or receiving water may commence for five days. On the fifth day of discharge, the influent and effluent shall be sampled again and submitted for analysis. Discharge may continue as long as the analytical results are received within 120 hours of sampling and the monitoring continues to indicate compliance. Otherwise, the initial start-up procedures and sampling must be repeated.
3. In cases of any temporary shutdowns unrelated to maintenance operations, any restart shall follow these initial start-up procedures if the Discharger reported any effluent limit violation during the previous three years.

B. Chemical Additives Monitoring

If applicable, the Discharger shall conduct monitoring related to chemical use as required in its Authorization to Discharge, treatment system design specifications, and Operations and Maintenance Manual.

C. Standard Observations

1. **Groundwater Treatment Systems.** At a monthly frequency, Dischargers shall conduct standard observations at their groundwater treatment systems as follows:
 - a. Odor: presences or absence, characterization, source, distance of travel, and wind direction.
 - b. Weather condition:
 - i. Air temperature;
 - ii. Wind direction and estimated velocity; and
 - iii. Total precipitation during the five days prior to observation.
 - c. Deposits, discolorations, or plugging in the conveyance system that could adversely affect the system reliability or performance.
 - d. Operation of valves, outlets, sprinkler heads, and/or pressure shutoff valves in conveyance system.
2. **Reclaimed Water.** At the frequency set forth in Table E-2, Dischargers shall conduct standard observations at Monitoring Locations REC-001 through REC-*n* as follows:
 - a. Floating and suspended materials of waste origin (e.g., oil, grease, algae, sand, and other macroscopic particulate matter): presence or absence, source, and size of affected area.

D. Minimum Levels

1. **Total Residual Chlorine.** The Discharger shall calibrate and maintain total residual chlorine analyzers to reliably quantify values of 0.1 mg/L and greater. This 0.1 mg/L shall be the minimum level (ML) and reporting limit (RL) for total residual chlorine.
2. **Metals.** Metals shall be analyzed for total (unfiltered) constituents with reporting levels not exceeding the Minimum Levels (MLs) specified in Attachment G.
3. **1,4-dioxane.** Use techniques to achieve reporting levels not exceeding 1 µg/L, such as selective ion mode or isotope dilution.
4. **All Other Pollutants.** All other pollutants shall use reporting levels not exceeding the Minimum Levels (MLs) specified in Attachment G

IX. REPORTING

A. General Reporting Requirements

The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.

B. Self-Monitoring Reports

1. **Format.** Dischargers shall submit Self-Monitoring Reports (SMRs) and cover letters via email to R2NPDES.GeneralPermits@waterboards.ca.gov and as further detailed in their Authorizations to Discharge. At any time during the term of this Order, the State or Regional Water Board may notify Dischargers to electronically submit SMRs using the State Water Board's California Integrated Water Quality System (CIWQS) website (<http://www.waterboards.ca.gov/ciwqs/index.html>). The CIWQS website will provide additional information for SMR submittal in the event of a planned service interruption for electronic submittal.
2. **Due Dates and Contents.** Dischargers shall submit start-up phase SMRs, semi-annual SMRs, and annual SMRs by the due dates, and with the contents, specified below:
 - a. **Start-up Phase SMRs** – Start-up Phase SMRs shall be due 45 days after the end of the calendar quarter in which the discharge started. The Start-up Phase SMR shall contain the following items:
 - i. All applicable items described in Attachment D sections V.B and V.C.
 - ii. A transmittal letter that includes the following:
 - (a) CIWQS ID and GeoTracker ID (if any) for the permitted facility;
 - (b) Clear identification of any violations of this Order or clear statement that there were no violations;
 - (c) Detailed description of any violations, their causes, and corrective actions taken or planned to resolve them and prevent recurrence;

- (d) Any claims of data invalidation (Data should not be submitted with an SMR if it does not meet quality assurance/quality control standards); and
 - (e) Signature (The transmittal letter shall be signed in accordance with Attachment D section V.B).
- iii. Results of analyses and observations as follows:
- (a) Calculations for all limitations expressed as averages shall use an arithmetic mean unless otherwise specified in MRP section IX.B.4;
 - (b) Summary of treatment system status during the reporting period (e.g., in operation or on standby) and reason for any non-routine treatment system shut down;
 - (c) Statement of maximum discharge flow (gpm) during start-up phase;
 - (d) Electronic spreadsheet containing all numerical monitoring results, including any field results (The numerical results shall include information, such as source of sample [i.e., influent, effluent, etc.], constituent, analytical method, calculation type, laboratory qualifier, units, MDL, RL, sampling date, analysis date, report name, and applicable comments or observations, if any; a Discharger shall identify any special methods and have prior Executive Officer approval); and
 - (e) A tabular summary of applicable Standard Observations.
- iv. If the Discharger monitors any pollutant more frequently than required by this Order, the Discharger shall include the results of such monitoring in the calculations and reporting for the applicable SMR.
- v. Laboratory reports with analytical results.
- vi. Operations and Maintenance Manual that lists facility and regulatory personnel, and describes all equipment, recommended operational strategies, process control monitoring, and maintenance activities. The Operations and Maintenance Manual shall be signed and stamped by the licensed professional engineer identified in Provision VI.C.4 of the Order.
- vii. Results for all monitoring specified in this MRP.
- b. Semi-Annual SMRs** — Semi-annual SMRs shall be due on August 15 and February 15 after each calendar semi-annual period. Semi-annual SMRs shall contain the following:
- i. Applicable items described in Standard Provisions V.B and V.C.
 - ii. Transmittal letter attached to each semi-annual SMR that includes the following:
 - (a) CIWQS ID and GeoTracker ID (if any) of the permitted facility.
 - (b) Operating status of the treatment facility during the reporting period.
 - (c) Clear identification of any violations of the Order or a clear statement that there were no violations.

reported in kilograms (kg) per annual reporting period and since effective date of initial discharge.

vii. Tabular summary of total effluent reclaimed during the annual reporting period, if any. Total volumes shall be reported in million gallons (MG) per annual reporting period and since effective date of initial discharge.

viii. Submittals required by Special Provision VI.C.3 of the Order.

ix. The Annual Report shall document that the annual fee has been paid.

3. Monitoring Periods. Monitoring periods for all required monitoring shall be completed as set forth in the table below:

Table E-3. Monitoring Periods and Reporting Schedule

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period ^[1]
Continuous	First day of discharge	All times while the facility is discharging
SP	Start-up date	First day of start-up phase through last day of start-up phase.
1/Month	First day of calendar month following the last day of start-up phase.	First day of calendar month through last day of calendar month
1/Quarter	Closest of January 1, April 1, July 1, or October 1 following (or on) the last day of start-up phase.	January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31
2/Year	Closest of January 1 or July 1 following (or on) the last day of the start-up period. ^[2]	January 1 through June 30 July 1 through December 31
1/Year	January 1 following (or on) the last day of the start-up period.	January 1 through December 31

Footnote:

^[1] Reporting begins on the effective date of Authorization to Discharge.

^[2] Monitoring conducted during the term of the previous order may be used to satisfy monitoring required with this sampling frequency.

4. RL and MDL Reporting. Dischargers shall report with each sample result the Reporting Level (RL) and Method Detection Limit (MDL) as set forth in this Order or as determined by the procedure in 40 C.F.R. part 136. Dischargers may select any analytical methods described in 40 C.F.R. part 136; however, RLs shall be below applicable water quality objectives (see Fact Sheet Table F-5) and effluent limitations (see Table 2 of the Order). Otherwise, RLs shall be as low as possible. Dischargers shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a.** Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b.** Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported. For purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ. The laboratory

may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (\pm a percentage of the reported value), numerical ranges (low to high), or any other means the laboratory considers appropriate.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected" or "ND."
- d. Dischargers shall instruct laboratories to establish calibration standards so that the lowest calibration standard is at or below the minimum level (ML) specified below (or its equivalent if there is differential treatment of samples relative to calibration standards). At no time is the Discharger to use analytical data derived from extrapolation beyond the lowest point of the calibration curve. The MLs for priority pollutants are included in Attachment G.

5. Compliance Determination

- a. Compliance with effluent limitations shall be determined using sample reporting protocols defined above and in the Fact Sheet and Attachments A and G. For purposes of reporting and administrative enforcement, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of a pollutant is greater than the effluent limitation and greater than or equal to the reporting level (RL).
- b. When determining compliance with an average effluent limitation and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of detected but not quantified (DNQ) or nondetect (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:
 - i. The data set shall be ranked from low to high, reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
 - ii. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

C. Discharge Monitoring Reports

1. At any time during the term of this Order, the State or Regional Water Board may notify Dischargers to submit Discharge Monitoring Reports (DMRs).
2. Once notified, Dischargers shall submit DMRs as required.

D. Violations and Unauthorized Discharges

- 1.** The Discharger shall report by telephone and email to the Regional Water Board staff (see Authorization to Discharge) who oversees the implementation of this Order within 24 hours of becoming aware of a bypass or violation of this Order.
- 2.** The Discharger shall report spills to the California Office of Emergency Services (telephone 800-852-7550) only when spills are in accordance with applicable reportable quantities for hazardous materials.
- 3.** The Discharger shall submit a written report to the Regional Water Board within five days following telephone and email notification unless directed otherwise by Regional Water Board staff. A report submitted electronically is acceptable. The written report shall include the following:
 - a.** Date and time of violation or spill, and duration if known;
 - b.** Location of violation or spill (street address or description of location, include map if necessary);
 - c.** Nature of violation or material spilled;
 - d.** Quantity of any material involved;
 - e.** Receiving water body affected, if any;
 - f.** Cause of violation or spill;
 - g.** Estimated size of affected area;
 - h.** Observed impacts to receiving waters (e.g., oil sheen, fish kill, or water discoloration);
 - i.** Corrective actions taken to correct violation or to contain, minimize, or clean up spill;
 - j.** Future corrective actions planned to prevent recurrence and implementation schedule;
 - k.** Spill Prevention, Control and Countermeasure Plan (SPCC) in effect, if any; and
 - l.** Persons or agencies notified.

ATTACHMENT F - FACT SHEET

Contents

I. Permit Information	F-2
II. Facility Description	F-2
A. Groundwater Treatment	F-2
B. Water Reclamation	F-3
C. Discharge Points and Receiving Waters	F-3
D. Existing Requirements	F-3
III. Applicable Plans, Policies, and Regulations	F-4
IV. Rationale For Effluent Limitations and Discharge Specifications	F-6
A. Discharge Prohibitions	F-7
B. Technology-Based Effluent Limitations	F-8
1. Scope and Authority	F-8
2. Applicable Limitations	F-9
C. Water Quality-Based Effluent Limitations	F-11
1. Scope and Authority	F-11
2. Beneficial Uses and Water Quality Criteria and Objectives	F-12
3. Need for WQBELs	F-14
4. WQBELs Calculations	F-17
D. Discharge Requirement Considerations	F-22
V. Rationale for Receiving Water Limitations	F-23
VI. Rationale for Provisions	F-23
A. Standard Provisions	F-23
B. Monitoring and Reporting Provisions	F-24
C. Special Provisions	F-24
1. Reopener Provisions	F-24
2. Application for General Permit Coverage and Authorization to Discharge	F-24
3. Water Reclamation Specifications (Water Reclamation Only)	F-24
4. Construction, Operation, and Maintenance Specifications	F-25
5. No Preemption	F-25
VII. Rationale for Monitoring and Reporting Requirements	F-25
VIII. Public Participation	F-26

Tables

Table F-1. Previous Effluent Limitations	F-3
Table F-2. Technology-Based Effluent Limitations	F-10
Table F-3. Factors Considered Pursuant to 40 C.F.R. section 125.3(d)(1)	F-11
Table F-4. Copper and Nickel Translators	F-14
Table F-5. Reasonable Potential Analysis	F-15
Table F-6. Summary of WQBELs	F-17
Table F-7. Aquatic Life-Based WQBELs	F-19
Table F-8. Aquatic Life-Based WQBELs (Copper)	F-21
Table F-8. Aquatic Life-Based WQBELs (Nickel)	F-21

ATTACHMENT F – FACT SHEET

This Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order. As described in section II.B of the Order, the California Regional Water Quality Control Board, San Francisco Bay Region (Regional Water Board) incorporates this Fact Sheet as its findings supporting the issuance of the Order.

I. PERMIT INFORMATION

- A.** This Order regulates the discharge or reclamation (or both discharge and reclamation) of extracted and treated groundwater resulting from the cleanup of groundwater at active or closed sites, such as service stations or construction sites. These groundwater treatment facilities extract and treat groundwater polluted by volatile organic compounds (VOCs), fuel leaks, fuel additives, and other related wastes (e.g., semi-volatile organic compounds [SVOCs], polycyclic aromatic hydrocarbons [PAHs], and metals). This Order reissues NPDES General Permit No. CAG912002, which the Regional Water Board issued through Order No. R2-2012-0012 (previous order) on February 8, 2012.
- B.** Site owners and operators that complete a Notice of Intent (NOI) form (Attachment B) and apply for Authorization to Discharge under this Order, and that are granted such authorization, are hereinafter called “Dischargers.” For purposes of this Order, references to “discharger” or “permittee” in applicable federal and State laws, regulations, plans, and policies are held to be equivalent to references to any Discharger herein. About 75 facilities were enrolled under the previous order at any one time.

II. FACILITY DESCRIPTION

A. Groundwater Treatment

The facilities that may be covered under this Order are groundwater treatment facilities that extract and treat groundwater polluted mainly by VOCs or fuel components, or both. Covered facilities may include active or closed sites, such as service stations or construction sites. This Order addresses discharges from these facilities to any surface waters, including creeks, streams, rivers (including flood control channels), lakes, or San Francisco Bay. Such discharges may occur directly to surface waters or through constructed storm drain systems.

Groundwater treatment facilities typically use aeration or granular activated carbon (GAC) systems, or both, to treat their groundwater prior to discharge. Facilities that employ other types of treatment that effectively remove VOCs or fuel-related pollutants may also be authorized pursuant to this Order subject to Executive Officer approval. The most common VOC pollutants these treatment systems treat are tetrachloroethylene and trichloroethylene. The most common fuel-related pollutants are benzene, ethylbenzene, toluene, total xylenes, methyl tertiary butyl ether (MTBE), and other petroleum hydrocarbons collectively called “total petroleum hydrocarbons” (TPHs). Other volatile or semi-volatile organic compounds or metals may also be of concern. Concentrations of other organic pollutants are usually below detectable levels.

B. Water Reclamation

Regional Water Board Resolution No. 88-160 (adopted October 19, 1988) urges Dischargers of extracted groundwater from site cleanup projects to reclaim their treated groundwater. The resolution states that, when reclamation is not technically and economically feasible, treated effluent should be directed to a publicly owned treatment works (POTW). Only if neither reclamation nor discharge to a POTW is technically and economically feasible, and if receiving water beneficial uses are not adversely affected, the Regional Water Board may authorize the discharge of treated and extracted groundwater in accordance with Waste Discharge Requirements (WDRs).

This Order allows reclamation of extracted treated groundwater in conjunction with discharge to surface water. Reclamation of extracted treated groundwater can take many forms, such as irrigation of landscaping or agriculture, dust control or soil compaction on construction sites, and industrial water supply.

C. Discharge Points and Receiving Waters

Dischargers may discharge to any San Francisco Bay Region surface waters, including estuarine and tidally influenced waters. Reclaimed water may be discharged to groundwaters or other waters of the State. Groundwater treatment facilities typically discharge effluent through storm drain systems, rivers, or creeks. The NOI form in Attachment B requires each Discharger to specify its discharge locations and to provide a map or diagram indicating the discharge path to surface waters.

D. Existing Requirements

The previous order included the following effluent limitations:

Table F-1. Previous Effluent Limitations

Pollutant	Units	Discharge to Receiving Waters used as Drinking Water Source ^[1]		Discharge to Other Receiving Waters	
		Daily Maximum	Average Monthly	Daily Maximum	Average Monthly
Benzene	µg/L	1	---	5	---
Carbon Tetrachloride	µg/L	0.50	0.25	5	4.4
Chloroform	µg/L	5	---	5	--
1,1-Dichloroethane	µg/L	5	---	5	---
1,2-Dichloroethane	µg/L	0.5	0.38	5	---
1,1-Dichloroethylene	µg/L	0.11	0.057	5	3.2
Ethylbenzene	µg/L	5	---	5	---
Methylene Chloride	µg/L	5	4.7	5	---
Tetrachloroethylene (PCE)	µg/L	1.6	0.8	5	---
Toluene	µg/L	5	---	5	---
Cis-1,2-Dichloroethylene	µg/L	5	---	5	---
Trans-1,2-Dichloroethylene	µg/L	5	---	5	---
1,1,1-Trichloroethane	µg/L	5	---	5	---
1,1,2-Trichloroethane	µg/L	1.2	0.6	5	---
Trichloroethylene (TCE)	µg/L	5	2.7	5	---

Pollutant	Units	Discharge to Receiving Waters used as Drinking Water Source ^[1]		Discharge to Other Receiving Waters	
		Daily Maximum	Average Monthly	Daily Maximum	Average Monthly
Vinyl Chloride	µg/L	0.5	---	1	---
Total Xylenes	µg/L	5	---	5	---
Methyl Tertiary Butyl Ether (MTBE)	µg/L	5	---	5	---
Total Petroleum Hydrocarbons [TPHs (as gasoline or as diesel)]	µg/L	50	---	50	---
Ethylene Dibromide (1,2-Dibromoethane)	µg/L	0.05	---	5	---
Trichlorotrifluoroethane	µg/L	5	---	5	---
Total Residual Chlorine	mg/L	0.0	---	0.0	---

Abbreviations:

mg/L= milligrams per liter

µg/L= micrograms per liter

Footnote:

^[1] Drinking water sources are defined as surface waters with the existing or potential beneficial uses of “municipal and domestic supply” or “groundwater recharge,” or both. (Groundwater recharge uses may include recharge areas to maintain salt balance or to halt saltwater intrusion into freshwater aquifers.)

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

A. Legal Authorities

This Order serves as WDRs pursuant to California Water Code article 4, chapter 4, division 7 (commencing with § 13260). This Order is also issued pursuant to Clean Water Act (CWA) section 402 and implementing regulations adopted by U.S. EPA and Water Code chapter 5.5, division 7 (commencing with § 13370). It shall serve as an NPDES permit for point source discharges to surface waters from enrolled facilities.

B. California Environmental Quality Act

Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of the California Environmental Quality Act, Public Resources Code division 13, chapter 3 (commencing with § 21100).

C. State and Federal Regulations, Policies, and Plans

1. Water Quality Control Plan. The Regional Water Board adopted the *Water Quality Control Plan for the San Francisco Bay Basin* (Basin Plan), which designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. Requirements in this Order implement the Basin Plan. In addition, this Order implements State Water Board Resolution No. 88-63, which established State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Receiving water beneficial uses include the following:

- Agricultural Supply
- Areas of Special Biological Significance
- Cold Freshwater Habitat
- Ocean, Commercial and Sport Fishing
- Estuarine Habitat
- Freshwater Replenishment
- Groundwater Recharge
- Industrial Service Supply
- Marine Habitat
- Fish Migration
- Municipal and Domestic Supply
- Navigation
- Industrial Process Supply
- Preservation of Rare or Endangered Species
- Water Contact Recreation
- Non-Contact Water Recreation
- Shellfish Harvesting
- Fish Spawning
- Warm Freshwater Habitat
- Wildlife Habitat

2. **Sediment Quality.** The State Water Board adopted the *Water Quality Control Plan for Enclosed Bays and Estuaries – Part 1, Sediment Quality* on September 16, 2008, and it became effective on August 25, 2009. This plan supersedes other narrative sediment quality objectives and establishes new sediment quality objectives and related implementation provisions for specifically defined sediments in most bays and estuaries. This Order implements the sediment quality objectives of this plan.
3. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** U.S. EPA adopted the NTR on December 22, 1992, and amended it on May 4, 1995 and November 9, 1999. About 40 criteria in the NTR apply in California. On May 18, 2000, U.S. EPA adopted the CTR. The CTR promulgated new toxics criteria for California and incorporated the previously adopted NTR criteria that applied in the State. U.S. EPA amended the CTR on February 13, 2001. These rules contain water quality criteria for priority pollutants.
4. **State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria U.S. EPA promulgated for California through the NTR and the priority pollutant objectives the Regional Water Board established in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria U.S. EPA promulgated through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives, and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
5. **Safe Clean Water.** In compliance with Water Code section 106.3, it is State of California policy that every human being has the right to safe, clean, affordable, and accessible water adequate for human consumption, cooking, and sanitary purposes. This Order promotes that policy by requiring dischargers to meet applicable water quality objectives, including maximum contaminant levels (MCLs) designed to protect human health, and to ensure that water is safe for domestic use. As explained in Fact Sheet section IV.C.3.d, the reasonable potential analysis for treated groundwater facilities considered MCLs.
6. **Antidegradation Policy.** Federal regulations at 40 C.F.R. section 131.12 requires that state water quality standards include an antidegradation policy consistent with the federal policy.

The State Water Board established California's antidegradation policy through State Water Board Resolution No. 68-16, "Statement of Policy with Respect to Maintaining High Quality of Waters in California," which is deemed to incorporate the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. Permitted discharges must be consistent with the antidegradation provisions of 40 C.F.R. section 131.12 and State Water Board Resolution No. 68-16.

- 7. Anti-Backsliding Requirements.** CWA sections 402(o) and 303(d)(4) and 40 C.F.R. section 122.44(l) restrict backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed. This Order retains effluent limitations no less stringent than those established by previous Orders.
- 8. Endangered Species Act Requirements.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code §§ 2050 to 2097) or the Federal Endangered Species Act (16 U.S.C.A. §§ 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the State, including protecting rare, threatened, or endangered species. The Discharger is responsible for meeting all applicable Endangered Species Act requirements.

D. Impaired Waters on CWA 303(d) List

In October 2011, U.S. EPA approved a revised list of impaired waters prepared pursuant to CWA section 303(d), which requires identification of specific waters where it is expected that water quality standards will not be met after implementation of technology-based effluent limitations on point sources. Where it has not done so already, the Regional Water Board plans to adopt total maximum daily loads (TMDLs) for pollutants on the 303(d) list. TMDLs establish wasteload allocations for point sources and load allocations for non-point sources and are established to achieve the water quality standards for the impaired waters. Specific waters on the 303(d) list impaired by pollutants within the scope of this Order include such waters as Castro Cove in Richmond, Central San Francisco Bay, Mission Creek, Islais Creek, and Oakland Inner Harbor. This Order is not expected to contribute to any water quality impairment because the effluent limitations included in this Order are based on water quality objectives protective of receiving water beneficial uses. Facilities that discharge to waters with applicable TMDLs may be required to obtain coverage under an individual permit.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants discharged into waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations: 40 C.F.R. section 122.44(a) requires that permits include applicable technology-based limitations and standards; and 40 C.F.R. section 122.44(d) requires that permits include water quality-based effluent limitations to attain and

maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of receiving waters.

Several specific factors affecting the development of limitations and requirements in this Order are discussed as follows:

A. Discharge Prohibitions

1. Prohibitions in this Order

- a. **Discharge Prohibition III.A** (No discharge other than as described in NOI and Authorization to Discharge): This prohibition is based on 40 C.F.R. section 122.21(a) and Water Code section 13260, which require filing an application and Report of Waste Discharge before discharge can occur. Discharges not described in an NOI and Authorization to Discharge are prohibited.
- b. **Discharge Prohibition III.B** (No discharge of earthen materials): This prohibition is based on Basin Plan Table 4-1, Discharge Prohibition 9, which prohibits discharges of silt, sand, clay, or other earthen materials in quantities sufficient to cause deleterious bottom deposits, turbidity, or discoloration in surface waters, or to unreasonably affect or threaten to affect beneficial uses.
- c. **Discharge Prohibition III.C** (No discharge of floating materials): This prohibition is based on Basin Plan Table 4-1, Discharge Prohibitions 8, which prohibits discharges of floating oil or other floating materials in quantities sufficient to cause deleterious bottom deposits, turbidity, or discoloration in surface waters. It is also based on Basin Plan Table 4-1, Discharge Prohibitions 13, which prohibits discharges of oil or any residuary product of petroleum, except in accordance with WDRs.
- d. **Discharge Prohibition III.D** (No storm drain discharge causing scouring, erosion, excessive sedimentation, or flooding): This prohibition is based on the sediment and erosion control goals of Basin Plan section 4.19 and is consistent with the Municipal Regional Stormwater NPDES Permit (Permit No. CAS612008, Order No. R2-2015-0049).
- e. **Discharge Prohibition III.E** (No discharge causing pollution, contamination, or nuisance): This prohibition is based on Water Code section 13050, which prohibits the creation of pollution, contamination, or a nuisance conditions as the result of discharges.
- f. **Discharge Prohibition III.F** (No bypass or overflow of untreated or partially treated groundwater). This prohibition is based on 40 C.F.R. section 122.41(m), which generally prohibits bypasses. Attachment D section I.G provides for circumstances whereby bypasses may be approved.
- g. **Discharge Prohibition III.G** (No water reclamation consisting of recharge or reinjection): This prohibition clarifies that water reclamation activities consisting of recharge or reinjection are beyond the scope of this Order.

2. Exception to Shallow Water and Dead-End Slough Discharge Prohibition

Basin Plan Discharge Prohibition 1 prohibits discharge of “any wastewater which has particular characteristics of concern to beneficial uses at any point at which the wastewater does not receive a minimum initial dilution of at least 10:1....” This prohibition is intended to provide an added degree of protection from the continuous effect of discharges and provide a buffer against the effects of abnormal discharges caused by temporary upsets or malfunctions. As explained in Basin Plan section 4.2, the Regional Water Board reviews requests for exceptions to this prohibition based in part on the reliability of a discharger’s system in preventing inadequately treated wastewater from being discharged to the receiving water. Basin Plan section 4.2 allows exceptions when an inordinate burden would be placed on a discharger relative to the beneficial uses protected and an equivalent level of environmental protection can be achieved by alternate means. An exception to Prohibition 1 will be considered where:

- An inordinate burden would be placed on the Discharger relative to the beneficial uses protected, and an equivalent level of environmental protection can be achieved by alternate means;
- A discharge is approved as part of a reclamation project; or
- Net environmental benefits will be derived as a result of the discharge; or
- A discharge is approved as part of a groundwater cleanup project and, in accordance with Resolution No. 88-160 “Regional Board Position on the Disposal of Extracted Groundwater from Groundwater Clean-Up Projects,” it has been demonstrated that neither reclamation nor discharge to a publicly owned treatment works is technically and economically feasible, and the discharger has provided certification of the adequacy and reliability of treatment facilities and a plan that describes procedures for proper operation and maintenance of all treatment facilities.

The Basin Plan further states:

Significant factors to be considered by the Regional Water Board in reviewing requests for exceptions will be the reliability of the discharger’s system in preventing inadequately treated wastewater from being discharged to the receiving water and the environmental consequences of such discharges.

This Order requires Dischargers to document in their NOIs that neither reclamation nor discharge to a POTW is technically and economically feasible. In addition, Dischargers are required to document how they will reliably prevent discharges of inadequately treated waste as prohibited by Discharge Prohibition III.F.

B. Technology-Based Effluent Limitations

1. Scope and Authority

CWA section 301(b) and 40 C.F.R. section 122.44 require that permits include conditions meeting technology-based requirements at a minimum and any more stringent effluent

limitations necessary to meet water quality standards. The CWA requires that technology-based effluent limitations (TBELs) be established based on several levels of control:

- a. Best practicable treatment control technology (BPT).** BPT represents the average of the best existing performance by well-operated facilities within an industrial category or subcategory. BPT standards apply to toxic, conventional, and non-conventional pollutants.
- b. Best available technology economically achievable (BAT).** BAT represents the best existing performance of treatment technologies that are economically achievable within an industrial point source category. BAT standards apply to toxic and non-conventional pollutants.
- c. Best conventional pollutant control technology (BCT).** BCT represents the control from existing industrial point sources of conventional pollutants, including biochemical oxygen demand, total suspended solids, fecal coliform, pH, and oil and grease. BCT standards are established after considering a two-part reasonableness test. The first test compares the relationship between the costs of attaining a reduction in effluent discharge and the resulting benefits. The second test examines the cost and level of reduction of pollutants from the discharge from publicly owned treatment works to the cost and level of reduction of such pollutants from a class or category of industrial sources. Effluent limitations must be reasonable under both tests.
- d. New source performance standards (NSPS).** NSPS represent the best available demonstrated control technology standards. The intent of NSPS guidelines is to set limitations that represent state-of-the-art treatment technology for new sources.

The CWA requires U.S. EPA to develop effluent limitations, guidelines, and standards representing application of BPT, BAT, BCT, and NSPS. CWA section 402(a)(1) and 40 C.F.R. section 125.3 authorize the use of best professional judgment (BPJ) to derive technology-based effluent limitations on a case-by-case basis when U.S. EPA has not promulgated effluent limitations, guidelines, and standards. When best professional judgment is used, the Regional Water Board must consider specific factors outlined in 40 C.F.R. section 125.3.

2. Applicable Limitations

The TBELs in this Order are based on BPJ, considering all reasonably available and pertinent data and information. The treatment systems regulated by this Order remove organic compounds, including VOCs and petroleum compounds, using such technologies as air stripping and activated carbon. Nationwide, U.S. EPA reports that granular activated carbon adsorption systems (GAC) are the most commonly used groundwater treatment method (Virginia State Water Control Board. USEPA Model General Permit and the Fact Sheet for Permit No. VAG83, December, 1997). Air stripping and GAC, used separately or in conjunction with one another, can achieve pollutant removal efficiencies between 95 and 99.5 percent for groundwater pump-and-treat waste streams (U.S. EPA. A Citizen's Guide to Activated Carbon Treatment, USEPA 542-F-12-001, September 2012). When properly designed and operated, these treatment systems can lower the concentration of all VOC and fuel-related pollutants with TBELs to levels below analytical detection limits.

This Order's TBELs are based on the Basin Plan and historical discharge data submitted by Dischargers enrolled under the previous order. The TBELs are the 99th percentile effluent concentration for each pollutant and are expressed as maximum daily effluent limitations. Considering all reported data, 99 percent are below the 99th percentile. Although there have been occasional exceedances, Dischargers generally manage their treatment systems such that compliance with these TBELs is feasible; many Dischargers have never exceeded these concentrations. Based on the historical record, there is only a 1 percent chance that a particular effluent sample would exceed the 99th percentile.

The TBELs are derived from effluent data collected between 2015 and 2016 at 30 permitted facilities. The data were censored to include only the following:

- Effluent data from GAC treatment systems,
- Effluent data reported with corresponding influent data above method detection limits,
- Effluent data not exceeding previous effluent limitations, and
- Effluent data reported with corresponding reporting levels and method detection limits.

When the 99th percentile can only be estimated because it is below the corresponding reporting level or SIP minimum level, the TBEL selected is the lowest corresponding SIP minimum level or, if no SIP minimum level is available, the lowest corresponding reporting level found among the available monitoring data.

Table F-2. Technology-Based Effluent Limitations

Pollutant	Maximum Daily Effluent Limit (µg/L)
Benzene	0.50 ^[2]
Chloroform	1.9 ^[1]
1,1-Dichloroethane	0.50 ^[2]
1,2-Dichloroethane	0.50 ^[2]
1,1-Dichloroethylene	0.50 ^[2]
Ethylbenzene	0.50 ^[2]
Tetrachloroethylene	0.50 ^[2]
Toluene	0.50 ^[2]
Cis-1,2-Dichloroethylene	0.50 ^[2]
Trans-1,2-Dichloroethylene	0.50 ^[2]
1,1,1-Trichloroethane	0.50 ^[2]
1,1,2-Trichloroethane	0.50 ^[2]
Trichloroethylene	0.65 ^[1]
Vinyl Chloride	0.90 ^[1]
Total Xylenes	0.50 ^[3]
MTBE	0.50 ^[3]
TPH as gasoline	50 ^[3]
TPH as diesel	50 ^[1]
TPH as motor oil	100 ^[3]
Total Residual Chlorine	0.0 ^[4]
pH	6.5 – 8.5 ^[4]

Abbreviation:

µg/L = micrograms per liter

Footnotes:

- (1) Based on 99th percentile
- (2) Based on lowest SIP minimum level
- (3) Based on lowest reporting level reported
- (4) Based on Basin Plan Table 4-2

In establishing these TBELs, the Regional Water Board considered the factors specified in 40 C.F.R. section 125.3(d), as indicated in the table below:

Table F-3. Factors Considered Pursuant to 40 C.F.R. section 125.3(d)(1)

Factors	Considerations
Cost relative to benefits	The cost of imposing these TBELs is reasonable given that existing Dischargers can comply without modifying their existing treatment processes.
Comparison of cost and pollutant reductions from publicly owned treatment works to cost and pollutant reductions from facilities subject to this permit	The facilities subject to this Order provide treatment through means such as air stripping and activated carbon. Such treatment systems are readily commercially available at costs considerably less than the cost of operating publicly owned treatment works, which must comply with the secondary treatment standards of 40 C.F.R. section 133.
Age of equipment and facilities	The TBELs can be met with existing equipment and facilities.
Processes employed	The TBELs can be met with existing processes.
Engineering aspects of application of control techniques	The existing controls are practicable and capable of meeting the TBELs.
Process changes	No process changes are necessary to meet the TBELs.
Non-water-quality environmental impact (including energy requirements)	Because no process changes are necessary, no non-water-quality impacts are foreseeable.

C. Water Quality-Based Effluent Limitations

1. Scope and Authority

This Order contains water quality-based effluent limitations (WQBELs) that implement water quality objectives that protect beneficial uses. CWA section 301(b) and 40 C.F.R. section 122.44(d) require that permits include limitations more stringent than federal technology-based requirements where necessary to achieve applicable water quality standards. According to 40 C.F.R. section 122.44(d)(1)(i), permits must include effluent limitations for all pollutants that are or may be discharged at levels that have a reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective, WQBELs must be established using (1) U.S. EPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting a narrative criterion, supplemented with relevant information (40 C.F.R. § 122.44[d][1][vi]). The process for determining reasonable potential and calculating WQBELs is intended to achieve applicable water quality objectives and criteria and to protect designated uses of receiving waters as specified in the Basin Plan. This Order imposes WQBELs for pollutants with reasonable potential to cause or contribute to

exceedances of water quality standards. For parameters with both TBELs and WQBELs, the more stringent limits apply.

2. Beneficial Uses and Water Quality Criteria and Objectives

Fact Sheet section III.C.1 identifies the potential beneficial uses of the receiving waters for discharges subject to this Order. Water quality criteria and objectives to protect these beneficial uses are described below.

- a. **Basin Plan.** The Basin Plan specifies numeric water quality objectives for many pollutants to protect aquatic life and municipal and agricultural water supplies. These include, among others, primary and secondary MCLs (see Basin Plan sections 3.3.21 and 3.3.22). To protect receiving waters with municipal and domestic supply (MUN), groundwater recharge (GWR), and freshwater replenishment (FRESH) beneficial uses, this Order incorporates a numeric criterion of 1.0 µg/L for 1,4-dioxane, which is the drinking water notification level the Division of Drinking Water established in November 2010. Notification levels are health-based advisory levels established for chemicals in drinking water that lack an MCL. A numeric effluent limitation for 1,4-dioxane is necessary for the protection of the MUN, GWR, and FRESH beneficial uses as authorized under Water Code section 13377.
- b. **CTR.** The CTR specifies numeric aquatic life and human health criteria for numerous priority pollutants. These criteria apply to inland surface waters and enclosed bays and estuaries. Some human health criteria are for consumption of “water and organisms” and others are for consumption of “organisms only.” Waters with the municipal or domestic supply beneficial use designation are subject to the “water and organisms” criteria.
- c. **NTR.** The NTR establishes numeric aquatic life criteria for a number of pollutants for San Francisco Bay waters upstream to and including Suisun Bay and the San Joaquin-Sacramento River Delta.
- d. **Sediment Quality Objectives.** The *Water Quality Control Plan for Enclosed Bays and Estuaries—Part 1, Sediment Quality* contains a narrative water quality objective: “Pollutants in sediments shall not be present in quantities that, alone or in combination, are toxic to benthic communities in bays and estuaries of California.” This objective is to be implemented by integrating three lines of evidence: sediment toxicity, benthic community condition, and sediment chemistry. The policy requires that if the Regional Water Board determines that a discharge has reasonable potential to cause or contribute to an exceedance of this objective, it is to impose the objective as a receiving water limit.
- e. **Receiving Water Salinity.** Basin Plan section 4.6.2 (like the CTR and the NTR) states that the salinity characteristics (i.e., freshwater versus saltwater) of the receiving water are to be considered in determining the applicable water quality objectives. Freshwater criteria apply to discharges to waters with salinities equal to or less than one part per thousand (ppt) at least 95 percent of the time. Saltwater criteria apply to discharges to waters with salinities equal to or greater than 10 ppt at least 95 percent of the time in a normal water year. For discharges to waters with salinities between these two categories, or tidally-influenced freshwaters that support estuarine beneficial uses, the applicable

water quality objectives are the lower of the salt or freshwater objectives (the latter calculated based on ambient hardness) for each substance.

Receiving waters for the discharges this Order covers include San Francisco Bay, other estuarine and tidally-influenced waters, and inland freshwaters. The reasonable potential analyses and WQBELs are based on the more stringent of the freshwater and saltwater criteria to fully protect all receiving waters.

The Basin Plan implements State Water Board Resolution No. 88-63, which establishes State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply (MUN). Because of the marine influence on all reaches of San Francisco Bay and other tidally influenced waters, total dissolved solids levels exceed 3,000 mg/L and thereby meet an exception to State Water Board Resolution No. 88-63. For this reason, waters with and without the MUN designation are considered separately below with respect to the need for, and calculation of, WQBELs.

- f. Receiving Water Hardness.** Some freshwater objectives for metals are hardness dependent (as hardness increases, the toxicity of certain metals decreases). In determining the freshwater water quality objectives that depend on hardness, a hardness value of 100 mg/L as CaCO₃ was used, which is conservative and generally protective of aquatic life in all circumstances contemplated by this permit. Mean and median hardness data collected through the Surface Water Ambient Monitoring Program are 250 mg/L and 232 mg/L. Values less than 100 mg/L were found primarily in Marin County, where dewatering activities rarely occur.
- g. Site Specific Translators.** NPDES regulations at 40 C.F.R. 122.45(c) require that effluent limitations for metals be expressed as total recoverable metal. Since water quality objectives for metals are typically expressed as dissolved metal, translators must be used to convert metals concentrations from dissolved to total recoverable and vice versa. The CTR includes default translators; however, site-specific conditions, such as water temperature, pH, suspended solids, and organic carbon affect the form of metal (dissolved, non-filterable, or otherwise) present in the water and therefore available to cause toxicity. In general, the dissolved form of the metal is more available and more toxic to aquatic life than non-filterable forms. Site-specific translators can be developed to account for site-specific conditions, thereby preventing exceedingly stringent or under protective water quality objectives.

This Order covers discharges to various receiving waters; therefore, site-specific conditions vary. CTR default translators were used for all metals, except for copper and nickel within the context of San Francisco Bay. The Suisun Bay, San Pablo Bay, Central San Francisco Bay, and Lower San Francisco Bay translators specified in Basin Plan Table 7.2.1-2 were used for copper. The South San Francisco Bay translators specified in Basin Plan Table 7.2.1-1 were used for copper and nickel. The North and Central San Francisco Bay translators for nickel recommended by the Clean Estuary Partnership's *North of Dumbarton Bridge Copper and Nickel Development and Selection of Final Translators (2005)* were used for Suisun Bay, San Pablo Bay, Central San Francisco Bay, and Lower San Francisco Bay.

Table F-4. Copper and Nickel Translators

San Francisco Bay Segment	Copper		Nickel	
	AMEL Translator	MDEL Translator	AMEL Translator	MDEL Translator
Suisun Bay and San Pablo Bay	0.38	0.66	0.27	0.57
Central and Lower San Francisco Bays	0.73	0.87	0.65	0.85
South San Francisco Bay	0.53	0.53	0.44	0.44

3. Need for WQBELs

Assessing whether a pollutant has reasonable potential to exceed a water quality objective is the fundamental step in determining whether a WQBEL is required.

- a. Methodology.** SIP section 1.3 sets forth the methodology used for priority pollutants to assess whether they have reasonable potential to exceed water quality objectives. In this Order, this methodology is also applied to non-priority pollutants as guidance in determining reasonable potential. The analysis begins with identifying the maximum effluent concentration (MEC) observed for each pollutant based on available effluent concentration data and the ambient background concentration (B). SIP section 1.4.3 states that ambient background concentrations are either the maximum ambient concentration observed or, for water quality objectives intended to protect human health, the arithmetic mean of observed concentrations. There are three triggers in determining reasonable potential:
- i. Trigger 1** is activated if the maximum effluent concentration is greater than or equal to the lowest applicable water quality criterion ($MEC \geq$ water quality criterion).
 - ii. Trigger 2** is activated if the ambient background concentration observed in the receiving water is greater than the water quality criterion ($B >$ water quality criterion) *and* the pollutant is detected in any effluent sample.
 - iii. Trigger 3** is activated if a review of other information indicates that a WQBEL is needed to protect beneficial uses.
- b. Effluent Data.** Effluent data from 74 facilities enrolled under the previous order during 2015 were used to characterize discharges and determine whether they have reasonable potential to cause or contribute to an exceedance of water quality criteria.
- c. Ambient Background Data.** The SIP states that, when calculating WQBELs, ambient background concentrations are to be either the observed maximum ambient water column concentrations or, for water quality objectives intended to protect human health from carcinogenic effects, the arithmetic mean of observed ambient water concentrations. Because the receiving waters for discharges from the facilities covered under this permit are varied, and because receiving waters are not expected to contain significant concentrations of VOCs or fuel-related pollutants, receiving water background concentrations were not considered for this analysis.
- d. Reasonable Potential Analyses.** Reasonable potential analyses were conducted for discharges of groundwater treated to remove VOCs and fuel-related pollutants. The MECs for detected parameters and most stringent applicable water quality criteria are

presented in the following tables, along with the analysis results (yes or no) for each pollutant. Reasonable potential was not determined for all pollutants because there are not applicable criteria for all pollutants and monitoring data are unavailable for others. When additional data become available, further analysis will be conducted to determine whether WQBELs are necessary.

Reasonable potential based on Trigger 3 has been determined for antimony, cadmium, chromium III, silver, sulfate, and thallium.

Table F-5. Reasonable Potential Analysis

CTR No.	Pollutant ^[1]	Unit	Governing Criteria	MEC or Minimum DL ^[2]	Result ^[3]
1	Antimony	µg/L	6.0	2.3	Yes ^[4]
2	Arsenic	µg/L	10	14	Yes
4	Cadmium	µg/L	1.1	0.49	Yes ^[4]
5a	Chromium (III)	µg/L	50	38	Yes ^[4]
5b	Chromium (VI)	µg/L	10	38	Yes
6	Copper				
	<i>South SF Bay Discharge</i>	µg/L	13	18	Yes
	<i>Central and Lower SF Bay Discharge</i>	µg/L	8.2	18	Yes
	<i>Suisun or San Pablo Bay Discharge</i>	µg/L	14	18	Yes
	<i>Other Discharge</i>	µg/L	3.7	18	Yes
7	Lead	µg/L	3.2	20	Yes
8	Mercury	µg/L	0.050	10	Yes
9	Nickel				
	<i>South SF Bay Discharge</i>	µg/L	19	130	Yes
	<i>Central and Lower SF Bay Discharge</i>	µg/L	13	130	Yes
	<i>Suisun or San Pablo Bay Discharge</i>	µg/L	30	130	Yes
	<i>Other Discharge</i>	µg/L	8.3	130	Yes
10	Selenium	µg/L	5.0	22	Yes
11	Silver	µg/L	2.2	0.15	Yes ^[4]
12	Thallium	µg/L	1.7	0.73	Yes ^[4]
13	Zinc	µg/L	86	230	Yes
14	Cyanide	µg/L	5.2	2.3	No
19	Benzene	µg/L	1.0	0.9	No
21	Carbon Tetrachloride	µg/L	0.3	ND	No
22	Chlorobenzene	µg/L	680	5.5	No
26	Chloroform	µg/L	No Criteria	4.6	No
27	Dichlorobromomethane	µg/L	0.56	0.35	No
28	1,1-Dichloroethane	µg/L	5.0	3.1	No
29	1,2-Dichloroethane	µg/L	0.38	1.8	Yes
30	1,1-Dichloroethylene	µg/L	0.06	12	Yes
32	1,3-Dichloropropylene	µg/L	0.50	0.011	No
33	Ethylbenzene	µg/L	300	0.09	No

CTR No.	Pollutant ^[1]	Unit	Governing Criteria	MEC or Minimum DL ^[2]	Result ^[3]
35	Methyl Chloride	µg/L	No Criteria	0.77	No
36	Methylene Chloride	µg/L	4.7	1.6	No
38	Tetrachloroethylene	µg/L	0.80	7.4	Yes
39	Toluene	µg/L	150	125	No
40	1,2-Trans-Dichloroethylene	µg/L	10	0.76	No
41	1,1,1-Trichloroethane	µg/L	200	0.6	No
42	1,1,2-Trichloroethane	µg/L	0.60	ND	No
43	Trichloroethylene	µg/L	2.7	270	Yes
44	Vinyl Chloride	µg/L	0.50	1.9	Yes
45	2-Chlorophenol	µg/L	120	0.48	No
57	Acenaphthylene	µg/L	No Criteria	0.03	No
58	Anthracene	µg/L	9,600	0.86	No
60	Benzo(a)Anthracene	µg/L	0.0044	0.8	Yes
61	Benzo(a)Pyrene	µg/L	0.0044	0.43	Yes
62	Benzo(b)Fluoranthene	µg/L	0.0044	0.25	Yes
63	Benzo(ghi)Perylene	µg/L	No Criteria	0.07	No
64	Benzo(k)Fluoranthene	µg/L	0.0044	0.78	Yes
68	Bis(2-Ethylhexyl)Phthalate	µg/L	1.8	7.3	Ud ^[5]
69	4-Bromophenyl Phenyl Ether	µg/L	No Criteria	0.45	No
73	Chrysene	µg/L	0.0044	0.58	Yes
74	Dibenzo(a,h)Anthracene	µg/L	0.0044	0.33	Yes
76	1,3-Dichlorobenzene	µg/L	400	0.017	No
79	Diethyl Phthalate	µg/L	23,000	0.2	No
86	Fluoranthene	µg/L	300	0.32	No
92	Indeno(1,2,3-cd) Pyrene	µg/L	0.0044	0.23	Yes
94	Naphthalene	µg/L	No Criteria	0.56	No
99	Phenanthrene	µg/L	No Criteria	0.6	No
100	Pyrene	µg/L	960	0.36	No
	1,2-Cis-Dichloroethylene	µg/L	6	180	Yes
	1,4-Dioxane	µg/L	1	33	Yes
	Sulfate	mg/L	250	120	Yes^[4]
	Turbidity	NTU	5	19	Yes
	Barium	mg/L	1	0.84	No
	Manganese	µg/L	50	1,900	Yes
	Total Xylenes	µg/L	1,750	0.38	No
	Methyl Tertiary Butyl Ether (MTBE)	µg/L	13	4.4	No
	Total Petroleum Hydrocarbons (TPH)	µg/L	No Criteria	4,200	No
	Ethylene Dibromide	µg/L	0.05	ND	No
	Trichlorotrifluoroethane	µg/L	1,200	1.6	No

Footnotes:

^[1] This list contains the CTR priority pollutants and, when data are available, other pollutants for which water quality objectives exist to protect municipal supply, groundwater recharge, or agricultural supply beneficial uses.

- [2] The Maximum Effluent Concentration (MEC) is the actual detected concentration unless preceded by a “<” sign, in which case the value shown is the minimum detection level (DL).
- [3] Results = Yes, if MEC ≥ WQC or Trigger 3;
 = No, if MEC < WQC or all effluent data are undetected;
 = Unknown (U), if no water quality criteria are available or data are insufficient.
- [4] Determination based on Trigger 3. Reasonable potential has been determined based on groundwater quality data communicated by prospective permit enrollees which show that standard treatment for VOCs, fuel leaks, or fuel-related pollutants may not treat these pollutants below water quality criterion.
- [5] Effluent data indicates exceedances of water quality criteria for bis(2-ethylhexyl)phthalate. However bis(2-ethylhexyl)phthalate is a common laboratory contaminant and is not anticipated to be a pollutant of concern for the type of effluent this Order allows. This Order requires sampling for bis(2-ethylhexyl)phthalate to be performed using ultra clean sampling techniques for re-evaluation during future permit reissuance.

e. Acute Toxicity. This Order contains WQBELs for acute toxicity because Basin Plan Table 4-3 requires them.

f. Reasonable Potential Analysis for Sediment Quality Objectives. Pollutants in some receiving water sediments may be present in quantities that alone or in combination are toxic to benthic communities. Efforts are underway to identify stressors causing such conditions. However, to date there is no evidence directly linking compromised sediment conditions to the discharges subject to this Order; therefore the Regional Water Board cannot draw a conclusion about the reasonable potential for the discharges to cause or contribute to exceedances of sediment quality objectives. Nevertheless, the Regional Monitoring Program continues to monitor San Francisco Bay sediment and seeks to identify stressors responsible for degraded sediment quality. Thus far, the monitoring has provided only limited information about potential stressors and sediment transport. The Regional Water Board is exploring appropriate requirements to impose on dischargers in the region, to obtain additional information that may inform future reasonable potential analyses.

4. WQBELs Calculations

The table below summarizes the WQBEL calculations based on human health, aquatic life, and drinking water standards (MCLs). WQBELs were calculated for each pollutant determined to have reasonable potential to cause or contribute to an exceedance of a water quality objective. As explained below, in most cases, the calculations are based on the procedures specified in SIP section 1.4. The most stringent WQBELs are shown in bold.

Table F-6. Summary of WQBELs

Pollutant	CTR-Human Health				CTR-Aquatic Life		MCLs	
	Discharges to Receiving Waters Used as Drinking Water		Discharges to Other Receiving Waters		Discharges to All Receiving Waters		Discharges to Receiving Waters Used as Drinking Water	
	AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)
Antimony, Total Recoverable	14	28	4,300	8,600	---	---	6.0	12
Arsenic, Total Recoverable	---	---	---	---	30.	59	10.	20
Cadmium, Total Recoverable	---	---	---	---	0.90	1.8	---	---

Pollutant	CTR-Human Health				CTR-Aquatic Life		MCLs	
	Discharges to Receiving Waters Used as Drinking Water		Discharges to Other Receiving Waters		Discharges to All Receiving Waters		Discharges to Receiving Waters Used as Drinking Water	
	AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)
Chromium III	---	---	---	---	170	340	50	100
Chromium VI	---	---	---	---	8.1	16	10	20
Copper, Total Recoverable								
<i>South SF Bay</i>	1,300	2,600	---	---	10	20	1,300	2,600
<i>Central or Lower SF Bay</i>	1,300	2,600	---	---	5.4	11.	1,300	2,600
<i>Suisun or San Pablo Bay</i>	1,300	2,600	---	---	7.1	14.	1,300	2,600
<i>Other</i>	1,300	2,600	---	---	2.9	5.8	1,300	2,600
Lead, Total Recoverable	---	---	---	---	2.6	5.2	15	30
Mercury, Total Recoverable	0.05	0.10	0.05	0.10	---	---	2.0	4.0
Nickel, Total Recoverable								
<i>South SF Bay</i>	610	1,200	4,600	9,200	15	31	100	200
<i>Central or Lower SF Bay</i>	610	1,200	4,600	9,200	10	21	100	200
<i>Suisun or San Pablo Bay</i>	610	1,200	4,600	9,200	25.	50	100	200
<i>Other</i>	610	1,200	4,600	9,200	6.8	14	100	200
Selenium, Total Recoverable	---	---	---	---	4.1	8.2	50	100
Silver, Total Recoverable	---	---	---	---	1.1	2.2	---	---
Thallium, Total Recoverable	---	---	6.3	13	---	---	2.0	4.0
Zinc, Total Recoverable	---	---	---	---	47	95	---	---
1,2-Dichloroethane	0.38	0.76 ^[1]	99	200	---	---	0.50	1.0
1,1-Dichloroethylene	0.057	0.11	3.2	6.4	---	---	6.0	12
Tetrachloroethylene	0.8	1.6	8.9	18	---	---	5.0	10
Cis-1,2-Dichloroethylene	---	---	---	---	---	---	6.0	12
1,4-Dioxane	---	---	---	---	---	---	1.0	2.0
Trichloroethylene	2.7	5.4	81	160	---	---	5.0	10
Vinyl Chloride	2.0	4.0	530	1,100	---	---	0.50	1.0
Benzo(a)Anthracene	0.0044	0.0088	0.049	0.098	---	---	---	---
Benzo(a)Pyrene	0.0044	0.0088	0.049	0.098	---	---	0.20	0.40
Benzo(b)Fluoranthene	0.0044	0.0088	0.049	0.098	---	---	---	---
Benzo(k)Fluoranthene	0.0044	0.0088	0.049	0.098	---	---	---	---
Chrysene	0.0044	0.0088	0.049	0.098	---	---	---	---
Dibenzo(a,h)Anthracene	0.0044	0.0088	0.049	0.098	---	---	---	---

Pollutant	CTR-Human Health				CTR-Aquatic Life		MCLs	
	Discharges to Receiving Waters Used as Drinking Water		Discharges to Other Receiving Waters		Discharges to All Receiving Waters		Discharges to Receiving Waters Used as Drinking Water	
	AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)
Indeno(1,2,3-cd) Pyrene	0.0044	0.0088	0.049	0.098	---	---	---	---
Sulfate	---	---	---	---	---	---	250,000	500,000
Manganese	---	---	---	---	---	---	50	100
Turbidity	---	---	---	---	---	---	5.0 (NTU)	10 (NTU)

Abbreviations:

µg/L = micrograms per liter

NTU = nephelometric turbidity unit

Footnote:

⁽¹⁾ The calculated MDEL for 1,2-dichloroethane of 0.76 µg/L is less stringent than the MDEL of 0.5 µg/L established in the previous order. The MDEL of 0.5 µg/L has been retained from the previous order to avoid backsliding.

- a. Mixing Zones and Dilution.** This Order does not establish any mixing zone for any discharge; therefore, the WQBELs are calculated without accounting for any dilution credits. This Order authorizes discharges to many types of receiving waters, the majority of which are anticipated to be storm drain systems that discharge to rivers, creeks, and streams. Many of these receiving waters are likely dry during the summer months, and thus dilution credits are inappropriate.
- b. WQBELs Based on Human Health Criteria.** WQBELs for pollutants that demonstrate reasonable potential based on CTR human health criteria are calculated in accordance with SIP section 1.4. The average monthly effluent limitations (AMELs) are set equal to the criteria. The maximum daily effluent limitations (MDELs) are calculated by multiplying the AMEL by an MDEL/AMEL multiplier of 2.01, which is derived from a default effluent data coefficient of variation (CV) of 0.60.
- c. WQBELs Based on Aquatic Life Criteria.** WQBELs for pollutants that demonstrate reasonable potential based on Basin Plan and CTR aquatic life criteria are calculated in accordance with SIP section 1.4 with a default coefficient of variation of 0.6.

Table F-7. Aquatic Life-Based WQBELs

Pollutant	Arsenic	Cadmium	Chromium III	Chromium VI
Units	µg/L	µg/L	µg/L	µg/L
Criteria –Acute	69	3.9	1,737	16
Criteria –Chronic	36	1.1	207	11
No. of samples per month	4	4	4	4
ECA acute	69	3.9	1,737	16
ECA chronic	36	1.1	207	11
CV (selected)	0.6	0.6	0.6	0.6
ECA acute mult99	0.32	0.32	0.32	0.32
ECA chronic mult99	0.53	0.53	0.53	0.53
LTA acute	22	1.3	558	5.2

Pollutant	Arsenic	Cadmium	Chromium III	Chromium VI
Units	µg/L	µg/L	µg/L	µg/L
LTA chronic	19	0.6	109	6.0
minimum of LTAs	19	1.3	109	5.2
AMEL mult95	1.6	1.6	1.6	1.6
MDEL mult99	3.1	3.1	3.1	3.1
AMEL (aq life)	30	0.9	170	8.1
MDEL(aq life)	59	1.8	340	16
MDEL/AMEL Multiplier	2.01	2.01	2.01	2.01
AMEL (human hlth)	-----	-----	-----	-----
MDEL (human hlth)	-----	-----	-----	-----
minimum of AMEL for Aq. life vs HH	30	0.9	170	8.1
Final limit - AMEL	30	0.9	170	8.1
Final limit - MDEL	59	1.8	340	16

Abbreviation:

µg/L = micrograms per liter

Table F-7. Aquatic Life-Based WQBELs (Continued)

Pollutant	Lead	Selenium	Silver	Zinc
Units	µg/L	µg/L	µg/L	µg/L
Criteria –Acute	82	20	2.2	95
Criteria –Chronic	3.2	5	-----	86
No. of samples per month	4	4	4	4
ECA acute	82	20	2.2	95
ECA chronic	3.2	5	-----	86
CV (selected)	0.6	0.6	0.6	0.6
ECA acute mult99	0.32	0.32	0.32	0.32
ECA chronic mult99	0.53	0.53	0.53	0.53
LTA acute	26	6.4	0.70	31
LTA chronic	1.7	2.6	-----	45
minimum of LTAs	1.7	2.6	0.70	31
AMEL mult95	1.6	1.6	1.6	1.6
MDEL mult99	3.1	3.1	3.1	3.1
AMEL (aq life)	2.6	4.1	1.1	47
MDEL(aq life)	5.2	8.2	2.2	95
MDEL/AMEL Multiplier	2.01	2.01	2.01	2.01
AMEL (human hlth)	-----	-----	-----	-----
MDEL (human hlth)	-----	-----	-----	-----
minimum of AMEL for Aq. life vs HH	2.6	4.1	1.1	47
Final limit - AMEL	2.6	4.1	1.1	47
Final limit - MDEL	5.2	8.2	2.2	95

Abbreviation:

µg/L = micrograms per liter

Table F-8. Aquatic Life-Based WQBELs (Copper)

Pollutant	Copper	Copper	Copper	Copper
Units	µg/L	µg/L	µg/L	µg/L
Basis and criteria type	CTR aquatic life	Basin Plan SSO South SF Bay	Basin Plan SSO Central and Lower SF Bays	Basin Plan SSO San Pablo and Suisun Bays
Criteria –Acute	5.8	-----	-----	-----
Criteria –Chronic	3.7	-----	-----	-----
SSO Criteria – Acute	-----	10.8	9.4	9.4
SSO Criteria – Chronic	-----	6.9	6.0	6.0
Site Specific Translator – MDEL	-----	0.53	0.87	0.66
Site Specific Translator - AMEL	-----	0.53	0.73	0.38
No. of samples per month	4	4	4	4
ECA acute	5.8	20	11	14
ECA chronic	3.7	13	8.2	16
CV (selected)	0.6	0.6	0.6	0.6
ECA acute mult99	0.32	0.32	0.32	0.32
ECA chronic mult99	0.53	0.53	0.53	0.53
LTA acute	1.9	6.5	3.5	4.6
LTA chronic	2.0	6.9	4.3	8.3
minimum of LTAs	1.9	6.5	3.5	4.6
AMEL mult95	1.6	1.6	1.6	1.6
MDEL mult99	3.1	3.1	3.1	3.1
AMEL (aq life)	2.9	10	5.4	7.1
MDEL(aq life)	5.8	20	11	14
MDEL/AMEL Multiplier	2.01	2.01	2.01	2.01
AMEL (human hlth)	1,300	1,300	1,300	1,300
MDEL (human hlth)	2,613	2,613	2,613	2,613
minimum of AMEL for Aq. life vs HH	2.9	10	5.4	7.1
Final limit - AMEL	2.9	10	5.4	7.1
Final limit - MDEL	5.8	20	11	14

Abbreviation:

µg/L = micrograms per liter

Table F-8. Aquatic Life-Based WQBELs (Nickel)

Pollutant	Nickel	Nickel	Nickel	Nickel
Units	µg/L	µg/L	µg/L	µg/L
Basis and criteria type	CTR aquatic life	Basin Plan SSO South SF Bay	Basin Plan SSO Central and Lower SF Bays	Basin Plan SSO San Pablo and Suisun Bays
Criteria –Acute	75	-----	-----	-----
Criteria –Chronic	8.3	-----	-----	-----
SSO Criteria – Acute	-----	74	74	74
SSO Criteria – Chronic	-----	8.2	8.2	8.2
Site Specific Translator – MDEL	-----	0.44	0.85	0.57
Site Specific Translator - AMEL	-----	0.44	0.65	0.27
No. of samples per month	4	4	4	4
ECA acute	75	170	87	130

Pollutant	Nickel	Nickel	Nickel	Nickel
Units	µg/L	µg/L	µg/L	µg/L
ECA chronic	8.3	19	13	30
CV (selected)	0.6	0.6	0.6	0.6
ECA acute mult99	0.32	0.32	0.32	0.32
ECA chronic mult99	0.53	0.53	0.53	0.53
LTA acute	24	54	28	24
LTA chronic	4.4	9.8	6.7	16
minimum of LTAs	4.4	9.8	6.7	16
AMEL mult95	1.6	1.6	1.6	1.6
MDEL mult99	3.1	3.1	3.1	3.1
AMEL (aq life)	6.8	15	10	25
MDEL(aq life)	14	31	21	50
MDEL/AMEL Multiplier	2.01	2.01	2.01	2.01
AMEL (human hlth)	610	610	610	610
MDEL (human hlth)	1,200	1,200	1,200	1,200
minimum of AMEL for Aq. life vs HH	6.8	15	10	25
Final limit - AMEL	6.8	15	10	25
Final limit - MDEL	14	31	21	50

Abbreviation:

µg/L = micrograms per liter

- d. WQBELs Based on MCLs.** WQBELs for pollutants that demonstrate reasonable potential based on the MCLs listed in the California Code of Regulations, title 22, sections 64431, 64444, and 64449 are calculated using SIP section 1.4 as guidance. These limits apply to discharges to waters with the MUN or GWR designations. The AMELs are set equal to the MCLs. The MDELs are calculated by multiplying the AMEL by an MDEL/AMEL multiplier of 2.01, which is derived from a default effluent data CV of 0.60.
- e. 1,4-Dioxane WQBELs.** The 1,4-dioxane WQBELs are based on the drinking water notification level established to protect human health (see Fact Sheet section IV.C.2.a). They were calculated in the same manner as the WQBELs based on MCLs.
- f. Acute Toxicity WQBELs.** The acute toxicity WQBELs are based on Basin Plan Table 4-3 (continuous discharge/quarterly or annual tests).

D. Discharge Requirement Considerations

- 1. Anti-backsliding.** This Order complies with the anti-backsliding provisions of CWA sections 402(o) and 303(d)(4) and 40 C.F.R. section 122.44(l), which generally require effluent limitations in a reissued permit to be as stringent as those in the previous permit. The requirements of this Order are at least as stringent as those in the previous order. Effluent limitations for carbon tetrachloride, ethylene dibromide, and trichlorotrifluoroethane have not been retained in this Order because no reasonable potential was found and discharge monitoring data indicate that they are rarely detected. State Water Board Order WQ 2001-16 found that anti-backsliding does not require a permit in such circumstances.

- 2. Antidegradation.** This Order is consistent with the antidegradation provisions of 40 C.F.R. section 131.12 and State Water Board Resolution No. 68-16. It continues the status quo with respect to the discharges authorized in the previous order. It does not allow for a reduced level of treatment or less stringent effluent limitations. It holds Dischargers to the same performance or better.
- 3. Stringency of Requirements for Individual Pollutants.** This Order contains both TBELs and WQBELs for individual pollutants. Its technology-based requirements implement minimum applicable federal technology-based requirements. In addition, this Order contains more stringent effluent limitations as necessary to meet water quality standards. Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement CWA requirements.

This Order's WQBELs have been derived to implement water quality objectives that protect beneficial uses. The beneficial uses and water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 C.F.R. section 131.38. The procedures for calculating these WQBELs are based on the CTR, as implemented in accordance with the SIP, which U.S. EPA approved on May 18, 2000. U.S. EPA approved most Basin Plan beneficial uses and water quality objectives prior to May 30, 2000. Beneficial uses and water quality objectives submitted to U.S. EPA prior to May 30, 2000, but not approved by U.S. EPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to 40 C.F.R. section 131.21(c)(1). U.S. EPA approved the remaining beneficial uses and water quality objectives so they are applicable water quality standards pursuant to 40 C.F.R. section 131.21(c)(2).

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

The receiving water limits are based on the water quality objectives listed in Basin Plan chapter 3 and are intended to ensure that receiving waters meet water quality standards in accordance with the CWA and regulations adopted thereunder.

VI. RATIONALE FOR PROVISIONS

A. Standard Provisions

Attachment D contains standard provisions that apply to all NPDES permits in accordance with 40 C.F.R. section 122.41 and additional conditions applicable to specific categories of permits in accordance with 40 C.F.R. section 122.42. Dischargers must comply with these provisions. The conditions set forth in 40 C.F.R. sections 122.41(a)(1) and (b) through (n) apply to all state-issued NPDES permits and must be incorporated into the permits either expressly or by reference.

In accordance with 40 C.F.R. section 123.25(a)(12), states may omit or modify conditions to impose more stringent requirements. This Order contains provisions that supplement the federal standard provisions in Attachment D. This Order omits federal conditions that address enforcement authority specified in 40 C.F.R. sections 122.41(j)(5) and (k)(2) because the State's enforcement authority under the Water Code is more stringent. In lieu of these conditions, this Order incorporates Water Code section 13387(e) by reference.

B. Monitoring and Reporting Provisions

CWA section 308 and 40 C.F.R. sections 122.41(h), 122.41(j)-(l), 122.44(i), and 122.48 require that NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 also authorize the Regional Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. The Monitoring and Reporting Program (MRP) in Attachment E establishes monitoring, reporting, and recordkeeping requirements that implement federal and State requirements. For more information regarding these requirements, see Fact Sheet section VII.

Pursuant to Water Code section 13267, the Executive Officer may specify additional effluent and ambient monitoring requirements in individual Authorizations to Discharge, such as, but not limited to, the following:

1. Monitoring in response to a complaint,
2. Stormwater monitoring,
3. Additional discharge observations, and
4. Additional priority pollutant scans.

The Executive Officer is most likely to specify additional monitoring requirements for Dischargers with flows greater than 10 gallons per minute.

C. Special Provisions

1. Reopener Provisions

These provisions are based on 40 C.F.R. sections 122.62 and 122.63 and allow modification of this Order and its effluent limitations as necessary in response to updated water quality objectives, regulations, or other new and relevant information that may become available in the future, and other circumstances as allowed by law.

2. Application for General Permit Coverage and Authorization to Discharge

Based on 40 C.F.R. section 122.28(b), this provision requires each Discharger to submit an NOI form and, upon receiving an Authorization to Discharge from the Executive Officer, comply with this Order. Pursuant to 40 C.F.R. section 122.28(b)(3), it also authorizes the Executive Officer to terminate any Authorization to Discharge or require a Discharger to apply for an individual permit.

3. Water Reclamation Specifications (Water Reclamation Only)

Water Reclamation Specifications are retained from the previous order. They are required to protect public health and because reclamation of treated groundwater is a preferred method of disposal. The basis for reclamation of treated groundwater is Water Board Resolution No. 88-160.

4. Construction, Operation, and Maintenance Specifications

- a. **Wastewater Facilities Review and Evaluation, and Status Reports.** This provision is to ensure adequate and reliable treatment and disposal of all wastewater and is based on 40 C.F.R. section 122.41(e).
- b. **Operations and Maintenance Manual Review and Status Reports.** This provision is to ensure that operations and maintenance procedures are in place that are useful and relevant to current equipment and operational practices. It is based on 40 C.F.R. section 122.41(e).

5. No Preemption

This Order permits the discharge of treated groundwater to waters of the State subject to the prohibitions, effluent limitations, receiving water limitations, and provisions of this Order. This provision clarifies that the Order does not preempt or supersede the authority of municipalities, flood control agencies, or other agencies to prohibit, restrict, or control discharges to storm drain systems or other watercourses subject to their jurisdiction. For example, this Order provides no water or groundwater rights, and does not preempt the authority of any local or State agency as it relates to water rights.

VII. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

The MRP is a standard requirement in all NPDES permits issued by the Regional Water Board, including this Order. It specifies sampling stations, pollutants to be monitored (including parameters for which effluent limitations are specified), monitoring frequencies, and additional reporting requirements. The principal purposes of a monitoring program are to document compliance with WDRs and prohibitions established by the Regional Water Board; to facilitate self-policing by dischargers in the prevention and abatement of pollution arising from waste discharges; to develop or assist in the development of limitations, discharge prohibitions, national standards of performance, pretreatment and toxicity standards, and other standards; and to prepare water and wastewater quality inventories.

The following provides the rationale for the monitoring and reporting requirements contained in the Monitoring and Reporting Program for this facility:

- A. **Influent Monitoring.** Influent monitoring is necessary to establish that pollutant loadings are below the levels for which the treatment systems were designed and to provide a warning if one or more new pollutants are being extracted that the treatment system may not be designed to remove.
- B. **Effluent Monitoring.** Effluent monitoring is necessary to evaluate compliance with the Order's prohibitions and effluent limitations, and to inform the next permit resissuance. The previous order required monitoring for non-limited parameters, such as 1,4-dioxane, metals, PAHs, TPH as motor oil, turbidity, and sulfate. Monitoring requirements for these pollutants have been updated to ensure compliance with this Order's effluent limitations.
- C. **Acute Toxicity Testing.** Acute toxicity tests are necessary to evaluate compliance with this Order's acute toxicity effluent limitations.

- D. Reclamation Monitoring Requirements.** Reclaimed water monitoring is necessary to ensure that reclamation of treated groundwater does not threaten the quality of any water of the State or create nuisance conditions.
- E. Receiving Water Monitoring.** Receiving water monitoring is necessary to characterize the effects that discharges could have on receiving waters and, in some cases, to evaluate compliance with receiving water limits. Freshwater monitoring is also necessary to calculate some water quality objectives.
- F. Other Monitoring Requirements.** Additional monitoring is necessary to verify that treatment systems will comply with permit requirements before initiating discharge operations, to ensure correct use of chemicals (e.g., coagulants) in accordance to the Authorization to Discharge and guidance documents, and to address performance-related issues in treatment systems and their effects on reclaimed water and receiving water not captured through monitoring analytical methods.

VIII. PUBLIC PARTICIPATION

The Regional Water Board considered the issuance of WDRs that will serve as an NPDES permit for groundwater treatment facilities in the San Francisco Bay Region. As a step in the WDRs adoption process, the Regional Water Board developed tentative WDRs and encouraged public participation in the WDRs adoption process.

- A. Notification of Interested Parties.** The Regional Water Board notified Dischargers and interested agencies and persons of its intent to prescribe WDRs and provided an opportunity to submit written comments and recommendations. Notice of the Regional Water Board's intent to adopt these WDRs was also provided through *The Mercury News in San Jose*. The public had access to the agenda and any changes in dates and locations through the Regional Water Board website at www.waterboards.ca.gov/sanfranciscobay.
- B. Written Comments.** Interested persons were invited to submit written comments concerning the tentative WDRs as explained through the notification process. Comments were due either in person or by mail at the Regional Water Board office at 1515 Clay Street, Suite 1400, Oakland, California 94612, to the attention of Marcos De la Cruz.

For full staff response and Regional Water Board consideration, the written comments were due at the Regional Water Board office by 5:00 p.m. on May 5, 2017.

- C. Public Hearing.** The Regional Water Board held a public hearing on the tentative WDRs during its regular meeting at the following date and time, and at the following location:

Date: Wednesday, November 8, 2017
 Time: 9:00 a.m.
 Location: Elihu Harris State Office Building
 1515 Clay Street, 1st Floor Auditorium
 Oakland, CA 94612

Contact: Marcos De la Cruz, (510) 622-2365, marcos.delacruz@waterboards.ca.gov

Interested persons were invited to attend. At the public hearing, the Regional Water Board heard testimony pertinent to the discharges, WDRs, and permit. For accuracy of the record, important testimony was requested to be in writing.

Dates and venues change. The Regional Water Board web address is www.waterboards.ca.gov/sanfranciscobay, where one could access the current agenda for changes in dates and locations.

- D. Reconsideration of Waste Discharge Requirements.** Any aggrieved person may petition the State Water Board to review the Regional Water Board decision regarding the final WDRs. The State Water Board must receive the petition at the following address within 30 calendar days of the Regional Water Board action:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

For instructions on how to file a petition for review, see www.waterboards.ca.gov/public_notices/petitions/water_quality/wqpetition_instr.shtml.

- E. Information and Copying.** Supporting documents and comments received are on file and may be inspected at the address above at any time between 9:00 a.m. and 5:00 p.m., Monday through Friday. Copying of documents may be arranged by calling (510) 622-2300.
- F. Register of Interested Persons.** Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference the general permit, and provide a name, address, and phone number.
- G. Additional Information.** Requests for additional information or questions regarding this Order should be directed to Marcos De la Cruz at (510) 622-2365 or marcos.delacruz@waterboards.ca.gov

ATTACHMENT G– MINIMUM LEVELS

List of Monitoring Parameters and Analytical Methods

CTR No.	Pollutant/Parameter	Analytical Method ¹	Minimum Levels ² (µg/l)											
			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP
1.	Antimony	204.2					10	5	50	0.5	5	0.5		1000
2.	Arsenic	206.3				20		2	10	2	2	1		1000
3.	Beryllium						20	0.5	2	0.5	1			1000
4.	Cadmium	200 or 213					10	0.5	10	0.25	0.5			1000
5a.	Chromium (III)	SM 3500												
5b.	Chromium (VI)	SM 3500				10	5							1000
	Chromium (total) ³	SM 3500					50	2	10	0.5	1			1000
6.	Copper	200.9					25	5	10	0.5	2			1000
7.	Lead	200.9					20	5	5	0.5	2			10,000
8.	Mercury	1631 (note) ⁴												
9.	Nickel	249.2					50	5	20	1	5			1000
10.	Selenium	200.8 or SM 3114B or C						5	10	2	5	1		1000
11.	Silver	272.2					10	1	10	0.25	2			1000
12.	Thallium	279.2					10	2	10	1	5			1000
13.	Zinc	200 or 289					20		20	1	10			
14.	Cyanide	SM 4500 CN ⁻ C or I				5								
15.	Asbestos (only required for dischargers to MUN waters) ⁵	0100.2 ⁶												
16.	2,3,7,8-TCDD and 17 congeners (Dioxin)	1613												
17.	Acrolein	603	2.0	5										
18.	Acrylonitrile	603	2.0	2										
19.	Benzene	602	0.5	2										
33.	Ethylbenzene	602	0.5	2										
39.	Toluene	602	0.5	2										
20.	Bromoform	601	0.5	2										

¹ The suggested method is the U.S. EPA Method unless otherwise specified (SM = Standard Methods). The Discharger may use another U.S. EPA-approved or recognized method if that method has a level of quantification below the applicable water quality objective. Where no method is suggested, the Discharger has the discretion to use any standard method.

² Minimum levels are from the *State Implementation Policy*. They are the concentration of the lowest calibration standard for that technique based on a survey of contract laboratories. Laboratory techniques are defined as follows: GC = Gas Chromatography; GCMS = Gas Chromatography/Mass Spectrometry; LC = High Pressure Liquid Chromatography; Color = Colorimetric; FAA = Flame Atomic Absorption; GFAA = Graphite Furnace Atomic Absorption; ICP = Inductively Coupled Plasma; ICPMS = Inductively Coupled Plasma/Mass Spectrometry; SPGFAA = Stabilized Platform Graphite Furnace Atomic Absorption (i.e., U.S. EPA 200.9); Hydride = Gaseous Hydride Atomic Absorption; CVAA = Cold Vapor Atomic Absorption; DCP = Direct Current Plasma.

³ Analysis for total chromium may be substituted for analysis of chromium (III) and chromium (VI) if the concentration measured is below the lowest hexavalent chromium criterion (11 µg/l).

⁴ The Discharger shall use ultra-clean sampling (U.S. EPA Method 1669) and ultra-clean analytical methods (U.S. EPA Method 1631) for mercury monitoring. The minimum level for mercury is 2 ng/l (or 0.002 µg/l).

⁵ MUN = Municipal and Domestic Supply. This designation, if applicable, is in the Findings of the permit.

⁶ Determination of Asbestos Structures over 10 [micrometers] in Length in Drinking Water Using MCE Filters, U.S. EPA 600/R-94-134, June 1994.

CTR No.	Pollutant/Parameter	Analytical Method ¹	Minimum Levels ² (µg/l)											
			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP
21.	Carbon Tetrachloride	601	0.5	2										
22.	Chlorobenzene	601	0.5	2										
23.	Chlorodibromomethane	601	0.5	2										
24.	Chloroethane	601	0.5	2										
25.	2-Chloroethylvinyl Ether	601	1	1										
26.	Chloroform	601	0.5	2										
75.	1,2-Dichlorobenzene	601	0.5	2										
76.	1,3-Dichlorobenzene	601	0.5	2										
77.	1,4-Dichlorobenzene	601	0.5	2										
27.	Dichlorobromomethane	601	0.5	2										
28.	1,1-Dichloroethane	601	0.5	1										
29.	1,2-Dichloroethane	601	0.5	2										
30.	1,1-Dichloroethylene or 1,1-Dichloroethene	601	0.5	2										
31.	1,2-Dichloropropane	601	0.5	1										
32.	1,3-Dichloropropylene or 1,3-Dichloropropene	601	0.5	2										
34.	Methyl Bromide or Bromomethane	601	1.0	2										
35.	Methyl Chloride or Chloromethane	601	0.5	2										
36.	Methylene Chloride or Dichloromethane	601	0.5	2										
37.	1,1,2,2-Tetrachloroethane	601	0.5	1										
38.	Tetrachloroethylene	601	0.5	2										
40.	1,2-Trans-Dichloroethylene	601	0.5	1										
41.	1,1,1-Trichloroethane	601	0.5	2										
42.	1,1,2-Trichloroethane	601	0.5	2										
43.	Trichloroethene	601	0.5	2										
44.	Vinyl Chloride	601	0.5	2										
45.	2-Chlorophenol	604	2	5										
46.	2,4-Dichlorophenol	604	1	5										
47.	2,4-Dimethylphenol	604	1	2										
48.	2-Methyl-4,6-Dinitrophenol or Dinitro-2-methylphenol	604	10	5										
49.	2,4-Dinitrophenol	604	5	5										
50.	2-Nitrophenol	604		10										
51.	4-Nitrophenol	604	5	10										
52.	3-Methyl-4-Chlorophenol	604	5	1										
53.	Pentachlorophenol	604	1	5										
54.	Phenol	604	1	1		50								
55.	2,4,6-Trichlorophenol	604	10	10										
56.	Acenaphthene	610 HPLC	1	1	0.5									
57.	Acenaphthylene	610 HPLC		10	0.2									
58.	Anthracene	610 HPLC		10	2									
60.	Benzo(a)Anthracene or 1,2 Benzanthracene	610 HPLC	10	5										
61.	Benzo(a)Pyrene	610 HPLC		10	2									
62.	Benzo(b)Fluoranthene or 3,4 Benzo(b)fluoranthene	610 HPLC		10	10									
63.	Benzo(ghi)Perylene	610 HPLC		5	0.1									
64.	Benzo(k)Fluoranthene	610 HPLC		10	2									
74.	Dibenzo(a,h)Anthracene	610 HPLC		10	0.1									

CTR No.	Pollutant/Parameter	Analytical Method ¹	Minimum Levels ² (µg/l)													
			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP		
86.	Fluoranthene	610 HPLC	10	1	0.05											
87.	Fluorene	610 HPLC		10	0.1											
92.	Indeno(1,2,3-cd) Pyrene	610 HPLC		10	0.05											
100.	Pyrene	610 HPLC		10	0.05											
68.	Bis(2-Ethylhexyl)Phthalate	606 or 625	10	5												
70.	Butylbenzyl Phthalate	606 or 625	10	10												
79.	Diethyl Phthalate	606 or 625	10	2												
80.	Dimethyl Phthalate	606 or 625	10	2												
81.	Di-n-Butyl Phthalate	606 or 625		10												
84.	Di-n-Octyl Phthalate	606 or 625		10												
59.	Benzidine	625		5												
65.	Bis(2-Chloroethoxy)Methane	625		5												
66.	Bis(2-Chloroethyl)Ether	625	10	1												
67.	Bis(2-Chloroisopropyl)Ether	625	10	2												
69.	4-Bromophenyl Phenyl Ether	625	10	5												
71.	2-Chloronaphthalene	625		10												
72.	4-Chlorophenyl Phenyl Ether	625		5												
73.	Chrysene	625		10	5											
78.	3,3'-Dichlorobenzidine	625		5												
82.	2,4-Dinitrotoluene	625	10	5												
83.	2,6-Dinitrotoluene	625		5												
85.	1,2-Diphenylhydrazine (note) ⁷	625		1												
88.	Hexachlorobenzene	625	5	1												
89.	Hexachlorobutadiene	625	5	1												
90.	Hexachlorocyclopentadiene	625	5	5												
91.	Hexachloroethane	625	5	1												
93.	Isophorone	625	10	1												
94.	Naphthalene	625	10	1	0.2											
95.	Nitrobenzene	625	10	1												
96.	N-Nitrosodimethylamine	625	10	5												
97.	N-Nitrosodi-n-Propylamine	625	10	5												
98.	N-Nitrosodiphenylamine	625	10	1												
99.	Phenanthrene	625		5	0.05											
101.	1,2,4-Trichlorobenzene	625	1	5												
102.	Aldrin	608	0.005													
103.	α-BHC	608	0.01													
104.	β-BHC	608	0.005													
105.	γ-BHC (Lindane)	608	0.02													
106.	δ-BHC	608	0.005													
107.	Chlordane	608	0.1													
108.	4,4'-DDT	608	0.01													
109.	4,4'-DDE	608	0.05													
110.	4,4'-DDD	608	0.05													
111.	Dieldrin	608	0.01													
112.	Endosulfan (alpha)	608	0.02													
113.	Endosulfan (beta)	608	0.01													

⁷ Measurement for 1,2-Diphenylhydrazine may use azobenzene as a screen: if azobenzene is measured at >1 ug/l, then the Discharger shall analyze for 1,2-Diphenylhydrazine.

CTR No.	Pollutant/Parameter	Analytical Method ¹	Minimum Levels ² (µg/l)											
			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP
114.	Endosulfan Sulfate	608	0.05											
115.	Endrin	608	0.01											
116.	Endrin Aldehyde	608	0.01											
117.	Heptachlor	608	0.01											
118.	Heptachlor Epoxide	608	0.01											
119-125	PCBs: Aroclors 1016, 1221, 1232, 1242, 1248, 1254, 1260	608	0.5											
126.	Toxaphene	608	0.5											