

STATE OF CALIFORNIA  
REGIONAL WATER QUALITY CONTROL BOARD  
SAN FRANCISCO BAY REGION

STAFF SUMMARY REPORT: James Parrish  
MEETING DATE: September 8, 2021

**ITEM: 6A**

**Sanitary District No. 5 of Marin County, Paradise Cove Treatment Plant and Wastewater Collection System, Tiburon, Marin County – Reissuance of NPDES Permit**

**DISCUSSION:**

This Tentative Order (Appendix A) would reissue the NPDES permit for the District's Paradise Cove Treatment Plant. The plant collects and treats domestic wastewater from an unincorporated area within the Town of Tiburon, serving a population of about 400 people. Its average dry weather design capacity is 0.04 million gallons per day (MGD), and it can treat up to 0.10 MGD during peak wet weather. The plant discharges treated wastewater through a deepwater outfall to Central San Francisco Bay.

The Tentative Order would continue to allow the District to discharge treated wastewater to Central San Francisco Bay. The requirements would also allow the District to replace chlorine disinfection with ultraviolet disinfection.

We did not receive comments on a tentative order circulated for public review. We made minor editorial and formatting changes, but did not substantively revise the Tentative Order; thus we expect it to remain uncontested.

**APPENDIX:**

A. Tentative Order

Appendix A  
Tentative Order