ATTACHMENT G

REGIONAL STANDARD PROVISIONS, AND MONITORING AND REPORTING REQUIREMENTS (SUPPLEMENT TO ATTACHMENT D)

November 2017

Contents

I.	ST	ANDARD PROVISIONS – PERMIT COMPLIANCE	G-1
	A.	Duty to Comply	G-1
	В.	Need to Halt or Reduce Activity Not a Defense	G-1
	C.	Duty to Mitigate	G-1
		1. Contingency Plan	G-1
		2. Spill Prevention Plan	G-2
	D.	Proper Operation and Maintenance	G-2
		1. Operation and Maintenance Manual	G-2
		2. Wastewater Facilities Status Report	G-2
		 Proper Supervision and Operation of Publicly Owned Treatment Works (POTWs) 	
	E.	Property Rights	
	F.	Inspection and Entry	G-2
	G.	Bypass	
	H.	Unset	G-2
	L	Other	G-3
II.	ST	ANDARD PROVISIONS – PERMIT ACTION	G-3
III	. ST	ANDARD PROVISIONS – MONITORING	G-3
111	• • • •	Sampling and Analyses	G-3
	11.	1 Certified Laboratories	G-3
		2 Minimum Levels	
		3 Monitoring Frequency	
	в	Standard Observations	
	Ъ.	1 Receiving Water Observations	
		 Receiving Water Observations Wastewater Effluent Observations 	G.6
		 Wastewater Efficient Observations Beach and Shoreline Observations 	0-0 G-6
		4 Waste Treatment and/or Disposal Facility Parinhery Observations	G 6
TX/	СТ	4. Waste Treatment and/or Disposal Pacinty Periphery Observations	
1 V	. 51	Records to be Maintained	G.6
	A. P	Records of Monitoring	0-0 G 7
	D.	1 Analytical Information	U-7 G 7
		Anarytical Information Disinfection Process	
		2. Distribution Process	G-/
		3. Treatment Process Bypasses	G-7
	C	4. Treatment Facility Overnows	G-7
X 7	C.	Claims of Confidentiality	
ν.	51	ANDAKD PKUVISIUNS – KEPUKTING	G-ð
	A.	Duty to Provide Information	G-8
	В.	Signatory and Certification Requirements	G-8
	C.	Monitoring Reports	G-8
	Б	1. Self-Monitoring Reports	G-8
	D.	Compliance Schedules	G-11
	E.	I wenty-Four Hour Reporting.	G-11
		1. Oil or Other Hazardous Material Spills	G-11
	г	2. Unauthorized Municipal Wastewater Treatment Plant Discharges	G-12
	F.	Planned Changes	G-13
	G.	Anticipated Noncompliance	G-13
	H.	Other Noncompliance	G-13
* **	I.	Uther Information	G-13
VI	. ST	ANDAKD PKUVISION – ENFORCEMENT	G-13

VII. ADDITIONAL PROVISIONS - NOTIFICATION LEVELS	. G-13
VIII. DEFINITIONS	. G-13

REGIONAL STANDARD PROVISIONS, AND MONITORING AND REPORTING REQUIREMENTS

APPLICABILITY

This document supplements the requirements of Federal Standard Provisions (Attachment D). For clarity, these provisions are arranged using to the same headings as those used in Attachment D.

I. STANDARD PROVISIONS - PERMIT COMPLIANCE

- **A. Duty to Comply** Not Supplemented
- B. Need to Halt or Reduce Activity Not a Defense Not Supplemented
- C. Duty to Mitigate Supplement to Attachment D, Provision I.C.
 - 1. Contingency Plan. The Discharger shall maintain a Contingency Plan as prudent in accordance with current facility emergency planning. The Contingency Plan shall describe procedures to ensure that existing facilities remain in, or are rapidly returned to, operation in the event of a process failure or emergency incident, such as employee strike, strike by suppliers of chemicals or maintenance services, power outage, vandalism, earthquake, or fire. The Discharger may combine the Contingency Plan and Spill Prevention Plan (see Provision I.C.2, below) into one document. In accordance with Regional Water Board Resolution No. 74-10, discharge in violation of the permit where the Discharger has failed to develop and implement a Contingency Plan as described below may be the basis for considering the discharge a willful and negligent violation of the permit pursuant to California Water Code section 13387. The Contingency Plan shall, at a minimum, provide for the following:
 - **a.** Sufficient personnel for continued facility operation and maintenance during employee strikes or strikes against contractors providing services;
 - **b.** Maintenance of adequate chemicals or other supplies, and spare parts necessary for continued facility operations;
 - **c.** Emergency standby power;
 - d. Protection against vandalism;
 - e. Expeditious action to repair failures of, or damage to, equipment, including any sewer lines;
 - **f.** Reporting of spills and discharges of untreated or inadequately treated wastes, including measures taken to clean up the effects of such discharges; and
 - **g.** Maintenance, replacement, and surveillance of physical condition of equipment and facilities, including any sewer lines.

- 2. Spill Prevention Plan. The Discharger shall maintain a Spill Prevention Plan to prevent accidental discharges and to minimize the effects of any such discharges. The Spill Prevention Plan shall do the following:
 - **a.** Identify the possible sources of accidental discharge, untreated or partially treated waste bypass, and polluted drainage;
 - **b.** State when current facilities and procedures became operational and evaluate their effectiveness; and
 - **c.** Predict the effectiveness of any proposed facilities and procedures, and provide an implementation schedule with interim and final dates when the proposed facilities and procedures will be constructed, implemented, or operational.

D. Proper Operation and Maintenance - Supplement to Attachment D, Provision I.D

- 1. Operation and Maintenance Manual. The Discharger shall maintain an Operation and Maintenance Manual to provide the plant and regulatory personnel with a source of information describing all equipment, recommended operational strategies, process control monitoring, and maintenance activities. To remain a useful and relevant document, the Operation and Maintenance Manual shall be kept updated to reflect significant changes in treatment facility equipment and operational practices. The Operation and Maintenance Manual shall be maintained in usable condition and be available for reference and use by all relevant personnel and Regional Water Board staff.
- 2. Wastewater Facilities Status Report. The Discharger shall maintain a Wastewater Facilities Status Report and regularly review, revise, or update it, as necessary. This report shall document how the Discharger operates and maintains its wastewater collection, treatment, and disposal facilities to ensure that all facilities are adequately staffed, supervised, financed, operated, maintained, repaired, and upgraded as necessary to provide adequate and reliable transport, treatment, and disposal of all wastewater from both existing and planned future wastewater sources under the Discharger's service responsibilities.
- **3. Proper Supervision and Operation of Publicly Owned Treatment Works (POTWs).** POTWs shall be supervised and operated by persons possessing certificates of appropriate grade pursuant to Title 23, section 3680, of the California Code of Regulations.
- E. Property Rights Not Supplemented
- F. Inspection and Entry Not Supplemented
- G. Bypass Not Supplemented
- H. Upset Not Supplemented

- I. Other Addition to Attachment D
 - 1. Neither the treatment nor the discharge of pollutants shall create pollution, contamination, or nuisance as defined by California Water Code section 13050.
 - 2. Collection, treatment, storage, and disposal systems shall be operated in a manner that precludes public contact with wastewater. If public contact with wastewater could reasonably occur on public property, warning signs shall be posted.
 - **3.** If the Discharger submits a timely and complete Report of Waste Discharge for permit reissuance, this permit shall continue in force and effect until the permit is reissued or the Regional Water Board rescinds the permit.

II. STANDARD PROVISIONS – PERMIT ACTION – Not Supplemented

III.STANDARD PROVISIONS – MONITORING

- A. Sampling and Analyses Supplement to Attachment D, Provisions III.A and III.B
 - **1.** Certified Laboratories. Water and waste analyses shall be performed by a laboratory certified for these analyses in accordance with California Water Code section 13176.
 - 2. Minimum Levels. For the 126 priority pollutants, the Discharger should use the analytical methods listed in Table B unless the Monitoring and Reporting Program (MRP, Attachment E) requires a particular method or minimum level (ML). All monitoring instruments and equipment shall be properly calibrated and maintained to ensure accuracy of measurements.
 - 3. Monitoring Frequency. The MRP specifies the minimum sampling and analysis schedule.

a. Sample Collection Timing

- i. The Discharger shall collect influent samples on varying days selected at random and shall not include any plant recirculation or other sidestream wastes, unless otherwise stipulated in the MRP. The Executive Officer may approve an alternative influent sampling plan if it is representative of plant influent and complies with all other permit requirements.
- **ii.** The Discharger shall collect effluent samples on days coincident with influent sampling, unless otherwise stipulated by the MRP. If influent sampling is not required, the Discharger shall collect effluent samples on varying days selected at random, unless otherwise stipulated in the MRP. The Executive Officer may approve an alternative effluent sampling plan if it is representative of plant discharge and in compliance with all other permit requirements.

- **iii.** The Discharger shall collect effluent grab samples during periods of daytime maximum peak flows (or peak flows through secondary treatment units for facilities that recycle effluent).
- **iv.** Effluent sampling for conventional pollutants shall occur on at least one day of any multiple-day bioassay the MRP requires. During the course of the bioassay, on at least one day, the Discharger shall collect and retain samples of the discharge. In the event that a bioassay result does not comply with effluent limitations, the Discharger shall analyze the retained samples for pollutants that could be toxic to aquatic life and for which it has effluent limitations.
 - (a) The Discharger shall perform bioassays on final effluent samples; when chlorine is used for disinfection, bioassays shall be performed on effluent after chlorination and dechlorination; and
 - (b) The Discharger shall analyze for total ammonia nitrogen and calculate the amount of un-ionized ammonia whenever test results fail to meet effluent limitations.

b. Conditions Triggering Accelerated Monitoring

- i. Average Monthly Effluent Limitation Exceedance. If the results from two consecutive samples of a constituent monitored in a particular month exceed the average monthly effluent limitation for any parameter (or if the required sampling frequency is once per month and the monthly sample exceeds the average monthly effluent limitation), the Discharger shall, within 24 hours after the results are received, increase its sampling frequency to daily until the results from the additional sampling show that the parameter complies with the average monthly effluent limitation.
- **ii. Maximum Daily Effluent Limitation Exceedance.** If a sample result exceeds a maximum daily effluent limitation, the Discharger shall, within 24 hours after the result is received, increase its sampling frequency to daily until the results from two samples collected on consecutive days show compliance with the maximum daily effluent limitation.
- **iii.** Acute Toxicity. If final or intermediate results of an acute bioassay indicate a violation or threatened violation (e.g., the percentage of surviving test organisms of any single acute bioassay is less than 70 percent), the Discharger shall initiate a new test as soon as practical, or as described in applicable State Water Board plan provisions that become effective after adoption of these Regional Standard Provisions. The Discharger shall investigate the cause of the mortalities and report its findings in the next self-monitoring report.
- **iv.** Chlorine. The Discharger shall calibrate chlorine residual analyzers against grab samples as frequently as necessary to maintain accurate control and reliable operation. If an effluent violation is detected, the Discharger shall collect grab samples at least every 30 minutes until compliance with the limitation is achieved,

unless the Discharger monitors chlorine residual continuously. In such cases, the Discharger shall continue to conduct continuous monitoring.

- v. **Bypass.** Except as indicated below, if a Discharger bypasses any portion of its treatment facility, it shall monitor flows and collect samples at affected discharge points and analyze samples for all constituents with effluent limitations on a daily basis for the duration of the bypass. The Discharger need not accelerate chronic toxicity monitoring. The Discharger may satisfy the accelerated acute toxicity monitoring requirement by conducting a flow-through test or static renewal test that captures the duration of the bypass (regardless of the method specified in the MRP). If bypassing disinfection units only, the Discharger shall only monitor bacteria indicators daily.
 - (a) Bypass for Essential Maintenance. If a Discharger bypasses a treatment unit for essential maintenance pursuant to Attachment D section I.G.2, the Executive Officer may reduce the accelerated monitoring requirements above if the Discharger (i) monitors effluent at affected discharge points on the first day of the bypass for all constituents with effluent limitations, except chronic toxicity; and (ii) identifies and implements measures to ensure that the bypass will continue to comply with effluent limitations.
 - (b) Approved Wet Weather Bypasses. If a Discharger bypasses a treatment unit or permitted outfall during wet weather with Regional Water Board approval pursuant to Attachment D section I.G.4, the Discharger shall monitor flows and collect and retain samples for affected discharge points on a daily basis for the duration of the bypass. The Discharger shall analyze daily for TSS using 24-hour composites (or more frequent increments) and for bacteria indicators with effluent limitations using grab samples. If TSS exceeds 45 mg/L in any composite sample, the Discharger shall also analyze daily the retained samples for all other constituents with effluent limitations, except oil and grease, mercury, PCBs, dioxin-TEQ, and acute and chronic toxicity. Additionally, at least once each year, the Discharger shall analyze the retained samples for one approved bypass for all other constituents with effluent limitations, except oil and grease, mercury, PCBs, dioxin-TEQ, and acute and chronic toxicity. This monitoring shall be in addition to the minimum monitoring specified in the MRP.

B. Standard Observations - Addition to Attachment D

- **1. Receiving Water Observations.** The following requirements only apply when the MRP requires standard observations of receiving waters. Standard observations shall include the following:
 - **a.** Floating and Suspended Materials (e.g., oil, grease, algae, and other microscopic particulate matter) presence or absence, source, and size of affected area.
 - **b.** Discoloration and Turbidity color, source, and size of affected area.

- c. Odor presence or absence, characterization, source, and distance of travel.
- **d.** Beneficial Water Use estimated number of water-associated waterfowl or wildlife, fisherpeople, and other recreational activities.
- e. Hydrographic Condition time and height of high and low tides (corrected to nearest National Oceanic and Atmospheric Administration location for the sampling date and time).
- **f.** Weather Conditions wind direction, air temperature, and total precipitation during five days prior to observation.
- 2. Wastewater Effluent Observations. The following requirements only apply when the MRP requires standard observations of wastewater effluent. Standard observations shall include the following:
 - **a.** Floating and Suspended Material of Wastewater Origin (e.g., oil, grease, algae, and other microscopic particulate matter) presence or absence.
 - **b. Odor** presence or absence, characterization, source, distance of travel, and wind direction.
- **3.** Beach and Shoreline Observations. The following requirements only apply when the MRP requires standard observations of beaches or shorelines. Standard observations shall include the following:
 - **a.** Material of Wastewater Origin presence or absence, description of material, estimated size of affected area, and source.
 - **b.** Beneficial Use estimate of number of people participating in recreational water contact, non-water contact, and fishing activities.
- 4. Waste Treatment and/or Disposal Facility Periphery Observations. The following requirements only apply when the MRP requires standard observations of the periphery of waste treatment or disposal facilities. Standard observations shall include the following:
 - a. Odor presence or absence, characterization, source, and distance of travel.
 - **b.** Weather Conditions wind direction and estimated velocity.

IV. STANDARD PROVISIONS – RECORDS

A. Records to be Maintained – Supplement to Attachment D, Provision IV.A

The Discharger shall maintain records in a manner and at a location (e.g., the wastewater treatment plant or the Discharger's offices) such that the records are accessible to Regional Water Board staff. The minimum retention period specified in Attachment D, Provision IV, shall be extended during the course of any unresolved litigation regarding permit-related discharges, or when requested by Regional Water Board or U.S. EPA, Region IX, staff.

A copy of the permit shall be maintained at the discharge facility and be available at all times to operating personnel.

B. Records of Monitoring – Supplement to Attachment D, Provision IV.B

Monitoring records shall include the following:

- **1.** Analytical Information. Records shall include analytical method detection limits, minimum levels, reporting levels, and related quantification parameters.
- 2. Disinfection Process. For the disinfection process, records shall include the following:
 - **a.** For bacteriological analyses:
 - i. Wastewater flow rate at the time of sample collection; and
 - **ii.** Required statistical parameters for cumulative bacterial values (e.g., moving median or geometric mean for the number of samples or sampling period identified in the MRP).
 - **b.** For the chlorination process (when chlorine is used for disinfection), at least daily average values for the following:
 - i. Chlorine residual of treated wastewater as it enters the chlorine contact basin (mg/L);
 - ii. Chlorine dosage (kg/day); and
 - iii. Dechlorination chemical dosage (kg/day).
- **3.** Treatment Process Bypasses. For all treatment process bypasses, including wet weather blending, records shall include the following:
 - a. Chronological log of treatment process bypasses;
 - **b.** Identification of treatment processes bypassed;
 - c. Beginning and ending dates and times of bypasses;
 - d. Bypass durations;
 - e. Estimated bypass volumes; and
 - **f.** Description of, or reference to other reports describing, the bypasses, their cause, the corrective actions taken (except for wet weather blending explicitly approved within the permit and in compliance with any related permit conditions), and any additional monitoring conducted.
- 4. Treatment Plant Overflows. The Discharger shall retain a chronological log of overflows at the treatment plant, including the headworks and all units and appurtenances downstream, and records supporting the information provided in accordance with Provision V.E.2, below.

C. Claims of Confidentiality – Not Supplemented

V. STANDARD PROVISIONS - REPORTING

- A. Duty to Provide Information Not Supplemented
- B. Signatory and Certification Requirements Not Supplemented
- C. Monitoring Reports Supplement to Attachment D, Provision V.C
 - **1. Self-Monitoring Reports.** For each reporting period established in the MRP, the Discharger shall submit a self-monitoring report to the Regional Water Board in accordance with the requirements listed in the MRP and below.
 - **a. Transmittal Letter.** Each self-monitoring report shall be submitted with a transmittal letter that includes the following:
 - **i.** Identification of all violations of effluent limitations or other waste discharge requirements found during the reporting period;
 - **ii.** Details regarding the violations, such as parameters, magnitude, test results, frequency, and dates;
 - iii. Causes of the violations;
 - **iv.** Corrective actions taken or planned to resolve violations and prevent recurrences, and dates or time schedules for implementation (the Discharger may refer to previously submitted reports that address the corrective actions);
 - v. Explanation for any data invalidation. Data should not be submitted in a selfmonitoring report if it does not meet quality assurance/quality control standards. However, if the Discharger wishes to invalidate a measurement after submitting it in a self-monitoring report, the Discharger shall identify the measurement suspected to be invalid and state the Discharger's intent to submit, within 60 days, a formal request to invalidate the measurement. The formal request shall include the original measurement in question, the reason for invalidating the measurement, all relevant documentation that supports invalidation (e.g., laboratory sheet, log entry, test results, etc.), and a discussion of the corrective actions taken or planned (with a time schedule for completion) to prevent recurrence of the sampling or measurement problem;
 - vi. Description of blending, if any. If the Discharger blends, it shall describe the duration of blending events and certify whether the blending complied with all conditions for blending;
 - vii. Description of other bypasses, if any. If the Discharger bypasses any treatment units (other than blending), it shall describe the duration of the bypasses and effluent quality during those times; and

- viii. Signature. The transmittal letter shall be signed in accordance with Attachment D, Provision V.B.
- **b.** Compliance Evaluation Summary. Each self-monitoring report shall include a compliance evaluation summary that addresses each parameter for which the permit specifies effluent limitations, the number of samples taken during the monitoring period, and the number of samples that exceed the effluent limitations.
- **c.** More Frequent Monitoring. If the Discharger monitors any pollutant more frequently than required by the MRP, the Discharger shall include the results of such monitoring in the calculation and reporting of the data submitted in the self-monitoring report.

d. Analysis Results

- i. **Tabulation.** Each self-monitoring report shall include tabulations of all required analyses and observations, including parameters, dates, times, sample stations, types of samples, test results, method detection limits, method minimum levels, and method reporting levels (if applicable), signed by the laboratory director or other responsible official.
- **ii. Multiple Samples.** Unless the MRP specifies otherwise, when determining compliance with effluent limitations (other than instantaneous effluent limitations) and more than one sample result is available, the Discharger shall compute the arithmetic mean. If the data set contains one or more results that are "Detected, but Not Quantified (DNQ) or "Not Detected" (ND), the Discharger shall instead compute the median in accordance with the following procedure:
 - (a) The data set shall be ranked from low to high, reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
 - (b) The median of the data set shall be determined. If the data set has an odd number of data points, the median is the middle value. If the data set has an even number of data points, the median is the average of the two values around the middle, unless one or both of these values is ND or DNQ, in which case the median shall be the lower of the two results (where DNQ is lower than a quantified value and ND is lower than DNQ).
- **iii. Duplicate Samples.** The Discharger shall report the average of duplicate sample analyses when reporting for a single sample result (or the median if one or more of the duplicates is DNQ or ND [see Provision V.C.1.c.ii, above]). For bacteria indicators, the Discharger shall report the geometric mean of the duplicate analyses.
- **iv. Dioxin-TEQ.** The Discharger shall report for each dioxin and furan congener the analytical results of effluent monitoring, including the reporting level, the method detection limit, and the measured concentration. The Discharger shall report all measured values of individual congeners, including data qualifiers. When calculating

dioxin-TEQ, the Discharger shall set congener concentrations below the minimum levels (MLs) to zero. The Discharger shall calculate and report dioxin-TEQ using the following formula, where the MLs, toxicity equivalency factors (TEFs), and bioaccumulation equivalency factors (BEFs) are as provided in Table A:

 $Dioxin-TEQ = \Sigma (C_x \times TEF_x \times BEF_x)$

where: C_x = measured or estimated concentration of congener *x* TEF_x = toxicity equivalency factor for congener x BEFx = bioaccumulation equivalency factor for congener *x*

Minimum Levels, Toxicity Equivalency Factors,											
and Bioaccumulation Equivalency Factors											
Dioxin or Furan Congener	Minimum Level (pg/L)	2005 Toxicity Equivalency Factor (TEF)	Bioaccumulation Equivalency Factor (BEF)								
2,3,7,8-TCDD	10	1.0	1.0								
1,2,3,7,8-PeCDD	50	1.0	0.9								
1,2,3,4,7,8-HxCDD	50	0.1	0.3								
1,2,3,6,7,8-HxCDD	50	0.1	0.1								
1,2,3,7,8,9-HxCDD	50	0.1	0.1								
1,2,3,4,6,7,8-HpCDD	50	0.01	0.05								
OCDD	100	0.0003	0.01								
2,3,7,8-TCDF	10	0.1	0.8								
1,2,3,7,8-PeCDF	50	0.03	0.2								
2,3,4,7,8-PeCDF	50	0.3	1.6								
1,2,3,4,7,8-HxCDF	50	0.1	0.08								
1,2,3,6,7,8-HxCDF	50	0.1	0.2								
1,2,3,7,8,9-HxCDF	50	0.1	0.6								
2,3,4,6,7,8-HxCDF	50	0.1	0.7								
1,2,3,4,6,7,8-HpCDF	50	0.01	0.01								
1,2,3,4,7,8,9-HpCDF	50	0.01	0.4								
OCDF	100	0.0003	0.02								

Table A
Minimum Levels, Toxicity Equivalency Factors,
and Bioaccumulation Equivalency Factors

- e. Results Not Yet Available. The Discharger shall make all reasonable efforts to obtain analytical data for required parameter sampling in a timely manner. Certain analyses may require additional time to complete analytical processes and report results. In these cases, the Discharger shall describe the circumstances in the self-monitoring report and include the data for these parameters and relevant discussions of any violations in the next self-monitoring report due after the results are available.
- **f. Annual Self-Monitoring Reports.** By the date specified in the MRP, the Discharger shall submit an annual self-monitoring report covering the previous calendar year. The report shall contain the following:
 - **i.** Comprehensive discussion of treatment plant performance, including documentation of any blending or other bypass events, and compliance with the permit. This

discussion shall include any corrective actions taken or planned, such as changes to facility equipment or operation practices that may be needed to achieve compliance, and any other actions taken or planned that are intended to improve the performance and reliability of wastewater collection, treatment, or disposal practices;

- **ii.** List of approved analyses, including the following:
 - (a) List of analyses for which the Discharger is certified;
 - (b) List of analyses performed for the Discharger by a separate certified laboratory (copies of reports signed by the laboratory director of that laboratory need not be submitted but shall be retained onsite); and
 - (c) List of "waived" analyses, as approved;
- **iii.** Plan view drawing or map showing the Discharger's facility, flow routing, and sampling and observation station locations;
- **iv.** Results of facility report reviews. The Discharger shall regularly review, revise, and update, as necessary, the Operation and Maintenance Manual, Contingency Plan, Spill Prevention Plan, and Wastewater Facilities Status Report so these documents remain useful and relevant to current practices. At a minimum, reviews shall be conducted annually. The Discharger shall describe or summarize its review and evaluation procedures, recommended or planned actions, and estimated time schedule for implementing these actions. The Discharger shall complete changes to these documents to ensure that they remain up-to-date.

D. Compliance Schedules – Not supplemented

E. Twenty-Four Hour Reporting – Supplement to Attachment D, Provision V.E

1. Oil or Other Hazardous Material Spills

- **a.** Within 24 hours of becoming aware of a spill of oil or other hazardous material not contained onsite and completely cleaned up, the Discharger shall report as follows:
 - i. If the spill exceeds reportable quantities for hazardous materials listed in 40 C.F.R. part 302. The Discharger shall call the State Office of Emergency Services (800-852-7550).
 - **ii.** If the spill does not exceed reportable quantities for hazardous materials listed in 40 C.F.R., part 302, the Discharger shall call the Regional Water Board (510-622-2369).
- **b.** The Discharger shall submit a written report to the Regional Water Board within five working days following either of the above telephone notifications unless directed otherwise by Regional Water Board staff. A report submitted electronically is acceptable. The written report shall include the following:

- i. Date and time of spill, and duration if known;
- **ii.** Location of spill (street address or description of location);
- iii. Nature of material spilled;
- iv. Quantity of material spilled;
- v. Receiving water body affected, if any;
- vi. Cause of spill;
- vii. Estimated size of affected area;
- viii. Observed impacts to receiving waters (e.g., oil sheen, fish kill, water discoloration);
- ix. Corrective actions taken to contain, minimize, or clean up the spill;
- **x.** Future corrective actions planned to prevent recurrence, and implementation schedule; and
- xi. Persons or agencies notified.

2. Unauthorized Municipal Wastewater Treatment Plant Discharges¹

- **a. Two-Hour Notification.** For any unauthorized discharge that enters a drainage channel or surface water, the Discharger shall, as soon as possible, but not later than two hours after becoming aware of the discharge, notify the California Office of Emergency Services (800-852-7550) and the local health officer or director of environmental health with jurisdiction over the affected water body. Notification shall include the following:
 - i. Incident description and cause;
 - ii. Location of threatened or involved waterways or storm drains;
 - iii. Date and time that the unauthorized discharge started;
 - **iv.** Estimated quantity and duration of the unauthorized discharge (to the extent known), and estimated amount recovered;
 - v. Level of treatment prior to discharge (e.g., raw wastewater, primary-treated wastewater, or undisinfected secondary-treated wastewater, etc.); and
 - vi. Identity of person reporting the unauthorized discharge.

¹ California Code of Regulations, Title 23, section 2250(b), defines an unauthorized discharge to be a discharge, not regulated by waste discharge requirements, of treated, partially treated, or untreated wastewater resulting from the intentional or unintentional diversion of wastewater from a collection, treatment, or disposal system.

- **b.** Five-Day Written Report. Within five business days following the two-hour notification, the Discharger shall submit a written report that includes, in addition to the information listed in Provision V.E.2.a, above, the following:
 - i. Methods used to delineate the geographical extent of the unauthorized discharge within receiving waters;
 - **ii.** Efforts implemented to minimize public exposure to the unauthorized discharge;
 - **iii.** Visual observations of the impacts (if any) noted in the receiving waters (e.g., fish kill, discoloration of receiving water) and extent of sampling if conducted;
 - iv. Corrective measures taken to minimize the impact of the unauthorized discharge;
 - **v.** Measures to be taken to minimize the potential for a similar unauthorized discharge in the future;
 - vi. Summary of Spill Prevention Plan or Operation and Maintenance Manual modifications to be made, if necessary, to minimize the potential for future unauthorized discharges; and
 - vii. Quantity and duration of the unauthorized discharge, and the amount recovered.
- F. Planned Changes Not supplemented
- G. Anticipated Noncompliance Not supplemented
- H. Other Noncompliance Not supplemented
- I. Other Information Not supplemented

VI. STANDARD PROVISION - ENFORCEMENT - Not Supplemented

VII. ADDITIONAL PROVISIONS - NOTIFICATION LEVELS - Not Supplemented

VIII. DEFINITIONS - Addition to Attachment D

More definitions can be found in Attachment A of this NPDES Permit.

A. Arithmetic Calculations –

1. Geometric Mean. The antilog of the log mean or the back-transformed mean of the logarithmically transformed variables, which is equivalent to the multiplication of the antilogarithms. The geometric mean can be calculated with either of the following equations:

Geometric Mean =
$$Anti \log \left(\frac{1}{N} \sum_{i=1}^{N} Log(C_i)\right)$$

Geometric Mean = $(C_1 \times C_2 \times ... \times C_N)^{1/N}$

Where "N" is the number of data points for the period analyzed and "C" is the concentration for each of the "N" data points.

2. Mass Emission Rate. The rate of discharge expressed in mass. The mass emission rate is obtained from the following calculation for any calendar day:

Mass emission rate (lb/day) =
$$\frac{8.345}{N} \sum_{i=1}^{N} Q_i C_i$$

Mass emission rate (kg/day) =
$$\frac{3.785}{N} \sum_{i=1}^{N} Q_i C_i$$

In which "N" is the number of samples analyzed in any calendar day and " Q_i " and " C_i " are the flow rate (MGD) and the constituent concentration (mg/L) associated with each of the "N" grab samples that may be taken in any calendar day. If a composite sample is taken, " C_i " is the concentration measured in the composite sample and " Q_i " is the average flow rate occurring during the period over which the samples are composited. The daily concentration of a constituent measured over any calendar day shall be determined from the flow-weighted average of the same constituent in the combined waste streams as follows:

$$C_d$$
 = Average daily concentration = $\frac{1}{Q_i} \sum_{i=1}^{N} Q_i C_i$

In which "N" is the number of component waste streams and "Q" and "C" are the flow rate (MGD) and the constituent concentration (mg/L) associated with each of the "N" waste streams. "Q_t" is the total flow rate of the combined waste streams.

3. Removal Efficiency. The ratio of pollutants removed by the treatment facilities to pollutants entering the treatment facilities (expressed as a percentage). The Discharger shall determine removal efficiencies using monthly averages (by calendar month unless otherwise specified) of pollutant concentration of influent and effluent samples collected at about the same time and using the following equation (or its equivalent):

Removal Efficiency (%) = $100 \times [1-(Effluent Concentration/Influent Concentration)]$

- **B. Blending** the practice of bypassing biological treatment units and recombining the bypass wastewater with biologically-treated wastewater.
- **C. Composite Sample** a sample composed of individual grab samples collected manually or by an automatic sampling device on the basis of time or flow as specified in the MRP. For flow-based composites, the proportion of each grab sample included in the composite sample shall be within plus or minus five percent (+/-5%) of the representative flow of the waste stream being

measured at the time of grab sample collection. Alternatively, equal volume grab samples may be individually analyzed with the flow-weighted average calculated by averaging flow-weighted ratios of each grab sample analytical result. Grab samples comprising time-based composite samples shall be collected at intervals not greater than those specified in the MRP. The quantity of each grab sample comprising a time-based composite sample shall be a set of flow proportional volumes as specified in the MRP. If a particular time-based or flow-based composite sampling protocol is not specified in the MRP, the Discharger shall determine and implement the most representative protocol.

- **D. Duplicate Sample** a second sample taken from the same source and at the same time as an initial sample (such samples are typically analyzed identically to measure analytical variability).
- **E. Grab Sample** an individual sample collected during a short period not exceeding 15 minutes. Grab samples represent only the condition that exists at the time the sample is collected.
- **F. Overflow** the intentional or unintentional spilling or forcing out of untreated or partially treated waste from a transport system (e.g., through manholes, at pump stations, or at collection points) upstream of the treatment plant headworks or from any part of a treatment plant.
- **G. Priority Pollutants** those constituents referred to in 40 C.F.R. part 122 as promulgated in the Federal Register, Vol. 65, No. 97, Thursday, May 18, 2000, also known as the California Toxics Rule.
- H. Untreated waste raw wastewater.

	Pollutant/Parameter		Minimum Levels ³												
		Analytical		1	1	<u> </u>	1	1	(µg/l)	ICP	1	IIVD	1	<u>т </u>	
NO.		Method	GC	GCMS	LC	Color	FAA	GFAA	ICP	MS	SPGFAA	HYD RIDE	CVAA	DCP	
1	Antimony	204.2					10	5	50	0.5	5	0.5		1000	
2	Arsenic	206.3				20		2	10	2	2	1		1000	
3	Beryllium						20	0.5	2	0.5	1			1000	
4	Cadmium	200 or 213					10	0.5	10	0.25	0.5			1000	
5a	Chromium (III)	SM 3500													
5b	Chromium (VI)	SM 3500				10	5							1000	
	Chromium (total)4	SM 3500					50	2	10	0.5	1			1000	
6	Copper	200.9					25	5	10	0.5	2			1000	
7	Lead	200.9					20	5	5	0.5	2			10,000	
8	Mercury	1631 (note) ⁵													
9	Nickel	249.2					50	5	20	1	5			1000	
10	Selenium	200.8 or SM 3114B or C						5	10	2	5	1		1000	
11	Silver	272.2					10	1	10	0.25	2			1000	
12	Thallium	279.2					10	2	10	1	5			1000	
13	Zinc	200 or 289					20		20	1	10				
14	Cyanide	SM 4500 CN ⁻ C or I				5									
15	Asbestos (only required for dischargers to MUN waters) ⁶	0100.2 7													
16	2,3,7,8-TCDD and 17 congeners (Dioxin)	1613													
17	Acrolein	603	2.0	5											
18	Acrylonitrile	603	2.0	2											
19	Benzene	602	0.5	2											
33	Ethylbenzene	602	0.5	2											
39	Toluene	602	0.5	2											
20	Bromoform	601	0.5	2											
21	Carbon Tetrachloride	601	0.5	2											
22	Chlorobenzene	601	0.5	2										_	
23	Chlorodibromomethane	601	0.5	2											
24	Chloroethane	601	0.5	2										<u> </u>	
25	2-Chloroethylvinyl Ether	601	1	1										<u> </u>	
26	Chloroform	601	0.5	2										<u> </u>	
75	1,2-Dichlorobenzene	601	0.5	2										1	

 Table B

 List of Monitoring Parameters and Analytical Methods

 2 The suggested method is the U.S. EPA Method unless otherwise specified (SM = Standard Methods). The Discharger may use another U.S. EPA-approved or recognized method if that method has a level of quantification below the applicable water quality objective. Where no method is suggested, the Discharger has the discretion to use any standard method.

³ Minimum levels are from the *State Implementation Policy*. They are the concentration of the lowest calibration standard for that technique based on a survey of contract laboratories. Laboratory techniques are defined as follows: GC = Gas Chromatography; GCMS = Gas Chromatography/Mass Spectrometry; LC = High Pressure Liquid Chromatography; Color = Colorimetric; FAA = Flame Atomic Absorption; GFAA = Graphite Furnace Atomic Absorption; ICP = Inductively Coupled Plasma; ICPMS = Inductively Coupled Plasma/Mass Spectrometry; SPGFAA = Stabilized Platform Graphite Furnace Atomic Absorption (i.e., U.S. EPA 200.9); Hydride = Gaseous Hydride Atomic Absorption; CVAA = Cold Vapor Atomic Absorption; DCP = Direct Current Plasma.

⁴ Analysis for total chromium may be substituted for analysis of chromium (III) and chromium (VI) if the concentration measured is below the lowest hexavalent chromium criterion (11 ug/l).

⁵ The Discharger shall use ultra-clean sampling (U.S. EPA Method 1669) and ultra-clean analytical methods (U.S. EPA Method 1631) for mercury monitoring. The minimum level for mercury is 2 ng/l (or 0.002 ug/l).

⁶ MUN = Municipal and Domestic Supply. This designation, if applicable, is in the Findings of the permit.

⁷ Determination of Asbestos Structures over 10 [micrometers] in Length in Drinking Water Using MCE Filters, U.S. EPA 600/R-94-134, June 1994.

	Pollutant/Parameter	Analytical Method ²	Minimum Levels ³											
CTR				r		r		r	(µg/l)		1		r	
No.			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP
76	1,3-Dichlorobenzene	601	0.5	2						1.10		1122		
77	1,4-Dichlorobenzene	601	0.5	2										
27	Dichlorobromomethane	601	0.5	2										
28	1,1-Dichloroethane	601	0.5	1										
29	1,2-Dichloroethane	601	0.5	2										
30	1,1-Dichloroethylene or 1,1-Dichloroethene	601	0.5	2										
31	1,2-Dichloropropane	601	0.5	1										
32	1,3-Dichloropropylene or 1,3-Dichloropropene	601	0.5	2										
34	Methyl Bromide or Bromomethane	601	1.0	2										
35	Methyl Chloride or Chloromethane	601	0.5	2										
36	Methylene Chloride or Dichloromethane	601	0.5	2										
37	1,1,2,2-Tetrachloroethane	601	0.5	1										
38	Tetrachloroethylene	601	0.5	2										
40	1,2-Trans-Dichloroethylene	601	0.5	1										
41	1,1,1-Trichloroethane	601	0.5	2										
42	1,1,2-Trichloroethane	601	0.5	2										
43	Trichloroethene	601	0.5	2										
44	Vinyl Chloride	601	0.5	2										
45	2-Chlorophenol	604	2	5										
46	2,4-Dichlorophenol	604	1	5										
47	2,4-Dimethylphenol	604	1	2										
48	2-Methyl-4,6-Dinitrophenol or Dinitro-2-methylphenol	604	10	5										
49	2.4-Dinitrophenol	604	5	5										
50	2-Nitrophenol	604	-	10										
51	4-Nitrophenol	604	5	10										
52	3-Methyl-4-Chlorophenol	604	5	1										<u> </u>
53	Pentachlorophenol	604	1	5										
54	Phenol	604	1	1		50								<u> </u>
55	2.4.6-Trichlorophenol	604	10	10		20								<u> </u>
56	Acenaphthene	610 HPLC	1	1	0.5									
57	Acenaphthylene	610 HPLC		10	0.2									
58	Anthracene	610 HPLC		10	2									
60	Benzo(a)Anthracene or 1,2 Benzanthracene	610 HPLC	10	5	2									
61	Benzo(a)Pyrene	610 HPLC		10	2									
62	Benzo(b)Fluoranthene or 3,4 Benzofluoranthene	610 HPLC		10	10									
63	Benzo(ghi)Pervlene	610 HPLC		5	0.1									
64	Benzo(k)Fluoranthene	610 HPLC		10	2									
74	Dibenzo(a,h)Anthracene	610 HPLC		10	0.1									
86	Fluoranthene	610 HPLC	10	1	0.05			1						<u> </u>
87	Fluorene	610 HPLC		10	0.1			1						<u> </u>
92	Indeno(1,2,3-cd) Pyrene	610 HPLC		10	0.05			1						<u> </u>
100	Pyrene	610 HPLC		10	0.05			1						<u> </u>
68	Bis(2-Ethylhexyl)Phthalate	606 or 625	10	5				1						<u> </u>
70	Butylbenzyl Phthalate	606 or 625	10	10										<u> </u>
79	Diethyl Phthalate	606 or 625	10	2										<u> </u>
80	Dimethyl Phthalate	606 or 625	10	2										<u> </u>
81	Di-n-Butyl Phthalate	606 or 625		10										<u> </u>

	Pollutant/Parameter	Analytical Method ²	Minimum Levels ³												
CTR No.									(µg/l)	ICP		HVD			
1.0.			GC	GCMS	LC	Color	FAA	GFAA	ICP	MS	SPGFAA	RIDE	CVAA	DCP	
84	Di-n-Octyl Phthalate	606 or 625		10											
59	Benzidine	625		5											
65	Bis(2-Chloroethoxy)Methane	625		5											
66	Bis(2-Chloroethyl)Ether	625	10	1											
67	Bis(2-Chloroisopropyl)Ether	625	10	2											
69	4-Bromophenyl Phenyl Ether	625	10	5											
71	2-Chloronaphthalene	625		10											
72	4-Chlorophenyl Phenyl Ether	625		5											
73	Chrysene	625		10	5										
78	3,3'-Dichlorobenzidine	625		5											
82	2,4-Dinitrotoluene	625	10	5											
83	2,6-Dinitrotoluene	625		5											
85	1,2-Diphenylhydrazine (note) ⁸	625		1											
88	Hexachlorobenzene	625	5	1											
89	Hexachlorobutadiene	625	5	1											
90	Hexachlorocyclopentadiene	625	5	5											
91	Hexachloroethane	625	5	1											
93	Isophorone	625	10	1											
94	Naphthalene	625	10	1	0.2										
95	Nitrobenzene	625	10	1											
96	N-Nitrosodimethylamine	625	10	5											
97	N-Nitrosodi-n-Propylamine	625	10	5											
98	N-Nitrosodiphenylamine	625	10	1											
99	Phenanthrene	625		5	0.05										
101	1,2,4-Trichlorobenzene	625	1	5											
102	Aldrin	608	0.005												
103	α-BHC	608	0.01												
104	β-ВНС	608	0.005												
105	γ-BHC (Lindane)	608	0.02												
106	δ-ВНС	608	0.005												
107	Chlordane	608	0.1												
108	4,4'-DDT	608	0.01												
109	4,4'-DDE	608	0.05												
110	4,4'-DDD	608	0.05												
111	Dieldrin	608	0.01												
112	Endosulfan (alpha)	608	0.02												
113	Endosulfan (beta)	608	0.01												
114	Endosulfan Sulfate	608	0.05												
115	Endrin	608	0.01												
116	Endrin Aldehyde	608	0.01												
117	Heptachlor	608	0.01												
118	Heptachlor Epoxide	608	0.01												
119- 125	PCBs: Aroclors 1016, 1221, 1232, 1242, 1248, 1254, 1260	608	0.5				<u> </u>								
126	Toxaphene	608	0.5												

⁸ Measurement for 1,2-Diphenylhydrazine may use azobenzene as a screen: if azobenzene is measured at >1 ug/l, then the Discharger shall analyze for 1,2-Diphenylhydrazine.