Table 3-5: Water Quality Objectives for Municipal Supply

Parameter	Objective (in MG/L)
Physical:	
Color (units)[a]	15.0
Odor (number)[a]	3.0
Turbidity (NTU)[a]	5.0
pH[b]	6.0 - 8.5
TDS[c]	500.0
EC (mmhos/cm)[c]	900
Corrosivity	non-corrosive
Inorganic Parameters:	
Aluminum[d]	1.0[d] / 0.2[a]
Antimony[d]	0.006
Arsenic[d]	0.05
Asbestos[d]	7 MFL[e]
Barium[d]	1.0
Beryllium[d]	0.004
Chloride[c]	250.0
Cadmium[d]	0.005
Chromium[d]	0.05
Copper[a]	1.0
Cyanide[d]	0.15
Fluoride[f]	0.6 - 1.7[g]
Iron[a]	0.3
Lead[b]	0.05
Manganese[a]	0.05
Mercury[d]	0.002
Nickel[d]	0.1
Nitrate (as NO_3)[d]	45.0
Nitrate + Nitrite (as N)[d]	10.0
Nitrite (as N)[d]	1.0
Selenium[d]	0.05
Silver[b]	0.1
Sulfate[c]	250.0
Thallium[d]	0.002
Zinc[a]	5.0
Organic Parameters:	
MBAS (Foaming agents)[a]	0.5
Oil and grease[b]	none
Phenols[b]	0.001
Trihalomethanes[b]	0.1
Chlorinated Hydrocarbons:	
Endrin[h]	0.002
Lindane[h]	0.0002
Methoxychlor[h]	0.03
Toxaphene[h]	0.003
2,3,7,8-TCDD (Dioxin)[h]	3×10^{-8}
2,4-D[h]	0.07
2,4,4-TP Silvex[h]	0.05

Parameter	Objective (in MG/L)
Synthetic Organic Chemicals:	
Alachor[h]	0.002
Atrazine[h]	0.001
Bentazon[h]	0.018
Benzo(a)pyrene[h]	0.0002
Dalapon[h]	0.2
Dinoseb[h]	0.007
Diquat[h]	0.02
Endothall[h]	0.1
Ethylene dibromide[h]	0.00005
Glyphosate[h]	0.7
Heptachlor[h]	0.00001
Heptachlor epoxide[h]	0.00001
Hexachlorecyclopentadiene[h]	0.001
Molinate[h]	0.02
Oxarnyl[h]	0.05
Pentachlorophenol[h]	0.001
Picloram[h]	0.5
Polychlorinated Biphenyls[h]	0.0005
Simazine[h]	0.004
Thiobencarb[h]	0.07 / 0.001
Volatile Organic Chemicals:	
Benzene[h]	0.001
Carbon Tetrachloride[h]	0.005
1,2-Dibromo-3-chloropropane[h]	0.0002
1,2-Dichlorobenzene[h]	0.6
1,4-Dichlorobenzene[h]	0.005
1,1-Dichloroethane[h]	0.005
1,2-Dichloroethane[h]	0.0005
cis-1,2-Dichloroethlyene[h]	0.006
trans-1,2-Dichloroethylene[h]	0.01
1,1-Dichloroethylene[h]	0.006
Dichloromethane[h]	0.005
1,2-Dichloropropane[h]	0.005
1,3-Dichloropropene[h]	0.0005
Ethylbenzene[h]	0.7
Methyl-tert-butyl ether[h]	0.013 / 0.005
Monochlorobenzene[h]	0.07
Styrene[h]	0.1
1,1,2,2-Tetrachloroethane[h]	0.001
Tetrachloroethylene[h]	0.005
1,2,4-Trichlorobenzene[h]	0.005
1,1,1-Trichloroethane	0.200
1,1,2-Trichloroethane[h]	0.005
Trichloroethylene[h]	0.005
Trichlorofluoromethane	0.15

Parameter	Objective (in MG/L)
Volatile Organic Chemicals (cont'd):	
1,1,2-Trichloro-1,2,2 trifluoromethane[h]	1.2
Toluene[h]	0.15
Vinyl Chloride[h]	0.0005
Xylenes (single or sum of isomers)[h]	1.750
Radioactivity:	
Combined Radium-226 and Radium-228[i]	5
Gross Alpha Particle Activity[i]	15
Tritium[i]	20,000
Strontium-90[i]	8
Gross Beta Particle Activity[i]	50
Uranium[i]	20

NOTES:

a. Secondary Maximum Contaminant Levels as specified in Table 64449- A of Section 64449, Title 22 of the California Code of Regulations, as June 3, 2005.

b. Table III-2, 1986 Basin Plan

c. Secondary Maximum Contaminant Levels as specified in Table 64449-B of Section 64449, Title 22 of the California Code of Regulations, as of June 3, 2005. (Levels indicated are "recommended" levels. Table 64449-B contains a complete list of upper and short-term ranges.)

d. Maximum Contaminant Levels as specified in Table 64431-A (Inorganic Chemicals) of Section 64431, Title 22 of the California Code of Regulations, as of June 3, 2005.

e. MFL = million fibers per liter; MCL for fibers exceeding 10 um in length.

f. Flouride objectives depend on temperature.

g. A complete list of optimum and limiting concentrations is specified in Table 64433.2-A of Section 64433.2, Title 22 of the California Code of Regulations, as of June 3, 2005.

h. Maximum Contaminant Levels as specified in Table 64444-A (Organic Chemicals) of Section 64444, Title 22 of the California Code of Regulations, as of June 3, 2005.

i. Maximum Contaminant Levels as specified in Table 4 (Radioactivity) of Section 64443, Title 22 of the California Code of Regulations, as of June 3, 2005.

j. Included Radium-226 but excludes Radon and Uranium.

MG/L Milligrams per liter
pCi/L pico Curries per liter