

Table 4–6: Dilution Credits for Calculation of Cyanide Water Quality–Based Effluent Limits for Shallow Water Dischargers

Discharger	Discharge Location	Dilution Credit^a
American Canyon	North Slough	3.25:1
Fairfield-Suisun	Boynton Slough	4.0:1
Hayward Marsh	Hayward Shoreline Regional Park Marsh Basin	3.25:1
Las Gallinas	Miller Creek	3.25:1
Mt. View SD	Peyton Slough	3.25:1
Napa SD	Napa River	3.25:1
Novato SD	San Pablo Bay	3.25:1
City of Palo Alto	Man-made-channel	3.25:1
City of Petaluma	Petaluma River	3.25:1
City of San Jose	Artesian Slough	3.0:1
Sonoma County Water Agency	Schell Slough	3.25:1
City of Sunnyvale	Moffett Channel	4.0:1
USS Posco	New York Slough	3.25:1

^a The dilution credit is expressed as the ratio of total parts mixed (effluent and receiving waters) to one part effluent.