

Table 7.8.2-4 Density-Based Wasteload Allocations^a for Municipal Wastewater Treatment Facilities

Facility	<i>E. coli</i> Density (CFU/100 mL)						NPDES Permit #
	<i>E. coli</i>		Fecal coliform ^b		Total coliform ^b		
	Geometric mean ^c	90 th %ile ^c	Geometric mean ^c	90 th %ile	Median ^c	Single sample max	
Napa Sanitation District	< 126	< 409	< 200	< 400	< 240	10,000	CA0037575
Town of Yountville	< 126	< 409	< 200	< 400	< 240	10,000	CA0038121
City of St. Helena	< 126	< 409	< 200	< 400	< 240	10,000	CA0038016
City of Calistoga	< 126	< 409	< 200	< 400	< 240	10,000	CA0037966
City of American Canyon	< 126	< 409	< 200	< 400	< 240	10,000	CA0038768
Napa River Reclamation District #2109	< 126	< 409	< 200	< 400	< 240	10,000	CA0038644

^aThese allocations are applicable year-round. Wasteload allocations apply to any sources (existing or future) subject to regulation by a NPDES permit.

^bThe allocations for total coliform and fecal coliform shall sunset and shall no longer be effective upon the replacement of the total and fecal coliform water quality objectives in the Basin Plan with *E.coli*-based water quality objectives for contact recreation.

^cBased on a minimum of five consecutive samples collected at approximately equal intervals over a 30-day period.