ATTACHMENT A

Provision C.3.b. Sample Reporting Table

| Provision C.3.b. Sample Reporting Table Regulated Projects Approved During the Reporting Period 07/08 to 06/09 City of Eden Annual Report FY 2008-09 | | | | | | | | | | | | | |
|--|--|--|---|--|--|--|---|--|---|--|---------------------------------|---|---|
| Project Name, Project Number, Location, Street Address, | Name of Developer, Project Phase No., ¹ Project Type & Description | Project Watershed ² | Total Site Area, Total Area of Land Disturbed | Total New and/or Replaced Impervious Surface Area ³ | Total Pre- and Post- Project Impervious Surface Area ⁴ | Status of Project ⁵ | Source Control Measures | Site Design Measures | Treatment Systems Installed ⁶ | Operation & Maintenance Responsibility Mechanism | Hydraulic Sizing Criteria | Alternative Compliance Measures ^{7,8} | HM Controls ^{9,10} |
| Private Project | ts | | - | | <u>-</u> | - | <u></u> | <u></u> | | <u>-</u> | - | | <u>+</u> |
| Nirvana Estates; Project #05-122; Property bounded by Paradise Lane, Serenity Drive, and Eternity Circle; Eden, CA | Heavenly Homes; Phase 1; Construction of 156 single-family homes and 45 townhomes with commercial shops and underground parking. | Runoff from site drains to Babbling Brook | 25 acres site area, 21 acres disturbed | 20 acres new | 20 acres post-project | Application submitted 12/29/07, Application deemed complete 1/30/08, Project approved 7/16/08 | Stenciled inlets, street sweeping, covered parking, car wash pad drains to sanitary sewer | Pervious pavement for all driveways, sidewalks, and commercial plaza | vegetated swales, detention basins, | Conditions of Approval require Homeowners Association to perform regular maintenance. Written record will be made available to City inspectors. | WEF Method | n/a | Contra Costa sizing charts used to design detention basin at Peace Park. Also contributed to in-stream projects in Babbling Brook |
| Barter Heaven; Project #05-345; Shoppers Lane & Bargain Avenue; 14578 Shoppers Lane, Eden, CA | Deals Galore Development Co.; Demolition of strip mall and parking lot and construction of 500-unit 5-story shopping mall with underground parking and limited outdoor parking. | Runoff from site drains to Bargain River | 5 acres site area, 3 acres disturbed | 1 acre new, 2 acres replaced | 3.5 acres pre-project, 4.5 acres post-project | Application submitted 7/9/08, Application deemed complete 8/2/08, Project approved 12/12/08 | Stenciled inlets, trash enclosures, underground parking, street sweeping | One-way aisles to minimize outdoor parking footprint; roof drains to planter boxes | tree wells with bioretention; planter boxes with bioretention | Conditions of Approval require property owner (landlord) to perform regular maintenance. Written record will be made available to City inspectors. | BMP Handbook Method | \$ 250,000 paid to Renew Regional Project sponsored by Riverworks Foundation, 243 Water Way, Eden, CA 408-345- 6789 | Renew Project includes treatment and HM Controls |

| | | | Regula | ated Project | s Approve | d During t | le Reportin he Reportin Report FY 2 | ng Period (|)7/08 to 06/0 | 09 | | | |
|--|---|--|---|--|--|--|---|---|---|--|---------------------------------|--|---|
| Project Name, Project Number, Location, Street Address, | Name of Developer, Project Phase No., ¹ Project Type & Description | Project Watershed ² | Total Site Area, Total Area of Land Disturbed | Total New and/or Replaced Impervious Surface Area ³ | Total Pre- and Post- Project Impervious Surface Area ⁴ | Status of Project ⁵ | Source Control Measures | Site Design Measures | Treatment Systems Installed ⁶ | Operation & Maintenance Responsibility Mechanism | Hydraulic Sizing Criteria | Alternative Compliance Measures ^{7,8} | HM Controls ^{9,10} |
| New Beginnings; Project No. #05- 456; Hope Street & Chance Road; 567 Hope Boulevard, Eden, CA | Fresh Start Corporation; Demolition of abandoned warehouse and construction of a 5-story building with 250 low- income rental housing units. | Runoff from site drains to Poor Man Creek | 5 acres site area, 100,000 ft ² disturbed | 1 acre replaced | 2 acres pre- project, 1 acre post- project | Application submitted 2/9/09, Application deemed complete 4/10/09; Project approved 6/30/09 | Trash enclosures, underground parking, street sweeping, car wash pad drains to sanitary sewer | | parking runoff flows to six bioretention units/gardens | Conditions of Approval require property owner (landlord) to perform regular maintenance. Written record will be made available to City inspectors. | not sized | Whole project is exempted from hydraulically sized treatment requirement - project is 100% low- income housing (Govt Code § 65589.5(h)(3)) | n/a |
| Public Project | S | | | | | | | | | | | | |
| Gridlock Relief, Project No. #05- 99, ABC Blvd between Main and Huett Streets, Eden, CA | City of Eden. Widening of ABC Blvd from 4 to 6 lanes | Runoff from site drains to Congestion River | 6 acres site area, 3 acres disturbed | 2 acres new, 1 acre replaced | 4 acres pre- project, 6 acres post-project | Application submitted 7/9/06, Application deemed complete 10/6/08, Project approved 12/9/08, Constructio n scheduled to begin 7/10/09 | none | ABC Blvd sloped to drain runoff into landscaped areas in median | Runoff leaving underdrain system of landscaped median is pumped to bioretention gardens along on either side of ABC Blvd | Signed statement from City of Eden assuming post- construction responsibility for treatment BMP maintenance. | WEF Method | n/a | BAHM used to design and size stormwater treatment units so that increased runoff is detained. |

Sample Reporting Table C.3.b. Footnotes

- 1. If a project is being constructed in Phases, use a separate row entry for each Phase.
- 2. State the watershed(s) that the Regulated Project drains to. Optional but recommended: Also state the downstream watershed(s).
- 3. State both the total new impervious surface area and the total replaced impervious surface area, as applicable.
- 4. For redevelopment projects state both the pre-project impervious surface area and the post-project impervious surface area.
- 5. State project application date; application deemed complete date; and final, major, staff-level discretionary review and approval date.
- 6. List stormwater treatment system(s) installed onsite or at a joint stormwater treatment system facility.
- 7. For Equivalent Offsite Treatment, on a separate page, give a discussion of the alternative compliance site including the information specified in Provision C.3.b.v.(1)(l)(i) for the offsite project.
- 8. For Regional Projects, on a separate page, provide the information specified in Provision C.3.b.v.(1)(I)(ii).
- 9. If HM control is not required, state why not.
- 10. If HM control is required, state control method used (e.g., method to design and size device(s) or method(s) used to meet the HM Standard, and description of device(s) or method(s) used, such as detention basin(s), biodetention unit(s), regional detention basin, or in-stream control).

Instructions for Provision C.3.b. Sample Reporting Table

- **1. Project Name, Number, Location, and Street Address** Include the following information:
 - Name of the project
 - Number of the project (if applicable)
 - Location of the project with cross streets
 - Street address of the project (if available)
- 2. Name of Developer, Project Phase Number, Project Type, and Project Description Include the following information:
 - Name of the developer
 - Project phase name and/or number (only if the project is being developed in phases) each phase should have a separate row entry
 - Type of development (i.e., new and/or redevelopment)
 - Description of development (e.g., 5-story office building, residential with 160 singlefamily homes with five 4-story buildings to contain 200 condominiums, 100 unit 2story shopping mall, mixed use retail and residential development (apartments), industrial warehouse)

3. Project Watershed

- State the watershed(s) that the Project drains into
- Optional but recommended: Also state the downstream watershed(s)
- 4. Total Site Area and Total Area of Land Disturbed State the total site area and the total area of land disturbed.
- 5. Total New and/or Replaced Impervious Surface Area
 - State the total new impervious surface area
 - State the total replaced impervious surface area, as applicable
- 6. Total Pre- and Post-Project Impervious Surface Area For redevelopment projects, state both the pre-project impervious surface area and the post-project impervious surface area.
- 7. Status of Project Include the following information:
 - Project application submittal date
 - Project application deemed complete date
 - Final, major, staff-level discretionary review and approval date
- **8. Source Control Measures** List all source control measures that have been or will be included in the project.

- **9.** Site Design Measures List all site design measures that have been or will be included in the project.
- **10.** Treatment Systems Installed List all post-construction stormwater treatment system(s) installed onsite and/or at a joint stormwater treatment system facility.
- **11. Operation and Maintenance Responsibility Mechanism** List the legal mechanism(s) that have been or will be used to assign responsibility for the maintenance of the post-construction stormwater treatment systems.
- 12. Hydraulic Sizing Criteria Used List the hydraulic sizing criteria used for the Project.

13. Alternative Compliance Measures

- Equivalent Offsite Treatment On a separate page, give a discussion of the alternative compliance project including the information specified in Provision C.3.b.v.(1)(l)(i) for the offsite project
- **Regional Project** On a separate page, provide the information specified in Provision C.3.b.v.(1)(l)(ii).

14. HM Controls

- If HM control is not required, state why not
- If HM control is required, state control method used (e.g., method to design and size device(s), method(s) used to meet the HM Standard, and description of device(s) or method(s) used, such as detention basin(s), biodetention unit(s), regional detention basins, or in-stream control)

ATTACHMENT B

Provision C.3.g. Alameda Permittees Hydromodification Management Requirements

Alameda Permittees Hydromodification Management Requirements

1. On-site and Regional Hydromodification Management (HM) Control Design Criteria

- **a.** *Range of flows to control*: Flow duration controls shall be designed such that post-project stormwater discharge rates and durations match pre-project discharge rates and durations from 10 percent of the pre-project 2-year peak flow¹ up to the pre-project 10-year peak flow, except where the lower endpoint of this range is modified as described in Section 6 of this Attachment.
- **b.** *Goodness of fit criteria*: The post-project flow duration curve shall not deviate above the pre-project flow duration curve by more than 10 percent over more than 10 percent of the length of the curve corresponding to the range of flows to control.
- **c.** Allowable low flow rate: Flow control structures may be designed to discharge stormwater at a very low rate that does not threaten to erode the receiving waterbody. This flow rate (also called Qcp^2) shall be no greater than 10 percent of the pre-project 2-year peak flow unless a modified value is substantiated by analysis of actual channel resistance in accordance with an approved User Guide as described in Section 6 of this Attachment.
- **d.** *Standard HM modeling*: On-site and regional HM controls designed using the Bay Area Hydrology Model (BAHM³) and site-specific input data shall be considered to meet the HM Standard. Such use must be consistent with directions and options set forth in the most current BAHM User's Manual.⁴ Permittees shall demonstrate to the satisfaction of the Executive Officer that any modifications of the BAHM made are consistent with the requirements of this Attachment and Provision C.3.f.
- e. *Alternate HM modeling and design*: The project proponent may use a continuous simulation hydrologic computer model⁵ to simulate pre-project and post-project runoff and to design HM controls. To use this method, the project proponent shall compare the

¹ Where referred to in this Order, the 2-year peak flow is determined using a flood frequency analysis procedure based on USGS Bulletin 17 B to obtain the peak flow statistically expected to occur at a 2-year recurrence interval. In this analysis, the appropriate record of hourly rainfall data (e.g., 35–50 years of data) is run through a continuous simulation hydrologic model, the annual peak flows are identified, rank ordered, and the 2-year peak flow is estimated. Such models include USEPA's Hydrologic Simulation Program—Fortran (HSPF), U.S. Army Corps of Engineers' Hydrologic Engineering Center-Hydrologic Modeling System (HEC-HMS), and USEPA's Storm Water Management Model (SWMM).

² Qcp is the allowable low flow discharge from a flow control structure on a project site. It is a means of apportioning the critical flow in a stream to individual projects that discharge to that stream, such that cumulative discharges do not exceed the critical flow in the stream.

³ The Bay Area Hydrology Model – A Tool for Analyzing Hydromodification Effects of Development Projects and Sizing Solutions, Bicknell, J., D. Beyerlein, and A. Feng, September 26, 2006. Available at

http://www.scvurppp-w2k.com/permit_c3_docs/Bicknell-Beyerlein-Feng_CASQA_Paper_9-26-06.pdf
 ⁴ The Bay Area Hydrology Model – A Tool for Analyzing Hydromodification Effects of Development Projects and Sizing Solutions, Bicknell, J., D. Beyerlein, and A. Feng, September 26, 2006. Available at http://www.scvurppp-w2k.com/permit_c3_docs/Bicknell-Beyerlein-Feng_CASQA_Paper_9-26-06.pdf

 ⁵ Such models include US EPA's Hydrologic Simulation Program—Fortran (HSPF), U.S. Army Corps of Engineers Hydrologic Engineering Center-Hydrologic Modeling System (HEC-HMS), and USEPA's Surface Water Management Model (SWMM).

pre-project and post-project model output for a rainfall record of at least 30 years, and shall show that all applicable performance criteria in 1.a-e above are met.

2. Impracticability Provision

Where conditions (e.g., extreme space limitations) prevent a project from meeting the HM Standard for a reasonable cost, *and* where the project's runoff cannot be directed to a regional HM control within a reasonable time frame, *and* where an in-stream measure is not practicable, the project shall use (1) site design for hydrologic source control, *and* (2) stormwater treatment measures that collectively minimize, slow, and detain⁶ runoff to the maximum extent practicable. In addition, the project proponent shall provide for or contribute financially to an alternative HM project as set forth below:

- **a.** *Reasonable cost*: To show that the HM Standard cannot be met at a reasonable cost, the project proponent must demonstrate that the total cost to comply with both the HM Standard and the Provision C.3.d treatment requirement exceeds 2 percent of the project construction cost, excluding land costs. Costs of HM and treatment control measures shall not include land costs, soil disposal fees, hauling, contaminated soil testing, mitigation, disposal, or other normal site enhancement costs such as landscaping or grading that are required for other development purposes.
- **b.** *Regional HM controls:* A regional HM control shall be considered available if there is a planned location for the regional HM control and if an appropriate funding mechanism for a regional HM control is in place by the time of project construction.
- **c.** *In-stream measures practicability:* In-stream measures shall be considered practicable when an in-stream measure for the project's watershed is planned and an appropriate funding mechanism for an in-stream measure is in place by the time of project construction.
- **d.** *Financial contribution to an alternative HM project:* The difference between 2 percent of the project construction costs and the cost of the treatment measures at the site (both costs as described in Section 2.a of this Attachment) shall be contributed to an alternative HM project, such as a stormwater treatment retrofit, HM retrofit, regional HM control, or in-stream measure that is not otherwise required by the Water Board or other regulatory agency. Preference shall be given to projects discharging, in this order, to the same tributary, mainstem, watershed, then in the same municipality or county.

3. Record Keeping

Permittees shall collect and retain the following information for all projects subject to HM requirements:

- a. Site plans identifying impervious areas, surface flow directions for the entire site, and location(s) of HM measures;
- b. For projects using standard sizing charts, a summary of sizing calculations used;
- c. For projects using the BAHM, a listing of model inputs;

⁶ Stormwater treatment measures that detain runoff are generally those that filter runoff through soil or other media and include bioretention units, bioswales, basins, planter boxes, tree wells, media filters, and green roofs.

- d. For projects using custom modeling, a summary of the modeling calculations with corresponding graph showing curve matching (existing, post-project, and post-project with HM controls curves);
- e. For projects using the Impracticability Provision, a listing of all applicable costs and a brief description of the alternative HM Project (name, location, date of start up, entity responsible for maintenance); and
- f. A listing, summary, and date of modifications made to the BAHM, including technical rationale. Permittees shall submit this list and explanation annually with the Annual Report. This may be prepared at the Countywide Program level and submitted on behalf of participating Permittees.

4. HM Control Areas

Applicable projects shall be required to meet the HM Standard when such projects are in areas of HM applicability shown in Figure A-1.⁷ Plans to restore a creek reach may reintroduce the applicability of HM requirements; in these instances, Permittees may add, but shall not delete, areas of applicability accordingly.

To assist in location and evaluation of project applicability, Figure A-1 depicts a number of features including the following:

- Hardened channels and culverts at least 24 inches in diameter (green solid or dashed lines);
- Natural channels (red lines);
- Boundaries of major watersheds (light blue lines); and
- Surface streets and highways (gray or black lines).

These data are of varying age, precision and accuracy and are not intended for legal description or engineering design. Watersheds extending beyond the County boundaries are shown for illustration purposes only. Project proponents are responsible for verifying and describing actual conditions of site location and drainage.

5. Figure A-1 is color-coded as follows:

- a. Solid pink areas Solid pink designates hilly areas, where high slopes (greater than 25 percent) occur. The HM Standard and all associated requirements apply in areas shown in solid pink on the map. In this area, the HM Standard does *not* apply if a project proponent demonstrates that all project runoff will flow through enclosed storm drains, existing concrete culverts, or fully hardened (with bed and banks continuously concrete-lined) channels to the tidal area shown in light gray.
- **b. Purple/red hatched areas** These are upstream of areas where hydromodification impacts are of concern because of factors such as bank instability, sensitive habitat, or restoration projects. The HM Standard and all associated requirements apply in areas shown in purple/red (printer-dependent) hatch marking on the map. Projects in these

⁷ The watercourses potentially susceptible to hydromodification impacts are identified based on an assessment approach developed by Balance Hydrologics (2003).

areas may be subject to additional agency reviews related to hydrologic, habitat or other watershed-specific concerns.

- c. Solid white areas Solid white designates the land area between the hills and the tidal zone. This area may be susceptible to hydromodification unless the site is connected to storm drains that discharge to the tidal area. The HM Standard and all associated requirements apply to projects in solid white areas *unless* a project proponent demonstrates that all project runoff will flow through fully hardened channels.⁸ Short segments of engineered earthen channels (length less than 10 times the maximum width of trapezoidal cross-section) can be considered resistant to erosion if located downstream of a concrete channel of similar or greater length and comparable cross-sectional dimensions. Plans to restore a hardened channel may affect the HM Standard applicability in this area.
- **d.** Solid gray areas Solid gray designates areas where streams or channels are tidally influenced or primarily depositional near their outfall in San Francisco Bay. The HM Standard does not apply to projects in this area. Plans to restore a hardened channel may affect the HM Standard applicability in this area.
- e. Dark gray, *Eastern County* area Dark gray designates the portion of eastern Alameda County that lies outside the discharge area of this NPDES permit. This area is in the Central Valley Regional Water Quality Control Board's jurisdiction.

6. Potential Exceptions to Figure A-1 Designations

The Program may choose to prepare a User Guide⁹ to be used for evaluating individual receiving waterbodies using detailed methods to assess channel stability and watercourse critical flow. This User Guide would reiterate and collate established stream stability assessment methods that have been presented in the Program's HMP.¹⁰ After the Program has collated its methods into a User Guide format, received approval of the User Guide from the Executive Officer,¹¹ and informed the public through such process as an electronic mailing list, the Permittees may use the User Guide to guide preparation of technical reports for the following: implementing the HM Standard using in-stream or regional HM controls; determining whether certain projects are discharging to a watercourse that is less susceptible (from point of discharge to the Bay) to hydromodification (e.g., would have a lower potential for erosion than set forth in these requirements); and/or determining if a watercourse has a higher critical flow and project(s) discharging to it are eligible for an alternative Qcp for the purpose of designing on-site or regional measures to control flows draining to these channels (i.e., the actual threshold of erosion-causing critical flow is higher than 10 percent of the 2year pre-project flow). In no case shall the design value of Qcp exceed 50 percent of the 2year pre-project flow.

⁸ In this paragraph, *fully hardened channels* include enclosed storm drains, existing concrete culverts, or channels whose bed and banks are continuously concrete-lined to the tidal area shown in light gray on the map.

⁹ The User Guide may be offered under a different title.

¹⁰ The Program's HMP has undergone Water Board staff review and been subject to public notice and comment.

¹¹ The User Guide shall not introduce a new concept, but rather reformat existing methods; therefore, Executive Officer approval is appropriate.

ATTACHMENT C

Provision C.3.g. Contra Costa Permittees Hydromodification Management Requirements

Contra Costa Permittees Hydromodification Management Requirements

1. Demonstrating Compliance with the Hydromodification Management (HM) Standard

Contra Costa Permittees shall ensure that project proponents shall demonstrate compliance with the HM Standard by demonstrating that any one of the following four options is met:

- **a.** *No increase in impervious area.* The project proponent may compare the project design to the pre-project condition and show that the project will not increase impervious area and also will not facilitate the efficiency of drainage collection and conveyance.
- **b.** *Implementation of hydrograph modification IMPs.* The project proponent may select and size IMPs to manage hydrograph modification impacts, using the design procedure, criteria, and sizing factors specified in the Contra Costa Clean Water Program's *Stormwater C.3 Guidebook.* The use of flow-through planters shall be limited to upper-story plazas, adjacent to building foundations, on slopes where infiltration could impair geotechnical stability, or in similar situations where geotechnical issues prevent use of IMPs that allow infiltration to native soils. Limited soil infiltration capacity in itself does not make use of other IMPs infeasible.
- **c.** Estimated post-project runoff durations and peak flows do not exceed pre-project durations and peak flows. The project proponent may use a continuous simulation hydrologic computer model such as USEPA's Hydrograph Simulation Program—Fortran (HSPF) to simulate pre-project and post-project runoff, including the effect of proposed IMPs, detention basins, or other stormwater management facilities. To use this method, the project proponent shall compare the pre-project and post-project model output for a rainfall record of at least 30 years, using limitations and instructions provided in the Program's Stormwater C.3 Guidebook, and shall show that the following criteria are met:
 - i. For flow rates from 10 percent of the pre-project 2-year runoff event (0.1Q2) to the preproject 10-year runoff event (Q10), the post-project discharge rates and durations shall not deviate above the pre-project rates and durations by more than 10 percent over more than 10 percent of the length of the flow duration curve.
 - **ii.** For flow rates from 0.5Q2 to Q2, the post-project *peak flows* shall not exceed pre-project peak flows. For flow rates from Q2 to Q10, post-project peak flows may exceed pre-project flows by up to 10 percent for a 1-year frequency interval. For example, post-project flows could exceed pre-project flows by up to 10 percent for the interval from Q9 to Q10 or from Q5.5 to Q6.5, but not from Q8 to Q10.
- **d.** Projected increases in runoff peaks and durations will not accelerate erosion of receiving stream reaches. The project proponent may show that, because of the specific characteristics of the stream receiving runoff from the project site, or because of proposed stream restoration projects, or both, there is little likelihood that the cumulative impacts from new development could increase the net rate of stream erosion to the extent that beneficial uses would be significantly impacted. To use this option, the project proponent shall evaluate the receiving stream to determine the relative risk of erosion impacts and take the appropriate actions as described below and in Table A-1. Projects 20 acres or larger in total area shall not use the medium risk methodology in (d)ii below.

i. *Low Risk.* In a report or letter report, signed by an engineer or qualified environmental professional, the project proponent shall show that all downstream channels between the project site and the Bay/Delta fall into one of the following *low-risk* categories.

(1) Enclosed pipes.

- (2) Channels with continuous hardened beds and banks engineered to withstand erosive forces and composed of concrete, engineered riprap, sackcrete, gabions, mats, and such. This category excludes channels where hardened beds and banks are not engineered continuous installations (i.e., have been installed in response to localized bank failure or erosion).
- (3) Channels subject to tidal action.
- (4) Channels shown to be aggrading (i.e., consistently subject to accumulation of sediments over decades) and to have no indications of erosion on the channel banks.
- **ii.** *Medium Risk.* Medium risk channels are those where the boundary shear stress could exceed critical shear stress as a result of hydrograph modification but where either the sensitivity of the boundary shear stress to flow is low (e.g., an oversized channel with high width to depth ratios) or where the resistance of the channel materials is relatively high (e.g., cobble or boulder beds and vegetated banks). In *medium-risk* channels, accelerated erosion due to increased watershed imperviousness is not likely but is possible, and the uncertainties can be more easily and effectively addressed by mitigation than by additional study.

In a preliminary report, the project proponent's engineer or qualified environmental professional shall apply the Program's *Basic Geomorphic Assessment*¹² methods and criteria to show each downstream reach between the project site and the Bay/Delta is either at *low-risk* or *medium-risk* of accelerated erosion due to watershed development. In a following, detailed report, a qualified stream geomorphologist¹³ shall use the Program's Basic Geomorphic Assessment methods and criteria, available information, and current field data to evaluate each *medium-risk* reach. For *each medium-risk* reach, the detailed report shall show one of the following:

- (1) A detailed analysis, using the Program's criteria, showing the particular reach may be reclassified as *low-risk*.
- (2) A detailed analysis, using the Program's criteria, confirming the *medium-risk* classification, and:
 - (a) A preliminary plan for a mitigation project for that reach to stabilize stream beds or banks, improve natural stream functions, and/or improve habitat values, and
 - (b) A commitment to implement the mitigation project timely in connection with the proposed development project (including milestones, schedule, cost estimates, and funding), and
 - (c) An opinion and supporting analysis by one or more qualified environmental professionals that the expected environmental benefits of the mitigation project

¹² Contra Costa Clean Water Program *Hydrograph Modification Management Plan*, May 15, 2005, Attachment 4, pp. 6-13. This method must be made available in the Program's *Stormwater C.3 Guidebook*.

¹³ Typically, detailed studies will be conducted by a stream geomorphologist retained by the lead agency (or, on the lead agency's request, another public agency such as the Contra Costa County Flood Control and Water Conservation District) and paid for by the project proponent.

substantially outweigh the potential impacts of an increase in runoff from the development project, and

- (d) Communication, in the form of letters or meeting notes, indicating consensus among staff representatives of regulatory agencies having jurisdiction that the mitigation project is feasible and desirable. In the case of the Regional Water Board, this must be a letter, signed by the Executive Officer or designee, specifically referencing this requirement. (This is a preliminary indication of feasibility required as part of the development project's Stormwater Control Plan. All applicable permits must be obtained before the mitigation project can be implemented.)
- iii. High Risk. High-risk channels are those where the sensitivity of boundary shear stress to flow is high (e.g., incised or entrenched channels, channels with low width-to-depth ratios, and narrow channels with levees) or where channel resistance is low (e.g., channels with fine-grained, erodible beds and banks, or with little bed or bank vegetation). In a high-risk channel, it is presumed that increases in runoff flows will accelerate bed and bank erosion. To implement this option (i.e., to allow increased runoff peaks and durations to a high-risk channel), the project proponent must perform a comprehensive analysis to determine the design objectives for channel restoration and must propose a comprehensive program of in-stream measures to improve channel functions while accommodating increased flows. Specific requirements are developed case-by-case in consultation with regulatory agencies having jurisdiction. The analysis will typically involve watershed-scale continuous hydrologic modeling (including calibration with stream gauge data where possible) of preproject and post-project runoff flows, sediment transport modeling, collection and/or analysis of field data to characterize channel morphology including analysis of bed and bank materials and bank vegetation, selection and design of in-stream structures, and project environmental permitting.

2. IMP Model Calibration and Validation

The Program shall monitor flow from Hydrograph Modification Integrated Management Practices (IMPs) to determine the accuracy of its model inputs and assumptions. Monitoring shall be conducted with the aim of evaluating flow control effectiveness of the IMPs. The Program shall implement monitoring where feasible at future new development projects to gain insight into actual versus predicted rates and durations of flow from IMP overflows and underdrains.

At a minimum, Permittees shall monitor five locations for a minimum of two rainy seasons. If two rainy seasons are not sufficient to collect enough data to determine the accuracy of model inputs and assumptions, monitoring shall continue until such time as adequate data are collected.

Permittees shall conduct the IMP monitoring as described in the IMP Model Calibration and Validation Plan in Section 5 of this Attachment. Monitoring results shall be submitted to the Executive Officer by June 15 of each year following collection of monitoring data. If the first year's data indicate IMPs are not effectively controlling flows as modeled in the HMP, the Executive Officer may require the Program to make adjustments to the IMP sizing factors or design, or otherwise take appropriate corrective action. The Permittees shall submit an IMP Monitoring Report by August 30 of the second year¹⁴ of monitoring. The IMP Monitoring Report

¹⁴ If the monitoring extends beyond 2 years, an IMP Monitoring Report shall be submitted by August 30 annually until model calibration and validation is complete.

shall contain, at a minimum, all the data, graphic output from model runs, and a listing of all model outputs to be adjusted, with full explanation for each. Board staff will review the IMP Monitoring Report and require the Program to make any appropriate changes to the model within a 3-month time frame.

3. Stormwater C.3 Guidebook and IMP Design Criteria

- a. <u>The Current Contra Costa Clean Water Program C.3 Guidebook, 4th Edition (September 2008) shall be implemented until the expiration of this permit (November 2014). Any significant changes in the designs of the IMPs, their sizing factors or manner of implementation shall be approved by the Water Board.NRCS Soil Groups: The Stormwater C.3 Guidebook shall include IMP sizing factors for use on development sites with Hydrologic Soil Group B and C soils, which shall be calculated using the methods and references in the Contra Costa Clean Water Program Hydrograph Modification Management Plan, dated May 15, 2005.</u>
- **b.**Self Retaining Areas: The *Stormwater C.3 Guidebook* shall also include appropriate criteria, based on detailed hydrologic analysis, to ensure runoff peak flows and durations from *self-retaining areas* do not exceed pre-project peak flows and durations from these same areas. Until such time as the Executive Officer approves these criteria, no areas shall be considered *self retaining* for the purposes of designing and implementing HM controls (i.e., stormwater flow and duration controls).

Table C-1: Summary of Option #4

Summary only. If there are conflicts between this summary table and the text of the Hydrograph Modification Management Standard, the text shall apply.

| Risk Classification and Definition | To Show Classification Applies | Requirements for HMP Compliance |
|---|---|---|
| Low: Enclosed pipes, channels with continuous hardened beds and banks, channels subject to tidal action, and channels shown to be aggrading over time with no sign of bank erosion. | An engineer or qualified environmental professional reviews all downstream reaches between the project site and the Bay/Delta and writes report/letter showing <i>all</i> reaches meet the <i>low risk</i> definition. | No additional requirements. |
| Medium: Channels where the boundary shear stress could exceed critical shear stress as a result of hydrograph modification, but where either the sensitivity of the boundary shear stress to flow is low (e.g., an oversized channel with high width to depth ratios) or where the resistance of the channel materials is relatively high (e.g., cobble or boulder beds and vegetated banks). Accelerated erosion due to increased watershed imperviousness is not likely but is possible, and the uncertainties can be more easily and effectively addressed by mitigation than by additional study. Not allowed for projects 20 acres or larger in total area. | An engineer or qualified environmental professional applies the Program's Basic Geomorphic Assessment* methods and Risk Class criteria and shows in a Preliminary Report that <i>each</i> downstream reach between the project site and the Bay/Delta is either <i>medium risk</i> or <i>low risk</i> . | The project proponent's qualified geomorphologist applies the Program's Basic Geomorphic Assessment* methods and criteria, available information, and current field data to show, for each reach that was characterized in the Preliminary Report as <i>medium risk</i> . The geomorphologist prepares a detailed report showing, for each reach, either: The particular reach should be reclassified as <i>low risk</i> . [No further action for that reach is required.] OR The particular reach is confirmed to be <i>medium risk</i> . Present a mitigation project plan to stabilize stream bed and/or banks, improve natural stream functions, and/or improve habitat values as described in Section 4.b.ii of the Standard. Approval includes Water Board staff written approval. |
| High: Channels where the sensitivity of boundary shear stress to flow is high (e.g., incised or entrenched channels, channels with low width to- depth ratios, and narrow channels with levees) or where channel resistance is low (e.g., channels with fine grained, erodible beds and banks, or with little bed or bank vegetation). | Default classification if neither <i>low</i> nor <i>medium</i> risk classification applies to all downstream channels between the project site and the Bay/Delta fall. | The project proponent's qualified geomorphologist conducts a Detailed Geomorphic and Hydrologic Assessment* to determine the design objectives for stream restoration and a comprehensive program of in-stream measures to improve channel functions while accommodating increased flows. Specific requirements are developed case by case in cooperation with the applicable regulatory agencies. As with all in-stream activities, Water Board staff sign off is required, and input should be sought in the project's early stages. |

* These methods are described in Contra Costa Clean Water Program Hydrograph Modification Management Plan, May 15, 2005, Attachment 4, and must be described in the Program's Stormwater C.3 Guidebook.

4. IMP Model Calibration and Validation Plan Objective

As part of the process of continuous improvement of the HMP, the Program shall investigate means to monitor flow from Hydrograph Modification Integrated Management Practices (IMPs). Monitoring shall be conducted with the aim of evaluating flow control effectiveness of the IMPs. The IMPs were redesigned in 2008 to meet a low flow criterion of 0.2Q2, not 0.1Q2, which is current HMP standard for Contra Costa County. The Program shall implement monitoring where feasible at future new development projects at a minimum of five locations and for a minimum of two rainy seasons to gain insight into actual versus predicted rates and durations of flow from IMP overflows and underdrains. If two rainy seasons are not sufficient to collect enough data to determine the accuracy of model inputs and assumptions, monitoring shall continue until such time as adequate data are collected.

a. The Dischargers Shall Identify and Establish Monitoring Sites – Program staff shall work with municipal Co-Permittees to identify potential monitoring sites on development projects that implement IMPs. Proposed sites shall be identified during review of planning and zoning applications so that monitoring stations can be designed and constructed as part of the development project. Monitoring shall begin after the development project is complete and the site is in use.

Criteria for appropriate sites include, but are not limited to, the following:

- To ensure applicability of results, the development project and IMPs should be typical of development sites and types of IMPs foreseen throughout the County. In particular, at least one each of the infiltration planter, flow-through planter, and *dry* swale shall be selected for monitoring.
- The area tributary to the IMP should be clearly defined, should contain and direct runoff at all rainfall intensities to the IMP. Two monitoring locations shall contain tributary areas that are a mix of pervious and impervious areas to test the pervious area simplifying assumptions used in the HMP, Table 14, Attachment 2, page 49. If no such locations are constructed by the monitoring period, modeling of mixed (pervious and impervious) tributary areas can substitute for direct monitoring of this type of location.
- The site shall be easily accessible at all times of day and night to allow inspection and maintenance of measurement equipment.
- Hourly rain gauge data representative of the site's location shall be available.
- **b. Documentation of Monitoring Sites** The Dischargers shall record and report (i.e., document) pertinent information for each monitoring site. Documentation of each monitoring site shall include the following:
 - Amount of tributary area;
 - Condition of roof or paving;
 - Grading and drainage to the IMP, including calculated time of concentration.
 - Locations and elevations of inlets and outlets;
 - As-built measurements of the IMP including depth of soil and gravel layers, height of underdrain pipe above the IMP floor or native soil;

- Detailed specifications of soil and gravel layers and of filter fabric and other appurtenances; and
- Condition of IMP surface soils and vegetation.
- c. Design, Construction, and Operation of Monitoring Sites The Dischargers shall ensure that IMPs selected for monitoring are equipped with a manhole, vault, or other means to install and access equipment for monitoring flows from IMP overflows and underdrains.

Development of suitable methods for monitoring the entire range of flows may require experiment. The Program and Water Board are interested in the timing and duration of very low flows from underdrains, as well as higher flows from IMP overflows. The Dischargers shall ensure that equipment is configured to measure the entire range of flows and to avoid potential clogging of orifices used to measure low flows.

The Dischargers shall ensure that construction of IMPs is inspected carefully to ensure that IMPs are installed as designed and to avoid potential operational problems. For example, gravel used for underdrain layers should be washed free of fines, and filter fabric should be installed without breaks.

The Dischargers shall ensure that, following construction, artificial flows are applied to the IMP to verify the IMP and monitoring equipment are operating correctly and to resolve any operational problems prior to measuring flows from actual rain storms.

The Dischargers shall ensure that monitoring equipment is properly maintained. Maintenance of monitoring equipment will require, initially, inspections during and after storms that produce runoff. The inspection and maintenance schedule may be adjusted as additional experience is gained.

- **d. Data to be Obtained** The Dischargers shall collect the following data for each IMP, during the monitoring period:
 - Hourly rainfall and more frequent rainfall data where available;
 - Hourly IMP outflow and 15-minute outflow for all time periods in which subhourly rainfall data are available;
 - Hourly IMP inflow (if possible) and more frequent inflow (if possible) when subhourly rainfall data are available; and
 - Notes and observations.
- e. Evaluation of Data The principal use of the monitoring data shall be a comparison of predicted to actual flows. The Dischargers shall ensure that the HSPF model is set up as it was to prepare the curves in Attachment 2 of the HMP, with appropriate adjustments for the drainage area of the IMP to be monitored and for the actual sizing and configuration of the IMP. Hourly rainfall data from observed storms shall be input to the model, and the resulting hourly predicted output recorded. Where sub-hourly rainfall data are available, the model shall be run with, and output recorded for, 15-minute time steps.

The Dischargers shall compare predicted hourly outflows to the actual hourly outflows. As more data are gathered, the Dischargers may examine aggregated data to characterize deviations from predicted performance at various storm intensities and durations. Because high-intensity storms are rare, it will take many years to obtain a suitable number of events to evaluate IMP performance under overflow conditions. Underdrain flows will occur more frequently, but possibly only a few times a year, depending on rainfall and IMP characteristics (e.g., extent to which the IMP is oversized, and actual, rather than predicted, permeability of native soils). However, evaluating a range of rainfall events that do *not* produce underflow will help demonstrate the effectiveness of the IMP.

5. Record Keeping and Reporting

Permittees shall collect and retain the following information for all projects subject to HM requirements:

- **a.** Site plans identifying impervious areas, surface flow directions for the entire site, and location(s) of HM measures;
- **b.** For projects using standard sizing charts, a summary of sizing calculations used;
- c. For projects using the BAHM, a listing of model inputs;
- **d.** For projects using custom modeling, a summary of the modeling calculations with corresponding graph showing curve matching (existing, post-project, and post-project with HM controls curves);
- **e.** For projects using the Impracticability Provision, a listing of all applicable costs and a brief description of the alternative HM project (name, location, date of start up, entity responsible for maintenance); and
- **f.** A list and thorough technical explanation of any changes in design criteria for HM Controls, including IMPs. Permittees shall submit this list and explanation annually with the Annual Report.
- 6. The current Contra Costa Clean Water Program C.3 Guidebook, 4th Edition (C.3 Guidebook) (September 2008) design approach and IMPs shall be used to comply with Provision C.3.g flow requirements until this permit expires and is reissued, pending model verification studies as described below. The IMPs shall be an implementation option as the flow control implementation for development projects up to a footprint of 30 acres

By April 1, 2014, the Contra Costa Clean Water Program shall submit a proposal containing one or a combination of the following three options (a.-c.) for implementation after the expiration and reissuance of this permit:

- a. Present model verification monitoring results demonstrating that the IMPs are sufficiently overdesigned and perform to meet the 0.1Q2 low flow design criteria; or
- b. Present study results of Contra Costa County streams geology and other factors that support the low flow design criteria of 0.2Q2 as the limiting HMP design low flow; or
- c. Propose redesigns of the IMPs to meet the low flow design criteria of 0.1Q2 to be implemented during the next permit term; or.

ATTACHMENT D

Provision C.3.g. Fairfield-Suisun Permittees Hydromodification Management Requirements

Fairfield-Suisun Permittees Hydromodification Management Requirements

1. On-site and Regional Hydromodification Management (HM) Control Design Criteria

- **a.** *Range of flows to control*: Flow duration controls shall be designed such that postproject stormwater discharge rates and durations match pre-project discharge rates and durations from 20 percent of the pre-project 2-year peak flow¹⁵ up to the pre-project 10-year peak flow.
- **b.** *Goodness of fit criteria*: The post-project flow duration curve shall not deviate above the pre-project flow duration curve by more than 10 percent over more than 10 percent of the length of the curve corresponding to the range of flows to control.
- **c.** Allowable low flow rate: Flow control structures may be designed to discharge stormwater at a very low rate that does not threaten to erode the receiving waterbody. This flow rate (also called Qcp¹⁶) shall be no greater than 20 percent of the pre-project 2-year peak flow.
- **d.** *Standard HM modeling:* On-site and regional HM controls designed using the Bay Area Hydrology Model (BAHM¹⁷) and site-specific input data shall be considered to meet the HM Standard. Such use must be consistent with directions and options set forth in the most current BAHM User Manual.¹⁸ Permittees shall demonstrate to the satisfaction of the Executive Officer that any modifications of the BAHM made are consistent with this Attachment and Provision C.3.g.
- **e.** Alternate HM modeling and design: The project proponent may use a continuous simulation hydrologic computer model¹⁹ to simulate pre-project and post-project runoff and to design HM controls. To use this method, the project proponent shall compare the pre-project and post-project model output for a rainfall record of at least 30 years, and shall show that all applicable performance criteria in 1.a–c above are met.
- **f.** *Sizing Charts:* The Program developed design procedures, criteria, and sizing factors for infiltration basins and bioretention units, based on a low flow rate that exceeds the allowable low flow rate. After the Program has modified its sizing factors²⁰ to the allowable criteria, received approval of the modified sizing factors from the Executive

¹⁵ Where referred to in this Order, the 2-year peak flow is determined using a flood flow frequency analysis procedure based on USGS Bulletin 17 B to obtain the peak flow statistically expected to occur at a 2-year recurrence interval. In this analysis, the appropriate record of hourly rainfall data (e.g., 35–50 years of data) is run through a continuous simulation hydrologic model, the annual peak flows are identified, rank ordered, and the 2-year peak flow is estimated. Such models include USEPA's Hydrologic Simulation Program—Fortran (HSPF), U.S. Army Corps of Engineers' Hydrologic Engineering Center-Hydrologic Modeling System (HEC-HMS), and USEPA's Storm Water Management Model (SWMM).

¹⁶ Qcp is the allowable low flow discharge from a flow control structure on a project site. It is a means of apportioning the critical flow in a stream to individual projects that discharge to that stream, such that cumulative discharges do not exceed the critical flow in the stream.

¹⁷ See www.bayareahydrologymodel.org , Resources

¹⁸ The Bay Area Hydrology Model User Manualis available at http://www.bayareahydrologymodel.org/downloads.html.

¹⁹ Such models include USEPA's Hydrologic Simulation Program—Fortran (HSPF), U.S. Army Corps of Engineers Hydrologic Engineering Center-Hydrologic Modeling System (HEC-HMS), and USEPA's Storm Water Management Model (SWMM).

²⁰ Current sizing factors and design criteria are shown in Appendix D of the FSURMP HMP.

Officer,²¹ and informed the public through such mechanism as an electronic mailing list, project proponents may meet the HM Standard by using the Program's design procedures, criteria, and sizing factors for infiltration basins and/or bioretention units.

2. Impracticability Provision

Where conditions (e.g., extreme space limitations) prevent a project from meeting the HM Standard for a reasonable cost, *and* where the project's runoff cannot be directed to a regional HM control within a reasonable time frame, *and* where an in-stream measure is not practicable, the project shall use (1) site design for hydrologic source control, *and* (2) stormwater treatment measures that collectively minimize, slow, and detain²² runoff to the maximum extent practicable. In addition, if the cost of providing site design for hydrologic source control and treatment measures to the maximum extent practicable does not exceed 2% of the project cost (as defined in "2.a." below), the project proponent shall provide for or contribute financially to an alternative HM project as set forth below:

- **a.** *Reasonable cost*: To show that the HM Standard cannot be met at a reasonable cost, the project proponent must demonstrate that the total cost to comply with both the HM Standard and the Provision C.3.d. treatment requirement exceeds 2 percent of the project construction cost, excluding land costs. Costs of HM and treatment control measures shall not include land costs, soil disposal fees, hauling, contaminated soil testing, mitigation, disposal, or other normal site enhancement costs such as landscaping or grading that are required for other development purposes.
- **b.** *Regional HM controls*: A regional HM control shall be considered available if there is a planned location for the regional HM control and if an appropriate funding mechanism for a regional HM control is in place by the time of project construction.
- **c.** *In-stream measures practicability*: In-stream measures shall be considered practicable when an in-stream measure for the project's watershed is planned and an appropriate funding mechanism for an in-stream measure is in place by the time of project construction.
- **d.** *Financial contribution to an alternative HM project*: The difference between 2 percent of the project construction costs and the cost of the treatment measures at the site (both costs as described in Section 2.a of this Attachment) shall be contributed to an alternative HM project, such as a stormwater treatment retrofit, HM retrofit, regional HM control, or in-stream measure. Preference shall be given to projects discharging, in this order, to the same tributary, mainstem, watershed, then in the same municipality or county.

3. Record Keeping

Permittees shall collect and retain the following information for all projects subject to HM requirements:

a. Site plans identifying impervious areas, surface flow directions for the entire site, and location(s) of HM measures;

²¹ The modified sizing factors will not introduce a new concept but rather make an existing compliance mechanism more stringent; therefore, Executive Officer approval is appropriate.

²² Stormwater treatment measures that detain runoff are generally those that filter runoff through soil or other media, and include bioretention units, bioswales, basins, planter boxes, tree wells, media, filters, and green roofs.

- **b.** For projects using standard sizing charts, a summary of sizing calculations used;
- c. For projects using the BAHM, a listing of model inputs;
- **d.** For projects using custom modeling, a summary of the modeling calculations with corresponding graph showing curve matching (existing, post-project, and post-project with HM controls curves);
- **e.** For projects using the Impracticability Provision, a listing of all applicable costs and a brief description of the alternative HM project (name, location, date of start up, entity responsible for maintenance); and
- **f.** A listing, summary, and date of modifications made to the BAHM, including technical rationale. Permittees shall submit this list and explanation annually with the Annual Report.

4. HM Control Areas

Applicable projects shall be required to meet the HM Standard when such projects discharge into the upstream reaches of Laurel or Ledgewood Creeks, as delineated in Figures C-1 and C-2. Plans to restore a creek reach may reintroduce the applicability of HM requirements; in these instances, Permittees may add, but shall not delete, areas of applicability accordingly.

ATTACHMENT E

Provision C.3.g. San Mateo Permittees Hydromodification Management Requirements

San Mateo Permittees Hydromodification Management Requirements

1. On-site and Regional Hydromodification Management (HM) Control Design Criteria

- **a.** *Range of flows to control:* Flow duration controls shall be designed such that post-project stormwater discharge rates and durations match pre-project discharge rates and durations from 10 percent of the pre-project 2-year peak flow²³ up to the pre-project 10-year peak flow.
- **b.** *Goodness of fit criteria*: The post-project flow duration curve shall not deviate above the pre-project flow duration curve by more than 10 percent over more than 10 percent of the length of the curve corresponding to the range of flows to control.
- **c.** Allowable low flow rate: Flow control structures may be designed to discharge stormwater at a very low rate that does not threaten to erode the receiving waterbody. This flow rate (also called Qcp²⁴) shall be no greater than 10 percent of the pre-project 2-year peak flow.
- **d.** *Standard HM modeling*: On-site and regional HM controls designed using the Bay Area Hydrology Model (BAHM²⁵) and site-specific input data shall be considered to meet the HM Standard. Such use must be consistent with directions and options set forth in the most current BAHM User Manual.²⁶ Permittees shall demonstrate to the satisfaction of the Executive Officer that any modifications of the BAHM made are consistent with the requirements of Provision C.3.g.
- **e.** Alternate HM modeling and design: The project proponent may use a continuous simulation hydrologic computer model²⁷ to simulate pre-project and post-project runoff and to design HM controls. To use this method, the project proponent shall compare the pre-project and post-project model output for a rainfall record of at least 30 years, and shall show that all applicable performance criteria in 1.a.–c. above are met.

2. Impracticability Provision

Where conditions (e.g., extreme space limitations) prevent a project from meeting the HM Standard for a reasonable cost, *and* where the project's runoff cannot be directed to a

²³ Where referred to in this Order, the 2-year peak flow is determined using a flood flow frequency analysis procedure based on USGS Bulletin 17 B to obtain the peak flow statistically expected to occur at a 2-year recurrence interval. In this analysis, the appropriate record of hourly rainfall data (e.g., 35–50 years of data) is run through a continuous simulation hydrologic model, the annual peak flows are identified, rank ordered, and the 2-year peak flow is estimated. Such models include USEPA's Hydrologic Simulation Program—Fortran (HSPF), U.S. Army Corps of Engineers' Hydrologic Engineering Center-Hydrologic Modeling System (HEC-HMS), and USEPA's Storm Water Management Model (SWMM).

²⁴ Qcp is the allowable low flow discharge from a flow control structure on a project site. It is a means of apportioning the critical flow in a stream to individual projects that discharge to that stream, such that cumulative discharges do not exceed the critical flow in the stream.

²⁵ See www.bayareahydrologymodel.org , Resources

²⁶ The Bay Area Hydrology Model User Manualis available at http://www.bayareahydrologymodel.org/downloads.html

²⁷ Such models include USEPA's Hydrologic Simulation Program—Fortran (HSPF), U.S. Army Corps of Engineers Hydrologic Engineering Center-Hydrologic Modeling System (HEC-HMS), and USEPA's Storm Water Management Model (SWMM).

regional HM control within a reasonable time frame, *and* where an in-stream measure is not practicable, the project shall use (1) site design for hydrologic source control, *and* (2) stormwater treatment measures that collectively minimize, slow, and detain²⁸ runoff to the maximum extent practicable. In addition, , if the cost of providing site design for hydrologic source control and treatment measures to the maximum extent practicable does not exceed 2% of the project cost (as defined in "2.a." below), the project proponent shall provide for or contribute financially to an alternative HM project as set forth below:

- **a.** *Reasonable cost*: To show that the HM Standard cannot be met at a reasonable cost, the project proponent must demonstrate that the total cost to comply with both the HM Standard and the Provision C.3.d treatment requirement exceeds 2 percent of the project construction cost, excluding land costs. Costs of HM and treatment control measures shall not include land costs, soil disposal fees, hauling, contaminated soil testing, mitigation, disposal, or other normal site enhancement costs such as landscaping or grading that are required for other development purposes.
- **b.** *Regional HM controls:* A regional HM control shall be considered available if there is a planned location for the regional HM control and if an appropriate funding mechanism for a regional HM control is in place by the time of project construction.
- **c.** *In-stream measures practicability:* In-stream measures shall be considered practicable when an in-stream measure for the project's watershed is planned and an appropriate funding mechanism for an in-stream measure is in place by the time of project construction.
- **d.** *Financial contribution to an alternative HM project*: The difference between 2 percent of the project construction costs and the cost of the treatment measures at the site (both costs as described in Section 2.a of this Attachment shall be contributed to an alternative HM project, such as a stormwater treatment retrofit, HM retrofit, regional HM control, or in-stream measure. Preference shall be given to projects discharging, in this order, to the same tributary, mainstem, watershed, then in the same municipality, or county.

3. Record Keeping

Permittees shall collect and retain the following information for all projects subject to HM requirements:

- **a.** Site plans identifying impervious areas, surface flow directions for the entire site, and location(s) of HM measures;
- **b.** For projects using standard sizing charts, a summary of sizing calculations used;
- c. For projects using the BAHM, a listing of model inputs;
- **d.** For projects using custom modeling, a summary of the modeling calculations with corresponding graph showing curve matching (existing, post-project, and post-project with HM controls curves);

²⁸ Stormwater treatment measures that detain runoff are generally those that filter runoff through soil or other media, and include bioretention units, bioswales, basins, planter boxes, tree wells, media filters, and green roofs.

- **e.** For projects using the Impracticability Provision, a listing of all applicable costs and a brief description of the alternative HM project (name, location, date of startup, entity responsible for maintenance); and
- **f.** A listing, summary, and date of modifications made to the BAHM, including technical rationale. Permittees shall submit this list and explanation annually with the Annual Report. This may be prepared at the Countywide Program level and submitted on behalf of participating Permittees.

4. HM Control Areas

Applicable projects shall be required to meet the HM Standard when such projects are in the HM control areas shown in Figure D-1. Plans to restore a creek reach may reintroduce the applicability of HM requirements; in these instances, Permittees may add, but shall not delete, areas of applicability accordingly.

The HM Standard and all associated requirements apply in areas that are shown in green on the map and noted in the map's key as *areas subject to HMP*. The other areas are exempt from the HM Standard because they drain to hardened channels or low gradient channels (a characteristic applicable to San Mateo County's particular shoreline properties), or are in highly developed areas. Plans to restore a hardened channel may affect areas of applicability.

Areas shown in Figure D-1 may be modified as follows:

- a. Street Boundary Interpretation Streets are used to mark the boundary between areas where the HM Standard must be met and exempt areas. Parcels on the boundary street are considered within the area exempted from the hydromodification requirements. Nonetheless, there might be cases where the drainage from a particular parcel(s) on the boundary street drains westward into the hydromodification required area and, as such, any applicable project on such a parcel(s) would be subject to the hydromodification requirements.
- **b.** Hardened Channel/Drainage to Exempt Area If drainage leaving a proposed project subject to the HM Standard is determined to flow only through a hardened channel and/or enclosed pipe along its entire length before directly discharging into a waterway in the exempt area or into tidal waters, the project would be exempted from the HM Standard and its associated requirements. The project proponent must demonstrate, in a statement signed by an engineer or qualified environmental professional, that this condition is met.
- **c. Boundary Re-Opener** If the municipal regional permit or future permit reissuances or amendments modify the types of projects subject to the hydromodification requirements, the appropriate location for an HMP boundary or boundaries will be reevaluated at the same time.

ATTACHMENT F

Provision C.3.g. Santa Clara Permittees Hydromodification Management Requirements

Santa Clara Permittees Hydromodification Management Requirements

1. On-site and Regional Hydromodification Management (HM) Control Design Criteria

- **a.** *Range of flows to control:* Flow duration controls shall be designed such that post-project stormwater discharge rates and durations match pre-project discharge rates and durations from 10 percent of the pre-project 2-year peak flow²⁹ up to the pre-project 10-year peak flow, except where the lower endpoint of this range is modified as described in Section 5 of this Attachment.
- **b.** *Goodness of fit criteria*: The post-project flow duration curve shall not deviate above the pre-project flow duration curve by more than 10 percent over more than 10 percent of the length of the curve corresponding to the range of flows to control.
- c. Allowable low flow rate: Flow control structures may be designed to discharge stormwater at a very low rate that does not threaten to erode the receiving waterbody. This flow rate (also called Qcp^{30}) shall be no greater than 10 percent of the pre-project 2-year peak flow unless a modified value is substantiated by analysis of actual channel resistance in accordance with an approved User Guide as described in Section 5 of this Attachment.
- **d.** *Standard HM modeling*: On-site and regional HM controls designed using the Bay Area Hydrology Model (BAHM³¹) and site-specific input data shall be considered to meet the HM Standard. Such use must be consistent with directions and options set forth in the most current BAHM User Manual.³² Permittees shall demonstrate to the satisfaction of the Executive Officer that any modifications of the BAHM made are consistent with this attachment and Provision C.3.g.
- **e.** Alternate HM modeling and design: The project proponent may use a continuous simulation hydrologic computer model³³ to simulate pre-project and post-project runoff and to design HM controls. To use this method, the project proponent shall compare the pre-project and post-project model output for a rainfall record of at least 30 years, and shall show that all applicable performance criteria in 1.a. c. above are met.

²⁹ Where referred to in this Order, the 2-year peak flow is determined using a flood flow frequency analysis procedure based on USGS Bulletin 17B to obtain the peak flow statistically expected to occur at a 2-year recurrence interval. In this analysis, the appropriate record of hourly rainfall data (e.g., 35–50 years of data) is run through a continuous simulation hydrologic model, the annual peak flows are identified, rank ordered, and the 2-year peak flow is estimated. Such models include USEPA's Hydrologic Simulation Program—Fortran (HSPF), U.S. Army Corps of Engineers' Hydrologic Engineering Center-Hydrologic Modeling System (HEC-HMS), and USEPA's Storm Water Management Model (SWMM).

³⁰ Qcp is the allowable low flow discharge from a flow control structure on a project site. It is a means of apportioning the critical flow in a stream to individual projects that discharge to that stream, such that cumulative discharges do not exceed the critical flow in the stream.

³¹ <u>See www.bayareahydrologymodel.org</u>, Resources.

³² The Bay Area Hydrology Model User Manual is available at http://www.bayareahydrologymodel.org/downloads.html.

³³ Such models include USEPA's Hydrologic Simulation Program—Fortran (HSPF), U.S. Army Corps of Engineers Hydrologic Engineering Center-Hydrologic Modeling System (HEC-HMS), and USEPA's Storm Water Management Model (SWMM).

2. Impracticability Provision

Where conditions (e.g., extreme space limitations) prevent a project from meeting the HM Standard for a reasonable cost, *and* where the project's runoff cannot be directed to a Regional HM control³⁴ within a reasonable time frame, *and* where an in-stream measure is not practicable, the project shall use (1) site design for hydrologic source control, *and* (2) stormwater treatment measures that collectively minimize, slow, and detain³⁵ runoff to the maximum extent practicable. In addition, if the cost of providing site design for hydrologic source control and treatment measures to the maximum extent practicable does not exceed 2% of the project cost (as defined in "2.a." below), the project shall contribute financially to an alternative HM project as set forth below:

- **a.** *Reasonable cost*: To show that the HM Standard cannot be met at a reasonable cost, the project proponent must demonstrate that the total cost to comply with both the HM Standard and the Provision C.3.d treatment requirement exceeds 2 percent of the project construction cost, excluding land costs. Costs of HM and treatment control measures shall not include land costs, soil disposal fees, hauling, contaminated soil testing, mitigation, disposal, or other normal site enhancement costs such as landscaping or grading that are required for other development purposes.
- **b.** *Regional HM control:* A regional HM control shall be considered available if there is a planned location for the regional HM control and if an appropriate funding mechanism for a regional control is in place by the time of project construction.
- **c.** *In-stream measures practicability:* In-stream measures shall be considered practicable when an in-stream measure for the project's watershed is planned and an appropriate funding mechanism for an in-stream measure is in place by the time of project construction.
- **d.** *Financial contribution to an alternative HM project:* The difference between 2 percent of the project construction costs and the cost of the treatment measures at the site (both costs as described in Section 2.a of this Attachment) shall be contributed to an alternative HM project, such as a stormwater treatment retrofit, HM retrofit, regional HM control, or in-stream measure. Preference shall be given to projects discharging, in this order, to the same tributary, mainstem, watershed, then in the same municipality or county.

3. Record Keeping

Permittees shall collect and retain the following information for all projects subject to HM requirements:

- **a.** Site plans identifying impervious areas, surface flow directions for the entire site, and location(s) of HM measures;
- **b.** For projects using standard sizing charts, a summary of sizing calculations used;
- c. For projects using the BAHM, a listing of model inputs;

³⁴ Regional HM controls are flow duration control structures that collect stormwater runoff discharge from multiple projects (each of which should incorporate hydrologic source control measures as well) and are designed such that the HM Standard is met for all the projects at the point where the regional control measure discharges.

 ³⁵ Stormwater treatment measures that detain runoff are generally those that filter runoff through soil or other media, and include bioretention units, bioswales, basins, planter boxes, sand filters, and green roofs.

- **d.** For projects using custom modeling, a summary of the modeling calculations with corresponding graph showing curve matching (existing, post-project, and post-project with HM controls curves);
- e. For projects using the Impracticability Provision, a listing of all applicable costs and a brief description of the alternative HM project (name, location, date of start up, entity responsible for maintenance); and
- f. A listing, summary, and date of modifications made to the BAHM, including technical rationale. Permittees shall submit this list and explanation annually with the Annual Report. This may be prepared at the Countywide Program level and submitted on behalf of participating Permittees.

4. HM Control Areas

Applicable projects shall be required to meet the HM Standard when such projects are located in areas of HM applicability as described below and shown in Figure E-1.

a. Purple areas: These areas represent catchments that drain to hardened channels that extend continuously to the Bay or to tidally influenced sections of creeks. The HM Standard and associated requirements do <u>not</u> apply to projects in the areas designated in purple on the map.

Plans to restore a creek reach may reintroduce the applicability of HM requirements, unless the creek restoration project is designed to accommodate the potential hydromodification impacts of future development; if this is not the case, in these instances, Permittees may add, but shall not delete, areas of applicability accordingly.

- **b. Red areas**: These areas represent catchments and subwatersheds that are greater than or equal to 65% impervious, based on existing imperviousness data sources. The HM Standard and associated requirements do <u>not</u> apply to projects in the areas designated in red on the map.
- **c. Pink areas**: These are areas that are under review by the Permittees for accuracy of the imperviousness data. The HM Standard and associated requirements <u>apply</u> to projects in areas designated as pink on the map until such time as a Permittee presents new data that indicate that the actual level of imperviousness of a particular area is greater than or equal to 65% impervious. Any new data will be submitted to the Water Board in one coordinated submittal within one year of permit adoption.
- **d.** Green area: These areas represent catchments and subwatersheds that are less than 65% impervious and are not under review by the Permittees. The HM Standard and associated requirements <u>apply</u> to projects in areas designated as green on the map.

5. Potential Exceptions to Map Designations

The Program may choose to prepare a User Guide³⁶ to be used for evaluating individual receiving waterbodies using detailed methods to assess channel stability and watercourse critical flow. This User Guide would reiterate and collate established stream stability assessment methods that have been presented in the Program's HMP.³⁷ After the Program has collated its methods into User Guide format, received approval of the User Guide from

³⁶ The User Guide may be offered under a different title.

³⁷ The Program's HMP has undergone Water Board staff review and been subject to public notice and comment.

the Executive Officer,³⁸ and informed the public through such process as an electronic mailing list, the Permittees may use the User Guide to guide preparation of technical reports for the following: implementing the HM Standard using in-stream or regional controls; determining whether certain projects are discharging to a watercourse that is less susceptible (from point of discharge to the Bay) to hydromodification (e.g., would have a lower potential for erosion than set forth in these requirements); and/or determining if a watercourse has a higher critical flow and project(s) discharging to it are eligible for an alternative Qcp for the purpose of designing on-site or regional measures to control flows draining to these channels (i.e., the actual threshold of erosion-causing critical flow is higher than 10 percent of the 2-year pre-project flow). In no case shall the design value of Qcp exceed 50 percent of the 2-year pre-project flow.

³⁸ The User Guide will not introduce a new concept, but rather reformat existing methods; therefore, Executive Officer approval is appropriate.

ATTACHMENT G

Provision C.3.h. Sample Reporting Table

Table C.3.h. – Operation and Maintenance of Stormwater Treatment Systems City of Eden Annual Report FY 2008-09

| Facility/Site Inspected and Responsible Party for Maintenance | Date of Inspection follow-up, etc.) | | Type of Treatment System or HM Control Inspected | Inspection Findings or Results | Enforcement Action Taken (Warning, NOV, administrative citation, etc.) | Comments | |
|--|---|-----------------|--|---|--|--|--|
| ABC Company 123 Alphabet Road San Jose | 23 Alphabet Road 12/06/08 annual Olisi | | offsite bioretention unit | proper operation | none | Unit is operating properly and is well maintained. | |
| DEF site | 12/17/08 | annual | onsite media filter | ineffective filter media | verbal warning | Media filter is clogged and needs to be replaced. | |
| 234 Blossom Drive Santa Clara | 12/19/08 | follow-up | onsite media filter | proper operation | none | New media filter in place and unit is operating properly. | |
| | 1/19/09 | follow-up | onsite media filter | proper operation | none | Unit is operating properly. | |
| | 12/21/08 | annual | onsite swales | proper operation | | Bioretention unit #2 is badly eroded | |
| GHI Hotel | | | onsite bioretention unit #1 | proper operation | notice of violation | because of flow channelization. Stormwater is flowing over the eroded areas, bypassing treatment and running | |
| 1001 Grand Blvd 227 Touring Parkway | | | onsite bioretention unit #2 | eroded areas due to flow channelization | | off into parking area. | |
| Tanway | 12/27/08 | follow-up | onsite bioretention unit #2 | proper operation | none | Entire bioretention unit #2 has been replanted and re-graded. Raining heavily but no overflow observed. | |
| Rolling Hills Estates | 01/17/09 | annual | onsite pond | sediment and debris accumulation | notice of violation | Pond needs sediment removal and check dam needs debris removal. | |
| Homeowners' Association | 01/24/09 | follow-up | onsite pond | sediment and debris accumulation | administrative citation \$1000 | Pond still a mess. Administrative citation requires maintenance within a week. | |
| 543 Rolling Hill Drive Pleasanton | 01/31/09 | follow-up | onsite pond | proper maintenance | none | Pond maintenance completed. | |
| | 02/18/09 | spot inspection | onsite pond | proper operation and maintenance | none | Proper operation and maintenance. | |

ATTACHMENT H

Provision C.8. Status and Long-Term Monitoring Follow-up Analysis and Actions

Status and Long-Term Monitoring Follow-up Analysis and Actions for Biological Assessment, Bedded Sediment Toxicity, and Bedded Sediment Pollutants

When results from Biological Assessment, Bedded Sediment Toxicity, and/or Bedded Sediment Pollutants monitoring indicate impacts at a monitoring location, Permittees shall evaluate the extent and cause(s) of impacts to determine the potential role of urban runoff as indicated in Table G-1.

| Chemistry Results ³⁹ | Toxicity Results ⁴⁰ | Bioassessment Results ⁴¹ | Action |
|---|-----------------------------------|--|--|
| No chemicals exceed Threshold Effect Concentrations (TEC), mean Probable Effects Concentrations (PEC) quotient < 0.5 and pyrethroids < 1.0 Toxicity Unit (TU) ⁴² | No Toxicity | No indications of alterations | No action necessary |
| No chemicals exceed TECs, mean PEC quotient < 0.5 and pyrethroids< 1.0 TU | Toxicity | No indications of alterations | Take confirmatory sample for toxicity. If toxicity repeated, attempt to identify cause and spatial extent. Where impacts are under Permittee's control, take management actions to minimize upstream sources causing toxicity; initiate no later than the second fiscal year following the sampling event. |

| Table G-1. Sediment Triad | Approach to Determinin | g Follow-Up Actions |
|---------------------------|---------------------------|---------------------|
| Table O-1. Scullent I hau | Approach to Detter mining | s ronow-op neuons |

³⁹ TEC and PEC are found in MacDonald, D.D., G.G. Ingersoll, and T.A. Berger. 2000. Development and Evaluation of Consensus-based Sediment Quality Guidelines for Freshwater Ecosystems. *Archives of Environ. Contamination and Toxicology* 39(1):20–31.

⁴⁰ Toxicity is exhibited when *Hyallela* survival statistically different than and < 20 percent of control.

⁴¹ Alterations are exhibited if metrics indicate substantially degraded community.

⁴² Toxicity Units (TU) are calculated as follows: TU = Actual concentration (organic carbon normalized) ÷ Reported *H. azteca* LC₅₀ concentration (organic concentration normalized). Weston, D.P., R.W. Holmes, J. You, and M.J. Lydy, 2005. Aquatic Toxicity Due to Residential Use of Pyrethroid Insecticides. *Environ. Science and Technology* 39(24):9778–9784.

| Chemistry Results ³⁹ | Toxicity Results ⁴⁰ | Bioassessment Results ⁴¹ | Action |
|--|-----------------------------------|--|---|
| No chemicals exceed TECs, mean PEC quotient < 0.5 and pyrethroids< 1.0 TU | No Toxicity | Indications of alterations | Identify the most probable cause(s) of the alterations in biological community. Where impacts are under Permittee's control, take management actions to minimize the impacts causing physical habitat disturbance; initiate no later than the second fiscal year following the sampling event. |
| No chemicals exceed TECs, mean PEC quotient < 0.5 and pyrethroids< 1.0 TU | Toxicity | Indications of alterations | Identify cause(s) of impacts and spatial extent. Where impacts are under Permittee's control, take management actions to minimize impacts; initiate no later than the second fiscal year following the sampling event. |
| 3 or more chemicals exceed PECs, the mean PEC quotient is > 0.5, or pyrethroids > 1.0 TU | No Toxicity | Indications of alterations | Identify cause of impacts. Where impacts are under Permittee's control, take management actions to minimize the impacts caused by urban runoff; initiate no later than the second fiscal year following the sampling event. |
| 3 or more chemicals exceed PECs, the mean PEC quotient is > 0.5, or pyrethroids > 1.0 TU | Toxicity | No indications of alterations | Take confirmatory sample for toxicity. If toxicity repeated, attempt to identify cause and spatial extent. Where impacts are under Permittee's control, take management actions to minimize upstream sources; initiate no later than the second fiscal year following the sampling event. |
| 3 or more chemicals exceed PECs, the mean PEC quotient is > 0.5, or pyrethroids > 1.0 TU | No Toxicity | No Indications of alterations | If PEC exceedance is Hg or PCBs, address under TMDLs |
| 3 or more chemicals exceed PECs, the mean PEC quotient is > 0.5, or pyrethroids > 1.0 TU | Toxicity | Indications of alterations | Identify cause(s) of impacts and spatial extent. Where impacts are under Permittee's control, take management actions to address impacts. |

ATTACHMENT I

Provision C.8. Standard Monitoring Provisions

All monitoring activities shall meet the following requirements:

- 1. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. [40 CFR 122.41(j)(1)]
- Permittees shall retain records of all monitoring information, including all calibration and maintenance of monitoring instrumentation, and copies of all reports required by this Order for a period of at least five (5) years from the date of the sample, measurement, report, or application. This period may be extended by request of the Water Board or USEPA at any time and shall be extended during the course of any unresolved litigation regarding this discharge. [40 CFR 122.41(j)(2), CWC section 13383(a)]
- 3. Records of monitoring information shall include [40 CFR 122.41(j)(3)]:
 - a. The date, exact place, and time of sampling or measurements;
 - b. The individual(s) who performed the sampling or measurements;
 - c. The date(s) analyses were performed;
 - d. The individual(s) who performed the analyses;
 - e. The analytical techniques or methods used; and,
 - f. The results of such analyses.
- 4. The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this Order shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both. [40 CFR 122.41(j)(5)]
- 5. Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in the monitoring Provisions. [40 CFR 122.41(l)(4)(iii)]
- 6. All chemical, bacteriological, and toxicity analyses shall be conducted at a laboratory certified for such analyses by the California Department of Health Services or a laboratory approved by the Executive Officer.
- 7. For priority toxic pollutants that are identified in the California Toxics Rule (CTR) (65 Fed. Reg. 31682), the Permittees shall instruct its laboratories to establish calibration standards that are equivalent to or lower than the Minimum Levels (MLs) published in Appendix 4 of the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (SIP). If a Permittee can demonstrate that a particular ML is not attainable, in accordance with procedures set forth in 40 CFR 136, the lowest quantifiable concentration of the lowest calibration standard analyzed by a specific analytical procedure (assuming that all the method specified sample weights, volumes, and processing steps have been followed) may be used instead of the ML listed in Appendix 4 of the SIP. The Permittee must submit documentation from the laboratory to the Water Board for approval prior to raising the ML for any priority toxic pollutant.
- 8. The Clean Water Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-

compliance shall, upon conviction, be punished by a fine of not more than 10,000 per violation, or by imprisonment for not more than six months per violation, or by both. [40 CFR 122.41(k)(2)]

9. If the discharger monitors any pollutant more frequently than required by the Permit, unless otherwise specified in the Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the reports requested by the Water Board. [40 CFR 122.41(l)(4)(ii)]

ATTACHMENT J

Minimum Trash Capture Area and Minimum Number of Trash Hot Spots

Table 10.1 Minimum Trash Capture Area and Trash Hot Spots for Population Based Permittees Data Source: <u>http://quake.abag.ca.gov/mitigation/pickdbh2.html</u> and Association of Bay Area Governments, 2005 ABAG Land Use Existing Land Use in 2005: Report and Data for Bay Area Counties

| | Population | Retail / Wholesale Commercial Acres | Minimum Trash Capture Catchment Area (Acres) ⁴³ | # of Trash Hot Spots per 30K Population | # of Trash Hot Spots per 100 Retail / Wholesale Commercial Acres | Minimum # of Trash Hot Spots ⁴⁴ |
|-----------------------------------|------------|--|--|---|---|--|
| Alameda County | | | | | | |
| San Leandro | 73,402 | 721 | 216 | 2 | 7 | 4 |
| Oakland | 420,183 | 759 | 228 | 14 | 8 | 8 |
| Dublin | 46,934 | 377 | 113 | 1 | 3 | 3 |
| Emeryville | 9,727 | 69 | 21 | 1 | 1 | 1 |
| Albany | 16,877 | 95 | 28 | 1 | 1 | 1 |
| Berkeley | 106,697 | 183 | 55 | 3 | 1 | 3 |
| Alameda County Unincorporated. | 140,825 | 375 | 112 | 4 | 3 | 4 |
| Alameda | 75,823 | 402 | 121 | 2 | 4 | 4 |
| Fremont | 213,512 | 698 | 209 | 7 | 6 | 7 |
| Hayward | 149,205 | 726 | 218 | 4 | 7 | 7 |
| Livermore | 83,604 | 423 | 127 | 2 | 4 | 4 |
| Newark | 43,872 | 314 | 94 | 1 | 3 | 3 |
| Piedmont | 11,100 | 1 | 0.3 | 1 | 1 | 1 |
| Pleasanton | 69,388 | 366 | 110 | 2 | 3 | 3 |
| Union City | 73,402 | 183 | 55 | 2 | 1 | 2 |

⁴³ 30% of Retail / Wholesale Commercial Acres

⁴⁴ If the hot spot # based on % commercial area is more than twice that based on population, the minimum hot spot # is double the population based #. *Attachment J* Date: September 24, 2009

| | Population | Retail / Wholesale Commercial Acres | Minimum Trash Capture Catchment Area (Acres) ⁴³ | # of Trash Hot Spots per 30K Population | # of Trash Hot Spots per 100 Retail / Wholesale Commercial Acres | Minimum # of Trash Hot Spots ⁴⁴ |
|-------------------------------------|------------|--|--|---|---|--|
| San Mateo County | | | | | | |
| San Mateo County Unincorporated. | 65,844 | 71 | 21 | 2 | 1 | 2 |
| Atherton | 7,475 | 0 | 0 | 1 | 1 | 1 |
| Belmont | 26,078 | 58 | 17 | 1 | 1 | 1 |
| Brisbane | 3,861 | 16 | 5 | 1 | 1 | 1 |
| Burlingame | 28,867 | 123 | 37 | 1 | 1 | 1 |
| Colma | 1,613 | 106 | 32 | 1 | 1 | 1 |
| Portola Valley | 4,639 | 9 | 3 | 1 | 1 | 1 |
| Daly City | 106,361 | 242 | 73 | 3 | 2 | 3 |
| East Palo Alto | 32,897 | 59 | 18 | 1 | 1 | 1 |
| Foster City | 30,308 | 67 | 20 | 1 | 1 | 1 |
| Half Moon Bay | 13,046 | 49 | 15 | 1 | 1 | 1 |
| Hillsborough | 11,272 | 0 | 0 | 1 | 1 | 1 |
| Menlo Park | 31,490 | 83 | 25 | 1 | 1 | 1 |
| Millbrae | 21,387 | 68 | 20 | 1 | 1 | 1 |
| Pacifica | 39,616 | 100 | 30 | 1 | 1 | 1 |
| Redwood City | 77,269 | 309 | 93 | 2 | 3 | 3 |
| San Bruno | 43,444 | 137 | 41 | 1 | 1 | 1 |
| San Carlos | 28,857 | 129 | 39 | 1 | 1 | 1 |
| San Mateo | 95,776 | 275 | 82 | 3 | 2 | 3 |
| South San Francisco | 63,744 | 195 | 58 | 2 | 1 | 2 |
| Woodside | 5,625 | 9 | 3 | 1 | 1 | 1 |

Attachment J

Date: September 24, 2009

| | Population | Retail / Wholesale Commercial Acres | Minimum Trash Capture Catchment Area (Acres) ⁴³ | # of Trash Hot Spots per 30K Population | # of Trash Hot Spots per 100 Retail / Wholesale Commercial Acres | Minimum # of Trash Hot Spots44 |
|--|------------|--|--|---|---|--------------------------------------|
| Contra Costa Coun | ty | | | | | |
| Contra Costa County Unincorporated. | 173,573 | 524 | 157 | 5 | 5 | 5 |
| Concord | 123,776 | 1016 | 305 | 4 | 10 | 8 |
| Walnut Creek | 65,306 | 329 | 99 | 2 | 3 | 3 |
| Clayton | 10,784 | 21 | 6 | 1 | 1 | 1 |
| Danville | 42,629 | 134 | 40 | 1 | 1 | 1 |
| El Cerrito | 23,320 | 105 | 32 | 1 | 1 | 1 |
| Hercules | 24,324 | 37 | 11 | 1 | 1 | 1 |
| Lafayette | 23,962 | 68 | 20 | 1 | 1 | 1 |
| Martinez | 36,144 | 142 | 43 | 1 | 1 | 1 |
| Moraga | 16,138 | 108 | 32 | 1 | 1 | 1 |
| Orinda | 17,542 | 24 | 7 | 1 | 1 | 1 |
| Pinole | 19,193 | 140 | 42 | 1 | 1 | 1 |
| Pittsburg | 63,652 | 520 | 156 | 2 | 5 | 4 |
| Pleasant Hill | 33,377 | 219 | 66 | 1 | 2 | 2 |
| Richmond | 103,577 | 391 | 117 | 3 | 3 | 3 |
| San Pablo | 31,190 | 131 | 39 | 1 | 1 | 1 |
| San Ramon | 59,002 | 274 | 82 | 1 | 2 | 2 |

Attachment J

| | Population | Retail / Wholesale Commercial Acres | Minimum Trash Capture Catchment Area (Acres) ⁴³ | # of Trash Hot Spots per 30K Population | # of Trash Hot Spots per 100 Retail / Wholesale Commercial Acres | Minimum # of Trash Hot Spots ⁴⁴ |
|--------------------------------------|------------|--|--|---|---|--|
| Santa Clara County | / | | | | | |
| Santa Clara County Unincorporated | 99,122 | 270 | 81 | 3 | 3 | 3 |
| Cupertino | 55,551 | 213 | 64 | 2 | 2 | 2 |
| Los Altos | 28,291 | 65 | 20 | 1 | 1 | 1 |
| Los Altos Hills | 8,837 | 0 | 0 | 1 | 1 | 1 |
| Los Gatos | 30,296 | 163 | 49 | 1 | 1 | 1 |
| Milpitas | 69,419 | 457 | 137 | 2 | 4 | 4 |
| Monte Sereno | 3,579 | 0 | 0 | 1 | 1 | 1 |
| Mountain View | 73,932 | 375 | 112 | 2 | 3 | 3 |
| Santa Clara | 115,503 | 560 | 168 | 3 | 5 | 5 |
| Saratoga | 31,592 | 41 | 12 | 1 | 1 | 1 |
| San Jose | 989,496 | 2983 | 895 | 32 | 29 | 32 |
| Sunnyvale | 137,538 | 548 | 164 | 3 | 5 | 5 |
| Palo Alto | 63,367 | 282 | 84 | 2 | 2 | 2 |
| Solano County | | | | | | |
| Vallejo | 120,416 | 559 | 168 | 4 | 5 | 5 |
| Fairfield | 106,142 | 486 | 146 | 3 | 4 | 4 |
| Suisun | 28,031 | 75 | 22 | 1 | 1 | 1 |
| Totals | 4,930,339 | 19057 | 5718 | 165 | 184 | 349 |

Attachment J

Date: September 24, 2009

| Table 10-2. | Non-Population Based Permittee Trash Hot Spot |
|--------------------|---|
| | and Trash Capture Assignments |

| Non population based Permittee | Number of Trash Hot Spots | Trash Capture Requirement |
|--|---------------------------------|--|
| Santa Clara Valley Water District | 12 | 4 trash booms or 8 outfall capture devices (minimum 2 ft. diameter outfall) or equivalent measures |
| Alameda County Flood Control Agency | 9 | 3 trash booms or 6 outfall capture devices (minimum 2 ft. diameter outfall) or equivalent measures |
| Alameda Co. Zone 7 Flood Control Agency | 3 | 1 trash boom or 2 outfall capture devices (minimum 2 ft. diameter outfall) or equivalent measures |
| Contra Costa County Flood Control Agency | 6 | 2 trash booms or 4 outfall capture devices (minimum 2 ft. diameter outfall) or equivalent measures |
| San Mateo County Flood Control District | 2 | 1 trash booms or 2 outfall capture devices (minimum 2 ft. diameter outfall) or equivalent measures |
| Vallejo Sanitation and Flood District | 1 | 1 trash boom or 2 outfall capture devices or equivalent measures (minimum 2 ft. diameter outfall) |

ATTACHMENT K

Standard NPDES Stormwater Permit Provisions

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD SAN FRANCISCO BAY REGION

Standard Provisions and Reporting Requirements

for

NPDES Stormwater Discharge Permits

February 2009

A. GENERAL PROVISIONS

- 1. Neither the treatment nor the discharge of pollutants shall create a pollution, contamination, or nuisance as defined by Section 13050 of the California Water Code.
- **2.** All discharges authorized by this Order shall be consistent with the terms and conditions of this Order.

3. Duty to Comply

- a. If a toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is established under Section 307(a) of the Clean Water Act, or amendments thereto, for a toxic pollutant which is present in the discharge authorized herein and such standard or prohibition is more stringent than any limitation upon such pollutant in a Board adopted Order, discharger must comply with the new standard or prohibition. The Board will revise or modify the Order in accordance with such toxic effluent standard or prohibition and so notify the discharger.
- b. If more stringent applicable water quality standards are approved pursuant to Section 303 of the Clean Water Act, or amendments thereto, the discharger must comply with the new standard. The Board will revise and modify this Order in accordance with such more stringent standards.
- c. The filing of a request by the discharger for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [40 CFR 122.41(f)]

4. Duty to Mitigate

The discharger shall take all reasonable steps to minimize or prevent any discharge in violation of this order and permit which has a reasonable likelihood of adversely affecting public health or the environment, including such accelerated or additional monitoring as requested by the Board or Executive Officer to determine the nature and impact of the violation. [40 CFR 122.41(d)]

5. Pursuant to U.S. Environmental Protection Agency regulations the discharger must notify the Regional Board as soon as it knows or has reason to believe (1) that they have begun or expect to begin, use or manufacture of a pollutant not reported in the permit

application, or (2) a discharge of toxic pollutants not limited by this permit has occurred, or will occur, in concentrations that exceed the limits specified in 40 CFR 122.42(a).

- **6.** The discharge of any radiological, chemical, or biological warfare agent waste is prohibited.
- **7.** All facilities used for transport, treatment, or disposal of wastes shall be adequately protected against overflow or washout as the result of a 100-year frequency flood.
- **8.** Collection, treatment, storage and disposal systems shall be operated in a manner that precludes public contact with wastewater, except where excluding the public is inappropriate, warning signs shall be posted.

9. Property Rights

This Order and Permit does not convey any property rights of any sort or any exclusive privileges. The requirements prescribed herein do not authorize the commission of any act causing injury to the property of another, nor protect the discharger from liabilities under federal, state or local laws, nor create a vested right for the discharge to continue the waste discharge or guarantee the discharger a capacity right in the receiving water. [40 CFR 122.41(g)]

10. Inspection and Entry

The Board or its authorized representatives shall be allowed:

- a. Entry upon premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of the order and permit;
- b. Access to and copy at, reasonable times, any records that must be kept under the conditions of the order and permit;
- c. To inspect at reasonable times any facility, equipment (including monitoring and control equipment), practices, or operations regulated or required under the order and permit; and
- d. To photograph, sample, and monitor, at reasonable times for the purpose of assuring compliance with the order and permit or as otherwise authorized by the Clean Water Act, any substances or parameters at any locations. [40 CFR 122.41(i)]

11. Permit Actions

This Order and Permit may be modified, revoked and reissued, or terminated in accordance with applicable State and/or Federal regulations. Cause for taking such action includes, but is not limited to any of the following:

- a. Violation of any term or condition contained in the Order and Permit;
- b. Obtaining the Order and Permit by misrepresentation, or by failure to disclose fully all relevant facts;
- c. Endangerment to public health or environment that can only be regulated to acceptable levels by order and permit modification or termination; and
- d. Any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.

12. Duty to Provide Information

The discharger shall furnish, within a reasonable time, any information the Board may request to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit. The discharger shall also furnish to the Board, upon request, copies of records required to be kept by its permit. [40 CFR 122.41(h)]

13. Availability

A copy of this permit shall be maintained at the discharge facility and be available at all times to operating personnel.

14. Continuation of Expired Permit

This permit continues in force and effect until a new permit is issued or the Board rescinds the permit. Only those dischargers authorized to discharge under the expiring permit are covered by the continued permit.

B. STANDARD STORM WATER PROVISIONS

These provisions apply to facilities which do not direct all storm water flows to the wastewater treatment plant headworks.

- 1. The Storm Water Pollution Prevention Plan (SWPP Plan) shall be designed in accordance with good engineering practices and shall address the following objectives:
 - a. to identify pollutant sources that may affect the quality of storm water discharges; and
 - b. to identify, assign, and implement control measures and management practices to reduce pollutants in storm water discharges.

The SWPP Plan may be combined with the existing spill prevention plan as required in accordance with Provision E.5. The SWPP Plan shall be retained on-site and made available upon request of a representative of the Board.

2. Source Identification

The SWPP Plan shall provide a description of potential sources which may be expected to add significant quantities of pollutants to storm water discharges, or which may result in non-storm water discharges from the facility. The SWPP Plan shall include, at a minimum, the following items:

- a. A topographical map (or other acceptable map if a topographical map is unavailable), extending one-quarter mile beyond the property boundaries of the facility, showing: the wastewater treatment facility process areas, surface water bodies (including springs and wells), and the discharge point(s) where the facility's storm water discharges to a municipal storm drain system or other points to waters of the State. The requirements of this paragraph may be included in the site map required under the following paragraph if appropriate.
- b. A site map showing:
 - i. Storm water conveyance, drainage, and discharge structures;
 - ii. An outline of the storm water drainage areas for each storm water discharge point;

- iii. Paved areas and buildings;
- iv. Areas of pollutant contact with storm water or release to storm water, actual or potential, including but not limited to outdoor storage, and process areas, material loading, unloading, and access areas, and waste treatment, storage, and disposal areas;
- v. Location of existing storm water structural control measures (i.e., berms, coverings, etc.);
- vi. Surface water locations, including springs and wetlands;
- vii. Vehicle service areas.
- c. A narrative description of the following:
 - i. Wastewater treatment process activity areas;
 - ii. Materials, equipment, and vehicle management practices employed to minimize contact of significant materials of concern with storm water discharges;
 - iii. Material storage, loading, unloading, and access areas;
 - iv. Existing structural and non-structural control measures (if any) to reduce pollutants in storm water discharge;
 - v. Methods of on-site storage and disposal of significant materials.
- d. A list of pollutants that have a reasonable potential to be present in storm water discharge in significant quantities.

3. Storm Water Management Controls

The SWPP Plan shall describe the storm water management controls appropriate for the facility and a time schedule for fully implementing such controls. The appropriateness and priorities of controls in the SWPP Plan shall reflect identified potential sources of pollutants. The description of storm water management controls to be implemented shall include, as appropriate:

a. Storm Water Pollution Prevention Personnel

Identify specific individuals (and job titles) who are responsible for developing, implementing, and reviewing the SWPP Plan.

b. Good Housekeeping

Good housekeeping requires the maintenance of clean, orderly facility areas that discharge storm water. Material handling areas shall be inspected and cleaned to reduce potential for pollutants to enter the storm drain conveyance system.

c. Spill Prevention and Response

Identify areas where significant materials can spill into or otherwise enter the storm water conveyance systems and their accompanying drainage points. Specific material handling procedures, storage requirements, cleanup equipment and procedures should be identified, as appropriate. The necessary equipment to implement a clean up shall be available and personnel trained in proper response, containment and cleanup of spills. Internal reporting procedures for spills of significant materials shall be established.

d. Source Control

Source controls, such as elimination or reduction of the use of toxic pollutants, covering of pollutant source areas, sweeping of paved areas, containment of potential pollutants, labeling all storm drain inlets with "No Dumping" signs, isolation/separation of industrial from non-industrial pollutant sources so that runoff from these areas does not mix, etc.

e. Storm Water Management Practices

Storm water management practices are practices other than those which control the sources of pollutants. They include treatment/conveyance structures such as drop inlets, channels, retention/detention basins, treatment vaults, infiltration galleries, filters, oil/water separators, etc. Based on assessment of the potential of various sources to contribute pollutants to storm water discharges in significant quantities, additional storm water management practices to remove pollutants from storm water discharges shall be implemented and design criteria shall be described.

f. Sediment and Erosion Control

Measures to minimize erosion around the storm water drainage and discharge points such as riprap, revegetation, slope stabilization, etc. shall be described and implemented.

g. Employee Training

Employee training programs shall inform all personnel responsible for implementing the SWPP Plan. Training should address spill response, good housekeeping, and material management practices. New employee and refresher training schedules should be identified.

h. Inspections

All inspections shall be done by trained personnel. Material handling areas shall be inspected for evidence of, or the potential for, pollutants entering storm water discharges. A tracking or follow up procedure shall be used to ensure appropriate response has been taken in response to an inspection. Inspections and maintenance activities shall be documented and recorder. Inspection records shall be retained for five years.

i. Records

A tracking and follow-up procedure shall be described to ensure that adequate response and corrective actions have been taken in response to inspections.

4. An annual facility inspection shall be conducted to verify that all elements of the SWPP Plan are accurate and up to date. The results of this review shall be reported in the annual report to the Board on October 1 of each year.

C. GENERAL REPORTING REQUIREMENTS

1. Signatory Requirements

a. All reports required by the order and permit and other information requested by the Board or USEPA Region 9 shall be signed by a principal executive officer or ranking

elected official of the discharger, or by a duly authorized representative of that person. [40 CFR 122.22(b)]

b. Certification

All reports signed by a duly authorized representative under Provision E.1.a. shall contain the following certification:

"I certify under penalty of law that this document and all attachments are prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who managed the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. [40 CFR 122.22(d)]

2. Should the discharger discover that it failed to submit any relevant facts or that it submitted incorrect information in any report, it shall promptly submit the missing or correct information. [40 CFR 122.41(1)(8)]

3. False Reporting

Any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall be subject to enforcement procedures as identified in Section F of these Provisions.

4. Transfers

- a. This permit is not transferable to any person except after notice to the Board. The Board may require modification or revocation and reissuance of the permit to change the name of the Permittee and incorporate such other requirements as may be necessary under the Clean Water Act.
- b. Transfer of control or ownership of a waste discharge facility under an National Pollutant Discharge Elimination System permit must be preceded by a notice to the Board at least 30 days in advance of the proposed transfer date. The notice must include a written agreement between the existing discharger and proposed discharger containing specific dates for transfer of responsibility, coverage, and liability between them. Whether an order and permit may be transferred without modification or revocation and reissuance is at the discretion of the Board. If order and permit modification or revocation and reissuance is necessary, transfer may be delayed 180 days after the Board's receipt of a complete application for waste discharge requirements and an NPDES permit.

5. Spill Prevention and Contingency Plans

The discharger shall file with the Board, for Executive Officer review and approval within ninety (90) days after the effective date of this Order, a technical report or a statement that the existing plan(s) was reviewed and updated, as appropriate, on preventive (failsafe) and contingency (cleanup) plans for controlling accidental

discharges, and for minimizing the effect of such events. The technical report or updated revisions should:

- a. Identify the possible sources of accidental loss, untreated or partially treated waste bypass, and polluted drainage. Loading and storage areas, power outage, waste treatment unit outage, and failure of process equipment, tanks and pipes should be considered.
- b. Evaluate the effectiveness of present facilities and procedures and state when they became operational.
- c. Predict the effectiveness of the proposed facilities and procedures and provide an implementation schedule containing interim and final dates when they will be constructed, implemented, or operational.

This Board, after review of the technical report or updated revisions, may establish conditions which it deems necessary to control accidental discharges and to minimize the effects of such events. Such conditions may be incorporated as part of this Order, upon notice to the discharger. If the discharger already has an approved plan(s) he shall update them as specified in the plan(s).

6. Compliance Reporting

a. Planned Changes

The discharger shall file with the Board a report of waste discharge at least 120 days before making any material change or proposed change in the character, location or volume of the discharge.

b. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final compliance dates contained in any compliance schedule shall be submitted within 10 working days following each scheduled date unless otherwise specified within this order and permit. If reporting noncompliance, the report shall include a description of the reason for failure to comply, a description and schedule of tasks necessary to achieve compliance and an estimated date for achieving full compliance. A final report shall be submitted within 10 working days of achieving full compliance, documenting full compliance

- c. Non-compliance Reporting (Twenty-four hour reporting:)
 - i. The discharger shall report any noncompliance that may endanger health or the environment. All pertinent information shall be provided orally within 24 hours from the time the discharger becomes aware of the circumstances. A written submission shall also be provided within five working days of the time the discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times and, if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
 - ii. The following shall be included as information that must be reported within 24 hours under this paragraph:

- (1) Any upset that exceeds any effluent limitation in the permit.
- (2) Violation of a maximum daily discharge limitation for any of the pollutants listed in this permit to be reported within 24 hours.
- (3) The Board may waive the above-required written report on a case-by-case basis.

D. ENFORCEMENT

- **1.** The provision contained in this enforcement section shall not act as a limitation on the statutory or regulatory authority of the Board.
- 2. Any violation of the permit constitutes violation of the California Water Code and regulations adopted hereunder and the provisions of the Clean Water Act, and is the basis for enforcement action, permit termination, permit revocation and reissuance, denial of an application for permit reissuance; or a combination thereof.
- **3.** The Board may impose administrative civil liability, may refer a discharger to the State Attorney General to seek civil monetary penalties, may seek injunctive relief or take other appropriate enforcement action as provided in the California Water Code or federal law for violation of Board orders.
- 4. It shall not be a defense for a discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this order and permit.
- **5.** A discharger seeking to establish the occurrence of any upset (See Definitions, G. 24) has the burden of proof. A discharger who wishes to establish the affirmative defense of any upset in an action brought for noncompliance shall demonstrate, through properly signed contemporaneous operating logs, or other relevant evidence that:
 - a. an upset occurred and that the Permittee can identify the cause(s) or the upset;
 - b. the permitted facility was being properly operated at the time of the upset;
 - c. the discharger submitted notice of the upset as required in paragraph E.6.d.; and
 - d. the discharger complied with any remedial measures required under A.4.

No determination made before an action for noncompliance, such as during administrative review of claims that noncompliance was caused by an upset, is final administrative action subject to judicial review. In any enforcement proceeding, the discharger seeking to establish the occurrence of any upset has the burden of proof. [40 CFR 122.41(n)]

E. DEFINITIONS

- **1.** Daily discharge means:
 - a. For flow rate measurements, the average flow rate measured during a calendar day or during any 24-hour period reasonably representative of the calendar day for purposes of sampling.

- b. For pollutant measurements, the concentration or mass emission rate measured during a calendar day or during any 24-hour period reasonably representative of the calendar day for purposes of sampling.
- 2. Daily Maximum Limit means the maximum acceptable daily discharge. For pollutant measurements, unless otherwise specified, the results to be compared to the daily maximum limit are based on composite samples.
- **3.** DDT and Derivatives shall mean the sum of the p,p' and o,p' isomers of DDT, DDD (TDE), and DDE.
- 4. Duly authorized representative is one whose:
 - a. Authorization is made in writing by a principal executive officer or ranking elected official;
 - b. Authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as general manager in a partnership, manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.); and
 - c. Written authorization is submitted to the USEPA Region 9. If an authorization becomes no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements above must be submitted to the Board and USEPA Region 9 prior to or together with any reports, information, or applications to be signed by an authorized representative.
- 5. Hazardous substance means any substance designated under 40 CFR 116 pursuant to Section 311 of the Clean Water Act.
- **6.** HCH shall mean the sum of the alpha, beta, gama (Lindane), and delta isomers of hexachlorocyclohexane.
- **7.** Inadequately Treated Waste is wastewater receiving partial treatment but failing to meet discharge requirements.
- **8.** Initial dilution is the process which results in the rapid and irreversible turbulent mixing of wastewater with receiving water around the point of discharge.
- 9. Mass emission rate is obtained from the following calculation for any calendar day:

. .

Mass emission rate (lb/day) =
$$\frac{8.345}{N} (\Sigma Q_i C_i)$$

N $i=1$
Mass emission rate (kg/day) = $\frac{3.785}{N} (\Sigma Q_i C_i)$
N $i=1$

In which 'N' is the number of samples analyzed in any calendar day. 'Q_i' and 'C_i' are the flow rate (MGD) and the constituent concentration (mg/L), respectively, which are associated with each of the 'N' grab samples which may be taken in any calendar day. If a composite sample is taken, 'C_i' is the concentration measured in the composite sample and 'Q_i' is the average flow rate occurring during the period over which samples are composited. The daily concentration measured over any calendar day of all constituents shall be determined from the flow- weighted average of the same constituents in the combined waste streams as follows:

 $C_{d} = \text{Average daily concentration} = \frac{1}{Q_{t}} (\sum_{i=1}^{N} Q_{i}C_{i})$

In which 'N' is the number of component waste streams. 'Q' and 'C' are the flow rate (MGD) and the constituent concentration (mg/L), respectively, which are associated with each of the 'N' waste streams. 'Qt' is the total flow rate of the combined waste streams.

- **10.** Maximum allowable mass emission rate, whether for a 24-hour, weekly 7-day, monthly 30-day, or 6-month period, is a limitation expressed as a daily rate determined with the formulas in paragraph above, using the effluent concentration limit specified in the order and permit for the period and the specified allowable flow. (Refer to Section C of Part A of Self- Monitoring Program for definitions of limitation period)
- **11.** Overflow is defined as the intentional or unintentional spilling or forcing out of untreated or partially treated wastes from a transport system (e.g. through manholes, at pump stations, and at collection points) upstream from the plant headworks or from any treatment plant facilities.
- **12.** Priority pollutants are those constituents referred to in 40 CFR S122, Appendix D and listed in the USEPA NPDES Application Form 2C, (dated 6/80) Items V-3 through V-9.
- **13.** Storm Water means storm water runoff, snow melt runoff, and surface runoff and drainage. It excludes infiltration and runoff from agricultural land.
- **14.** Toxic pollutant means any pollutant listed as toxic under Section 307(a)(1) of the Clean Water Act or under 40 CFR S401.15.
- **15.** Total Identifiable Chlorinated hydrocarbons (TICH) shall be measured by summing the individual concentrations of DDT, DDD, DDE, aldrin, BHC, chlordane, endrin, heptachlor, lindane, dieldrin, PCBs and other identifiable chlorinated hydrocarbons.
- **16.** Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass or overflow. It does not mean economic loss caused by delays in production.
- **17.** Upset means an exceptional incident in which there is unintentional temporary noncompliance with effluent technology based permit limitations in the order and permit because of factors beyond the reasonable control of the discharger. It does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

18. Waste, waste discharge, discharge of waste, and discharge are used interchangeably in this order and permit. The requirements of this order and permit are applicable to the entire volume of water, and the material therein, which is disposed of to surface and ground waters of the State of California.