

Issue Date: April 15, 2022

Franklin Fueling Systems
EVO 600 and EVO 6000 Console with TSP-HIS-XL Dual Float Sensor,
INTERSTITIAL DETECTOR (LIQUID-PHASE)

Detector:

Output type: Qualitative
Sampling frequency: Continuous
Operating principle: float switch

Test Results:

	<u>Brine Low Level</u>	<u>Brine High Level</u>
--	----------------------------	-----------------------------

TSP-HIS-XL

Detection time (min)	<1	<1
Fall time (min)	<1	<1
Threshold Level (in)	1.00061	10.9546

Applicability:

California Code of Regulations require a written statement of compatibility for systems containing products other than those used in this evaluation.

Comments:

Sensor is reusable.

Franklin Fueling Systems

3760 Marsh Road

Madison, WI 53718

Evaluator: Ken Wilcox Associates

Tel: (816) 443-2494

Date of Evaluation: 08/23/2013, 12/17/2018

Tel: (800) 225-9787

E-mail: info@franklinfueling.com

URL: www.franklinfueling.com

| [Home](#) | [Vendors: A - F](#) | [Vendors: G - M](#) | [Vendors: N - S](#) | [Vendors: T - Z](#) | [Method Index](#) |

Appearance on this list is not to be construed as an endorsement by any regulatory agency nor is it any guarantee of the performance of the method or equipment. Equipment should be installed and operated in accordance with all applicable laws and regulations.

For full details, please refer to our expanded "[DISCLAIMER](#)" page.