

After Winter Spill Event			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	450 cfs	538 cfs	<b>538 cfs</b>
December	450 cfs	538 cfs	<b>538 cfs</b>
January	450 cfs	538 cfs	<b>538 cfs</b>
February	450 cfs	630 cfs	<b>630 cfs</b>
March	450 cfs	1068 cfs	<b>1068 cfs</b>

If No Winter Spill Event			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	400 cfs	538 cfs	<b>538 cfs</b>
December	400 cfs	538 cfs	<b>538 cfs</b>
January	400 cfs	538 cfs	<b>538 cfs</b>
February	400 cfs	630 cfs	<b>630 cfs</b>
March	400 cfs	1068 cfs	<b>1068 cfs</b>

\*State Water Resources Control Board has issued a Water Quality Certification to the Pacific Gas and Electric Company for the Pit 3, 4 and 5 Hydroelectric Project, which asserts minimum instream flow requirement on the Pit River from Pit River Dam No. 5 to the Pit River No. 5 Powerhouse as summarized in the above table. A compliance gage has not been identified for this stream section. Please contact the State Water Resources Control Board for further guidance.

**Web Link to Water Quality Certification:**

[Water Quality Certification for Pit 3, 4 and 5 Hydroelectric Project](#)