

Dry Water Year Type			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	200 cfs	653 cfs	<b>653 cfs</b>
December 1-15	200 cfs	767 cfs	<b>767 cfs</b>
December 16-31	135 cfs	767 cfs	<b>767 cfs</b>
January	135 cfs	767 cfs	<b>767 cfs</b>
February	135 cfs	794 cfs	<b>794 cfs</b>
March	200 cfs	951 cfs	<b>951 cfs</b>

Normal Water Year Type			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	385 cfs	653 cfs	<b>653 cfs</b>
December 1-15	385 cfs	767 cfs	<b>767 cfs</b>
December 16-31	280 cfs	767 cfs	<b>767 cfs</b>
January	280 cfs	767 cfs	<b>767 cfs</b>
February	280 cfs	794 cfs	<b>794 cfs</b>
March	350 cfs	951 cfs	<b>951 cfs</b>

\*Federal Energy Regulatory Commission has issued a new license to the Turlock Irrigation District and Modesto Irrigation District for the New Don Pedro Project, which asserts minimum instream flow requirement on the Tuolumne River below Don Pedro Dam at La Grange Rd Bridge as summarized in the above table. A compliance gage has not been identified for this stream section. Please contact the State Water Resources Control Board for further guidance.

**Web Link to FERC License:**

[FERC License #P-2299 New Don Pedro Project](#)