

All Water Year Types			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November 1-15	75 cfs	373 cfs	373 cfs
November 16-30	50 cfs	373 cfs	373 cfs
December	50 cfs	373 cfs	373 cfs
January	50 cfs	395 cfs	395 cfs
February	50 cfs	461 cfs	461 cfs
March	50 cfs	546 cfs	546 cfs

*Federal Energy Regulatory Commission has issued a new license to the Pacific Gas and Electric Company for the Pit 1 Hydroelectric Project, which asserts minimum instream flow requirement on the Pit River from the Pit 1 Forebay to the Pit 1 Powerhouse as summarized in the above table. A compliance gage has not been identified for this stream section. Please contact the State Water Resources Control Board for further guidance.

Web Link to Water Quality Certification:

[Water Quality Certification for the Pit 1 Hydroelectric Project](#)