

Dry Water Year Type			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	0.1 cfs	6 cfs	6 cfs
December	0.1 cfs	6 cfs	6 cfs
January	0.1 cfs	6 cfs	6 cfs
February	0.1 cfs	8 cfs	8 cfs
March	0.1 cfs	9 cfs	9 cfs

Normal Water Year Type			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	0.5 cfs	6 cfs	6 cfs
December	0.5 cfs	6 cfs	6 cfs
January	0.5 cfs	6 cfs	6 cfs
February	0.5 cfs	8 cfs	8 cfs
March	0.5 cfs	9 cfs	9 cfs

*Federal Energy Regulatory Commission has issued a new license to the Pacific Gas and Electric Company for the DeSabra-Centerville Hydroelectric Project, which asserts minimum instream flow requirement at USGS gage 11405100 as summarized in the above table.

Web Link to Water Quality Certification:

[Water Quality Certification for the DeSabra-Centerville Hydroelectric Project](#)