CALIFORNIA
Water Boards

EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIQUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

May 12, 2017

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7015 1520 0001 8017 0514

Mr. Antonio Berastain
Maintenance Manager
Livermore Amador Valley Transit Authority
1362 Rutan Drive
Livermore, California 94551
aberastain@mvtransit.com

SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS LOCATED AT LIVERMORE AMADOR VALLEY TRANSIT AUTHORITY, 875 ATLANTIS COURT, LIVERMORE

Dear Mr. Berastain:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on April 28, 2017, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	**Failure to Tag Monitoring Equipment –** At the time of inspection, a current annual monitoring certification sticker was not attached to the electronic line leak detector or the vacuum sensor box inside tank one's turbine sump. Additionally, there was not a current sticker attached to tank two's vacuum sensor box.	All	April 28, 2017	Ongoing	23 CCR 2638(f)
2	**Failure to Monitor Product Piping –** The liquid sensors inside both under dispenser containers (UDC) were not able to detect a leak at the earliest opportunity because they were not place in a vertical position.	All	April 28, 2017	Ongoing	H&SC 25290.1(d) 23 CCR 2630(d)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and the Livermore Pleasanton Fire Department within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance. Additionally, please ensure that all tank sumps, UDCs, and spill containers are free of liquid and debris.

Please send all compliance documentation to the following:

State Water Board
Mr. Douglas McDevitt
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
douglas.mcdevitt@waterboards.ca.gov

Local CUPA
Ms. Danielle Stefani
Assistant Fire Marshall
Livermore Pleasanton Fire Department
3560 Nevada Street
Pleasanton, California 94566
dastefani@lpfire.org

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of $500 to $5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,

Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: *(via email only)*

Ms. Danielle Stefani
Assistant Fire Marshall
Livermore Pleasanton Fire Department
dastefani@lpfire.org

Ms. Tamara Edwards
Director of Finance
Livermore Amador Valley Transit Authority
Tedwards@lavta.org