CALIFORNIA
Water Boards

EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIQUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

March 30, 2017

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7015 1520 0001 8017 2181

Mr. Karl Vogeley
Fleet Manager
City of Glendale Public Works
541 West Chevy Chase Drive
Glendale, California 91204
kvogeley@glendaleca.gov

SUBJECT: RETURN TO COMPLIANCE; UNDERGROUND STORAGE TANK SYSTEM AT GLENDALE PUBLIC WORKS PERKINS BUILDING, 141 NORTH GLENDALE AVENUE, GLENDALE

Dear Mr. Vogeley:

The State Water Resources Control Board (State Water Board) is in receipt of documents you submitted on behalf of the City of Glendale (City) in response to our February 3, 2017 Notice of Violation (NOV). The documents demonstrate that the ongoing violations cited in the NOV have been corrected. Please be aware that the State Water Board's determination that the violations have been corrected does not preclude the State Water Board from pursuing enforcement against the City related to the violations, including the imposition of suspended penalties pursuant to the Final Consent Judgment and Permanent Injunction (Los Angeles Superior Court, Case #BC552862) or the imposition of civil penalties pursuant to section 25299 of the Health and Safety Code.

During our investigation of this matter, we noted that the Designated Operator (DO) monthly inspection report form currently used by the City does not properly document all DO inspection requirements. To ensure that all required information is documented and attached to the monthly DO inspection report form, the State Water Board recommends the City use a form similar to the following, http://www.unidocs.org/hazmat/ust/misc/un-057.pdf.

Sincerely,

Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: See next page.

cc: *(via email only)*

Mr. Thomas Marchant
Fire Battalion Chief
Glendale City Fire Department
tmarchant@glendaleca.gov

Ms. Lucy Varpetian
Senior Assistant City Attorney
City of Glendale
lvarpetian@glendaleca.gov