CALIFORNIA
Water Boards

EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIQUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

March 13, 2018

*(Via email and Certified Mail)*
**CERTIFIED MAIL**
**NO. 7017 2680 0000 6195 8787**

Mr. Fred Camarillo
Interim Deputy Director of Public Works
City of Port Hueneme/Service Yard
250 N. Ventura Road
Port Hueneme, California 93041
fcamarillo@cityofporthueneme.org

**SUBJECT: NOTICE OF VIOLATION - NO FURTHER ACTION REQUIRED; UNDERGROUND STORAGE TANK SYSTEMS AT CITY OF PORT HUENEME SERVICE YARD, PORT HUENEME**

Dear Mr. Camarillo:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on February 23, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

| No. | Violation | Tank | Start Date | Stop Date | Regulation |
|---|---|---|---|---|---|
| 1 | **Failure to Monitor Tank –** The site uses an automatic tank gauge to perform monthly 0.2 gph leak rate test on the single-walled tanks. The Veeder Root (VR) monitoring panel was not programmed to the correct leak detection specification requirement of "enhanced mode." The VR monitoring panel was reprogramed at time of inspection. | All | February 23, 2018 | February 23, 2018 | H&SC 25292(a); 23 CCR 2643(b)(1) |

To our knowledge, the violation above has been corrected. Therefore, no further action is required at this time. The State Water Board reserves the right to bring an action against the owner and/or operator of the tanks in violation, or it may recommend that County of Ventura

Environmental Health Division pursue enforcement, or County of Ventura Environmental health Division may elect to pursue enforcement independently.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,

Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
**Office of Enforcement**

cc: *(via email only)*

Mr. Don Villafana
Public Works Director
City of Port Hueneme
dvillafana@cityofporthueneme.org

Ms. Alicia Morales, R.E.H.S.
Supervising Environmental Health Specialist
Hazardous Materials Program
alicia.morales@ventura.org

Mr. Andrew Evans
Environmental Health Specialist
Hazardous Materials Program
andrew.evans@ventura.org