April 12, 2019

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7018 0680 0000 1017 6793

Mr. Brad Jones
Fuel Site Compliance Specialist
County of Fresno
Fleet Services Division
4551 East Hamilton
Fresno, California 93702
bradjones@co.fresno.ca.us

SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM LOCATED AT BARTON MOTOR POOL, 500 SOUTH BARTON AVENUE, FRESNO

Dear Mr. Jones:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST at your facility on March 27, 2019, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16 & 18:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	**Failure to Maintain Evidence of Financial Responsibility –** A current Chief Financial Officer (CFO) letter is not available in CERS. The CFO letter must be renewed annually as indicated under the coverage period on the Certification of Financial Responsibility.	Unleaded	March 27, 2019	Ongoing	23 CCR 2711(a)(11), 2711(d), & 2808.1(c)(2); H&SC 25292.2
2	**Failure to Maintain Training Records –** The Facility Employee Training Certificate was not available at the time of inspection.	Unleaded	March 27, 2019	Ongoing	23 CCR 2715(c)(4)

No.	Violation	Tank	Start Date	Stop Date	Regulation
3	**Failure to Maintain Monitoring Plan –** In CERS, under recordkeeping, equipment maintenance and calibration records are marked "No"; however, it should be marked "Yes."	Unleaded	March 27, 2019	Ongoing	23 CCR 2632(d)(1)
4	**Failure to Maintain Site Map/Plot Plan –** The site map in CERS does not show the piping layout for the UST system.	Unleaded	March 27, 2019	Ongoing	23 CCR 2711(a)(8)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Fresno County Department of Public Health within sixty (60) days from the date of this letter. Have your Designated Operator (DO) make specific notations in the next monthly DO report indicating the ongoing violations have been corrected. The monthly DO report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board
Mr. Douglas McDevitt
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
douglas.mcdevitt@waterboards.ca.gov

Local CUPA
Mr. Vincent Mendes
Supervising Environmental Health Specialist
Fresno County Department of Public Health
200 W Pontiac Way, Building 3
Clovis, California 93612
vmendes@co.fresno.ca.us

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of $500 to $5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 323-0600, or by email at brian.taylor@waterboards.ca.gov.

Sincerely,

Brian Taylor
Senior Engineering Geologist (Supv.)
UST Enforcement Unit
Office of Enforcement

cc: See next page.

cc: *(via email only)*

Mr. Ken Christiansen
Fleet Services Manager
County of Fresno
Fleet Services Division
kchristensen@fresnocounty.gov

Mr. Vincent Mendes
Supervising Environmental Health Specialist
Fresno County Department of Public Health
Environmental Health Division
vmendes@co.fresno.ca.us

Mr. Harry Yee
Supervising Environmental Health Specialist
Fresno County Department of Public Health
Environmental Health Division
hyee@co.fresno.ca.us