

Public Hearing (9/16/09)
Once Through Cooling
Deadline: 9/30/09 by 12 noon



**Pacific Gas and
Electric Company**

Mark Krause
Director
State Agency Relations


1415 L Street, Suite 280
Sacramento, CA 95814
(916) 386-5709
Fax: (916) 386-5720
MCKD@pge.com

September 30, 2009

Electronic Delivery

State Water Resources Control Board
P.O. Box 100
Sacramento, CA 95812

Re: Comment Letter - OTC Policy



Please find attached PG&E's comments on the Draft Policy On The Use Of Coastal And Estuarine Waters For Power Plant Cooling, Tenera Memo, and Enercon Study. Please contact me should you have any questions.

Sincerely,

Attachment

Pacific Gas and Electric Company's
Comments on the State Water Resources Control Board's Proposed Policy

Water Quality Control Policy on the Use of
Coastal and Estuarine Waters for Power Plant Cooling

September 30, 2009

I. INTRODUCTION AND SUMMARY

Pacific Gas and Electric Company (PG&E) supports the protection of California's marine resources through development of a consistent statewide policy implementing Section 316(b) of the Clean Water Act. As we have previously stated, we support efforts to transition away from once through cooling and have clearly demonstrated that support through the construction of our two new dry-cooled facilities, Gateway and Colusa, as well as through the repowering of our Humboldt facility without the use of once through cooling. Additionally, subject to approvals from the California Public Utilities Commission (CPUC) and California Energy Commission (CEC), we have entered into a power purchase agreement with Mirant that will retire Contra Costa Units 6 & 7 and replace these units with combustion turbines at the adjacent Mirant Marsh Landing facility – eliminating once through cooling at the Contra Costa facility. The only PG&E-owned facility that will continue to utilize once through cooling is the Diablo Canyon Power Plant (Diablo Canyon), a 2,300 MW baseload facility located on the Central Coast.

PG&E is pleased to have the opportunity to provide comments on the State Water Resources Control Board's (Water Board) current draft policy and substitute environmental document (SED).¹ Overall, we believe that the draft policy is moving in a positive direction. We are very encouraged by the Water Board's on-going efforts to engage the CPUC, the CEC, and the California Independent System Operator (CAISO) (collectively, the Energy Agencies) in both policy development and implementation strategy. This coordination is absolutely essential to ensure that implementation of an OTC policy maintains the reliability and stability of the state's electric grid.

We are also pleased to see that the draft policy addresses the unique contribution of the state's nuclear plants. These baseload plants provide roughly 12% of the state's electric generation – Diablo Canyon provides 22% of PG&E's power needs – and do so efficiently and without greenhouse gas or criteria pollutant emissions. They also represent tremendous capital investments for the state's ratepayers.

¹ We incorporate our prior comments submitted in 2006 and 2008 by reference, which should already be a part of the administrative record in this proceeding. We refer here to exhibits attached to our earlier comments as 2006 Exhibit _ or 2008 Exhibit __ and have not attached another copy to these comments. Exhibits to these comments are labeled Exhibit ___.

PG&E strongly supports the inclusion of a cost-benefit variance in the policy. While there is certainly a need to develop many details regarding the scope and implementation of the variance, we believe that acknowledging the need to balance the costs and benefits of compliance is central to establishing a workable policy.

In our detailed comments below, PG&E provides input and recommendations on aspects of the policy that we believe require additional consideration prior to adoption. These areas include:

Evaluating the biological impact of once through cooling, particularly as it relates to quantifying the benefits of policy implementation

PG&E strongly believes that as further work is done to quantify the benefits of compliance, site-specific assessments of biological impact are required. Facilities such as Diablo Canyon have over 30 years of biological data available to demonstrate that there has been no significant impact to fish populations since the commencement of plant operations. Further data from the SED indicates that Diablo Canyon contributes a disproportionately small percentage of both impingement and entrainment. These factors must be considered in quantifying the benefits of policy implementation.

Developing realistic compliance alternatives under Track 2

A thorough review of the various once through cooling alternatives, other than closed cycle cooling, clearly demonstrates that no technologies are available – even in combination – that will provide the 84% level of reduction required under Track 2. For this compliance option to be meaningful there must be available technology to achieve the 84% benchmark.

Establishing a more detailed process to ensure a flexible implementation schedule

Effective implementation of the policy requires on-going review of the implementation schedule. The Statewide Advisory Committee on Cooling Water Intake Structures (SACCWIS) must provide input on a regular basis – preferably quarterly or semi-annually, the Energy Agencies must maintain a leadership role in providing input to the Water Board on the implementation schedule, and plant operators must have a clear process by which they can seek changes in the implementation schedule.

Developing a workable interim mitigation approach

The current proposal requires the development and implementation of major capital equipment and mitigation projects on an interim basis. There are a myriad of issues which suggest that establishing a fund to which plant operators could contribute mitigation funds would provide much more efficient, effective water quality improvements. Water Board or Regional Board staff could oversee projects and ensure timely implementation.

Utilizing existing nuclear plant cooling tower feasibility studies

Both PG&E and SCE have recently completed detailed cooling tower feasibility studies that adequately scope the very real site-specific engineering, construction, and operational challenges posed by the retrofit of the nuclear facilities. Before requiring additional studies,

PG&E recommends, and the CEC supports, the evaluation of these studies by the nuclear review committee established in the proposed policy.

Developing definitions and guidance on cost-benefit variance

In order to ensure consistent and effective implementation of a cost-benefit variance, work is needed to further define how both costs and benefits will be quantified – and what constitutes “wholly disproportionate.” Additionally, the variance should not be discretionary. If any eligible plant operator demonstrates, based on the Water Board’s criteria, that the costs of compliance are wholly disproportionate to the environmental benefits – the discharger should be granted a variance.

II. COMMENTS ON THE SUBSTITUTE ENVIRONMENTAL DOCUMENT

PG&E believes that the Substitute Environmental Document (SED) provides background to inform the development of the proposed OTC policy, but many areas do not provide sufficient data to perform the level of analysis necessary under CEQA. Below are detailed comments on the various sections.

A. BIOLOGICAL IMPACTS FROM ONCE THROUGH COOLING

1. Diablo Canyon’s OTC impacts are minimal

PG&E previously submitted substantial comments on the level of adverse environmental impacts thought to be associated with once through cooling systems. 2008 Comments, pp. 5-10; 2006 Comments, pp. 15-16, 23-26. We will not restate these comments in their entirety, but rather summarize the key points below and provide additional data.

First, PG&E continues to believe OTC impacts are very site specific in nature and that Diablo Canyon’s impact is minimal. Demonstrating this point is the material provided in the SED summarizing levels of entrainment and impingement by facility. Diablo Canyon is a baseload facility that runs at nearly continual full capacity. Based on the data of average flows from 2000 to 2005, Diablo Canyon circulates roughly 22% of the state’s once through cooling flow. However, only 1% of the impingement and 8% of entrainment are associated with Diablo Canyon. SED, pp. 31-32. Thus, the location and design of the plant’s cooling water intake system ensures that its impact, if any, is far less than its proportion of cooling water flow.

Diablo Canyon’s impingement impact is not just “less” than other plants as stated in the SED – it is virtually non-existent (totaling less than 1600 pounds per year) and was found by the Central Coast Regional Board to be “so minor that no alternative technologies are necessary to address impingement at DCCP, and the cost of any impingement reduction technology would be wholly disproportionate to the benefits to be gained.” 2008 Comments,

p. 5; 2006 Comments, Exhibit 6, p. 2. Additionally, Diablo Canyon has not documented a single sea turtle or marine mammal death due to impingement.

Diablo Canyon's entrainment is estimated at an average of approximately 11% of fish larvae in the source water body. This must be understood in the context that over 99% of fish larvae do not reach adulthood. Available data demonstrate that the operation of Diablo Canyon has not caused any detectable impacts on adult fish populations in the region. As part of the plant's biological monitoring program, PG&E has collected data on fish populations at control stations in the Diablo Canyon area since 1976 – ten years prior to plant operation. Graphs of this data demonstrate that there have been no shifts in population that can be attributed to entrainment. Exhibit 1, pp. 3-4. Further, a previously submitted study by researchers from California Polytechnic University in San Luis Obispo indicated no evidence of a declining trend for Rockfish along the Central Coast. 2008 Exhibit 1; 2006 Exhibit 20. This study began in 1980 – five years before plant operation. If the operation of Diablo Canyon was impacting rockfish populations, this study should have found declining populations of species susceptible to entrainment.

2. General comments on biological impacts

Comments previously submitted by PG&E in both 2006 and 2008 addressed various concerns regarding the evaluation of biological impacts. First, PG&E believes it is important to stress that the focus on fish and shellfish is appropriate. U.S. Environmental Protection Agency (USEPA) has determined that phytoplankton and zooplankton do not warrant assessment as there is a very low probability of impact given their extremely short generation times, ability to continually reproduce, and abundance throughout California's coastal waters and beyond. 2008 Comments, p. 9.

Second, both Section 316(b) of the Clean Water Act and Porter-Cologne recognize the potential for some effects due to once through cooling. Section 316(b) requires that adverse impacts be minimized – not eliminated. Thus, it is not appropriate to equate a fish kill from a chemical spill or other non-compliance activity to impingement from a permitted once through cooled facility.

There is no direct evidence that once through cooling is causing adverse environmental impacts at all OTC facilities. Impacts are site specific and should be assessed as such. This fact must be considered when quantifying any benefits from policy implementation.

B. COMMENTS ON ENVIRONMENTAL EFFECTS AND MITIGATION

PG&E's overall comment on the assessment of the policy's environmental effects is that the analysis glosses over many areas of concern and does not provide sufficient detail to adequately address the impacts from implementation. Our key concerns are outlined below.

1. Reasonably foreseeable means of compliance

The SED utilized two documents – one from the USEPA and one from the Electric Power Research Institute (EPRI) to evaluate various types of potential compliance measures: flow reduction, physical barriers, collections systems, behavioral barriers, and operational modifications. PG&E believes that the SED greatly overestimates the ability of plants to use alternative technologies, in lieu of cooling towers, to meet the 84% reduction target established in Track 2.

The SED's cooling tower discussion highlights advancements in saltwater cooling technology. Unfortunately, the SED cites a CEC study on cooling towers that is not available on the CEC website or through staff and we were unable to obtain the report from Water Board staff as well.² Our understanding is that this report may be a draft and has not yet been finalized. PG&E would appreciate the opportunity to review and comment on this report. The SED also includes a list of facilities with saltwater cooling towers. SED, p. 86. It is important to note that there are no coastal nuclear facilities with saltwater towers on the list – and a majority of the sites on the list are not coastal sites. The nuclear facility included on the list, Palo Verde in Arizona, is a high salinity fresh water site, with salt concentrations significantly below those found in the marine environment at Diablo Canyon. The chemical contaminants in the cooling source water at Palo Verde are also primarily non-chloride salts unlike ocean water which has very high concentrations of sodium chloride.

PG&E is very concerned about the issues raised by the potential installation of large scale saltwater towers at nuclear facilities, particularly those with limited options for cooling tower siting. The significant potential for arcing on high voltage transmission systems that deliver electricity from power plants to the grid and also provide emergency auxiliary power from offsite sources is a serious concern. For nuclear facilities in particular, loss of transmission system integrity will result in reactor trips and exercise of nuclear safety systems. At Diablo Canyon, the 500 kV main bank transmission systems would be vulnerable to extensive salt deposition with any cooling tower configuration, and the 230 kV auxiliary power systems would be significantly vulnerable with placement of saltwater towers north of the facility. An unreliable auxiliary or emergency power supply would essentially make operation of the facility unacceptable from a nuclear safety perspective. In addition to the arcing of high voltage systems, accelerated aging of plant equipment would also occur due to extensive saltwater induced corrosion. Given our significant concern over the inadequate evaluation of cooling tower feasibility, PG&E commissioned Enercon Services Inc. to perform a detailed feasibility study of the Diablo Canyon site. The study is attached as Exhibit 2.

The other technologies or operational measures assessed all raise significant concerns for many facilities. The wide mesh barrier nets discussed in the SED are for the reduction of

² The report is cited in footnote 114 of the SED (CEC. Cost, Performance, and Environmental Effects of Salt Water Cooling Towers. 2007.)

impingement only and are best suited for seasonal installations involving high impingement events. This technology is obviously of very limited value – and of no value at all for Diablo Canyon.

The discussion in the SED on aquatic filter barriers suggests that this technology may have more applicability than is likely the case. At the Lovett installation, reliability was low and there were significant maintenance problems. As described, Mirant, the owner of both Lovett and Contra Costa decided not to install AFBs at Contra Costa based both on the results at Lovett as well as the results of preliminary testing at Contra Costa. Furthermore, there is no experience with this technology in an open-ocean environment.

The relocation of intakes further offshore would, in most cases, simply exchange one type of entrainment for another. At Diablo the costs would be exorbitant and productive, pristine rocky reef habitat would be lost. It would also simply switch entrainment to more commercially and recreationally important species – which is not likely to be a positive outcome.

The consideration of seasonal operation restrictions is not a feasible alternative for a facility that provides baseload power. Further, nuclear plants in particular are designed to run at full capacity and are not well suited to ramp up and down or run at partial capacity. For fossil plants, this option may be difficult as well. Plants are often needed in the summer, when larval densities can be at their highest at some locations. In any case, it is unlikely to provide the level of reduction required under Track 2.

The last technology mentioned in the discussion is wedgewire screens. This technology, as indicated in the SED, is limited in use to river environments. Thus, it is not viable at most California OTC facilities.

Thus, short of cooling towers, the analysis does not identify any technologies that are readily available and well tested to meet the requirements set out in Track 2. Without such flexibility, facilities are left with no compliance option – and must retire unless repowering makes sense. The Water Board should reconsider whether it may make the most overall sense to provide a greater degree of compliance flexibility so as to allow facilities options other than cooling towers and create incentives to do what is truly feasible in the short term. This is particularly true for plants that are required to maintain grid stability.

2. Potential adverse environmental effects

In general, the SED's analysis of potential adverse environmental effects associated with implementation of the policy is quite cursory. Below are comments on the areas that clearly require more analysis.

a. *Aesthetics*

Staff's assessment that there are no significant aesthetic impacts is not accurate. While we do not provide comment on each facility, as for Diablo Canyon, PG&E believes that there are significant impacts. Given site constraints, plume-abated towers are not possible at the site. The Enercon study includes a detailed plume study and found that the plume would be visible in San Luis Obispo approximately 20% of the time. Exhibit 2, Appendix A-7. Additionally, the plume would be over half a mile high roughly 35% of the year. Thus, it would frequently be visible from Avila Beach and San Luis Obispo – as well as continually visible from the ocean. We believe that this is an aesthetic impact that warrants evaluation.

a. *Agriculture*

There are agricultural activities both north and south of the plant -- livestock grazing in both areas and various crops are grown to the south. As mentioned above, plume/drift abatement towers cannot be installed at Diablo Canyon due to space limitations. Salt drift at Diablo Canyon would be at least 15 million pounds per year and it would very likely impact agriculture – particularly to the south. This potential impact on agriculture warrants evaluation.

c. *Air Quality*

The SED analysis does not adequately address the air quality permitting issues associated with saltwater cooling towers. The availability of PM10 credits is not discussed in sufficient detail – and this is a key issue in the San Luis Obispo Air Pollution Control District. The SLOAPCD issued a letter to the Central Coast Regional Board in 2004 indicating that cooling towers were likely not permissible for the Morro Bay facility due to a lack of available credits, as well as consideration of whether cooling towers reflected BACT. 2006 Exhibit 7. The SED estimates PM10 emissions from cooling towers at Diablo Canyon to range from 993 tons per year (USEPA method) to 50 tons per year (alternative method). In either case, it is highly unlikely that cooling towers could be permitted.

d. *Water Quality*

The SED analysis does not reflect potentially serious water quality issues given that the cooling tower blowdown is saltier and warmer than the existing discharge. PG&E's Enercon study indicated that a new offshore diffuser would be necessary to ensure that the blowdown meets Ocean Plan requirements. The construction of the diffuser would cause environmental effects that must be properly assessed.

e. *Utility and Service Systems*

The SED analysis of impacts on the state's electric grid relies on the Jones and Stokes report prepared in 2008. PG&E believes that this report did not provide significant value to the process and that the Water Board must look to the Energy Agencies, and the CAISO in particular, for an accurate assessment of the overall risks associated with policy implementation, as well as recommendations on implementation of compliance schedules and strategies. The study itself acknowledged these shortcomings:

Though this study makes optimistic conclusions about the industry's ability to compensate for mass OTC plant retirements at relatively modest costs, it is extremely important to understand that the modeling effort conducted for this study was limited in scope, capable of only taking a snapshot of the big picture, due to time constraints. Ideally, the modeling effort would have been expanded to thousands of runs examining each OTC plant in great detail, instead of the limited number of runs that were possible for this study.

Because of this limitation, the key recommendation arising from this study is that the industry must continue comprehensive study of the issue, examining the reliability implications of retirement of each plant individually and in combinations with all other plants, and constantly reassess the reliability implications of the Board's new policy as it is planned and enacted.³

The Energy Agencies and SACCWIS must continue to inform the process to ensure that grid reliability remains an overarching priority.

3. Economic analysis

The SED's economic analysis clearly states that closed cycle or dry cooling are more favorable when part of a new facility's initial construction or a repower of an existing facility and PG&E agrees with this position. Retrofits present significant economic and operational challenges at existing facilities. Further, the Jones and Stokes low-end estimate of \$100 million to develop transmission and generation solutions in the event all of the OTC plants are eliminated has absolutely no credibility. As previously stated, this report cannot be relied on to develop a reasonable approach or cost estimate of policy implementation.

Given the insufficiency of the Tetra Tech cooling tower feasibility report, PG&E commissioned a more detailed report from Enercon Services, Inc. This report is included in our comments as Exhibit 2. PG&E requests that this section be modified to reflect the additional detailed cost information developed by Enercon. Exhibit 2, pp. 3, 52-56,

³ Jones and Stokes, Electric Grid Reliability Impacts From Once-through Cooling in California, p. 6 (April 2008).

Appendix A-11. PG&E estimates that a retrofit would raise rates by more than 10% during an estimated 17-month outage and up to 6% over a twenty year period. These are significant increases, especially when considered cumulatively with other large maintenance and construction projects undertaken to strengthen grid reliability and deliver renewable power.

III. SPECIFIC COMMENTS ON THE PROPOSED POLICY

A. POLICY INTRODUCTION

The proposed SACCWIS includes not only the Energy Agencies, but representatives from the State Lands Commission, Coastal Commission, and Air Resources Board. While these additional agencies all have an important role to play in the permitting arena, it makes more sense for the Energy Agencies to maintain responsibility for recommending modifications to the implementation schedule. The primary driver to any schedule modifications should be – as indicated in the policy introduction – preventing the disruption of the state’s electrical power system. The Energy Agencies are best situated to provide input on each plant’s role in maintaining system reliability. These agencies understand and have direct regulatory authority for power plants and transmission facilities. Other agencies can provide valuable input regarding permitting challenges or other regulatory hurdles, but it is the Energy Agencies that can integrate that information as it relates to maintaining the reliability and stability of California’s power grid.

Additionally, while the policy acknowledges the need to phase compliance so as to maintain grid reliability, the ability of the utilities to procure adequate resources to ensure reliability, through either the replacement or repowering of existing facilities, is dependent upon the outcome of several regulatory processes. Implementation of the process by which OTC facilities would be replaced or repowered -- the CPUC's Long Term Procurement Plan (LTPP) and, subsequently the utilities' Long Term Request for Offer (LTRFO) activities - includes a great deal of uncertainty. While utilities can plan for a particular outcome, the vagaries of the process require the need for significant flexibility. The multiple steps along the way - submittal of offers, negotiating of deals, approval by the CPUC, permitting through the CEC, and construction - all are subject to a variety of business and regulatory hurdles. Thus, there is a strong need to ensure adequate flexibility in the OTC policy implementation schedule in order to ensure that those facilities needed for grid reliability purposes can continue to operate as necessary. If the policy is adopted, the Water Board must understand that in many cases, the proposed schedule reflects a "best case" scenario and there may be a need to modify the proposed schedule based on developments in the aforementioned proceedings.

B. REQUIREMENTS FOR EXISTING PLANTS

1. Feasibility of cooling towers required under Track 1

a. *Tetra Tech Study is inadequate*

The Tetra Tech study performed for the Water Board in 2007 is not sufficiently detailed to provide a foundation to determine the feasibility of cooling tower retrofits at any of the OTC plants. This creates a fundamental difficulty for policy implementation – as it is quite clear that the real outcome would be retirements and repowers. Very few, if any, facilities will embark upon a retrofit. Closed cycle cooling – or dry cooling – may be BTA for a new facility, but there is no evidence that it is BTA for all existing facilities.

As an example of the cursory nature of the Tetra Tech report, no one from Tetra Tech visited the Diablo Canyon plant or talked to anyone at PG&E regarding the feasibility of retrofitting Diablo Canyon. It is not possible or appropriate to make a determination of retrofit feasibility for a large nuclear plant without visiting the site and talking with those most familiar with plant operations. Given the complete inadequacy of the Tetra Tech report – but yet the continued assertion that cooling towers are a feasible option for Diablo Canyon – PG&E commissioned another more detailed study by Enercon Services. Exhibit 2. In summary, the report finds that there are enormous challenges associated with the retrofit and that capital expenditures alone would surpass \$2 billion dollars and total costs would exceed \$4.5 billion. The results of the study are summarized below.

b. *The Water Board must consider PG&E's Enercon Cooling Tower Feasibility Study*

The Enercon study concludes that “any retrofit of Diablo Canyon is a highly speculative project with likely insurmountable permitting obstacles, substantial engineering challenges, significant adverse environmental impacts, costs exceeding \$4 billion dollars, and uncertainty regarding the Power Plant’s post-retrofit operating capacity factors.” Exhibit 2, p. 1. The Diablo Canyon site is very geographically constrained, limiting the placement of cooling towers. The necessary configuration requires the excavation of over 2 million cubic yards of soil/rock, the demolition of over 170,000 square feet of existing buildings and parking areas, and major modifications to existing in-plant systems such as condensers, electrical systems, and service cooling water heat exchangers. The project’s construction would take 45 months, with an outage of at least 17 months. Replacement power during this period would emit between 9-10 MMT of greenhouse gases.

There are also significant permitting challenges. As discussed in previous comments, the necessary PM10 credits do not exist in the San Luis Obispo Air District. The plume would be over half a mile high roughly 35% of the year and visible from San Luis Obispo approximately 20% of the year. Further, the warmer, saltier discharge would require

installation of a diffuser in Patton Cove south of the plant. This would eliminate rocky reef habitat in the area – as well as destroy the 33-year old control station for Diablo Canyon’s biological monitoring program. The retrofit also raises a number of potential Nuclear Regulatory Commission (NRC) safety concerns which would require formal review and approval through the license amendment process. These include an increased risk of flooding from the cooling tower water, accelerated aging due to salt deposition, security concerns due to opening of the protected area during construction, and rerouting of the Independent Spent Fuel Storage Installation haul road. The plant would be derated an average of 55 MW, with up to a 70 MW derate in the summer, causing the on-going emission of 164,000 MT per year of greenhouse gases from replacement power generation.

c. *The Water Board must provide a definition of “feasible”*

The current version of the proposed policy does not include a definition of “feasible” – so it is unclear how a Regional Board would determine whether closed cycle cooling is “feasible” for any particular facility. The 2006 version of the policy used a definition of “feasible” that was equivalent to a CEQA-related definition and the 2008 version included a different definition. Effective, consistent policy implementation requires a well-understood definition of feasibility. PG&E supports the use of the 2006 draft OTC policy definition: “capable of being accomplished in a successful manner within a reasonable period of time, taking into account economic, environmental, legal, social, and technological factors.”

2. Track 2 provides no meaningful compliance option

Track 2 as proposed in the draft policy does not present a real alternative compliance option. For the most part, cooling towers are the only option available to achieve the minimum reductions of approximately 84% as required under Track 2. A facility has no choice but to retrofit to cooling towers, repower, or retire. A facility that cannot retrofit with cooling towers for any reason – economic, technical, or administrative – must retire as there is no other alternative that will achieve the required reductions. Even if reductions of 75% could be achieved – this would be insufficient to meet the policy’s requirements. As discussed in section II.B.1, there are no readily available technologies that can meet the requirements – and operational measures may not be sufficient, if available at all. The Water Board should consider development of a more tiered approach for existing facilities that would provide a true alternative in the event that closed cycle cooling cannot be achieved.

3. Interim mitigation must be carefully designed

Proposed interim compliance measures include large organism exclusion devices for offshore intakes, ceasing intake flows when power is not being generated and developing restoration measures. The policy contains no details as to how these provisions would be implemented – and this is likely to create a great deal of unnecessary confusion. Clarifying how these measures will be implemented will ensure more consistent and efficient compliance.

a. *Offshore Exclusion Devices*

As Diablo Canyon does not have an offshore intake, PG&E generally has no opinion on the use of exclusion devices for large organisms. However, as with any technology requirement, the Board should ensure that this is a cost-effective approach. If a facility plans to retire, repower or retrofit in the longer term, it may not make economic sense to install such a device for the short term.

b. *Reduction in Cooling Water Flows*

The proposal also calls for the elimination of cooling water flows unless a facility is engaged in "power-generating activities" or "critical system maintenance." Nuclear power plants generally must operate the cooling system for several days prior to reactor start up following either a refueling outage or a forced outage. This is due to the need to heat-up the secondary (turbine) condensate system and establish the required condensate chemistry and condenser vacuum before reactor start and systems feed forward can commence. PG&E believes that this required procedure meets the definition of a "critical system maintenance" activity. It should be noted that the time in which cooling system flow will be required when power generation is not occurring will likely be significantly longer for nuclear facilities in comparison to most fossil fueled facilities.

c. *Mitigation Measures*

The third component of the interim requirements poses the greatest challenge. Mitigation measures must be implemented to mitigate for the interim impact through existing programs, funding new projects, or developing a new project. This approach raises several complex questions: 1) how to define the mitigation period; 2) how to scale mitigation; and 3) how to quantify the mitigation. Additionally, the timeframe to develop and receive approval to implement projects may be longer than the interim mitigation period.

Assuming that issues of scaling and timeframe can be overcome, PG&E supports the concept of establishing a fund to which the discharger could contribute mitigation funds. The Board staff could then develop projects on a more holistic basis that may provide a greater overall benefit to the State's water quality.

4. The NRC has no procedure in place to grant a Nuclear Safety Exemption

Although the policy sets out a compliance exemption if compliance would cause a conflict with a nuclear safety requirement, the NRC does not have any existing process in place to provide such a determination. It is our understanding that the Water Board staff has not talked to the NRC about the form of approval necessary. In general, the NRC makes formal approvals or findings in conjunction with standard applications – such as a license

amendment. Thus, in order to obtain any formal determination from the NRC, the nuclear plant operator would likely have to fully develop plans to install cooling towers and present these to the NRC as a license amendment. There is no process to receive a preliminary determination on a license amendment – the NRC would perform a full review. This undertaking would cost millions of dollars – and if the operator found in the early stages of design that the design would conflict with a safety requirement, they would not further pursue it. Without the operator pursuing the license amendment, the NRC would likely not provide a preliminary or advisory opinion as to whether the proposal would conflict with a safety requirement. The bottom line is that this “exemption” does not provide a realistic compliance exemption as no plant would undertake the level of work that would be necessary to obtain a license amendment denial. In most cases, if enough money is spent, safety issues could likely be engineered away with additional modifications. The real question is how efficiently the plant would operate after a retrofit. When making the level of modifications necessary to implement a retrofit – the primary concern is that the plant will not operate anywhere near its current 95-100% capacity factor after installation.

C. IMPLEMENTATION

1. The implementation process requires more detailed guidance

PG&E strongly believes that a coordinated approach to OTC policy implementation is a critical element in maintaining grid stability. We are encouraged to see the participation and input from the Energy Agencies and believe that their continued participation is essential to ensuring the reliability and stability of the state’s electric system.

Further, the policy currently requires the SACCWIS to provide updates on the implementation schedule beginning in 2013 and every two years thereafter. It is essential that the Energy Agencies provide updates to the Board on a much more frequent schedule. After adoption of the policy, updates should be provided on a semi-annual or quarterly basis. This will ensure that the Water Board fully understands the complexity and challenges posed by implementation of the policy and that the schedule can be modified as necessary to reflect changes needed to ensure grid stability.

Last, the process by which a facility can seek modification of the implementation schedule should be more clearly defined. If a facility believes that it cannot meet the timeframe for compliance established in the schedule, the process to present data to support their position should be included within the policy.

2. Nuclear facility requirements need additional specificity

In general, PG&E supports the Board’s approach of ensuring a more detailed, thorough investigation of alternatives to once through cooling at the nuclear plants. The nuclear plants are baseload facilities that provide approximately 12% of the state’s electricity needs. They represent an enormous capital investment and produce electricity cost-

effectively, efficiently and emission free. The plants have the ability to provide electricity for years to come – playing a pivotal role in ensuring that the state meet its AB 32 goals of GHG emission reductions and providing a key foundation to greater reliance on renewable resources. Further, the retrofitting of a nuclear plant is an extraordinarily complex, site-specific undertaking which warrants extensive evaluation.

PG&E has continued to look at a variety of alternatives to once through cooling at Diablo Canyon – from its design phase in the 1970s to more recent efforts including the review of options in 2000 as part of our updated 316(b) Demonstration Study prepared by Tenera with oversight by the Central Coast Regional Board’s Technical Work Group, a study by Burns Engineering in 2003, and a more detailed study of cooling tower feasibility by Enercon in 2009. Exhibit 2. As a first step to any further review of feasibility, the latest report prepared by Enercon for PG&E, as well as the report developed by SCE for the SONGS facility, should be reviewed by the Water Board’s proposed nuclear review group. There is likely no need to initiate yet another study of cooling tower feasibility.

Finally, PG&E supports a cost-benefit variance approach and believes that a review of the studies prepared to date will demonstrate that cooling tower retrofits at the nuclear plants are clearly not a realistic option – with the costs vastly outweighing any benefits.

a. *Evaluate existing studies before requiring additional studies*

The proposed policy requires the two nuclear plant operators to conduct special studies of once through cooling alternatives. Before commissioning any additional studies, PG&E strongly recommends that the Water Board review the Enercon study recently prepared for PG&E and described above, as well as work prepared for SCE. These studies thoroughly evaluate the feasibility of cooling towers at each facility. Additionally, at the September 16, 2009 hearing on the proposed policy, the CEC stated its support for evaluation the utilities’ feasibility studies as the starting point of any alternatives analysis. These existing studies should be peer reviewed, perhaps by EPRI or another qualified consultant, before any additional studies are commissioned.

b. *Consultant should be selected with input from nuclear review committee*

If additional studies are required, PG&E also strongly recommends that the independent consultant be selected with input from members of the nuclear review committee. It is absolutely critical that the consultant have significant nuclear engineering expertise. To date, the various reports prepared for the Water Board on cooling tower feasibility and grid stability have proven to be superficial at best – and clearly insufficient to provide a strong foundation for policy choices.

c. *Nuclear Review Committee should include all Energy Agencies*

The proposed policy defines the Nuclear Review Committee membership, at a minimum, as a representative from each operator, the Water Board, the Central Coast and San Diego Regional Boards, the environmental community, and the SACCWIS. PG&E strongly recommends that the membership include a representative from the CPUC, the CEC, and the CAISO. Representation from the Energy Agencies will ensure that grid reliability and stability -along with ratepayer considerations - continue to play a predominant role in assessing alternatives to once through cooling for the nuclear plants.

D. WHOLLY DISPROPORTIONATE DEMONSTRATION

PG&E strongly supports the inclusion of a wholly disproportionate demonstration in the proposed policy. This is an absolutely critical component to ensuring that the policy is implemented in a reasonable, cost-effective fashion. It should also be noted that at the September 16, 2009 hearing on the proposed policy, the CPUC registered its support for the wholly disproportionate approach stating concerns with the cost of alternatives and a disinclination to trade water impacts for air impacts. Given the Supreme Court's decision in *Entergy vs. Riverkeeper*, 129 S.Ct. 1498 (2009), it makes fundamental sense for the Water Board to include, at a minimum, a cost-benefit variance within its policy. As Justice Breyer stated in his concurring opinion,

“Every real choice requires a decisionmaker to weigh advantages against disadvantages, and disadvantages can be seen in terms of (often quantifiable) costs. Moreover, an absolute prohibition [on cost-benefit analysis] could bring about irrational results.....it is particularly so in an age of limited resources available to deal with grave environmental problems, where too much wasteful expenditure devoted to one problem may well mean considerably fewer resources available to deal effectively with other (perhaps more serious) problems. *Id.* at 1513.

While many facilities will eventually repower or retire, recently updated facilities and the nuclear facilities represent a substantial capital investment and are poised to provide cost effective, efficient, and cleaner power to the state for years to come – and a variance which allows these facilities to weigh the costs of compliance and the potential benefits is essential to ensuring that compliance dollars are spent cost effectively. Furthermore, the policy would require such facilities to fully mitigate any impacts that cannot be reduced through technology or operational measures. It is very likely that the funds spent on mitigation may provide for a greater overall environmental benefit than the elimination of once through cooling – at least at some facilities.

PG&E is encouraged by the inclusion of the cost-benefit test in the policy, however additional work is needed to define the applicability of the variance. For instance, consideration should be given to its interplay with the very limited compliance options provided under Track 1 and Track 2. For facilities that play a critical role in maintaining grid reliability, as determined by the Energy Agencies, consideration should be given to either a definitive means to extend compliance deadlines or access to the cost-benefit variance. The

policy must ensure that it will not cause the premature closure of a facility needed to maintain California's electric stability.

Additionally, further details are required to ensure a consistent application of the provision. The proposed policy does not include sufficient definitions and explanations of how costs are calculated, how benefits are calculated, and how the two are compared. Much time, effort, and energy has been spent by staff at the USEPA, NOAA and other agencies to develop tools for the estimation of costs and benefits. The Water Board should be careful not to reinvent the wheel – or to be overly concerned that such estimations cannot be made. Environmental costs and benefits are calculated frequently in the regulatory setting – and USEPA has published a guidance document on the subject.⁴ Below we have highlighted some key concerns.

1. The variance must be granted if the discharger makes the required showing

As proposed, the Regional Board *may* grant a variance if a discharger demonstrates that the cost of compliance is wholly disproportionate to the benefits achieved. PG&E believes that the Water Board should establish a clear framework for making such a demonstration – and if the discharger meets this burden, the variance must be granted. Assuming that the variance is established to avoid the irrational outcome of spending billions of dollars to achieve a very small benefit, allowing it to be granted on a discretionary basis could lead to inconsistent results that contradict the objective of the statewide policy.

2. Costs must be defined in a manner comparable to benefits

The proposed policy requires the discharger to provide information on the costs of compliance in terms of “dollars per megawatt hour of electrical energy produced over an amortization period of twenty years.” SED, p. A-8. While the calculation of benefits appears to be “lump sum” in nature, the costs are presented on an amortized basis and further divided by the number of megawatt hours of electricity produced. This appears to create two different types of cost streams. Costs and benefits need to be presented in a manner that allows for accurate comparison and evaluation.

3. The estimation of benefits should be reviewed

The proposed policy's approach to benefits calculation should be reviewed. Currently, it states that “Habitat Production Foregone or some other appropriate method approved by the Regional Water Board” must be used to determine the benefits from impingement and entrainment reductions. First, PG&E believes that the Water Board should set a standard for the Regional Boards to follow. Individual Regional Boards should not be able to select different benefit assessment models. This situation would clearly lead to inconsistent results.

⁴ USEPA. Guidelines for Preparing Economic Analysis. 2000.

The SED suggests that an ecological approach to benefits calculation is necessary because only 2% of what is entrained and impinged is accounted for under standard processes for quantifying benefits. SED, p. 79. This misstates the situation. In standard economic analysis, all fish and shellfish are accounted for through trophic transfer modeling. All that is not accounted for is phytoplankton or zooplankton. As discussed in section II.A.2, USEPA has found that there is a very low potential impact to these species due to their extremely short generation times, continual reproductive capabilities, and abundance along the entire California coast (and in many cases, the entire Pacific Ocean and beyond).⁵ Thus, there is no need to include zooplankton and phytoplankton in any benefits assessment.

The proposed policy's recommended approach, the Habitat Production Foregone (HPF) model, has not been subject to significant peer review. The HPF model was developed by scientists working with the Central Coast Regional Board on various entrainment studies during the 1990s. As stated in our 2006 and 2008 comments⁶ concerns with the HPF model include: 1) failure to provide a necessary linkage between impingement and entrainment effects, ecological services, and human services; 2) failure to consider discounting, and thus a high likelihood of overestimating the size of a restoration project; 3) no accounting for uncertainty in its analysis; and 4) failure to consider biological compensation, especially in relationship to larval losses – further overestimating the size of a restoration project. Further, in our prior comments, we submitted reviews of the HPF approach by two U.C. Santa Barbara resource economists, as well as Triangle Economic Research. 2006 Exhibits 11, 13, 14. All three of these reviews found that the approach violates fundamental economic principles by using habitat replacement as a proxy for the value of the lost resource.

Additionally, the results of the HPF model are based on averaging the various entrainment rates for all fish that are evaluated and the source water body size for each species. This averaging process introduces a great deal of uncertainty as to what the calculation represents. The final result is presented as a range of habitat size and the evaluation done for Diablo Canyon demonstrates the potential breadth of such a range. The Independent Scientists' Report to the Central Coast Board estimated the size of an artificial reef to compensate for entrainment losses ranged from 85 hectares to 412 hectares – a factor of five. 2006 Exhibit 16. There is no obvious mechanism to choose a point within the range and thus, there is a great deal of discretion that goes into making a final determination.

The Water Board should review existing cost-benefit models developed and used by other agencies, as well as the cost-benefit guidance document prepared by USEPA, and provide clear guidance to the Regional Boards on how to perform such an assessment.

⁵ United States Environmental Protection Agency (USEPA). 1977 Draft Guidance for Evaluating Adverse Impact of Cooling Water Intake Structures on the Aquatic Environment: Section 316(b) P.L. 92-500.

⁶ See 2008 Comments, pp. 18-19; 2006 Comments, pp. 20-21.

3. Guidance on the definition of wholly disproportionate is necessary

While PG&E strongly supports the use of a cost-benefit test, it is essential that the term “wholly disproportionate” be defined. If there is no definition, each Regional Board is free to make its own determination and this will lead to the very inconsistency that the Water Board is trying to avoid by developing the OTC policy. It is entirely appropriate for the Water Board to establish a minimum threshold over which costs are found to be wholly disproportionate. While there is no clear cut answer, several court cases suggest a range of two to three times benefits would be reasonable.⁷

V. CORRECTIONS

Page 3 Table 1

There is no pending lawsuit regarding Diablo Canyon’s NPDES permit. The administratively extended permit contains a finding that the cooling water intake structure reflects best technology available. The Central Coast Board held a hearing regarding alleged thermal discharge non-compliance in March 2000. This hearing was closed and a tentative settlement reached, incorporating both thermal and 316(b) issues in October 2000. The settlement was reviewed and approved by the Central Coast Board in March 2003. The parties signed the document in June 2003. However, the Central Coast Board did not renew the NPDES in July 2003, as contemplated in the settlement agreement. Thus, the permit remains on administrative extension and the settlement is on hold.

Page 85 Table 20

The salt water cooling tower facility list includes a facility that identifies PG&E as the project owner. This is Pittsburg Unit 7 and Mirant is the current owner.

Page 108

Gateway is a combined cycle dry cooled facility. It has been operational since 2008.

EXHIBITS

1. Memo from TENERA Environmental to Bryan Cunningham (PG&E), September 2009
2. Enercon Services Inc. Diablo Canyon Cooling Tower Feasibility Study 2009

⁷ See e.g. *Ohio v. U.S. Department of the Interior*, 880 F.2d 432, 444 (D.C. Cir. 1989), *reh denied en banc*, 897 F.2d 1151 (1989); *General Ry. Signal Co. v. Washington Metropolitan Transit Authority*, 875 F.2d 320, 326 (D.C. Cir. 1989), *cert denied*, 494 U.S. 1056 (1990).



Date: 23 September 2009

To: Mr. Bryan Cunningham, PG&E DCPD

From: John Steinbeck

Re: Information on Trends from Adult Fish Monitoring at DCPD

Mr. Cunningham,

Here is the information you requested on trends in the adult fish monitoring done at DCPD as part of the NPDES Receiving Water Monitoring Program. The data does not include the most recent monitoring data from 2008 since those data had not been submitted to the RWQCB at the time the graphs were prepared.

Adult fish populations have been monitored in the areas around DCPD as part of the NPDES permit requirements for the thermal discharge beginning in 1976 almost ten years before the plant began commercial operation and the monitoring continues on a quarterly sampling schedule. Locations inside Diablo Cove are sampled to monitor effects of the thermal discharge on natural marine communities and then those data are compared with data from a cove (Patton Cove) south of the plant that is not affected by the warm water discharge. The data from Patton Cove provide a baseline for examining the effects of the thermal discharge but can also be used to look at changes that may be occurring due to natural variation in the marine environment and, to some extent, potential effects of entrainment by the plant cooling water intake system.

The highest levels of entrainment from a study at DCPD conducted from October 1996 through June 1999¹ were estimated for larvae from small fishes that occur on rocky reefs in shallow nearshore areas, the same habitat sampled at the stations in Patton Cove, which are all in relatively shallow water (10–40 ft). The fishes with high levels of entrainment losses included fishery targets such as cabezon and rockfishes, and non-fishery species such as sculpins and greenlings. The annual average abundances of several fishery and non-fishery species are presented (Figure 1). These fishes were selected as they were representative of fishes that are primarily bottom dwellers and are therefore best sampled by the methods used for the study, although the cryptic habits of most of the species result in underestimates of their actual abundances. Since DCPD operates at a high capacity factor, effects of entrainment might be expected to occur as a long-term trend showing declining abundances resulting from the reduced larval supply

¹ TENERA Environmental Inc. 2000. Diablo Canyon Power Plant 316(b) Demonstration Report. Submitted to Pacific Gas & Electric Co., San Francisco, CA.

in the system, although larval supply from distant spawning populations can potentially be a source of developing larvae that can colonize benthic habitats in the vicinity of DCP.

The data for several of the fishes show declines in the early 1990s or following 1997. El Niño conditions persisted through the 1991–1993 period resulting in very low recruitment for many species in 1992. The prolonged El Niño conditions during the early part of the decade were followed in 1997 by another major El Niño event, producing the warmest seawater temperature anomalies recorded since 1950. In addition, the early and mid-1990's saw the advent of trap fishing along the central coast of California (Bloeser 1999) that resulted in declines in cabezon (*Scorpaenichthys marmoratus*), rockfishes and other species. Live fish trapping has been identified as a cause of declines in adult abundances in other areas.² Declines in the abundances of cabezon and KGB-complex rockfishes (Figures 1a and 1b) during the early 1990s that might be due to a combination of fishing and El Niño conditions have appeared to level off following the implementation of regulations on the live fish fishery in the late 1990s and the closure of the areas around Diablo Canyon, including Patton Cove, due to heightened security following the terrorist events of September 2001. Environmental variability, larval drift, migratory behavior, fishing impacts, and the open nature of the coastal system can all affect localized abundances of fishes and the additional mortality caused by larval entrainment from DCP is not strongly reflected in the long-term abundance data from species that would be expected to be affected.

Recent analyses of recreational fishery data show that catches from the local recreational partyboat fishery showed increases in the shallow water fishery in the late 1980s and 1990s, and stabilized at a lower level from 2003–2005 (Figure 2). A statewide analysis of recreational fishery trends by Stephens et al.³ showed that the stocks in central California have not experienced the same declines seen elsewhere in the California, and Dotson and Charter⁴ also reported an increase in commercial partyboat fishing success in central California relative to southern California ports (Figure 3). The species examined in these studies included many of the same rockfish species analyzed for the Diablo Canyon entrainment study, including the kelp/grass/black-and-yellow group of rockfishes that had the highest overall estimated entrainment.


² Starr, R. M., K. A. Johnson, E. A. Laman, and G. M. Cailliet. 1998. Fishery resources of the Monterey Bay National Marine Sanctuary. Publ. No. T-042. California Sea Grant College System, University of California, La Jolla, CA. 102 pp.

³ Stephens, J. S. Jr., D. Wendt, D. Wilson-Vandenberg, J. Carroll, R. Nakamura, E. Nakada, S. Rienecke, and J. Wilson. 2006. Rockfish resources of the south central California coast: analysis of the resource from partyboat data, 1980–2005. CalCOFI Reports 47:140–155.


⁴ Dotson, R. C., and R. L. Charter. 2003. Trends in the southern California sport fishery. CalCOFI Rep. 44:94–106.

Fishes Targeted by Fisheries


a) Cabezon



b) KGB Rockfishes




c) Monkeyface Eel




Fishes Not Targeted by Fisheries

d) Smoothhead Sculpin



e) Snubnose Sculpin



f) Painted Greenling




Figure 1. Annual mean number of fish per 50 m transect from three stations in Patton Cove from 1976 through 2007. Data collected as part of DCPD monitoring of the thermal discharge required by the plant NPDES permit.




Figure 2. Partyboat catch per unit effort (number of fishes per fisher per hour) for eleven rockfishes and two greenling species from ports on the south Central Coast, 1980–2005 from the following sources: 1980–1997 California Department of Fish and Game and 2003–2005 California Polytechnic State University (from Stephens et al. 2006). Data from 1998–2002 collected by Pacific Fisheries Management Commission were not available.




Figure 3. Annual average commercial passenger fishing vessel (CPFV) catch per angler by geographic zone 1959 to 1998. (Figure 3 from Dotson and Charter 2003). The Diablo Canyon Power Plant is located north of Avila Beach in Zone D.

Diablo Canyon Power Plant



Cooling Tower Feasibility Study

March 2009

Prepared by:

Enercon Services Inc.
401 Roland Way
Oakland, CA 94621



DCPP Cooling Tower Feasibility Study

Table of Contents

<u>Section</u>	<u>Page</u>
I. Executive Summary	1
1. Overview	1
2. Design and Construction	1
3. Nuclear Safety	2
4. Environmental Impact and Permitting	2
5. Project Schedule and Costs	3
II. Background & Introduction	4
III. Conceptual Design Overview	5
1. Location of Cooling Towers	5
2. Conceptual Design Summary	9
3. Reduction in Electrical Output with Cooling Towers	13
IV. Construction and Engineering Assessment	15
1. Relocation and Excavation	15
A. Relocation of Existing Facilities	15
B. Relocation of ISFSI Haul Road	18
C. Site Civil Work	18
2. Constructability of Interconnecting Piping	19
3. Modifications to Existing Systems and Required New Systems	21
A. Condenser Modifications	21
B. Service Cooling Water Seawater Supply	22
C. Main Circulating Pumps	23
D. Circulating Water System Piping	24
E. Makeup Water Supply	25
F. Chlorination/Dechlorination of Effluent Streams	25
4. Electrical System Requirements	26
A. Electrical Design	26
B. Instrumentation and Controls	27
V. Nuclear Safety and Licensing	29
1. Nuclear Safety System Requirements	29
2. NRC Licensing	31
3. Security	32

DCPP Cooling Tower Feasibility Study

Table of Contents (cont.)

VI. Environmental Impacts and Permitting	32	
1. Air Quality – Plume/Salt Drift	32	
2. Water Quality – Cooling Tower Blowdown	38	
3. Adverse Impacts	42	
4. Permitting	45	
VII. Additional Studies	47	
1. Special Studies	47	
VIII. Conceptual Schedule	48	
1. Introduction	48	
2. Schedule Basis, Calendar, Resources	49	
3. Pre-Shutdown Construction	50	
4. Construction During Plant Shutdown	50	
5. Plant Re-Start and Construction Completion	52	
IX. Cost Estimate Summary	52	
1. Cost Estimate Overview	52	
2. Capital Project Costs	53	
3. Decommissioning Costs	54	
4. Operation and Maintenance Costs	54	
5. Replacement Power During Construction	54	
6. Replacement Power due to Derated Capacity	55	
Acronyms And Abbreviations	58	
<u>Tables</u>		
Table 1	Issues that Would Threaten the Feasibility of the Project	4
Table 2	Projected Average Flow to/from Ocean (per Unit)	11
Table 3	Reduction in Plant Electrical Output	14
Table 4	Buildings/Facilities that Would Require Relocation	15
Table 5	Visible Plume Length Frequency Summary – Percent	33
Table 6	Plume Heights – Centerline Height Percent by Direction	34
Table 7	Summary of Thermal Plume Analysis	41
Table 8	Projected Direct Adverse Environmental Impacts of DCPP Retro	44
Table 9	Required Construction and Operation Permits & Licenses	47
Table 10	Cost Estimate Summary	53
Table 11	Major Equipment Procurement Cost	56

DCPP Cooling Tower Feasibility Study

Table of Contents (continued)

Figures

Figure 1	Diablo Canyon Site	6
Figure 2	Topographic Map of Site	7
Figure 3	Cooling Tower Location	8
Figure 4	50,000 Sq. Ft. Warehouse that Would Require Demolition	9
Figure 5	Cross Section Showing Required Excavation	9
Figure 6	Proposed Circulating Water Pump Pit (SK-C-8)	10
Figure 7	Decrease in Generator Output (per Unit)	14
Figure 8	Displaced Facilities	17
Figure 9	Revised Site Layout	17
Figure 10	Existing Circulating Water Conduits	19
Figure 11	Original Circulating Water Tunnel Excavation & Construction	19
Figure 12	Existing Underground Utilities West of Turbine Building	20
Figure 13	Cooling Tower Plume (Looking North)	36
Figure 14	Cooling Tower Plume (Looking Southeast)	36
Figure 15	Plumes from Nuclear Power Plant Cooling Towers	37
Figure 16	Hrs/Day that Blowdown Temp Would Exceed Discharge Limit	41
Figure 17	Conceptual Installation and Plume – Perspective From Ocean	57

Sketches

Circulating Water System Flow Diagram	SK-M-1
Auxiliary Water Systems Flow Diagram	SK-M-2
Auxiliary Water System Arrangement	SK-M-3
Sketch of Blowdown Diffuser Lines	SK-M-4
Cooling Tower Retrofit Electrical Single Line	SK-E-1
Electrical System Oneline for CT Auxiliaries	SK-E-2
Topo Layout of Cooling Towers	SK-C-1
Cooling Tower Profile Existing Ground Elevation	SK-C-2
Cooling Tower Cross Section	SK-C-3
Cooling Tower Basin Layout-1	SK-C-4
Cooling Tower Basin Layout-2	SK-C-5
Cooling Tower Basin Details	SK-C-6
Pump Pit Plan	SK-C-7
Pump Pit Section	SK-C-8
Pump Pit Walls	SK-C-9
Cooling Tower Schematic Layout	SK-C-10
Cooling Tower Layout & Access Road Relocation	SK-C-11
Cooling Tower Circulating Water Piping Layout	SK-C-12
Cooling Tower Concrete Pipe Cross Section-1	SK-C-13
Cooling Tower Concrete Pipe Cross Section-2	SK-C-14
Cooling Tower Concrete Tunnel Layout	SK-C-15
Cooling Tower Concrete Tunnel Layout Sect A-A	SK-C-16

DCPP Cooling Tower Feasibility Study

Table of Contents (continued)

Sketches (continued)

Arrangement of Underground 13.8 kV Conduit Run	SK-C-17
Before Proposed Control Board Changes	SK-J-1
After Proposed Control Board Changes	SK-J-2
DCPP Cooling Tower Control System Conceptual Block Diagram	SK-J-3
Preliminary Triconex I/O Point Count	SK-J-4
Preliminary Bently Nevada I/O Point Count	SK-J-5

Appendices

A-1 Equipment Cost Summary
A-2 Equipment List
A-3 Pre-Procurement Design Estimate
A-4 Design Change Package Estimate
A-5 Vendor Pump Quotes
A-6 I&C Detailed Cost Estimate
A-7 Plume Characteristics of Proposed Cooling Towers at DCPP
A-8 Civil Quantities Summary
A-9 Electrical Cable Tray & Conduit Estimate
A-10 Fuel Consumption Summary
A-11 Project Cost Estimate
A-12 Conceptual Schedule
A-13 Power Plant Systems Effluent Concerns

DCPP Cooling Tower Feasibility Study

I. Executive Summary

1. Overview

In response to the 2008 Tetra Tech Inc. cooling tower feasibility assessment performed for the California Ocean Protection Council, PG&E engaged Enercon Services Inc. (Enercon) to prepare a more detailed, site-specific assessment of the feasibility of cooling towers at the Diablo Canyon site. This assessment builds upon earlier work, including the 2003 study by Burns Engineering, and provides a further, more detailed analysis of the feasibility of a cooling tower retrofit. There is no precedent for mechanical draft cooling towers using saltwater makeup at a nuclear facility, and no precedent for a retrofit of the magnitude necessary at Diablo Canyon. Enercon concludes that any retrofit at Diablo Canyon is a highly speculative project with likely insurmountable permitting obstacles, substantial engineering challenges, significant adverse environmental impacts, costs exceeding \$4-billion dollars, and uncertainty regarding the Power Plant's post-retrofit operating capacity factors. Further, plant downtime, reduction of average net electrical output, and a potential for ongoing reduced capacity factors would together cause a significant loss in generation, and would greatly undermine the State's ability to meet its Green House Gas (GHG) emissions reduction goals under California Assembly Bill AB 32.

2. Design and Construction Concerns

Enercon concludes, as prior reports have found, that only mechanical draft cooling towers are remotely feasible at the site. Dry cooling is not feasible due to limited space availability, and natural draft towers are not suitable for the site given space and seismic concerns. Furthermore, due to limited space, mechanical draft towers could only be non-plume abated. The conceptual layout includes four tower arrays – each 140 feet by 620 feet, with two rows of ten cells each. Key design and construction issues include:

- Demolition and relocation of over 170,000 square feet of existing structures, parking for 1,000 vehicles, and the Independent Spent Fuel Storage Installation (ISFSI) storage cask haul road.
- Excavation of over 2 million cubic yards of soil and rock.
- 250,000 diesel truck round trips to haul construction materials and excavation spoils.
- Modification of major existing systems including the main condensers, service cooling water heat exchangers, and electrical systems.
- Extremely difficult tie-in process given existing underground facilities to the west and south of the power plant.

- Construction of an offshore diffusers system for the discharge of a minimum 72-million gallons per day of high salinity cooling tower blowdown.
- Approximately 3-3/4 year construction timeframe, with a minimum of 17 months dual-unit downtime.
- An average of over 3,000 workers, requiring 7.4-million miles of bus trips.

3. Nuclear Safety Concerns

Enercon identified several significant issues that will likely require NRC review and approval of License Amendment Requests (LARs) in order to ensure acceptable safety levels during construction, as well as post retrofit operation. Further analysis of these issues is required to make determinations regarding potential conflicts with nuclear safety requirements. Key issues include:

- Increased flood risk to safety-related systems from cooling tower water.
- Accelerated aging of plant equipment and an increase in possible plant trips due to salt deposition.
- Interruption of the safety-required Auxiliary Saltwater (ASW) system during construction.
- Increased potential loss of offsite power.
- Rerouting of existing approved ISFSI haul road.
- Increased risk of interruption to the fire protection system during construction.
- Security concerns related to the opening of the protected area boundaries during construction.

4. Environmental Impact and Permitting Concerns

The installation and operation of cooling towers raises significant adverse environmental impacts concerns and poses substantial, likely insurmountable, permitting obstacles. Key issues identified include:

- PM₁₀ emissions likely can not be permitted by the San Luis Obispo County Air Pollution Control District (APCD).
- Salt deposition of at least 7,500 tons per year would impact plant equipment, adjacent agricultural lands, and terrestrial habitat.
- The vapor plume from tower operations would be over 2,460 feet high 35% of the year. Although low visibility conditions may obscure the plumes, and many plumes large enough to be visible are likely to occur at night, meteorological conditions conducive to plume visibility are predicted to occur within 1 hour of sunrise or sunset on the order of 45 times per year for Avila Beach, and 300 times per year for San Luis Obispo.
- Fossil-fueled replacement power for the minimum 17 month dual-unit downtime will result in the emission of roughly 10,000,000-tons of GHGs. Derated capacity and additional auxiliary power requirements for cooling tower operations total an

average of approximately 55 MW, enough to supply power for approximately 42,000 California homes. Long term negative impacts on GHG emissions of roughly 180,000-tons per year would also result.

- Construction of a diffuser system in Patton Cove south of the power plant will directly disrupt approximately a half-acre of pristine rocky marine habitat.
- Permits for both construction and operation are required from many government agencies including: The California Coastal Commission, State Lands Commission, Central Coast Regional Water Quality Control Board, San Luis Obispo County (Building and APCD), and the U.S. Army Corps of Engineers. It is highly unlikely that all the necessary permits can be obtained.

5. Project Schedule and Costs

Enercon's assessment is that prior order-of-magnitude estimates grossly understate the cost of a cooling tower retrofit. A more detailed evaluation of project scope, design and engineering, and required construction results in the following regarding costs and schedule:

- The overall duration for construction would be approximately 3-3/4 years. The plant shutdown during the construction period would be at least 17 months:
 - Extensive excavation west of the Turbine Building in an area congested with both safety related and nonsafety related systems, piping and conduits.
 - Significant condenser modifications.
 - Need to assure continued operation of the safety related ASW system to provide cooling to the spent fuel pools even during shutdown.
 - Extensive relocation of existing systems and facilities.
 - Massive excavation for cooling tower installation.
- Total initial project costs are estimated at \$4.5 billion (2008 Dollars) and would result in an estimated Utility customer rate increase of roughly 10%:
 - Capital costs estimated at \$2.7 billion.
 - Cost of replacement power for the minimum 17 month downtime is estimated at \$1.8 billion.
 - Increased decommissioning costs total \$67 million.
- Additional on-going costs total \$39 million annually:
 - Cooling tower operations and related maintenance is estimated at \$7.4 million per year.
 - Replacement Power for derated capacity and cooling tower operations totals \$31.6 million per year.

Ongoing costs assume that the plant would be capable of continuing to produce power at roughly current levels / capacity factors. If plant operational efficiency decreases, and net power production is reduced more than the 55 MW expected, electric rates will likely increase even more to cover the purchase of additional replacement power.

**Issues that Would Seriously Threaten the Feasibility of a
DCPP Cooling Tower Retrofit Project**

- Significant Permitting Obstacles.
- Significant Adverse Environmental Effects.
- Significant Nuclear Safety/Licensing Obstacles.
- 17 Month Minimum 2-Unit Plant Shutdown.
- Severe Shortage of Suitable Land Available For Cooling Towers.
- Substantial Excavation.
- Demolition and Relocation of Numerous Facilities.
- Initial Costs Estimated at 4.5 Billion Dollars.
- Total Annual Salt Deposition Exceeding 7,500 Tons.
- Plumes Often Visible From San Luis Obispo and Avila Beach.
- Greatest Loss in Plant Electric Output (nearly 70 MW per Unit) Would Occur at Times of Peak Summer Demand.

Table 1: Issues that Would Threaten the Feasibility of the Project

II. Background and Introduction

Diablo Canyon Power Plant (DCPP) could be subject to a requirement to retrofit the existing once-through cooling system to closed-cycle cooling. Ongoing development of Federal Clean Water Act Section 316(b) regulations regarding aquatic organism Impingement and Entrainment (I&E) and a California Specific Policy for 316(b) rule implementation may require all coastal power plants to reduce Marine I&E to levels commensurate with a closed-cycle cooling system. Previous conceptual analyses of retrofitting DCPP to closed-cycle cooling have been performed by Tetra Tech Inc. (2002, 2008) and Burns Engineering (2003). These studies were limited in scope, and do not provide detailed analysis regarding existing plant operating system and site issues that influence the feasibility of such a project, and the engineering and construction challenges that would be posed by implementation of a retrofit. At the request of PG&E, Enercon Services developed the following study to expand on the previous studies, and further develop the scope, site specific feasibility, projected costs, and a conceptual implementation schedule associated with retrofitting DCPP to closed-cycle cooling.

Enercon developed a more detailed technical conceptual design of the cooling tower retrofit than was done in the previous Tetra Tech and Burns studies, including initial sizing of the equipment, electrical single line development, earthwork and concrete quantity estimation, site/equipment layout considerations, and identification of significant technical, permitting, and nuclear licensing obstacles. Cost estimates for procurement of the major mechanical and electrical equipment have been obtained from equipment suppliers. The Engineering cost estimates for the project are based on years of industry

and Diablo Canyon specific experience. Enercon worked with PG&E and Cannon Associates in developing the construction cost estimate and project conceptual schedule.

Enercon Services, Inc., founded in 1983, is an engineering, environmental, technical and management services firm with a wealth of engineering design and project management experience in the nuclear power industry, including extensive design change experience at Diablo Canyon, as well as specific involvement in studies for retrofitting cooling towers at existing power plants.

Cannon Associates, established in 1976, is a multidisciplinary consulting firm composed of civil, structural, mechanical engineers and environmental and land use planners with expertise in construction management. Cannon performed civil engineering for the Diablo Canyon ISFSI, and coordinated with Granite Construction Inc. for the ISFSI construction.

III. Conceptual Design Overview

1. Location of Cooling Towers


Perhaps the most challenging aspect of this study has been selection of a suitable location for the cooling towers. There is a severe shortage of suitable land available for cooling towers at the plant due to its location on a small marine terrace sandwiched between the shoreline cliffs and the adjacent steep landslide-prone hillsides. Every potential location for the cooling towers results in significant disadvantages or insurmountable obstacles. Enercon concludes that mechanical draft cooling towers utilizing seawater as makeup are the only potential option. Enercon further concludes that the only viable mechanical draft cooling towers would consist of nonplume-abated rectangular bank cooling towers. Plume abated cooling towers cannot be installed in any workable configuration at the facility due to size/topographic constraints.

Ideally, from a piping layout viewpoint, it would be desirable to place the Unit 1 cooling towers to the northwest of the power block, and the Unit 2 cooling towers to the southeast of the power block. However, the area north of the plant is unavailable for several reasons including its classification as a sensitive archeological site incorporating an extensive Native American (Central Coast Chumash) ancestral burial ground. The Diablo Creek and associated established riparian habitat is also located between the existing power plant and all northern areas. The creek environment would have to be extensively disrupted and developed to accommodate substantial northward construction for any plant systems. Additionally, such a location would be undesirable from a salt drift viewpoint, since prevailing winds from the northwest would maximize the salt drift on the plant and the associated 500 kV and 230 kV transmission lines.



Figure 1 – Diablo Canyon Site

Consideration was given to locating the cooling towers alongside the entrance road south of the plant. This has proved unworkable due to the steep terrain of the surrounding hills which would require substantial excavation and retaining wall construction. Additionally, this area is fairly narrow, and placing the cooling towers too close to the ocean is undesirable due to the instability of the soil and the potential for future landslides. The great distance of the cooling towers at this location from the power block would also mean much greater frictional losses in pumping, driving up power requirements. Although locating the cooling towers in this area would have the least impact on existing facilities, it has been ruled out due to the reasons cited above.




**Figure 2 – Topographic Map of Site
Showing Steep Terrain and Limited Area for Cooling Towers**

Other areas for the cooling towers considered were in the vicinity of Warehouse “B” and parking lot #1 as well as to the east of the plant. Again, the steep hillsides to the east and unstable soils to the west ruled out these areas. Another disadvantage of a site east of the plant would be to increase the salt buildup on the transmission lines and switchyard. Additionally, locating the cooling towers at a height significantly higher than the elevation of the condensers raises the condenser waterbox operating pressure due to the higher static head from the cooling tower risers, as well as increasing the nuclear safety related flooding hazard in the turbine building due to the cooling tower supply lines draining backwards into the building via a failed waterbox.

The only possible remaining site for the cooling towers was determined to be in the area including the main warehouse, cold machine shop, hazardous materials building, fire station, parking lots 6, 7 and 8, engineering office buildings 201 and 202, and a dozen smaller buildings (Figure 3). All of these facilities would need to be relocated with great impact on the administration and operation of the facility. The Independent Spent Fuel Storage Installation (ISFSI) haul road would require rerouting due to the excavation requirements for the cooling towers, sending the proposed route through the security firing range, necessitating its relocation as well. All four cooling tower arrays would be placed at an elevation of approximately 85’ to 90’, requiring a significant excavation effort as described elsewhere in this report. It is critical to place the cooling tower basins at these elevations in order to minimize the nuclear safety related threat of flooding, as well as to reduce overall pumping costs and excessive pressures in the condenser waterboxes.

As in the previous studies, a natural draft design for the cooling towers was eliminated from consideration because of seismic and other concerns. Likewise, circular arrangement mechanical draft cooling towers were eliminated from consideration due to the lack of sufficient suitable land due to the narrow site layout.



**Figure 3 – Cooling Tower Location
(Displaced Facilities in Red) (SK-C-11 Rev. 0)**

Based on the above evaluation, and discussions with a cooling tower supplier as to the best size, number, and configuration of cells to fit the available space, the conceptual design for each unit consists of two rectilinear arrays of mechanical draft cooling towers, 20 cells per array, arranged in two rows (side-by-side) of 10 cells each. This configuration is called “back-to-back”, having hot water risers coming from the outboard side of each cell, and air coming in from the outboard side of each cell. This configuration is less desirable than a circular arrangement where cooling air can enter from inside and outside the cells, but such a configuration was ruled out at DCPD because of the lack of suitable land. The 2-Unit DCPD configuration would thus consist of 4 rectangular collections of 20 cells, having a footprint of 140’ by 620’ each. For each unit, a pump suction pit for the circulating water pumps would be located at the north end of the two 20 cell assemblies to take suction from the cooling tower basins (Figure 6). The cooling towers proposed are based on an approach of 17°F, with a cost estimate provided by Marley, a well known supplier.



Figure 4 – 50,000 Sq Ft Warehouse that Would Require Demolition and Relocation




Figure 5 – Cross Section Showing Required Excavation

2. Conceptual Design Summary

Each unit would be retrofitted with two nonplume-abated rectangular configured mechanical draft cooling tower arrays. Each cooling tower would be arranged in a back-to-back array, 2 cells wide by 10 cells long.

Each operating unit's two existing 50% capacity circulating water pumps would be replaced with five 25% capacity circulating water pumps (10 total for 2 units) located in a new pump pit adjacent to the cooling towers. The use of five 25% capacity circulating water pumps (4 plus 1 installed spare) is a typical and commercially prudent and cost effective configuration that effectively eliminates downtime due to pump/motor failure or maintenance, and eliminates plant load reductions in the event of a single pump trip. The pumps would discharge into two new 10 ft square buried conduits carrying the cooling water to the west side of the turbine building where they would transition into the existing conduits on the way to the main condensers (reference SK-M-1 and SK-C-12). Likewise, the cooling flow exiting the condensers would utilize the existing conduits

until it reaches the west side of turbine building where it would transition into the proposed 10 ft square conduits returning to the cooling towers.




Figure 6 – Proposed Circulating Water Pump Pit (SK-C-8)

Three new 50% capacity makeup water pumps per unit (6 total for 2 units) would be installed in the intake structure near the present location of the existing circulating water pumps and intake coolers (which would be removed should the plant be retrofitted with cooling towers). The pumps would discharge into a 48” paralined steel common discharge header which would be routed up through one of the to be abandoned concrete tunnels going to the turbine building, and on to the two circulating water conduits going to the main condensers.

The present Service Cooling Water (SCW) heat exchangers are cooled by the existing once-through circulating water. As discussed below, the warmer cooling water from the cooling towers would be too warm, necessitating replacement of the two SCW heat exchangers per unit, and many of the components cooled by the SCW system. To avoid the need for this replacement and the associated significant additional costs, the SCW heat exchangers would be cooled by their own once-through cooling system. Three new 50% SCW seawater supply pumps per unit, located at the existing intake structure, would provide this cooling water for the system heat exchangers. In addition to providing an installed spare, the third 50% capacity pump would be operated to supply dilution flow for the cooling tower blowdown when needed during times of high wet bulb temperature to meet the anticipated facility effluent thermal limit of 20 F° above ambient.

The present Condensate Cooler in each unit is cooled by a side stream off the once-through circulating water, and is used when needed to reduce the main condensate temperature and thereby provide additional cooling for the main generator hydrogen cooler and stator cooler. The need for this “extra” cooling would increase since the condenser backpressure, and thus the condensate temperature, would increase with the use of closed loop cooling towers. The warmer water from the cooling towers would be insufficient to provide the required cooling. Therefore, a side stream off the proposed SCW seawater supply pumps would be used to cool the Condensate Coolers.

The present once-through cooling for the safety related ASW system would remain a once-through system by necessity, and continue to use existing dedicated intake pumps and ocean water supply. Warmer cooling tower circulating water would be insufficient to provide the necessary cooling required for the existing plant Component Cooling Water (CCW) heat exchangers that are vital equipment in an installed critical nuclear safety system. Retrofit of this plant system to function within acceptable Nuclear Operating License parameters with closed-cycle cooling is infeasible.

Flow From Ocean

Description	Flow (gpm)	
	Existing	Cooling Towers
Condenser Cooling (gpm)	860,000	0
ASW System (gpm)	11,500	11,500
Service Cooling Water HX (gpm)	4,300	4,300
Condensate Cooler (gpm)	n/a	2,000
Cooling Tower Makeup	n/a	37,800
Blowdown Dilution (ΔT Control)	n/a	6,400 *
Seawater Reverse Osmosis System	500	500
Total (gpm)	876,300	62,500
Percent of Existing Flow	-	7.1%

Discharge To Ocean

Description	Flow (gpm)	
	Existing	Cooling Towers
Condenser Cooling (gpm)	860,000	0
ASW System (gpm)	11,500	11,500
Service Cooling Water HX (gpm)	4,300	4,300
Condensate Cooler (gpm)	n/a	2,000
Cooling Tower Blowdown	n/a	25,200
Blowdown Dilution (ΔT Control)	n/a	6,400 *
Seawater Reverse Osmosis System	240	240
Total (gpm)	876,040	49,640
Percent of Existing Flow	-	5.7%

* When needed for blowdown temperature dilution (~ 25% of the time)

Table 2: Projected Average Flow to/from Ocean (per Unit)

Both the SCW system supply and cooling tower makeup seawater lines would require periodic chemical treatment (concentrated chlorination or chlorine/bromine treatment) to control pipeline biofouling. The ASW inlet flow is required to be continuously chlorinated to protect the vital function of the system. It would be necessary to continuously dechlorinate the effluent of the ASW system, and most likely dechlorinate

SCW system effluent during chemical treatment, since the present ability to dilute these streams prior to discharge using the high volume main condenser once-through cooling water flow would no longer be possible.

Each unit would require a steady state cooling tower circulating system blowdown flow of approximately 25,200 gpm when running at full load. The concentration of the circulating water would be 1.5x normal seawater. Thus the blowdown would have a concentration of about 52,500 ppm total dissolved solids (TDS) given an average seawater concentration of 35,000 ppm TDS. The blowdown stream is toxic to marine life due to the higher salt concentration. Therefore, it would either have to be rapidly mixed with the ambient seawater as it is introduced into the ocean, or it would have to be treated prior to discharge to reduce its TDS concentration back to that of seawater. As discussed elsewhere, treatment of this quantity of blowdown is not practical. It has been determined that the most practical means of disposal for cooling tower blowdown is discharge to an array of diffuser nozzles placed on the ocean floor offshore of the facility. The proposed location for a diffuser system is south of the existing power plant near Patton Cove. Routing high salinity cooling tower blowdown to the existing plant outfall located on the shoreline at Diablo Cove cannot be permitted, nor is it an optimal configuration for efficient cooling tower operation.

The tube side of the main condensers (waterboxes) are designed for 25 psig. Due to the height and location of the cooling towers, the new pressure in the waterboxes would be on the order of 45 psig, necessitating strengthening or replacement of the waterboxes. In addition, the existing rolled tube-to-tubesheet joints in each condenser are presently susceptible to saltwater leaks. Leaks into the condensate system can lead to damage of the safety related steam generators and/or unplanned plant shutdowns. An increase in condenser waterbox pressure would significantly increase leakage and associated chloride intrusion into the secondary system. Therefore, the condenser waterbox and tubes would be replaced with modular welded tube-to-tubesheet units.

Mechanical draft cooling towers have considerably more power requirements than the existing once-through cooling system. This additional power is primarily for the mechanical draft fans required for the tower cells. At 300 horsepower (hp) each, about 12 MVA per unit are needed at an assumed power factor of 0.88. Other new power required for the cooling tower installation would be the makeup water pumps drawing about 2,700 kVA per unit. Also, each unit would require a seawater supply to the SCW system, requiring another 170 kVA. The new circulating water pumps would have higher head requirements than the existing circulating water pumps, resulting in an increase power requirement of 2.5 MVA. The various existing auxiliary transformers at Diablo Canyon do not have sufficient capacity to provide the additional loads to power the cooling tower fans and other auxiliaries. Therefore, a new bay with circuit breakers, disconnects, and transformers would be added at the 500 kV switchyard with additional transformers and other electrical equipment added downstream to serve the new loads.

The existing sewage treatment system would most likely need to be upgraded to meet more stringent effluent limits. The high volume circulating water system would no

longer be available to dilute the treated sewage effluent stream. A new packaged system would be sized for 50,000-gpd, and would consist of a flow equalization tank, aeration tank, clarifier, clearwell, pressurized multimedia filtration system, anoxic tank for nitrate reduction, and a UV light system for disinfection. The effluent could be treated by the proposed system to have 10 mg/L of biological oxygen demand (BOD), 10 mg/L of total suspended solids (TSS), 5 mg/L of total nitrogen, and 1 mg/L of ammonia. The Seawater Reverse Osmosis Unit (SWRO) brine reject and filter backwash effluent would be directed to the tower blowdown diffuser system due to high salinity.

3. Reduction in Electrical Output with Cooling Towers

Replacing the once-through cooling system using saltwater cooling towers would result in a higher backpressure in the main condensers because the cooling water temperature entering the condensers would be greater than the present once-through ocean water temperature. For purposes of this study, hourly wet bulb temperatures for the years 2003 through 2007 were taken from the National Weather Service (NWS) Station at the San Luis Obispo (SLO) Airport. This data was considered the most accurate of available local data, and therefore most appropriate for use in this study. Accurate Diablo Canyon site specific data for humidity or wet bulb temperature was not available. The airport weather station data gives lower wet bulb temperatures (due to drier inland conditions) than would actually be experienced at the Diablo Canyon site. The lower wet bulb values cause a reduced estimate of plume size, and a lower prediction of circulating water temperatures. Thus the conservative bias introduced by use of SLO rather than site specific coastline data results in smaller predicted plumes, and a decrease in the predicted loss of plant electrical output.

The once-through ocean cooling water as measured at the intake structure has an average inlet temperature of 53.9°F, with a standard deviation of 2.5°F. The average wet bulb temperature is 52.0°F, with a standard deviation of 6.8°F. With the cooling tower approach of 17°F, it is seen that with cooling towers in service the circulating water entering the condensers would be 69.0°F, on average. When compared with the once-through cooling water inlet temperature of 53.9°F, this amounts to an increase of 15.1°F on average for condenser inlet cooling water temperatures when using cooling towers.

The turbine exhaust pressure was determined using standard Heat Exchange Institute (HEI) condenser backpressure calculation methodology utilizing the DCPD turbine performance test data to determine the associated cleanliness factor. The DCPD Turbine (Alstom) Thermal Kit backpressure correction curve was then used to determine the effect on generator electrical output. (Note: The original Westinghouse low pressure turbine rotors were replaced with Alstom rotors in 2005 & 2006.)




Figure 7 – Decrease in Generator Output (per Unit)

The average yearly loss in generator output due to the proposed cooling tower retrofit project (including an optimized condenser) based on a 90% capacity factor (both pre and assumed post cooling tower retrofit) would be approximately 204,000 Megawatt Hours (MWhr) for Units 1 & 2 combined. When considering the additional loads required for the cooling tower fans and pumps, the total decrease in plant electrical output would be approximately 451,000 MWhr/yr. The average decrease in generator output with retrofit cooling towers and an optimized condenser would be 12.9 MW per unit (25.8 MW for 2-units). As can be seen in Figure 7, the change in Megawatts would vary from an increase of approximately 21 MW per unit to a loss of approximately 69 MW per unit depending on the corresponding wet bulb and ocean water temperatures. The gain in MW during certain temperature conditions is due to the proposed replacement of the condenser tube bundles with new optimized bundles. Unfortunately, as can be seen in Figure 7, the greatest loss in generator output would be at the time of peak summer electric demand.

Description	MW/Unit	MW/2-Units	MWhr/year*
Circulating Water Pumps ΔMW	2.2	4.4	36,810
Makeup Water Pumps	2.4	4.8	40,157
Cooling Tower Fans	10.0	20.0	167,320
SCW Seawater Supply Pumps	0.2	0.4	3,346
Average Lost Generation	12.9	25.8	203,547
Net Loss in Plant Output	27.7	55.4	451,180

* 2-Units - Based on a 90% Capacity Factor & 25-Day Refueling Outages.

Table 3: Reduction in Plant Electrical Output

Without optimized condensers, the average 2-unit decrease in generator output with retrofit cooling towers would be 59.8 MW (versus 25.8 MW with optimized condensers) with an average yearly generator loss of approximately 471,700 MWhr, and a net loss in

plant output of 719,000 MWhr (versus 451,200 MWhr with installation of new optimized condensers).

For purposes of this study and associated cost estimates, it has been assumed that the plant capacity factor after the cooling tower installation would be identical to the pre-cooling tower capacity factor (approximately 90% including refueling outages). In reality, the capacity factor would likely be reduced due to the increased complexity of a saltwater tower cooling system, the corrosive effects on plant equipment due to salt deposition from the tower drift, and the potential for tripping of the 500 kV lines due to flash-over from excessive salt deposition.

IV. Construction and Engineering Assessment

1. Relocation and Excavation

A. Relocation of Existing Facilities

In order to adequately site the cooling towers, many existing facilities would need to be relocated, either onsite to a less convenient location or offsite to the surrounding community. These include parking lots 6, 7 and 8, with some 1,000 parking spots, and the main warehouse building. The cold machine shop (CMS) is presently located inside the security protected area boundary in close proximity to the power block which provides significant convenience. With the cold machine shop relocated outside of the protected area boundary, this convenience and efficiency would be lost. An even greater loss of convenience and efficiency would apply to the main warehouse which would be relocated 50% onsite but outside of the protected area and 50% offsite. Facilities such as the security firing range, design engineering offices, record storage, etc., would have to be relocated entirely offsite adding considerable cost and inconvenience. The following table is a list of buildings and facilities that would require relocation and/or demolition.

Buildings/Facilities that Would Require Relocation and/or Demolition

Blg #	Description	Impact	Relocate Onsite or Offsite?	Existing Sq Ft	Required Sq Ft	
					Onsite	Offsite
115	Main Warehouse	Demo & Relocate	Part Onsite & Part Offsite	50,000	25,000	25,000
116	Cold Machine Shop (CMS)	Demo & Relocate	Onsite	15,000	15,000	0
506	Radwaste Offices	Demo & Relocate	Onsite	1,000	1,000	0
508	(near cold machine shop)	Demo & Relocate	Onsite	1,000	1,000	0
127	Haz Materials Warehouse	Demo & Relocate	Onsite	4,000	4,000	0
201	Design Engineering Offices	Demo & Relocate	Part Onsite & Part Offsite	12,000	6,000	6,000
202	Design Engineering Offices	Demo & Relocate	Part Onsite & Part Offsite	4,000	2,000	2,000
220	Design Engineering Offices	Demo & Relocate	Part Onsite & Part Offsite	1,000	500	500

Buildings/Facilities that Would Require Relocation and/or Demolition (cont.)

Blg #	Description	Impact	Relocate Onsite or Offsite?	Existing Sq Ft	Required Sq Ft	
					Onsite	Offsite
248	Outage Human Resources	Demo & Relocate	Part Onsite & Part Offsite	1,000	500	500
250	Project Offices	Demo & Relocate	Part Onsite & Part Offsite	3,000	1,500	1,500
252	Project Offices	Demo & Relocate	Part Onsite & Part Offsite	3,000	1,500	1,500
217	Restrooms	Demo & Relocate	Onsite	500	500	0
253	Offices	Demo & Relocate	Part Onsite & Part Offsite	500	250	250
260	Security/Records Storage	Demo & Relocate	Part Onsite & Part Offsite	2,000	1,000	1,000
261	Records Storage/Offices	Demo & Relocate	Part Onsite & Part Offsite	2,000	1,000	1,000
262	Telecom/Project Offices	Demo & Relocate	Part Onsite & Part Offsite	2,000	1,000	1,000
263	Training Facility	Demo & Relocate	Part Onsite & Part Offsite	2,000	1,000	1,000
264	Building Services	Demo & Relocate	Part Onsite & Part Offsite	2,000	1,000	1,000
251	Fire House	Demo & Relocate	Onsite	3,000	3,000	0
254	Storage Facility	Demo	Neither - Eliminate	8,000	0	0
255	Storage Facility	Demo	Neither - Eliminate	8,000	0	0
114	Firing Range	Demo & Relocate	Offsite	3,000	0	3,000
114A	Security Training	Demo & Relocate	Offsite	500	0	500
114B	Security Training	Demo & Relocate	Offsite	500	0	500
113	Warehouse B	Demo	Neither - Eliminate	18,000	0	0
120	Hazardous Waste	Demo & Relocate	Onsite	3,000	3,000	0
125	Fire Water Tank/Pump House	Demo & Relocate	Onsite	2,000	2,000	0
124	Sewage Treatment Plant	Demo & Relocate	Onsite	1,000	2,000	-
165	Biology Offices/Career Ctr	Demo	Neither - Eliminate	2,000	0	0
160	Biology Laboratory	Demo	Neither - Eliminate	4,000	0	0
110	Blast and Paint Facility	Demo	Neither *	3,000	0	0
122	GC Fab Shop	Demo	Neither *	8,000	0	0
n/a	Vehicle Inspection Station	Demo & Relocate	Onsite	1,000	1,000	0
n/a	Parking Garage I	New	Onsite	-	180,000	-
n/a	Parking Garage II	New	Onsite	-	320,000	-
Total Square Feet				171,000	574,750	46,250

* The Blast & Paint Facility and the GC Fab Shop would be incorporated in the new CMS.

Table 4: Buildings/Facilities that Would Require Relocation and/or Demolition




Figure 8 – Displaced Facilities




Figure 9 – Revised Site Layout

B. Relocation of ISFSI Haul Road

Location of the cooling towers would make it necessary to reroute the existing ISFSI haul road and re-engineer the subgrade for the anticipated loads. In particular, the new road would need to pass to the west of the cooling towers, just east of the Simulator Building and the Maintenance Training Building. Beneath the road would be the new circulating water concrete tunnels, each having an internal cross section of approximately 10' x 10', with reinforced concrete walls 3 feet thick. This dimension was selected in order to be able to fit all 8 tunnels (4 supply and 4 return) for both units alongside each other as they approach the western side of the turbine building. Because of the location of the cooling towers with respect to the condensers, the tunnels would have to cross over each other in certain areas, meaning deeper excavation. The tunnels would have to be engineered for the excessive loads anticipated on the road above them, not only due to the ISFSI casks but also due to normal operational/maintenance loads, as well as outage-related loads.

The revised ISFSI haul road would need to avoid the zones where the potential for landslides will exist for 75 years after the installation. This setback requirement originates from the California Coastal Commission, and is necessary in order to obtain a building permit from San Luis Obispo County. The potential for future landslides exists at the location of the existing access road near Warehouse "B" and parking lot #1. California Coastal Commission rules do not allow for reinforcement of the littoral area around landslides in order to reduce the likelihood of future landslides. These points would need to be taken into account when finalizing the new ISFSI haul road.

C. Civil Site Work

Siting the cooling towers to the southeast of the turbine building would necessitate massive excavation of the hillside to the east of the cooling towers. All four separate tower basins would be excavated to a base elevation of 85' to 90'. The excavations would leave slopes of 2 to 1 (tangent = 0.5). Although choosing a higher slope would reduce the amount of excavated fill to be removed, the higher slope would be hazardous for personnel. On the west side of the cooling towers some excavation and relocation work for the access/ISFSI haul road would be necessary (Reference Sketches SK-C-1, 2, & 3).

The volume of excavated soil and rock has been estimated at 2,011,000 bank cubic yards. This material would need to be trucked to an offsite disposal facility, requiring roughly 200,000 truckloads. The total amount of soil and rock includes an estimate that 52% is rock, based on review of the geological information in the ISFSI Final Safety Analysis Report (FSAR) Update.

2. Constructability of Interconnecting Piping

Figure 10 schematically shows the existing circulating water conduits to the main condensers. Connections would have to be made to all the supply and return conduits including those coming from the north end of the Unit 1 condensers. Review of detailed site drawings clearly shows that the excavations and routing required for these large diameter connections would quickly become an extremely complex engineering and construction task.




Figure 10 – Existing Circulating Water Conduits




Figure 11 – Original Circulating Water Tunnel Excavation & Construction

The limited area for this intertie in front of the turbine building is extremely congested with both safety related and nonsafety related systems, piping, and conduits as shown in Figure 12.




Figure 12 – Existing Underground Utilities West of Turbine Building

Constructing the large diameter concrete tunnels with the associated excavation in this area would result in the disruption of numerous systems that would have to be relocated to accomplish this construction. The safety related ASW system bisects this area, and is required to remain in operation even with both units shut down. The difficulty, time, and cost associated with these excavations, tie-ins, and system interferences are immense. The development of the details of this aspect of the retrofit would likewise be an immense task.

Those utilities which are buried in the vicinity of the proposed tunnel excavations, which would require temporary protection and/or relocation during construction and/or final relocation upon construction completion, include but are not limited to:

- | | |
|----------------------------------|------------------------------------|
| Seawater Reverse Osmosis Lines | I&C Conduits & Pull Boxes |
| Telephone Communications | Aux Saltwater Vacuum Breaker Lines |
| Microwave Communications | Building Roof Drains |
| Security Systems (undefined) | Storm Drains |
| Potable Water Piping | Yard Fire Loop & Branch Lines |
| Sewage Lines & Septic Tanks | Instrument Air & Service Air |
| Electrical Conduits & Pull Boxes | Outdoor Lighting |
| Fiber Optic Cables | Electrical Grounding Cable |
| 12 kV Power Cables | Auxiliary Saltwater Lines (ASW) |

3. Modifications to Existing Systems and Required New Systems

A. Condenser Modifications

The present condenser has a history of tube leaks which would be made worse by significantly increasing the waterbox pressures. The present condensers have 2 to 3% of their tubes plugged due to leakage. Increased tube leaks would have an adverse impact on the operation of the condensate polishers and potentially an adverse impact on transient feedwater and main steam chemistry. Secondary side water chemistry is an important aspect of nuclear safety due to potential degradation of steam generators and main turbines (missile generation) and potential plant trips. Plant trips due to chemistry excursions unnecessarily exercise plant safety systems. Transient departures from water and steam chemistry limits would, as a minimum, impact the steam generator and main turbine warranties.

The tube side of the existing main condensers (tubes, waterboxes, and transition pieces) is designed for 25 psig. Due to the height and location of the cooling towers, the new pressure in the waterbox would be on the order of 45 psig, necessitating strengthening or replacement of the waterbox. Additionally, as noted previously in this report, the rolled tube-to-tubesheet joints in the installed condensers are currently susceptible to saltwater leaks into the condensate system (which can lead to damage of the safety related steam generators and/or unplanned unit shutdowns). The increase in condenser waterbox pressure would increase leakage. Because of these current design limitations and the high probability of significantly increased chloride salts intrusion associated with elevated system pressures, the condenser waterboxes and tubes would be replaced by necessity with modular welded tube-to tubesheet units. The transitions from the buried conduits to the waterboxes would also be upgraded to withstand the increase in pressure.

In order to optimize the performance of the new bundles and thereby minimize the lost generation due to hotter inlet cooling water, the proposed tube bundles would be composed of $\frac{3}{4}$ " diameter titanium tubes (compared to the present 1" diameter tubes) resulting in increased total tube surface area.

Installation of the new condenser tube bundles would be a major undertaking. In order to provide access for the new bundles, existing equipment and large structural members would have to be removed and then reinstalled. The lower end of the large transition pieces from the waterboxes to the underground conduits are imbedded in the turbine building floor concrete, necessitating concrete excavation and replacement.

B. Service Cooling Water Seawater Supply

Inside the turbine building the circulating water presently cools not only the main condensers but also the SCW heat exchangers and the condensate cooler for the main generator hydrogen coolers (to maintain generator gas temperature within limits).

The increase of cooling water temperature to 17°F above the highest wet bulb temperatures (as well as the increase in pressure) would necessitate replacement of both the SCW heat exchangers and the condensate cooler for each unit, and many of the components cooled by the SCW system.

The SCW system removes heat from various secondary system components via a closed loop cooling cycle and rejects the heat to the main circulating water system. The closed loop SCW system presently runs with a typical cold end temperature on the order of 79°F (e.g. 54°F on average seawater inlet flow cools the service cooling water to 79°F). Even if the existing heat exchangers were replaced with much larger heat exchangers, it would not be possible to cool the SCW to 79°F using the warmer circulating water from the cooling towers during periods of highest wet bulb temperature.

The heat loads cooled by the SCW system include:

- Main Feed Pumps Turbine Lube Oil Coolers
- Condensate Booster Pumps Lube Oil Coolers
- Generator Exciter
- Fuse Wheel
- Generator Seal Oil Coolers
- Iso-Phase Bus Coolers
- Main Turbine Reservoir Lube Oil Coolers
- Post LOCA Sampling System Room Air Conditioning and Sample Panel Chiller
- Plant Air Compressors 05 and 06 (via the SCW Booster Pumps)
- Reciprocating Air Compressor Jacket Coolers and Aftercoolers
- Air System Air Dryers
- TSC Air Conditioning Units
- Personnel Access Control Room Air Conditioning Unit
- Operations Ready Room Air Conditioning Unit
- Condenser Vacuum Pump Seal Water Heat Exchanger
- Electro-Hydraulic Control Coolers
- Feedwater Sample Cooler 72
- #2 Heater Drain Pump Lube Oil Coolers and Sample Cooler
- Secondary Process Control Room Isothermal Bath Water Chiller

In addition to replacement of the SCW heat exchangers themselves, many of the above components cooled by the system would require modification or replacement due to the higher SCW closed loop circulating cooling water temperatures. To avoid the need for these extensive plant equipment upgrades, the existing SCW heat exchangers would be cooled by their own once-through cooling system. Therefore, for each unit, three new

50% SCW seawater supply pumps (6 total) sized at 3,150 gpm at 86' total differential head (TDH) would be provided. They would draw water from the intake structure and the cooling flow would be routed in new 20" paralined steel pipes up to the turbine building. The new 20" lines must be routed through an already congested area surrounding the main condensers to the SCW heat exchangers located on the east side of the turbine building. A branch to the condensate coolers would be provided even though the equipment is infrequently used at present for either unit. This routing would replace routing which presently consists of short runs from near the main condenser intake lines embedded in concrete below the 85' (ground) level. The new piping would not be embedded in the concrete, and would therefore invariably have a negative impact on operating and maintenance activities in the vicinity.

To minimize biofouling, it would be necessary to chlorinate the SCW seawater supply lines. The sodium hypochlorite injection system used for the existing main circulating water system would be used for this purpose.

C. Main Circulating Water Pumps

The proposed cooling systems new main circulating water pumps would be 25% capacity each, with one installed spare per unit. They would be rated at 215,000 gpm at 110' TDH. The motor size would be 7,600 hp and would operate at 327 rpm. The five pumps would be vertical turbine configuration, arranged in a row, taking suction from the pump pit which is adjacent to the cooling towers. The pumps would discharge into a common 8' diameter paralined steel circular cross section manifold with valves on either side of the middle pump's tee into the manifold. This would allow any 4 of the 5 pumps to be operated. At either end of the manifold, a transition is made into a 10' by 10' square cross section reinforced concrete tunnel. These two tunnels are directed side-by-side and transition into the existing 11'-9" square concrete tunnels which lead to each unit's main condensers. With this configuration, similar to the existing configuration, the plant may be operated at 50% capacity while one side of each main condenser is taken out of service. Unlike the present configuration without a spare, the spare pump would be able to serve either supply tunnel in the event of another pump's failure.

Each pump's capacity of 215,000 gpm would mean a sudden reduction of flow whenever that pump is taken out of service. This could give rise to pressure fluctuations, known as "water hammer", with possible destructive results. Thus, studies of the effects of water hammer would be recommended, in order to mitigate its detrimental effects. Another characteristic of the closed cooling tower loop being considered is the fact that upon shutdown of the circulating water pumps, some water would flow backward from the high points in the condenser waterboxes (elevation of ~104') and the cooling tower hot side distribution piping (elevation ~125') into the cooling tower basin / pump pit. The basin and pit combined capacity would be sized to accommodate this overflow, which would be routed to the ocean through the weirs discharging to the system blowdown lines.

D. Circulating Water System Piping

Piping conforming to Piping Specification “G” would be utilized. This is steel pipe with an internal coating called “paralining”. It has provided excellent service for existing Diablo Canyon seawater applications such as the ASW system, and is suitable for the proposed circulating water system. Concrete coated steel pipe is inferior because of minute cracks in the concrete lining allowing chloride migration to the underlying steel with subsequent destructive corrosion.

Although Specification “G” includes pipe up to a maximum diameter of 24”, the company that provided the pipe in the past, Barber-Webb, has indicated that pipe up to 8’ diameter can be paralined. The coating must be applied under controlled conditions in the factory. This means it would need to be flanged as opposed to welded in the field since the coating cannot be applied reliably in the field. Sections up to 40’ in length can be shipped to the jobsite. Paralined pipe would be used for the makeup water supply, cooling tower blowdown, and the SCW seawater supply. Additionally, the discharge of each of the circulating water pumps would be a paralined 78” diameter steel pipe (Reference Sketches SK-C-12 to 16). The common discharge line that all five pumps connect to would be an 8’ paralined pipe.

For the long sections of buried circulating water conduit to and from the cooling towers, concrete-walled tunnels are specified. Conveying 50% of the total flow, they would be a 10’ by 10’ square cross section with 12” 45° fillets at the corners. The walls would be about 3’ thick with steel reinforcement. This configuration and material of construction is consistent with the existing tunnels, although the existing tunnels are larger, with a cross section of 11’-9”. The new tunnels would have a velocity of 9.8 feet per second (fps) vs. 7.0 fps for the existing tunnels, but the increased pressure drop is tolerable. Having the smaller cross section allows for a more compact arrangement, especially to the west of the turbine building where all 8 tunnels (4 supply and 4 return) would be buried side-by-side. The new tunnels would be built in place in excavations prepared for them. In some areas to the west of the turbine building and to the west of the cooling towers, the tunnels would need to cross underneath each other, requiring extra deep trenching. This configuration cannot be avoided since the proposed cooling towers for both units are on the south side of the plant.

In the area to the west of the turbine building the new tunnels would transition into the existing tunnels. At this interface, a barricade would be constructed in the old tunnels to isolate them from the empty sections coming from the ocean intake structure and going to the discharge structure. These empty tunnels coming up the hill from the intake structure, specifically lines 1-1 and 2-1, would have the 48” makeup water lines and the 20” SCW system lines routed inside them up to an area near the transition point where they would be routed out of the tunnel on to their respective destinations.

E. Makeup Water Supply

New makeup water pumps would be installed in the intake structure near the removed circulating water pumps. Each unit would be furnished with three, 50% capacity makeup water pumps sized at 22,500 gpm at 216' TDH. With two pumps running, a maximum makeup flow of 45,000 gpm can be delivered, providing a margin over the steady-state makeup requirement of 37,800 gpm. The individual pumps would discharge into a 36" paralined steel pipe. The common discharge header for each unit would be a 48" paralined steel pipe. This pipe would be routed through one of the existing concrete tunnels going to the turbine building that would be abandoned if the plant were retrofit with cooling towers. The 48" makeup water line would be taken through the tunnel wall near the junction point where the new 10 ft square concrete tunnels coming from the cooling towers joined the existing tunnels. The makeup water line for each unit would then branch into two 36" paralined steel pipes each going to one of the two main circulating water tunnels leading to the main condensers.

F. Chlorination and Dechlorination of Effluent Streams

As mentioned elsewhere in this report, both the service cooling water supply lines and the makeup water supply lines would be chlorinated to control pipeline marine biofouling. The ASW stream is also continuously chlorinated. It would be necessary to dechlorinate both the ASW and SCW systems downstream of the heat exchangers since the ability to dilute with main condenser flow would no longer be possible.

The existing site dechlorination system utilizes aqueous sodium bisulfite injected into the condenser discharges. This system is currently installed to service only the main condensers periodically, and would require significant modification to service other effluent streams directly, as well as operate on a continuous basis. For a combined flow of 16,000 gpm per unit (ASW and the SCW seawater supply) approximately 61 gallons of commercial bulk sodium bisulfite would be required each day to adequately dechlorinate. This would result in additional annual chemical supply costs of \$150,000. The estimate is based on an initial residual chlorine level target of 1 part per million (ppm) at system heat exchanger inlets.

The blowdown stream could contain residual chlorine, however it would be expected in very low concentrations under most circumstances. Chlorine would be introduced into the main circulating water system under normal operating conditions by the makeup water supply. However, the treated influent would represent only a small percentage of the systems total circulating volume at any given time. System chemical demand, including operation of the cooling towers that would result in extensive exposure of the circulating water to the atmosphere, would likely cause rapid reduction of residual biofouling treatment chemicals. It is not anticipated that routine injection of additional sodium hypochlorite into the cooling tower circulating water would be required because the concentration of salts in the system would be toxic to most common forms of aquatic life.

If excessive organic microfouling of main condenser tube surfaces did occur under certain conditions, periodic oxidant treatment of the cooling tower circulating system may be required. In that event, the blowdown stream could be temporarily isolated until residual chlorine levels reduced below discharge limitations, the entire circulating system could be dechlorinated, or the blowdown flow could be directly dechlorinated. Main condenser circulating system effluents should not otherwise require dechlorination.

4. Electrical System Requirements

A. Electrical Design Features

Mechanical draft cooling towers have considerably more power requirements than the existing once-through cooling system. This additional parasitic power is primarily for the mechanical draft fans required for the cells. At 300 hp each, about 12 MVA per unit are needed at an assumed power factor of 0.88. Other new power required for the cooling tower installation would be the makeup water pumps drawing about 2,700 kVA per unit. Also, each unit would require a seawater supply to the service cooling water system, requiring another 170 kVA.

The new circulating water pumps would replace the existing circulating water pumps which would be abandoned and removed from the intake structure. The new circulating water power requirements are roughly equivalent to the existing requirements but would not be fed from the existing 12 kV buses. Rather, new 13.8 kV power would be brought down from the 500 kV switchyard.

The various existing auxiliary transformers at Diablo Canyon do not have nearly enough margin to provide the additional loads to power the cooling tower fans and other auxiliaries. The most practical and cost effective way to provide the new power requirements has been determined to take power from the outgoing 500 kV transmission lines, one 500 kV line source for Unit 1, the other for Unit 2. A new bay at the 500 kV switchyard would be required to locate each unit's cooling tower transformer (Reference Sketch SK-E-1). The power sent to these transformers would need to be metered in order to make corrections to the power sent out. The voltage would be first reduced from 500 kV to 13.8 kV, with the outgoing 13.8 kV conductors routed down to the cooling tower locations (Reference Sketch SK-C-17). A voltage level of 13.8 kV is selected rather than 12 kV because 13.8 kV is a more standardized high voltage level used in industry. The 500 kV/13.8 kV transformers would be rated at 64 MVA with a power factor of 0.88. At the cooling tower area, the 13.8 kV conductors would be routed to the new circulating water pumps, rated at about 7,600 hp each, five per unit. The other 13.8 kV conductors would be routed to three transformers per unit, each having a rating of 13.8 kV/4 kV, 5.4 MVA capacity. Individual 4 kV buses would be routed from each of the three transformers into an adjoining electrical equipment building where the 4 kV breakers for the 40 cooling tower fan motors would be located. Each unit's cooling tower electrical building would be approximately 16'W x 160'L x 12' H, constructed of protected coating steel, and set atop a concrete foundation.

The new service cooling water supply pumps and makeup water pumps and their transformers and switchgear would be located in the existing intake structure, placed immediately on the upstream (intake bay) side of where the existing circulating water pumps now reside. Power for the makeup water pumps would be 4 kV, from new transformers, one per unit, rated at 12 kV/4 kV with a capacity of 9 MVA each. The service cooling water seawater supply pump motors, at 100 hp nameplate each, would be stepped down to 440V, requiring additional small transformers. The 12 kV input power for the 12 kV/4 kV transformers would come from the existing 12 kV feeds to the abandoned circulating water pumps (Reference Sketch SK-E-2).

B. Instrumentation and Controls

The existing high voltage electrical bus and circulating water system controls are via hard wired relay logic. The operator interfaces for these systems consist of hardwired switches, indicators, and annunciator windows on vertical boards VB-5 and VB-4, respectively, in the main control room. There is insufficient space in the main control room to provide similar hardwired operator interfaces for the additional high voltage buses and circulating water system controls. Modern control systems reliably utilize touch screen operator interfaces and digital controls. Therefore this approach would be used.

Refer to Sketch SK-J-3 for a conceptual block diagram of the proposed control system and operator interface. The proposed control system for the new high voltage buses and the circulating water system would be the Triconex Tricon digital control system. This highly reliable, triple redundant platform already provides the main turbine controls and feed water system controls at DCP. It has been approved for safety related applications by the NRC, and DCP intends to use it for safety related control and protective systems in future upgrade projects (Note: Electrical protective functions such as over-current protection would be performed by equipment other than the Triconex). The Triconex control hardware (one main chassis, three expansion chassis, and associated field termination panels per unit) would be located in the electrical room at the new cooling tower location. A total of four Triconex cabinets per unit would be anticipated in this location. There would also be a remote input/output (I/O) expansion chassis per unit and associated field termination panels located in the intake structure. A total of two Triconex cabinets per unit are anticipated in this location. Reference Sketch SK-J-4 for a preliminary Triconex I/O list.

Machinery vibration monitoring would be provided by four Bently Nevada racks per unit in the cooling tower electrical room and three racks per unit in the intake structure. Three Bently Nevada cabinets are expected to be required in the former location and two in the latter per unit. Data would be transmitted to the Triconex control system via data links. Reference Sketch SK-J-5 for a preliminary Bently Nevada I/O list.

Chemistry monitoring and injection controls would be required for the new bisulfite injection system. Control would be through the Triconex.

Interface equipment would be required for a connection to the Cal ISO for monitoring power usage of the new equipment.

The main operator interface would consist of touch screen human machine interfaces (HMIs) in the main control room. Sketches SK-J-1 and 2 show that two HMIs would be installed on the bench board section of VB-4. A panel in the cooling tower electrical room would have two additional HMIs as well as backup hardwired control switches and indications for critical electrical bus controls. Existing annunciator panels in the main control room would be revised to provide alarm windows for the new equipment. Data would be provided to the plant process computer (PPC) via a data link to the plant data network (PDN). This would allow process data to be displayed on PPC HMIs on the operator control consoles in the main control room.

Communication between the Triconex main chassis and main control room HMIs, between the Triconex main chassis and the remote I/O chassis, and between the Triconex main chassis and the plant data network would be via new redundant fiber optic cables. A relatively small number of hardwired circuits would be required from the cooling tower electrical room to the intake structure or directly to the turbine building. In the former case, it is expected that existing circuits between the intake structure and the turbine building could be reused. In the latter case, the new circuits could be run with the fiber optic cables. I/O circuits from new equipment to Triconex and Bently Nevada equipment would be hardwired. By locating the Triconex I/O chassis near the equipment, circuit lengths would be reduced.

Uninterruptible Power Supplies (UPS) would be required for the new Triconex and Bently Nevada equipment. There would be a UPS in the cooling tower electrical equipment room and a UPS in the intake structure for each unit. Operating parameters and alarms would input to the Triconex and this information would be available at the main control room and HMIs in the cooling tower electrical room.

The control system would provide manual start and stop capabilities for equipment and, where appropriate, automatic sequenced operation of equipment (e.g. cooling tower fans) during startups and shutdowns. Cooling fan starts would be sequenced based on unit load via a signal from the existing main turbine control system (MTCS).

Changes would be required to the existing MTCS. A turbine load signal would be needed to the circulating water control system. Existing logic that reduces turbine load upon loss of a circulating water pump would require changes. A turbine trip upon 13.8 kV bus undervoltage may be desirable in addition to the existing turbine trip on low vacuum. The existing MTCS cannot accommodate significant additional logic since it is heavily loaded. Changes are expected to be minimal so are not expected to require an upgrade to the MTCS.

Changes to the reactor trip logic are not anticipated but would need to be investigated if this project was to be implemented. If required, this could result in changes to the solid

state protective system (SSPS) inputs and changes to significant numbers of plant drawings, documents, and procedures.

V. Nuclear Safety and Licensing

1. Nuclear Safety System Requirements

Retrofitting Diablo Canyon with closed loop cooling towers creates several nuclear safety issues that would have to be addressed. It is most likely that these issues would require Nuclear Regulatory Commission (NRC) review and approval via License Amendment Requests (LARs) to insure an acceptable level of safety. There is a risk that such issues could result in LARs that would not pass the NRC review and approval process. As noted previously, retrofit of the ASW system to a closed-cycle cooling configuration is not feasible from a Nuclear Safety and Licensing perspective. The nuclear safety related issues include:

- **Flooding**

The condenser cooling water system is a nonsafety related system and is not required for the safe shutdown of the plant. However, flooding caused by failure of the system in the area of the condensers could jeopardize safety related systems located in the turbine building (Emergency Diesel Generators, Component Cooling Water heat exchangers, safety related conduits and controls). The Diablo Canyon Final Safety Analysis Report (FSAR) discusses the possibility of flooding from the cooling water system, and the attributes of the system that lessen the risk due to flooding. Key to those attributes is the present low pressure in the condenser waterboxes and a circulating water pump trip upon high water in the turbine building sump. With the present system, after a circulating water pump trip and coastdown, the water in the large conduits would drain by gravity flow back to the ocean and not into the turbine building. Retrofitting the present system with cooling towers adversely changes both these system attributes – the waterbox pressure would approximately double, and after a pump trip, large quantities of water in the circulating water pipes (now at an elevation higher than the condensers) would gravity drain into the turbine building. This increase in flood risk would have to be addressed in the FSAR Update and may not be acceptable to the Nuclear Regulatory Commission (NRC).
- **Salt Deposition – Increase in Plant Trips**

As discussed further under “Air Quality – Plume / Salt Drift”, there would be significant salt deposition on the power lines leaving the plant giving rise to an increase in the frequency of plant trips due to “loss of off site power”. Although the plant is designed to safely shut down after such an event, it would result in an increased reliance on the plant safety systems which increases the plant safety risk, and is a topic of interest to the NRC.

- **Salt Deposition – Accelerated Aging of Plant Equipment**

Salt deposition from the cooling towers would have the general effect of increasing corrosion, required maintenance, and frequency of failure of exposed plant equipment. For example, with a southeasterly wind the plume could engulf the safety related Emergency Diesel Generator (EDG) ventilation intakes. This would accelerate the corrosion problems with the EDG radiators (already a problem with existing salty air), and may cause operational problems with the EDG controls. See further discussion under “Air Quality – Plume / Salt Drift”
- **ASW System Interruption**

The massive and complex construction excavation activities west of the turbine building necessitated by the cooling tower retrofit would increase the probability of interruption of the safety related Auxiliary Saltwater (ASW) cooling system during construction. Even during plant shutdown, the ASW system is required for spent fuel pool cooling. The NRC may prohibit this increased risk of disruption of the safety related ASW cooling system, and may require an alternate means of cooling the spent fuel pools.
- **Loss of Offsite Power**

The past plant design basis was to withstand a full load rejection without a reactor trip by running back the turbine. The plant would remain online powering the house loads off the 25 kV bus. With the recent replacement of the steam generators, the design basis of the plant has been changed to a 50% load reduction rather than a full load rejection. However, previous plant load rejection controls are still functional, and there are scenarios in which the reactor will not trip and the turbine generator will continue to supply house loads (including the reactor coolant pumps and the circulating water pumps) after both 500 kV breakers open. If cooling towers were installed, power to the circulating water pumps would no longer be from the 25 kV generator output bus but from the 500 kV system. Similarly, power to the new cooling tower fans would be provided from the 500 kV system. Therefore, unlike the existing system, condenser vacuum would be lost if both 500 kV breakers open. Existing protective systems would result in a turbine low vacuum trip and subsequent reactor trip. It may be necessary for protective logic to be implemented to immediately trip the reactor when both 500 kV breakers open rather than relying on an eventual low vacuum turbine trip. This would require changes to the SSPS inputs and changes to significant numbers of plant drawings, documents, and procedures. Further study of this issue and NRC review and approval would be required if the project were implemented.
- **ISFSI Haul Road Rerouting**

Hauling dry casks of spent fuel from the Fuel Handling Building up to the ISFSI storage area has been described in the ISFSI FSAR, and has been reviewed/approved by the NRC. The haul road is important to safety and has several requirements including a maximum slope of 8.5%, as well as support of loadings from the dry cask transporter. The present route has avoided

existing and future landslide-prone areas and has been designed to withstand the effects of a Hosgri Fault earthquake while encumbered with a loaded transporter without the transporter being damaged (tipping over). Therefore, the new routing of this haul road due to the installation of cooling towers and their auxiliaries would require a new detailed analysis and review/approval by the NRC.

- **Landslide Potential**
Certain areas of the site are active landslide zones. The relocation of the ISFSI haul road, as well as the location of the cooling towers and their auxiliaries, would need to be located to avoid areas of anticipated future landslides. This issue would be subject to NRC scrutiny.
- **Fire Protection System Interruptions During Construction**
The NRC would have concerns with the possibility of any compromises to the fire protection system, such as accidental damage to the yard fire loop, which could occur during construction. This is a risk since extensive excavation would be required for the cooling towers and concrete tunnel construction.
- **Security During Construction**
The massive excavations and disruptions of normal site security boundaries, and the large numbers of construction personnel and equipment crossings of Protected Area (PA) boundaries, would be of concern to the NRC.

2. NRC Licensing

NRC regulations 10 CFR 50.59, 10 CFR 50.90 and 10 CFR Part 51 govern proposed changes to a nuclear plant. These regulations specify when prior NRC review and approval of plant changes is necessary. As part of a cooling tower retrofit, PG&E would perform a 10 CFR 50.59 evaluation in accordance with the guidance provided in Revision 1 of NEI 96-07 and Regulatory Guide 1.187, both dated November 2000. As discussed previously in this report, retrofitting Diablo Canyon with closed loop cooling towers creates several nuclear safety issues that in accordance with 10 CFR 50.59 would require NRC review and approval via the License Amendment Request (LAR) process (10 CFR 50.90 and 10 CFR Part 51). These issues include the increased risk of flooding of safety related equipment, the increased risk of plant trips and accelerated aging of plant equipment due to salt deposition, the rerouting of the ISFSI haul road, and the risk of disruption of the ASW system during construction. There is a significant risk that the NRC would not be willing to grant a license amendment to allow the change in design that creates or increases these nuclear safety issues. Also, the NRC will need to ensure that the National Environmental Policy Act (NEPA) is appropriately implemented for the environmental effects of the proposed cooling towers construction and operation. In order to request NRC approval, the final design must be completed, applicable State permits issued, and an LAR prepared and submitted to the NRC. The NRC review period typically takes one year after submittal of the LAR. In addition, it is anticipated that interveners would request NRC hearings. NRC hearings could take two to three additional years.

3. Security

Retrofitting cooling towers at DCPD would have a major impact on site security. The plant PA boundary would have to be ultimately relocated to accommodate the installation of the cooling towers and their auxiliaries. The boundary for this would be approximately in the same area to the southeast of the power block, with the cooling towers, circulating water pumps, and the associated electrical buildings being located outside the PA. The relocated main warehouse would also be located outside the PA.

VI. Environmental Impacts and Permitting

1. Air Quality – Plume / Salt Drift

Significant visible plumes would be generated by cooling towers at DCPD, and would be frequently visible from San Luis Obispo and/or Avila Beach. The largest plumes would have lengths exceeding 5 miles and heights exceeding 2,500 feet.

Background: When the ambient air is cooler than the moist cooling tower exhaust air, it cannot absorb all the moisture, and the excess moisture in the exhaust air stream condenses creating a visible plume. Under certain conditions, a cooling tower plume presents a significant fogging hazard to its surroundings. The water evaporated in the cooling process is "pure" water, in contrast to the drift droplets carried along with the plume. "Drift" is the water droplets that become entrained in the air stream as it passes through the cooling tower. The rate of drift loss is a function of cooling tower design and configuration, airflow rate through the cooling tower, and water loading. Drift droplets have the same or greater concentration of impurities as the water entering the cooling tower. Because the drift contains the minerals and chemicals of the makeup water, contact of these salts and chemicals with plants, building surfaces, and human activity can be detrimental and/or hazardous. Sedimentation of drift droplets downwind of the cooling towers would result in an increase in ground level concentrations of salt chemicals.

Due to their size and the limited space available at DCPD, plume-abated cooling towers could not be located at the plant site. They are larger than the nonplume-abated cooling towers being evaluated in this study, and require a significantly larger footprint. The plume-abated cooling towers have a greater height required for the cooling tubes and additional fans for the incoming hot water. For proper operation they also need to have air coming in from both sides ruling out the back-to-back rectilinear arrangement selected for the nonplume-abated cooling towers. The only layout possibilities for plume-abated cooling towers would either be circular or extended rectilinear footprints with a width of only one cell and a length necessary for 40 cells (~2,400'). Neither configuration is a possibility given the characteristics of the site discussed elsewhere. The tubes would have to be titanium for corrosion resistance. The fan power would be about double what

the nonplume-abated cooling towers consume. The cost for plume-abated cooling towers is at least 150% of that for nonplume-abated cooling towers. In summary, the lack of a suitable location has ruled out plume-abated cooling towers for DCP.

To determine the environmental impact of cooling towers at DCP, the seasonal/annual cooling tower impact (SACTI) prediction code was utilized along with the cooling tower design data and local meteorology data. The SACTI software is described by the NRC in Section 5.3.3.1 of Standard Review Plan, NUREG-1555, as appropriate for this purpose. For purposes of this study it is assumed that both units are operating at 100% power.

As noted previously, accurate Diablo Canyon site specific data for humidity or wet bulb temperature is not available. Therefore, for purposes of this study, hourly wet bulb temperatures for the years 2003 through 2007 were taken from the National Weather Service (NWS) station at the San Luis Obispo (SLO) Airport. Site specific wind velocity and direction data for DCP was utilized. The SLO Airport weather station data gives lower wet bulb temperatures (due to drier inland conditions) than would be experienced at the Diablo Canyon site. The use of these lower wet bulb values rather than site specific coastline data results in smaller predicted plumes (provides a conservative study bias).

A summary of visible plume lengths that would result from cooling towers at DCP is presented in Table 5. Plumes greater than 1/3 of a mile in length would be present approximately 73% of the time during winter and 60% of the time in the fall. Plumes greater than 2 miles in length would be present approximately 35% of the time during winter and 25% of the time in the fall. In most cases, the plumes tend to lie either towards the northwest (over the plant itself, especially in the winter) or to the southeast (along the access road from Avila Beach).

	Winter	Spring	Summer	Fall
Most Frequent Plume Heading Directions	NW,SE	SE,ESE,SSE	SE,ESE	SE,ESE,SSE
Percent of Plumes < 1/3 miles	26.9	35.0	44.2	40.4
Percent of Plumes >1/3 to 2 mile	38.5	28.2	30.3	34.8
Percent of Plumes >2 to 5 miles	30.3	32.8	24.3	22.5
Percent of Plumes >5 Miles	4.3	4.0	1.3	2.2

Table 5: Visible Plume Length Frequency Summary – Percent

Table 6 shows the percent of time for various centerline heights of the plumes above the tops of the proposed cooling towers. The highest plumes, like the longest ones shown in Table 5, extend down the coast in the ESE to SSE direction.

	<100m (<330 ft)	100 - <500m (330 - 1640 ft)	500-<750m (1640 - 2460 ft)	750 - 810m (2460 - 2700 ft)	Total Percent
S	0.43	0.36	0.71	1.5	3
SSW	0.26	0.39	0.66	1.22	2.53
SW	0.35	0.49	0.86	1.4	3.1
WSW	0.39	0.42	0.67	1.3	2.78
W	0.38	0.4	0.83	1.6	3.21
WNW	0.23	0.78	1	2.55	4.56
NW	0.56	1.89	1.94	4	8.39
NNW	1.24	2.51	1.26	1.93	6.94
N	1.36	1.02	0.62	0.97	3.97
NNE	0.43	0.52	0.3	0.45	1.7
NE	0.36	0.44	0.27	0.37	1.44
ENE	0.43	0.42	0.22	0.31	1.38
E	1.24	0.75	0.49	0.76	3.24
ESE	7.44	2.87	1.29	2.08	13.68
SE	13.81	3.34	3.8	9.75	30.7
SSE	1.44	0.71	1.87	5.36	9.38
All	30.35	17.31	16.79	35.55	100.00

Table 6: Plume Heights – Centerline Height Percent by Direction

Plume visibility by calendar time is not an output of the SACTI program, but estimates can be made based on the frequency of conducive meteorological conditions. Such an estimate determined that plumes would be generated of sufficient size to be seen from Avila Beach between an hour before sunrise and an hour after sunset approximately 45 times per year, and from San Luis Obispo approximately 300 times per year. The plumes would be visible from San Luis for approximate 200 sunsets per year.

Estimates of salt, TDS, PM₁₀, and water deposits are given in Tables 9a, 9b, 9c, and 10 of Appendix A-7. Due to the use of saltwater, the salt deposition rates are notable for some distance. The five miles of plant access road along the coastline will be exposed to some amount of salt. The makeup of the total dissolved solids is over 75% sodium chloride. The total annual salt deposition would exceed 7,500 tons.

Buildup of salt on the transformers, conductors, and insulators associated with the 500 kV system would require continuous attention in the form of frequent water washings and monitoring of the system to minimize flashover incidents. The power generation industry

experiences significant problems caused by salt buildup on electrical systems at plants which are less exposed to salt deposition than that which would be seen at DCPD should cooling towers be installed. Numerous plants located on coastal areas, e.g., SONGS in Southern California, Turkey Point in Florida, and Brunswick in North Carolina, have experienced flashover of high voltage equipment due to excessive accumulations of salt. (Reference Nuclear Industry OE 21874, OE 21784, and SER 10-93). To combat the problems of excessive salt buildup, operators have found it necessary to increase the frequency of water washing. Also, increased vigilance is placed on monitoring electrical measurements associated with the transmission system to obtain early warnings of flashover in order to avoid equipment damage.

At DCPD, salt drift from the cooling towers would deposit large quantities of salt in a broad radius surrounding the cooling towers (Reference Table 8 for Adverse Environmental Impacts). The amount of salt deposits on the exposed high voltage electrical components would greatly increase over the existing salt deposition rates. Frequent washings and monitoring would be required – at a minimum. Precise predictions of increased outages due to electrical flashover of equipment attributable to excessive salt buildup associated with cooling tower drift is not possible, but an increase in such outages with attendant interruption of generation would be expected. The alternative of locating high voltage transmission lines underground between the generator step up transformers and the switchyard is extremely costly and of questionable reliability, and has not been considered in this study.

Shading and fog from the plumes are given in Tables 11 and 12 of Appendix A-7. There will be some loss of sunlight near the cooling towers. The fogging is predicted to interact directly with plant components to the NW and plant worker and equipment or commercial transport vehicles approaching from the SE.



Figure 13 – Cooling Tower Plume (Looking North)



Figure 14 – Cooling Tower Plume (Looking Southeast)



Palo Verde – Mechanical Draft Towers in a Dry Environment



Palo Verde



Washington Public Power #2



Cattenom



Cattenom

Figure 15 – Plumes from Nuclear Power Plant Cooling Towers

2. Water Quality – Cooling Tower Blowdown

Each unit would require a steady state blowdown flow of approximately 25,200 gpm when running at full load. The concentration of the circulating water would be 1.5 times normal seawater. Thus the blowdown would have a concentration of about 52,500 ppm TDS given an average seawater concentration of 35,000 ppm TDS. The blowdown stream is toxic to marine life due to the higher TDS concentration, therefore it would either have to be rapidly diluted with ambient seawater as it is introduced into the ocean or it would have to be treated to reduce its TDS concentration back to that of seawater.

Technology exists for removing salt from concentrated waste streams. The technology is known as zero liquid discharge (ZLD) and typically involves successive stages of reverse osmosis, brine concentration, followed by crystallization where a salt cake is created. At DCPD the waste stream of concentrate obviously could not be put back into the ocean, so the salt cake would have to be dried and trucked offsite to a waste disposal facility. Besides this waste disposal activity, the main disadvantage of ZLD for this application is the very high cost of the equipment and the high levels of electric power required. A rule of thumb for power requirements for ZLD (per discussion with Aquatech) is 15 kW of power are required for each gpm of waste stream to be treated. Thus, for DCPD's waste stream of 25,200 gpm per unit that would mean 378 MW of power. In DCPD's case this power is overstated since not all the dissolved solids would be extracted from the blowdown, but rather just about 1/3 of them in order to achieve a TDS level equal to the ocean. However, DCPD would still require the brine concentrator and crystallizer systems since whatever salt levels removed would have to be trucked away in solid form. Brine concentrator and crystallizer engineering and operation is fraught with challenges because of scale buildup on the heat exchange surfaces as well as corrosion. Dryer operation is also problematic. Periodic acid cleaning of the systems is required.

Due to the problems associated with ZLD systems as described above, they are not considered practical for the massive application that would be required for DCPD. Rather, the blowdown stream would be mixed with receiving waters by use of diffuser arrays in order to mitigate the effects of the concentrated wastewater stream on sea life.

Plant effluent salinity within 10% of ambient has been provided (regulator guidance) as the acceptable range for discharge permit approval if the outfall configuration does not facilitate rapid diffusion in the ocean receiving water. This concentration range cannot be achieved even with dilution of cooling tower blowdown with the 51-mgd remaining once-through cooling volume proposed for the ASW/SCW systems (72-mgd at 1.5x combined with 51-mgd at 1.0x results in a discharge salinity of approximately 1.3x). Therefore, the cooling tower blowdown cannot be permitted for discharge to a single shoreline or submerged outfall point without substantial additional dilution water sources. Other plant effluent streams (including freshwater wastewater streams) do not provide enough volume to appreciably impact dilution. Additionally, use of excessive amounts of ambient seawater purposefully drawn into plant systems to achieve acceptable outfall salinity would be counter to any retrofit effort implemented to minimize seawater use.

The only practical option for rapid dilution to ambient salinity is use of a diffusion system spread across an acceptably large area in the receiving water body. For this application, a seafloor-anchored diffuser piping array placed out from the shoreline and intertidal zone would be required to reduce or eliminate potential negative impacts to receiving water quality and marine life.

Of specific concern for cooling tower blowdown (in addition to necessity for rapid dilution in receiving waters) are the Effluent Limit Guidelines (ELGs) for select constituents. These ELGs are specific for point of discharge from cooling tower systems, and not for final concentrations detected at a facility's combined wastewater outfall. Chromium (Cr) and Zinc (Zn) have blowdown ELGs of 0.2 mg/L (milligrams per liter or parts per million) and 1.0 mg/L respectively. An assessment of intake seawater (influent) samples taken monthly for DCPD during the period 2005-2007 determined that Cr was almost exclusively non-detectible with one value of 0.2 ug/L (micrograms per liter or parts per billion) concentration during the period. Zn was also routinely non-detectible; however, several instances of detection did occur with a maximum concentration of 59 ug/L during the period. For both of these constituents, concentration factors of 1.5x or even 2.0x in cooling tower blowdown would not result in an exceedance of the process specific ELGs provided available makeup at DCPD continued to exhibit low concentrations. Other cooling tower blowdown priority pollutant ELGs should likewise not be problematic provided ambient seawater chemistry off the plant site remained stable.

Closed-cycle systems tend to exhibit more alkaline pH than makeup water. For DCPD, ambient seawater normally has a pH in the range of 7.8 to 8.4. This pH range facilitates chlorine/bromine control of biological fouling in existing seawater systems. As discussed previously in this report, the high salinity projected for cooling tower system operations should reduce or eliminate macrofouling concerns (primarily marine barnacle and mussel fouling) within the system. However, fouling of main condenser tube surfaces might still occur under certain conditions due to micro-organisms capable of withstanding the high salinity. This could require periodic chlorination treatment of the main condensers. However, such treatment would be hindered by elevated pH conditions. Acid (hydrochloric or sulfuric acid) injection to depress system pH could be necessary in order to facilitate microfouling oxidation treatment within the main condensers. It is not anticipated that addition of inorganic acids to effect moderate pH depression would negatively impact overall water quality in the system, or subsequently reduce the ability to discharge the blowdown.

Chlorine treatment on an as-needed basis injected immediately upstream of the main condenser inlets could be accomplished with only a temporary increase in residual oxidants within the system. The cooling tower blowdown may require temporary isolation in the event residual chlorine was persistent. If actual operations required extended chlorination treatment, or resulted in excessive residual chemical concentrations, cooling tower blowdown dechlorination capability could be required. Actual need for pH moderation, main condenser biofouling treatment, and/or periodic cooling tower blowdown dechlorination is highly speculative. Therefore, equipment

specifications and costs to implement these processes have not been considered in this study.

The blowdown stream would be taken from the cold side of the cooling towers, having a maximum temperature of 83°F given a “maximum” wetbulb temperature of 66°F (this “maximum” wetbulb represents a point 2 standard deviations to the right of the mean wetbulb value of 52.0°F, representing all but 193 hours per average year when the wetbulb is greater than 66°F).

Blowdown would be directed into a pipe from a weir gate at the pump pit to achieve the desired flow. From there the pipe would be directed to the ocean near Patton Cove, south of the intake cove. The temperature and concentration of the blowdown being higher than that of the seawater would result in a density of 64.7 lb/cu ft, as compared with a seawater density of 64.0 lb/cu ft. Being heavier, the blowdown stream would tend to sink amid the seawater, with negative effects on benthic marine communities. To counter this tendency, the blowdown stream would be channeled through diffusers at a high velocity, (5 ft/sec minimum) in order to promote mixing with the surrounding seawater. The blowdown distribution system would consist of a large distribution header, approximately 36”, which would be filled from a weir at each circulating water pump pit where the flow could be set for a steady state flow of 25,200 gpm per unit, and would discharge under water on the sea floor (Reference Sketch SK-M-4). On the top of the underwater pipe would be located an array of diffuser nozzles (approximately 600 1½-inch diameter nozzles). Given equal flow they would each have a discharge velocity of 6.6 feet per second. At this velocity, the concentrated stream would be forced to mix with the less concentrated seawater as it exited the nozzle. Static head from the 85 foot elevation at the inlet of the blowdown line would provide the driving force for the flow. The nozzles would be located on 1 foot centers, two at each station, symmetrically configured pointing upward at an angle of 60° from the horizontal. The diffuser section of the piping would start 200 feet from shore and extend another 300 feet for a total of 500 feet per unit. Fiberglass would be a suitable material for the diffuser system.

The blowdown plume was modeled with CORMIX, a comprehensive software system for the analysis, prediction, and design of outfall mixing zones resulting from the discharge of aqueous pollutants into diverse water bodies. It contains mathematical models of point source discharge mixing within an intelligent computer-aided design interface. The programs focus is environmental impact assessment and regulatory management. It has been developed under several cooperative funding agreements between U.S. EPA, U.S. Bureau of Reclamation, Cornell University, Oregon Graduate Institute, University of Karlsruhe, Portland State University, and MixZon Inc. during the period 1985-2007.

CORMIX is a recommended analysis tool in the permitting of industrial, municipal, thermal, and other point source discharges to receiving waters. The system’s major emphasis is on predicting the geometry and dilution characteristics of the initial mixing zone so that compliance with water quality regulatory constraints may be judged.

CORMIX was used to evaluate the thermal and total dissolved solids (TDS) plumes that would be discharged as a result of the closed-cycle cooling installation. The expected

thermal plume from the diffuser array ports was found to be 0.80 meters (2.6 feet) long before reaching the 2.78°C (5°F) isotherm above the ambient. The expected TDS plume was found to be approximately 0.77 meter (2.5 feet) long. The current thermal discharge associated with the once-through cooling system is much larger, has an average thermal differential of approximately 11.1°C (20°F), and dissipates from a single shoreline outfall. An amendment would be required to the power plant’s NPDES Permit to define the modified thermal discharge characteristics, including use of the entirely new offshore diffuser array. The actual plant discharge has not been designed, but the results provided would be bounding for any similar discharge. Table 7 summarizes the CORMIX results:

Plume Type	Ocean Temperature °C (°F)	Discharge Flow Rate (Per Unit) m ³ /s (gpm)	Isotherm Considered °C (°F)	Plume Length m (ft)
Thermal	9.33 (48.8)	1.59 (25,200)	2.78 (5)	0.80 (2.6)
TDS	9.33 (48.8)	1.59 (25,200)	2.78 (5)	0.77 (2.5)

Table 7: Summary of Thermal Plume Analysis

DCPP is currently permitted to return wastewater to the ocean at a temperature of no more than 22°F higher than ambient seawater intake temperature. It has been assumed that a reconfigured DCPP would be required to meet the 20°F limit above ambient receiving water temperatures for a ‘new’ discharge in accordance with the California Thermal Plan. Since the cooling water blowdown would always be 17 °F higher than the wet bulb temperature, there would be numerous occasions when the blowdown temperature would be more than 20°F above the ocean temperature. Examination of wet bulb temperature and ocean temperature at the intake structure show that the differential temperature would exceed 20°F approximately 25% of the time. The use of SLO Airport weather station wet bulbs, which are likely lower than the wetter immediate coastal zone, adds a bias which tends to reduce the estimated hours per year that the blowdown would exceed the ocean water temperature by more than 20°F.

Figure 16 shows the hours per day that the blowdown would exceed the ocean water temperature by more than 20°F (based on data from the years 2003 – 2007). Note that the limit is rarely exceeded in winter, but often in summer.




Figure 16 – Hours/Day that the Blowdown Water Temperature Would Exceed the Discharge Limit

Under such conditions it would be necessary to cool/dilute the blowdown stream with a colder stream such as the service cooling water seawater supply or the makeup water system. For purposes of this study, a 20" branch from the SCW seawater supply would be routed to the inlet of the blowdown line to achieve the desired mixing. During these periods when blowdown temperature reduction is required, it would be necessary to run the third SCW supply pump. This would result in an additional volume of raw seawater use during these periods.

3. Adverse Impacts

Retrofit of DCPD to closed-cycle cooling would create significant adverse environmental impacts. These direct adverse impacts, as discussed below, would be realized both during implementation of the project, as well as during post-retrofit operation of the facility. Additionally, the large workforce, and transportation of equipment and materials required during the construction phase, would generate negative impacts to the immediate surrounding communities. Personnel transportation to and from the facility would substantially increase light vehicular traffic in the immediate area for an extended period. Heavy equipment and materials trucking would significantly impact traffic flow and generate appreciable road noise.

The project would generate significant adverse impacts related to overall electric industry green house gas (GHG) emissions. Loss of DCPD Units 1 & 2 for an extended period of time during construction (projected at 17 months minimum) would require replacement of the entire base load generation capacity of the facility. This lost electric supply would most likely be replaced throughout the period of construction with higher utilization of available fossil fuel generation units. Additionally, the permanent loss of unit efficiency and increase in required auxiliary power for the cooling tower system operations would result in an ongoing reduction in net base load generation. This post implementation reduction in electric generation capacity would need to be replaced by other base load generation facilities (fossil units). The loss of long term capacity would effectively reduce future supply gains from planned efficient fossil and renewable resource generation projects in the State.

Demolition, construction, and transport activities associated with a retrofit project would be substantial. The very large equipment associated with these activities would rely on diesel combustion, and therefore result in substantial consumption of fuel oil as well as the associated onsite emissions of GHG and particulates. Most construction activities would occur within the existing, previously disturbed, site industrial areas. However, the placement of a discharge dispersion system on the seafloor offsite of the plant would disrupt and segment pristine rocky marine habitat, as well as disrupt transited intertidal zones during pipe placement. The large demolition and new construction projects would also generate substantial volumes of related debris. Metals, wood, concrete, and asphalt can be recycled; however they would still require offsite transport resulting in additional fossil fuel consumption. Non-recyclable fills, plastics, equipment and existing building

materials would need to be transported offsite as well, and disposed in limited available landfill space.

Salt emissions from the saltwater makeup mechanical draft cooling towers would present a significant new adverse impact at the plant site. Salt drift would plague the entire industrial site and all exposed plant equipment, as well as settle on surrounding lands. The deposition of salt to the terrestrial plant and animal community on coastal bluffs southeast of the facility would dramatically increase, far in excess of the natural contamination from winds coming off the adjacent sea. Additionally, substantial vapor plumes from the cooling tower complex would be visible during certain periods to surrounding communities.

Operation of the cooling tower systems would generate large volumes of high salinity elevated temperature blowdown requiring disposal to the Pacific Ocean. Construction of the diffuser system for discharge of the blowdown would disrupt the existing seafloor community, and operation of the system could result in establishment of high salinity zones potentially toxic to microscopic organisms in the immediate vicinity of diffuser ports. Such unfavorable conditions could occur in the receiving water when currents are low and ocean conditions calm resulting in less efficient mixing and dispersion.

Since PG&E owns large acreage tracts surrounding the power plant, noise generated from the cooling towers, primarily due to the fans, should not be a significant issue at the industrial site boundary. However, the cooling towers would increase the ambient noise levels in their surrounding vicinity which would impact the occupancy of nearby offices and facilities.

The following table summarizes the projected significant adverse environmental impacts:

Adverse Impact	Cause	Projected Magnitude
Project Implementation (Construction Phase):		
Green House Gas (GHG) Emissions for Replacement Power	Unit 1 & 2 Replacement Power During Extended Outages. (Lost carbon-free generation most likely replaced by fossil-fuel generation.) See Notes 1 & 2.	10,318,500 Tons CO₂ GHG Emissions
Project Fossil Fuel Combustion	Transport of Construction Equipment, Construction Materials, Removal of Spoils, Debris, & Recyclable Materials, Onsite Grading & Construction Activities and Bussing of Craft Workers.	> 4,424,000 Gallons of Diesel Fuel. Reference Appendix A-10, "Fuel Consumption Summary"
Disruption of Benthic Marine Habitat	Area Preparation and Placement of Discharge Dispersion Piping on Seafloor.	Loss of 0.35 Acres of Rocky Subtidal
Construction Debris Disposal	Landfill of Non-Recyclable (Non-Metal or Wood) Construction and Site Debris.	3,600 Cubic Yards Landfill Disposal 300 roll-offs filled to 12-cubic yards
Facility Operations Post-Construction:		
Green House Gas (GHG) Emissions for Replacement Power	Generation Required to Replace Unit 1 & 2 Efficiency Loss & Increased Site Auxiliary Power Requirements. (Lost carbon-free generation most likely replaced by fossil-fuel generation.). See Notes 1 & 3.	180,500 Tons CO₂/Year GHG Emissions.
Salt Emissions and Deposition	Cooling Tower Salt Drift	15,000,000 Pounds per Year Deposited on surrounding lands & equipment. Calculation based on 25 day outages, drift of 86 gpm and .0405 gm/gm fraction of salts (Reference Appendix A-7).
Vapor Plume	Cooling Tower Emissions	Plume Lengths Exceeding 5 miles Plume Heights Exceeding 2,500 feet 45+ Times/Yr Visible from Avila Beach 300+ Times/Yr Visible from SLO
Blowdown Discharge Dispersion Zone with High TDS	High salinity and thermal dispersion zone. Potential for negative impacts to marine organisms that come in direct contact. (Estimate of water volume affected by 1200 operating diffuser array nozzles.)	350 Cubic Meters in Receiving Water Estimated high TDS zone above each diffuser array: 91m long * 2.5m wide * 0.77m high = 176 cubic meters per unit
Corrosion Control Emissions	Site corrosion control initiatives would substantially increase including necessity to resurface and paint metal equipment and structures.	> 500 lbs/year Increase in Volatile Organic Compound (VOC) Emissions

Table 8: Projected Direct Adverse Environmental Impacts of DCPD Retrofit.

Table 8 Notes:

1. GHG calculations based on California Public Utilities Commission (CPUC) Greenhouse Gas Emissions Performance Standard Documents: 800-900 Pounds of CO₂ per MW-Hr provided as emissions from efficient combined-cycle turbine natural gas fueled generation. 800 Lbs/MW-Hr used in GHG emissions estimates.

2. GHG emissions for Project Replacement Power During Construction (Unit 1 & Unit 2 Net Generation Capacity of 1155 MW/Unit with 17 Month Dual-Unit Outage):
 $[2310 \text{ MW} * 0.9 * 517 \text{ Days/project} * 24 \text{ Hrs/day}] = [25,796,232 \text{ MW-Hrs}] * 800 \text{ lbs. CO}_2/\text{MW-Hr} = 20,636,985,600 \text{ lbs. CO}_2 = 10,318,493 \text{ Tons CO}_2 \text{ or } 9,380,448 \text{ Metric Tons CO}_2.$

3. GHG emissions for Annual Replacement Power Post-Project Operations (Average 55.4 MW Facility Reduction in Electric Output & Anticipated 90% Facility Capacity Including One 25-Day Unit Refueling Outage per Cycle):
 $451,180 \text{ MW-Hrs/Yr [Ref. Table 3]} * 800 \text{ lbs. CO}_2/\text{MW-Hr} = 360,944,000 \text{ lbs. CO}_2/\text{Yr} = 180,472 \text{ Tons CO}_2/\text{Yr} \text{ or } 163,693 \text{ Metric Tons CO}_2/\text{Yr}.$

4. Permitting

Implementation of retrofitting DCPD to a closed-cycle cooling configuration would require a substantial regulatory permitting effort. In addition, due to existing or potential restrictive requirements and conditions, the ability to acquire all key construction approval and/or post project plant system operating permits would be very difficult. One key environmental permit (air emissions permit) presents a potentially insurmountable obstacle to project feasibility. Furthermore, no single regulatory agency controls or has overriding authority over all required project permits and licenses further complicating any permitting assessment.

In accordance with power plant construction projects in the State of California within the last decade, crucial operating permits would have to be secured (or at minimum a firm legal commitment obtained from the regulatory agency responsible) before project construction could start. These include permits required for unit operations post retrofit. Without the assurance that operating permits will be obtainable/approved following construction, a power plant retrofit project would be too risky to proceed. For DCPD these key permits would include, at a minimum: 1) a substantially revised facility wastewater discharge requirements permit (National Pollution Discharge Elimination System [NPDES] Permit), and 2) an Air Emissions Permit-to-Operate (PTO) for cooling tower operations due to projected substantial PM₁₀ emissions.

A Coastal Zone Coastal Development Permit (CDP) would be required for the overall project from the California Coastal Commission prior to initiating construction. Obtaining final Coastal Commission approval for such a project is highly speculative, and assurance of post project operating permit and license availability would likely be a CDP approval condition under any scenario. Additionally, the fact that plume abatement cooling towers are infeasible on the plant site, and frequent substantial vapor plumes are projected to be visible from surrounding communities, reduces the likelihood of commission approval. Conditions in a CDP would also likely include significant mitigation or offsets for environmental impacts of project implementation (construction traffic, construction pollution, site aesthetic impacts, salt plume impacts to surrounding lands, etc.), and could result in substantial additional project costs that are not included in the current estimates.

Air permitting for mechanical draft wet cooling towers, a key required post retrofit environmental operating permit, is problematic for DCPD. San Luis Obispo County is a non-attainment region for State of California PM₁₀ air quality parameters. Obtaining a permit for significant new PM₁₀ emissions would require substantial emissions offsets that currently are not available within the air district. With the projected growth of local and state populations, the lack of emissions offsets presents a real and potentially insurmountable obstacle to permitting a cooling tower system at DCPD.

The implementation of a retrofit would require significant modification to the Power Plant's current NPDES Permit issued by the California Regional Water Quality Control Board, Central Coast Region (CCRWQCB). Potential modifications could include more restrictive effluent limitations, as well as additional discharge and receiving water monitoring. This could add substantially to ongoing facility operation and maintenance costs. If the discharge would be considered "new" under the State Thermal Plan (likely due to the proposed installation of an offshore diffuser array for tower blowdown), the outfall limit would be set at 20°F above ambient receiving water temperatures. The thermal limit could necessitate periodic unit power reductions, and/or the use of additional raw seawater for mixing with tower blowdown (Reference Report Section III.2 Conceptual Design Summary).

As previously discussed, the only practical/viable option for discharge of the large volume of high salinity cooling tower blowdown is diffusion offshore. Construction of an offshore piping system would require a State tidal and submerged lands lease and Army Corp of Engineers permit before the overall retrofit project could begin. Additionally, approval for diffuser system installation would be a prerequisite for obtaining NPDES Permit approval. The scenario of nested regulatory approvals would necessitate significant administrative lead time for wastewater discharge system related permit and license authorizations, and to insure timely sequenced resolution.

Approval of all project related Local and State permits, or at a minimum firm agency commitments to provide final approval for fully developed draft permits, would be necessary to support NRC licensing for the extensive nuclear plant modifications. Estimates of lead time for various administrative efforts reflect allowances to adequately resolve anticipated Local and State permitting challenges prior to submittal of an NRC Operating License Amendment Request (LAR).

The following table summarizes anticipated project permit and licensing requirements:

Regulatory Agency	Permit Type & Function	Administrative Allowance (Begin Documentation and Permitting Process)	Probable Constraints & Significant Special Conditions
Project Implementation/Construction Permits:			
California Coastal Commission	Coastal Zone Development Permit (CDP). (<i>Overall Project Construction and Building Authorization Permit</i>)	3-Years prior to project NRC LAR Submittal.	Obtain key environmental operating permit commitments before overall project approval. Special conditions and offsets.
County of San Luis Obispo	Project Component Building Permits(s) & Grading Permits.	3-Years prior to project NRC LAR Submittal. (<i>In conjunction with CDP</i>)	Special conditions and offsets likely required. Scope unknown.
U.S. Army Corps of Engineers (ACE)	Section 404 Nationwide Permit (NWP) for Structural Discharge. (<i>Permit for seafloor dredging and materials placement for offshore wastewater diffuser array</i>)	5-Years prior to project NRC LAR Submittal. (<i>Commitment to support NPDES permitting effort</i>)	Seafloor damage and disruption mitigation likely required.
California State Lands Commission (SLC)	Right of Way (ROW) and Lease for Tidal and Submerged Lands at Patton Cove. (<i>Lease for wastewater diffuser array lands use</i>)	5-Years prior to project NRC LAR Submittal. (<i>In conjunction with ACE Section 404 permit effort</i>)	Unknown
State Water Resources Control Board (SWRCB)	Construction Storm Water Discharge Permit. (<i>Required for project >1 acre of ground disturbance</i>)	4-Months prior to initial construction.	None-Anticipated. Routine type project permit.
SLO County Air Pollution Control District (APCD)	Concrete Batch Plant Permit-to-Operate (PTO).	4-Months prior to batch plant operations.	Dust control measures and fuel combustion emissions restrictions (if fossil-fueled).
New/Revised Facility Operating Permits:			
Regional Water Quality Control Board (RWQCB) Central Coast Region-3	National Pollution Discharge Elimination Systems (NPDES) Permit. Facility Wastewater Discharge Requirements.	4-Years prior to project NRC LAR Submittal. (<i>Draft Permit and Agency commitment likely required before CDP approval</i>)	No variance from California Thermal Plan maximum temperature limits. More restrictive constituent limitations on equipment specific wastewater pathways (Sewage, SWRO, etc.).
SLO County Air Pollution Control District (APCD)	New Cold Machine Shop Abrasive Blasting & Painting Unit Air Emissions Permit-to-Operate (PTO)	4-Months prior to initial unit operations.	None-Anticipated. In-kind or similar equipment replacement for existing unit.
SLO County Air Pollution Control District (APCD)	Cooling Tower Air Emissions Permit-to-Operate (PTO).	4-Years prior to project NRC LAR Submittal. (<i>Draft Permit and Agency commitment likely required before CDP approval</i>)	Require procurement of PM ₁₀ emissions offsets. Offsets are currently unavailable and potentially unattainable.

**Table 9: Required Construction and Operation Permits & Licenses
Not Including NRC Nuclear Reactor Operating License Amendments/Extensions for Units 1 & 2**

VII. Additional Studies

1. Special Studies

Numerous technical issues would require further study at a point during the design phase of the cooling tower retrofit. These include (but are not limited to):

- **Circulating Water Pump Pit:** It is recommended that the pits be designed by modeling studies, which can be done by the circulating pump suppliers, among others.

- **Diffuser Design:** Effective diffusion of the heated and concentrated blowdown needs to be analyzed further to ensure sufficient mixing would be achieved.
- **Soils Investigations:** Additional borings and soil testing is advisable where heavy loads are anticipated due to the cooling tower basins and the pump pits.
- **Water Hammer Analyses:** Very large water flows can be subjected to high pressure spikes or low pressure vacuum formation during transient conditions. These fluctuations, known as “water hammer” require analyses to avoid or minimize the pressure fluctuations through design features.
- **Cooling Tower/Condenser/Flow Rate Optimization:** If the retrofit were to proceed, a more detailed optimization of the combined cooling tower performance, condenser design, piping size and cooling water flow rate should be performed.
- **Power Plant System Effluents:** Further design of a retrofit would require additional analyses of a variety of existing effluent streams which would remain even with a closed-cycle cooling system. Needed analyses include evaluating the capacity of the liquid radwaste system to manage smaller batch discharges, assessing the potential to redirect the reverse osmosis system to a newly constructed offshore diffuser, and the need to further treat other remaining discharges such as the steam generator blowdown, turbine building sump effluent, and makeup water treatment system blowdown. In addition, the effect of reduced seawater flows and potential for extended periods of stagnation within auxiliary system heat exchangers, would likely create challenges due to elevated copper concentrations in the remaining discharge. Reference Appendix 13, Power Plant System Effluents Concerns.

VIII. Conceptual Schedule

1. Introduction

The conceptual schedule for implementing closed-cycle cooling using mechanical draft cooling towers at Diablo Canyon was developed using current regulatory proposals. Start dates for construction were chosen to accommodate the 01/01/2021 deadline provided in the California SWRCB draft policy for implementing I&E reduction goals at operating facilities that use once-through cooling. The schedule provides that both units will be shutdown in extended closed-cycle retrofit outages prior to the deadline, with return to service and commercial power generation not occurring until after the deadline. The schedule also provides for substantial project lead time which will be necessary to facilitate extensive permitting, licensing, design, and work planning activities.

The conceptual schedule is based on both units operating as long as practical (approximately 21-22 months) during construction of new site replacement facilities, and the cooling tower/site excavation. Initial construction (10 months) involves building new site facilities to replace those displaced by the new cooling towers and related services. Permitting (SLO County Building, California Coastal Commission, NRC LAR approval,

etc.) would be required prior to start of new facility construction. Demolition of displaced facilities can begin after warehouse inventories and displaced personnel have been moved. Excavation and construction of the cooling towers would then follow.

Cooling tower basin excavation, re-configuration of the Protected Area (PA) perimeter, and start of the Circulating Water Tunnel (CWT) construction between the tower basins and the tie-in inside the PA would require that major yard utilities be taken out of service. This would initiate the overall plant shutdown. Specifically, loss of service for the 480V & 4,160V (non-vital) electrical yard loops would challenge the operability of several mechanical systems needed to run the plant. Disruption of the fire loop, domestic water, circulating water and other water systems would result. The shutdown and eventual re-start would be staggered with 2 to 3 weeks between Unit 1 and Unit 2. During plant shutdown and tunnel construction (including tie-ins), both units' ASW piping would remain in service supporting CCW. Special protection measures would be in place.

Several parallel construction paths would be ongoing during plant shutdown: (a) Condenser retrofit, SCW piping and other displaced turbine building equipment rework, (b) Construction and tie-in of new/existing CW tunnels west of the turbine building, including displaced/re-routed utilities, (c) Rework/configuration of the intake structure for new makeup and SCW pumps, piping, and related services, and (d) Electrical service changes to match new equipment at the intake, the cooling tower basins, and the 500 kV switchyard.

The overall duration for construction would be approximately 3-3/4 years. The plant shutdown during the construction period would be at least 17 months. Durations assume that engineering design can be developed to support permitting, that permits can be obtained, and that the regulatory process does not extend overall construction. Anticipated Federal, State, and County (SLO) permitting are included in the schedule.

2. Schedule Basis, Calendar, Resources

The schedule assumes an average (plateau) peak work force of approximately 3,000 craft between 2nd Q, 2020 and 4th Q, 2021 (18 months). This occurs primarily during plant shutdown. Actual peaks within this timeframe could be as high as 4,000. The conceptual schedule has not been resource loaded at this level of detail. Bussing from several offsite staging areas would be required to reduce the number of automobile trips to and from the site. Prior to the plant shutdown, craft requirements would be approximately half the peak period level (1,500), and for the last 9 months of construction that number would reduce to approximately 1,000 workers.

The distribution of craft would be such that approximately 2/3 of the above hours are based upon 2 x 10 hour/day shifts and a 6 day work week. Non-critical craft would work a single 10 hour x 5 days/week shift.

The construction and engineering activity durations are based upon judgment. Input for the overall durations has been reviewed by DCP System and Design Engineering and

Construction Planning. Many of the durations are based upon historical information from original construction or more recently completed projects.

The permanent (existing) plant staff is assumed to remain constant at about 1,250. The plant shutdown and on-going construction are expected to require support for capital improvement and maintenance projects similar in size and value to those presently being conducted during both ongoing operations and refueling outages.

3. Pre-Shutdown Construction

Permitting for anticipated Federal, State, and County agencies covers about 7 years; this can be adjusted relative to the start of engineering. Design is only shown for the replacement facilities. These are the "drivers" for early site construction. Other engineering design (cooling towers, pumps, piping, tunnels and supporting system changes, and related design) has not been shown on the schedule, but is understood to occur in the overall timeframe. Front-end engineering is precedent to the permitting process. Final engineering supports site construction and is assumed dependent on the permitting process. The initial construction would be for facilities needing to relocate before cooling tower construction: main warehouse, cold machine shop, engineering/other offices (Parking Lot #7), new sewage treatment plant, new parking structure (1,000 spaces) and the vehicle inspection station. Locations for some of these are tentative and require more engineering evaluation. Some of these may have to be located offsite, or divided to suit multiple smaller (partial) footprints.

The overall duration to construct new/displaced facilities would be approximately 10 months, plus 1 to 2 months for personnel and inventory moves. After that, cooling tower excavation could proceed (generally) from west to east. Cooling tower basins' grade would be at elevation 83' to elevation 85' and would cover approximately 40 acres (encompassing Lots #6, 7, 8, the main warehouse and southern portions of Reservoir Road).

Security changes needed to support construction are extensive. These affect the re-arrangement of the existing PA fencing, circuitry, and camera/microwave systems. During re-work and restoration of the PA, compensatory security measures will be in place (24/7) to ensure the integrity of the Plant Security PA Boundary.

During 2019 through 1st Q 2020, it would be necessary to conduct fuel cask campaign operations to ready both fuel pools for full core offloads that occur during the plant shutdown(s). Limited access during realignment of Reservoir Road (2nd/3rd Q of 2019) could impact ISFSI operations.

4. Construction During Plant Shutdown

Excavation of the cooling tower basins, the pump pits and new tunnels between the cooling towers and inside the PA would involve interruption of main plant 480V & 4 kV electrical systems. As tunnel trenching proceeds past the security building into the PA,

the entire southern security boundary must be protected and eventually re-worked. Excavation for the tunnels into the PA west of the turbine building expands the number of systems to be temporarily shut down and re-configured. It is not practical to reroute or try to "jumper" the affected systems because the tunnels' path for both units covers such a large area (the planned excavation extends northward past the actual plant centerline between Unit 1 & Unit 2). Key vital systems are not allowed to be shut down, but require special protection to ensure continued operability. The main fire loop, the ASW piping, the diesel fuel oil tanks and piping are among those requiring protection.

The new circulating water tunnels would require 8 connections to existing tunnels. On the supply side, 4 of these would meet the existing inlet tunnels and penetrate them. Tie-in of the new tunnels would have to minimize the impact and exposure of the 4 ASW supply pipes. These are on the upper opposing CWT walls. The proposed routing avoids the ASW pipes on the inner walls and the 480V vital duct banks on top of the tunnels by using tie-in routing from the outside or below. Shoring and sequencing of the work in getting to the required elevation requires dedicated construction engineering to map, expose and protect all of the U/G utilities in the areas.

The excavation in front (west) of the turbine building and the corresponding reinstallation of the affected underground utilities followed by backfill need to be completed before and after movement and access of equipment for the main condenser rework and other affected equipment on elevation 85' of the turbine building. The PA west of both (especially Unit 2) buildings could not support equipment movement during much of the first half of 2020.

During plant shutdown, fuel would be offloaded and stored in each unit's spent fuel pool. Essentially, each unit would be in a 17 month refueling outage. Considerable capital and maintenance work would be planned during the shutdowns in addition to the cooling tower scope, but is not included in this conceptual schedule or estimate. The ramp down and power ascension of both units will be staggered by approximately 2 to 3 weeks.

Normal unit refuelings and cycle lengths would be utilized for the cycle preceding each unit's shutdown. The schedule for starting construction of replacement facilities in 2018 and plant shutdowns commencing in early 2020 would be preceded by 1R21 in the 4th Q of 2018, and 2R21 in the 4th Q of 2019. Refuelings would not resume until approximately 18 months and 21 months after the re-start of commercial operations or September of 2023 and February of 2024 in accordance with the conceptual schedule.

Other critical activities, needed to integrate the new cooling towers, pumps, and hardware into the plant, involve construction of a new access road into the back (east) side of the powerblock. This occurs at the bench at elevation 115' and allows cask transporter traffic between the Fuel Handling Building (FHB) and the ISFSI facility via Reservoir Road up the hill. The new road to the bench at elevation 115' must transition approximately 30 ft of elevation over almost 400 ft of length. Routing of grading, compaction and paving equipment in this area, and overall construction represent a challenge to electrical and compressor equipment southeast of the Unit 2 Turbine Building. The Radwaste

maintenance and compressor facility would require relocation (related services are also affected). Tie-ins for switchgear at the 500 kV Switchyard and main buried electrical services down to the power block and the cooling tower basins would take place while the plant is shut down.

No specific line activities are included in the conceptual schedule for control room simulator changes. Engineering design and hardware order placement for affected boards would be in 2018 and 2019. Physical changes would be done in 2020 to support actual operator training in 2021 before restart.

The new makeup and blowdown lines, between the cooling towers and intake (and the cooling towers and offshore diffuser), follow the CWT work and mechanical installations at the intake; the work is not critical path. Two 36" diameter blowdown lines are routed underground from the cooling tower basins to Patton Cove and then several hundred feet offshore to the discharge (diffuser array) location. The existing CWT bores 1-2 and 2-2 will serve as a corridor for routing the makeup piping from the intake to the new tunnel tie-ins inside the PA. The blowdown lines require special engineering, permitting and installation to ensure that ocean floor and sea life protection is maximized. The schedule has very summary level of detail showing these activities over an approximate 15 months.

5. Plant Re-start and Construction Completion

The schedule assumes that Unit 1 & Unit 2 restarts are on staggered schedules (2 to 3 weeks apart) to facilitate safe startup operations for each unit. Approximately 2 months of startup and testing would precede fuel loading and restart per unit. Reloading of fuel, system tests and paralleling each unit to the grid including power ascension would require about two weeks. During this period, and the 2 to 3 months preceding, plant security must complete all of its final testing of the new, reconfigured, PA boundaries.

The post-startup duration for construction is about 4 to 6 months. Very little definition has been included for these noncritical activities. Backfilling, grading & paving outside the PA, noncritical utilities' testing and restoration, signage, painting, training and close-out of all construction packages can all complete after plant restart.

IX. Cost Estimate Summary

1. Cost Estimate Overview

The cost of retrofitting DCP with mechanical draft cooling towers is comprised of 5 elements; 1) Capital Project Cost, 2) Decommissioning Cost, 3) Operation and Maintenance Cost, 4) Cost of Replacement Power to compensate for lost MW during construction shutdown period, and 5) Cost of Replacement Power for lost MW Capacity due to the derating of DCP caused by the cooling system reconfiguration. A summary of these costs and a high level description of the basis for each of these estimates follows:

Capital Project Cost	\$2,689,000,000*
Decommissioning Cost	\$67,000,000*
Operation and Maintenance Cost	\$7,400,000/Year*
Replacement Power – Lost During Construction	\$1,806,000,000*
Replacement Power – Loss in Net Plant Output	\$31,600,000/Year*

**2008 Dollars Excluding Escalation and AFUDC*

Table 10: Cost Estimate Summary

Unit prices used in determining capital project costs are derived using PG&E capital projects guidelines, manufacturer/vendor input, recent actual costs from other major capital projects at DCPD and input from the engineering, operations, project management and the work planning departments, as well as estimating judgment.

2. Capital Project Cost: \$2,689 Million

This cost is based on the conceptual design prepared by Enercon Services and described in this report (Reference Capital Project Cost Estimate Details Appendix A-11). The estimate includes permitting, engineering, procurement and installation of the new system and re-design of existing systems to accommodate the new system. Construction cost includes relocation of the plant infrastructure to accommodate the new equipment. Reconstruction of displaced plant facilities onsite would be limited to the existing developed footprint at DCPD. Not all of the facilities which would be displaced can be fully relocated onto the existing DCPD footprint. Allowances have been included for reconstruction of those facilities at an offsite location. Equipment manufacturers have provided budgetary proposals based on the conceptual design and are incorporated into the cost estimate including applicable taxes. Based on the size of this project, its manpower requirements and recent DCPD experience, travel through the town of Avila Beach would be restricted to a limited number of ‘trips’ through the community. This restriction would require DCPD to provide offsite parking, bussing (transportation to and from the facility for approximately 3,000 craft personnel), as well as pay for the associated travel time. Maintenance or repairs to public roadways outside of DCPD are not included in this cost estimate. As safety and security are always a foremost concern at DCPD, the cost of maintaining and ensuring a safe and secure facility are included in the construction costs.

No allowances have been made for escalation, project financing costs and/or foreign currency exchange rate fluctuations. All costs are in present day (2008 US Dollars) and include indirect cost and corporate overhead exclusive of financing costs (Accumulated Funds Used During Construction - AFUDC). AFUDC is an estimate of PG&E’s cost of capital invested in a project during construction, and is applied to all the Utility’s capital orders or projects that have a construction period greater than 30 days. AFUDC is

applied to a project's total direct cost, applicable taxes, and capital administrative & general (A&G). AFUDC is accrued from the first month that costs are first charged to a project and continues until the month the project is declared operational. AFUDC is included in a project's overall cost and recovered from the ratepayers. Based on the proposed schedule, it is estimated that the total capital project costs presented would double if it were to include AFUDC and escalation. Demolition cost includes an allowance for fluorescent light fixture and ballast disposal, asbestos disposal as contained in some building systems, and lead abatement at the existing security firing range. No other allowances have been made for hazardous, contaminated or environmentally adverse material abatement of any kind.

3. Decommissioning Cost: \$67 Million

The project would have a significant impact on the overall decommissioning cost at the end of the useful life of DCP. Though the current developed footprint would not be expanded, the areas currently used for parking would be replaced by structures. The new construction put in place would eventually be removed as part of the station's decommissioning process. The cost of this added removal scope must be included in the decommissioning fund. The cost estimate for the decommissioning is based on analysis of the current estimate of the cost to decommission DCP as a percentage of the escalated cost to build the plant, and is adjusted to a lower value to reflect the non-contaminated nature of the new systems (decommissioning at 2.5% of install costs).

4. Operation and Maintenance Cost: \$7.4 Million Annually

The operation and maintenance cost of maintaining the mechanical draft cooling towers is based on general vendor recommendations. The costs which have been provided include daily, weekly, monthly, quarterly, semi-annual and annual inspections and maintenance. Labor, material and chemicals are also included. Allowances have been included for the cost of increased maintenance to electrical equipment due to salt drift and for the cost of travel between onsite and offsite facilities. These costs would be in addition to costs currently incurred for operation and maintenance of the existing cooling system. Combined intake pump and electrical systems, cooling systems piping, concrete conduit, and main condenser operation and maintenance cost are assumed to be roughly equivalent (Reference Appendix A-11 Project Cost Estimates Page-2 Annual Increase to Station Operation & Maintenance Cost).

5. Replacement Power – Lost MW During Construction: \$1,806 Million

In order to safely execute this project, both nuclear units would be shut down when construction activities expose main mechanical or electrical systems or jeopardize any nuclear safety related systems. During this shutdown period, power must be purchased to meet the demand of the PG&E service area. This period is expected to last a minimum of 17 months (517 days). The formula for calculating replacement power is based on an estimate of each unit's annual output priced using PG&E's current (2008) long term power procurement forecasts of \$70 per MWhr, and a Plant Capacity Factor of 90%.

Construction Replacement Power Cost Estimate Calculation:
 $\$70/\text{MW} * 1,155 \text{ MW}/\text{Hr} * 24 \text{ Hr}/\text{Day} * 517 \text{ Days} * 2 \text{ (Units)} * 0.9 \text{ (Capacity Factor)}$
= \$1,805,736,240 (say \$1,806,000,000)

6. Replacement Power – Lost MW due to Derated Capacity plus Additional Auxiliary Power: \$31.6 Million Annually

After installation, the cooling towers would result in decrease in net plant output due to a decrease in generator output, and an increase in required plant auxiliary power. PG&E would meet service territory demand by purchasing an equal quantity of replacement power ongoing. The cost of replacement power is calculated using an average of \$70 per MWhr based conservatively low on PG&E's 2008 replacement energy costs. Plant Capacity Factor of 0.9 assumes a one unit 25-day refueling outage during any given year.

Average Derate Annual Replacement Power Cost Estimate Calculation:
 $\$70/\text{MW} * 451,180 \text{ MW-Hrs}/\text{Yr}$ [Ref. Table 3]
= \$31,582,600 (say \$31,600,000)

Description	Total Price 2 Units
Mechanical Equipment:	
Cooling Towers	\$80,000,000
Condenser Waterbox/Tubesheets/Tubes	\$62,780,000
Circulating Water Pumps	\$46,400,000
Other Pumps	\$4,900,000
Valves (96", 78", & 36")	\$3,999,000
Electrical Equipment:	
500 kV/13.8 kV Transformers	\$8,000,000
Other Transformers	\$3,420,000
Cooling tower electrical building. Foundation not included	\$2,870,000
500 kV substation package for cooling tower power supply (excluding transformers)	\$12,000,000
Other:	
Dechlorination System	\$500,000
Paralined Steel Piping	\$18,222,000
Fiberglass Reinforced Plastic Piping	\$1,072,000
Instrumentation and Controls	\$4,254,000
Sewage Treatment Plant	\$300,000
Total Major Equipment Procurement Cost	\$248,189,000

**Excludes shipping, taxes, import fees, etc.*

Table 11: Major Equipment Procurement Cost*




Figure 17 – Conceptual Installation and Plume – Perspective From Ocean

Acronyms and Abbreviations

A&G	Administrative & General
AFUDC	Accumulated Funds Used During Construction
APCD	Air Pollution Control District
ASW	Auxiliary Saltwater
BOD	Biological Oxygen Demand
C	Celsius
CARB	California Air Resource Board
CCW	Component Cooling Water
CDP	Coastal Development Permit
CDR	Condensate Regeneration System
CFR	Code of Federal Regulations
Cu	Copper
CWP	Circulating Water Pump
CWT	Circulating Water Tunnel
CY	Cubic Yard
DCPP	Diablo Canyon Power Plant
EDG	Emergency Diesel Generator
ELGs	Effluent Limit Guidelines
EPA	Environmental Protection Agency
F	Fahrenheit
FHB	Fuel Handling Building
FSAR	Final Safety Analysis Report
GHG	Green House Gas
GPD	Gallons per Day
GPM	Gallons per Minute
HEI	Heat Exchange Institute
HMI	Human Machine Interface
hp	Horsepower
HX	Heat Exchanger
I&C	Instrumentation & Control
I&E	Impingement and Entrainment
I/O	Input/Output
ISO	Independent System Operator
ISFSI	Independent Spent Fuel Storage Installation
kW	Kilowatt
kV	Kilovolt
kVA	Kilovolt-Amps
LAR	License Amendment Request
LRW	Liquid Radioactive Waste
MGD	Million Gallons per Day
mg/L	Milligrams per Liter (parts per million)
MTCS	Main Turbine Control System
MVA	Million Volt-Amps
MWHR	Megawatt Hour

MWTS	Makeup Water Treatment System
NEI	Nuclear Energy Institute
NEPA	National Environmental Policy Act
NPDES	National Pollutant Discharge Elimination System
NRC	Nuclear Regulatory Commission
NWS	National Weather Service
OE	Operating Experience
OTC	Once-Through Cooling
PA	Protected Area (inside security perimeter)
PM ₁₀	Particulate Matter 10µm and smaller
PDN	Plant Data Network
PPC	Plant Process Computer
PTO	Permit to Operate
PSIG	Pounds per Square Inch Gauge
Q	Quarter
RO	Reverse Osmosis
RWQCB	Regional Water Quality Control Board
SACTI	Seasonal/Annual Cooling Tower Impact
SCW	Service Cooling Water
SER	Safety Evaluation Report
SGBD	Steam Generator Blowdown
SLO	San Luis Obispo
SONGS	San Onofre Nuclear Generating Station
SSPS	Solid State Protective System
SWRCB	State Water Resources Control Board
SWRO	Seawater Reverse Osmosis
TBS	Turbine Building Sump
TDH	Total Differential Head
TDS	Total Dissolved Solids
ug/L	Micrograms per Liter (parts per billion)
UPS	Uninterruptable Power System
UV	Ultra Violet
WB	Wet Bulb
ZLD	Zero Liquid Discharge

Appendix A-1
DCPP Cooling Tower Feasibility Study
Major Equipment Procurement Cost Summary

Mechanical Equipment:

Description	Quantity/Unit	Cost per Item	Total Price Per Unit	Total Price 2 Units
Cooling tower, mechanical draft (40 cells, each with 300HP fan, non plume-abated design; Back-to-back FRP; 60'x60' cell size - includes installation, excludes basin (Marley Corp.)	1	40,000,000	40,000,000	80,000,000
Condenser Waterbox/Tube Bundle Replacement Modules - Includes installation, excludes required modifications for access. (A Badcock Power Inc)	1	31,390,000	31,390,000	62,780,000
Circulating Water Pumps 215,000 GPM x 110' TDH, Model 106 APH 327 RPM 13.2kV 7600 HP Motor AL6XN Construction (Flowserve Corp.)	5	4,640,000	23,200,000	46,400,000
Makeup Water Pump 22,500 GPM x 216' TDH Model 56APK 720 RPM 1600 HP motor 2205 Duplex Construction (Flowserve Corp)	3	636,667	1,910,001	3,820,002
Service Cooling Water Seawater Supply Pumps 3150 GPM x 86' TDH, Model 16ENL 1800 RPM 460V 100 HP Motor 2205 Duplex Construction (Flowserve Corp)	3	180,000	540,000	1,080,000
36" butterfly valves motor-controlled for isolation Henry Pratt Model XR-70 150B Flanged Cast iron body with rubber lining Stainless steel disc edge & shaft Teflon-lined Fiberglass-backed	41	19,900	815,900	1,631,800
36" butterfly valves manual gear/hand wheel actuator for flow balance, placed at each cell Henry Pratt Model XR-70 150B Flanged Cast iron body with rubber lining Stainless steel disc edge & shaft Teflon-lined Fiberglass-backed	40	12,500	500,000	1,000,000
78" Henry Pratt Model XR-70 150B flanged butterfly valve Electrical motor operator Ductile Iron body with rubber lining Stainless steel disc edge & shaft Telfon-lined fiberglass-backed bearings	5	82,500	412,500	825,000
96" Henry Pratt Model XR-70 150B Flanged butterfly valves Electrical motor operator Ductile iron body with rubber lining Stainless steel disc edge & seat Teflon-lined fiberglass-backed bearings	2	135,500	271,000	542,000
20" Henry Pratt Model XR Flanged Butterfly Valves Electrical motor operator	1	12,500	12,500	25,000
Upgraded package sewage treatment system for both units				300,500
Major Mechanical Equipment Total Cost				198,404,302

Appendix A-1
DCPP Cooling Tower Feasibility Study
Major Equipment Procurement Cost Summary

Electrical Equipment:

Description	Quantity/Unit	Cost per Item	Total Price Per Unit	Total Price 2 Units
500kV/13.8kV 64MVA AUX transformers with DETC on HV side, +/-2x2.5% HV wye connection graded insulation 2V delta connection HV-B1L 1425kV, HV-neutral BIL 150kV	2	2,000,000	4,000,000	8,000,000
13.8kV/4kV 5.4 MVA oilfilled transformers with DETC	3	420,000	1,260,000	2,520,000
12kV/4 kV 9.0MVA oilfilled transformers with DETC for intake structure	1	420,000	420,000	840,000
Cooling tower electrical building with lineup of 5 kV Outdoor metal clad switchgear consisting of (3) 5 kV, 1200A incoming cubicles, (36) 5kV, 1200A Feeder Cubicles, & (1) 5kV, 1200A Future Feeder Cubicle, HVAC's, Battery Systems, & Work Space. Bldg is approx 161' long x 16' wide x 12' 11 gage coated steel. Foundation not included	1	2,869,555	2,869,555	2,869,555
4160v/440v 550 kVA oil-filled transformers	4	30,000	120,000	240,000
1 complete breaker-and-a-half bay (consisting of (3) 500kV circuit breakers, at least 6 breaker disconnect switches, 2 main bus extensions, all required CCVT's, 2 sets of 500 kV metering units each with a pair of isolation switches)			12,000,000	12,000,000
Major Electrical Equipment Procurement Cost				26,469,555

Dechlorination System:

Dechlorination System	1	250,000	250,000	500,000
-----------------------	---	---------	---------	----------------

Paralined Steel Piping:

Description	Quantity/Unit	Cost per Item	Total Price Per Unit	Total Price 2 Units
Circulating Water Tower Feed Lines 1440' long 8' dia pipe			2,770,164	5,540,328
Circulating Water Tower Feed Lines 800' long 6' dia pipe			1,079,240	2,158,480
Circulating Water Tower Feed Lines 480' long 4' dia pipe			376,332	752,664
Service Cooling Water Seawater Supply 16" dia pipe, 30 ft long coming off from each pump			18,095	36,190
Service Cooling Water Seawater Supply 4200' long 20" dia pipe			838,255	1,956,770
Makeup Water Line 600' long 48" dia pipe			470,430	940,860
Makeup Water Line 70' long 36" dia pipe			42,014	84,028
Blowdown Discharge 1600' long 36" dia pipe			762,680	1,525,360
Pump discharge 78" paralined steel, ~32ft long			120,378	240,756
Tee's, elbows, & flanges				5,334,058
Paralined Steel Piping Procurement Cost:				18,569,494

Appendix A-1
DCPP Cooling Tower Feasibility Study
Major Equipment Procurement Cost Summary

Fiberglass Piping:

36" fiberglass pipe: 600' of pipe w/ diffuser nozzles & 800' w/o difuser nozzles	1,072,050
--	------------------

Instrumentation and Controls:

Description	Quantity/Unit	Cost per Item	Total Price Per Unit	Total Price 2 Units
GE Fanuc Operator touchscreens	4	7,520	35,081	70,161
Triconex control system and vendor engineering	1		952,553	1,905,105
Bently Nevada vibration monitoring system, vendor engineering, and software licenses	1		583,764	1,167,529
Uninterruptible power supplies	2	44,950	89,899	179,799
36" magnetic flowmeters	2	69,721	139,443	278,885
Chemistry monitors	1 lot		100,000	200,000
Field instruments	1 lot		126,400	252,800
Cal ISO interface equipment	2		100,000	200,000
Major I&C Equipment Procurement Cost:				4,254,279

Total Major Equipment Procurement Cost	\$249,269,680
---	----------------------

Appendix A-2
DCPP Cooling Tower Feasibility Study
Equipment List

List of Major Equipment (Total for BOTH UNITS)

Mechanical Equipment

- 1) (2) Mechanical Draft Non Plume-Abated Saltwater Cooling Towers, Each w/ 40 cells, each cell 60' x 60' plan w/ 300 hp fan.
- 2) (2) Condenser Modules 90,000 0.75" OD x 22BWG titanium tubes, surface area of 716,800 ft², pressure drop of 10.65 ft H₂O at 862,690 GPM
- 3) (10) Circulating Water Pumps, 215,000gpm x 110' tdh vertical, Flowserve Model 106APH w/ 327 rpm 13.2kV 7600 hp WPII Induction Motor.
- 4) (6) Makeup Water Pumps, 22,500 gpm x 216' tdh vertical, Flowserve Model 56APK w/ 720 rpm 4kV 1600 hp WPII motor.
- 5) (6) Service Cooling Water Seawater Supply Pumps, 3150 gpm x 86' tdh vertical, Flowserve Model 16ENL w/ 1800 rpm 460V 100 hp WPII motor.
- 6) (82) 36" Henry Pratt Model XR-70 150B flanged butterfly valves w/ replaceable packing bonnet & elec. mtr op, cast iron w/ rubber lining body, ductile iron w/ rubber lining disc, stainless steel disc edge & shaft, Teflon-lined Fiberglass-back bearings. (1) valve at each cooling tower cell for isolation. (1) valve at discharge of each makeup water pump.
- 7) (80) 36" Henry Pratt Model XR-70 150B flanged butterfly valves w/ manual gear/hand wheel actuator, cast iron w/ rubber lining body, ductile iron w/ rubber lining disc, stainless steel disc edge & shaft, Teflon-lined Fiberglass-back bearings. (1) valve at each cooling tower cell for flow balance.
- 8) (10) 78" Henry Pratt Model XR-70 150B flanged butterfly valve w/ replaceable packing bonnet & electrical motor operator, ductile iron w/ rubber lining body & disc, stainless steel disc edge & shaft, Telfon-lined fiberglass-backed bearings. (1) valve at discharge of each circulating water pump.
- 9) (4) 96" Henry Pratt Model XR-70 150B Flanged butterfly valves w/ replaceable packing bonnet & electrical motor operator, ductile iron w/ rubber lining & disc, stainless steel disc edge & seat, Teflon-lined fiberglass-backed bearings. (2) valves at the common discharge line where 5 discharge pumps connect.
- 10) (2) 20" Henry Pratt Model 2FII 150B Flanged Butterfly valves with replaceable packing bonnet & electrical motor operator, cast iron with rubber lining. Valves at the service cooling seawater supply line before the blowdown inlet.
- 11) Upgraded packaged sewage treatment system consisting of flow equalization tank, aeration tank, clarifier, clearwell, pressurized multimedia filtration system, anoxic tank for nitrate reduction and UV light system for disinfection.

Electrical Equipment

- 1) (4) HV Transformers, each 64MVA, 500/13.8kV AUX w/o CTs, arresters, w/ DETC on HV side, HV wye connection graded insulation, LV delta connection, HV-BIL 1425kV, HV-neutral BIL 150kV.
- 2) (6) Medium Voltage Cooling Tower Transformers, each 5.4MVA, 13.8kV/4kV oil filled w/ DETC.

Appendix A-2
DCPP Cooling Tower Feasibility Study
Equipment List

- 3) (2) Medium Voltage Intake Structure Auxiliary Transformers, each 9 MVA, 12kV/4kV oil-filled w/ DETC.
- 4) (1) Electrical Equipment Houses, each 177'L x 16'W x 12' H, of 11 gauge coated steel, (5) 15kV/1200A metalclad switchgear breakers & (1) Lineup of 5kV Outdoor Metalclad Switchgear consisting of (3) 5kV/1200A Incoming Cubicles, (36) 5kV/1200A Feeder Cubicles, & (1) 5kV/1200A future Feeder Cubicle, HVAC's, Battery Systems, & Work Space. Building is approximately 161'long x16'wide x 12', 11 gage coated steel. Foundation is not included.
- 5) (2) 4160v/440v 550kVA oil-filled transformers for Service Cooling Water Seawater Supply pump motor.
- 6) (1) complete breaker-and-a-half bay consisting of (3) 500kV circuit breakers, no fewer than 6 breaker disconnect switches, (2) main bus extensions, all required CCVT's (2) sets of 500KV metering units each with a pair of isolation switches.

Paralined Steel Piping (total for both units):

Circulating Water Tower Feed Lines: 2880' long 8' dia. Pipe.

Circulating Water Tower Feed Lines: 1600' long 6' dia. Pipe.

Circulating Water Tower Feed Lines: 960' long 4' dia. Pipe.

Service Cooling Water Seawater Supply: 16" dia. pipe, 30 ft long coming off from each pump.

Service Cooling Water Seawater Supply: 8400' long 20" dia. Pipe.

Makeup Water Line: 1200' long 48" dia. pipe.

Makeup Water Line: 140' long 36" dia. pipe.

Blowdown Discharge: 3200' long 36" dia. pipe.

Pump discharge: 78" paralined steel, ~32ft long.

Tee fittings: (32) 96" dia., (32) 72" dia., & (8) 48" dia..

90° elbows: (4) 96" dia., (10) 48" dia. (38) 20" dia. & (18) 32" dia..

45° elbows: (2) 36" dia. & (24) 20" dia..

30° elbows: (2) 48" dia., (2) 36" dia., (4) 32" dia., & (8) 20" dia..

36" diameter Fiberglass Pipe (for both units):

36" dia. 1400' total, 1.199" thick wall, 3/8" thick stiffeners, 400' with (80) FRP couplings mounted in (2) rows the length of the pipe, 12" on centers.

(2) 50 PSI rated flanges both ends.

Instrumentation and Controls Equipment

- 1) (8) GE Fanuc 15" touch screen PC operator interfaces with Wonderware software.
- 2) (2) Triconex model 8110 main chassis.
- 3) (8) Triconex model 8111 expansion chassis.
- 4) (6) Triconex model 9000 expansion chassis I/O bus cable.
- 5) (20) Triconex model 8310 chassis power module.
- 6) (6) Triconex model 3008 main processors.
- 7) (8) Triconex model 4352A TCM communications module.
- 8) (40) Triconex model 3501E/T digital input module.

Appendix A-2
DCPP Cooling Tower Feasibility Study
Equipment List

- 9) (80) Triconex model 9563-810 digital input field termination module.
- 10) (26) Triconex model 3636R/T relay output module.
- 11) (52) Triconex model 9668-110 relay output field termination module.
- 12) (18) Triconex model 3700 0-5VDC analog input module.
- 13) (36) Triconex model 9771-210 analog input field termination module.
- 14) (10) Triconex model 3706A thermocouple analog input module.
- 15) (20) Triconex model 9764-310 thermocouple input field termination module.
- 16) (4) Triconex model 3511 pulse input module.
- 17) (4) Triconex model 9753-110 pulse input field termination module.
- 18) (1) Triconex model 7254-4 Trisation license.
- 19) (1) Triconex model 7260 diagnostics monitor license.
- 20) (8) Kepco model HSP 28-36MR 24 VDC power supply.
- 21) (8) Kepco model HSP 48-36MR 48 VDC power supply.
- 22) (8) Garrettcom model 6K16 fiber switches.
- 23) (2) Kontron Compact PCI maintenance PC.
- 24) (2) Nematron model LM8006-2WO maintenance HMI.
- 25) (12) Triconex system cabinets.
- 26) (14) Bently Nevada model 3500/05 racks.
- 27) (28) Bently Nevada model 3500/15 power supplies.
- 28) (14) Bently Nevada model 3500/22 TDI transient data interface modules.
- 29) (14) Bently Nevada model 3500/92 gateway communication modules.
- 30) (14) Bently Nevada model 3500/25 keyphasor modules.
- 31) (54) Bently Nevada model 3500/42 proximito/velometer modules.
- 32) (62) Bently Nevada model 3500/42 proximito/velometer modules with modification for triaxial accelerometers.
- 33) (8) Bently Nevada model 3500/33 relay output modules.
- 34) (4) Bently Nevada model 3500/92 VGA modules.
- 35) (4) Bently Nevada model 3500/94 touch screen HMIs.
- 36) (10) Bently Nevada system cabinets.
- 37) (2) Bently Nevada System 1 server.
- 38) (1) Bently Nevada 3500 software and licenses and System 1 licenses.
- 39) (4) 5KVA UPS with 120 VAC input and output and integral sealed batteries.
- 40) (4) 36" flanged magnetic flowmeters.
- 41) (96) Temperature transmitters.
- 42) (lot) Chemistry monitors.
- 43) (lot) Miscellaneous instrumentation.
- 44) (2) Interface equipment for Cal ISO.

Commodities

- 1) 13.8kV insulated cable
- 2) 4kV insulated cable
- 3) Carbon Steel Pipe with internal "Paraline" coating.

**Appendix A-3
Cooling Tower Feasibility Study
Estimate of Engineering**

Pre-Procurement Design Engineering

Discipline	No. of Workers	Duration	Hrs/Month	Total Hrs
Management	2	30	160	9,600
Administration	2	30	160	9,600
Mechanical	6	30	160	28,800
Civil/Arch	6	30	160	28,800
Electrical	5	24	160	19,200
I&C	2	18	160	5,760
Planning/Scheduling	3	24	160	11,520
Piping	3	18	160	8,640
Layout	4	18	160	11,520
Permitting/Environmental	4	30	160	19,200
Licensing	4	30	160	19,200
Total Hours				171,840

Appendix A-4
DCPP Cooling Tower Feasibility Study
Design Change Package Estimate

Project Description	Engineering Hours									
	Mechanical	Piping	Civil	I&C	Electrical	Seismic	Environmental	Operating, Loop Test, & STP Procedures	PMT Procedure Preparation	Others
	Excavation for cooling towers at a base elevation of ~85' incl, soil/geotech calcs, excavation planning, dwg preparation, access assessment, scheduling	400		2000				400		
Cooling towers basin construction, incl soil/geotech calcs, excavation planning, dwg preparation, foundation design.	200		2000							
ISFSI haul road reconstruction, incl heavy load study, soil/geotech coord, road foundation dsgn, ISFSI FSAR Update, LAR Coord, security review	200	200	3000		200	500				1000
Temporary Access route construction, incl soils/geotech coord, foundation dsgn, security review, interference coord	200		3000		600					200
Lighting for cooling towers, incl temporary & permanent, load dsgn, circuit analysis, conduit dsgn, O&M review	1000		1000		1000			200	200	200
New conduit tunnels from condenser discharge to cooling towers, incl soils/geotech dsgn, surveying reqts, flow resistance calcs, civil dsgn, concrete/rebar calcs, O&M review, dwg preparation, security review, interference coord.	600	1000	3,000	200	1000	2000	400	200	400	200
Circulating Water Pump Pit construction, incl soils/geotech coord, concrete/rebar dsgn, hydraulic review, O&M review, pump vendor coord.	2000		3000	200						200
Cooling Towers Electrical Building & Transformer Yard, incl soils/geotech coord, foundation dsgn, electrical safety review, security review, O&M review	2000		2000	500	3,000					100
Modification of the 500kV switchyard to install 500kV/13.8kV 62MVA AUX transformers, incl soils/geotech input, electrical safety review, relocation of interferences, Cal ISO coord, O&M review.	2000		2000	1000	3000	1000		800	800	
Power supply and controls to cooling tower fans, incl vendor coord, excavation planning, soils/geotech coord, O&M review, conduit support	3000		2000	200	5000			400	400	

Appendix A-4
DCPP Cooling Tower Feasibility Study
Design Change Package Estimate

Project Description	Engineering Hours									
	Mechanical	Piping	Civil	I&C	Electrical	Seismic	Environmental	Operating, Loop Test, & STP Procedures	PMT Procedure Preparation	Others
	Installation of CW pumps, 8' dia paralined steel pipe at pump pit, other individual I.o. pumps, HXs & valves, incl vendor coord, O&M review, civil/electr/I&C/piping support, installation planning/scheduling	4000	3000	2000	200	2000			400	400
Installation of CW Piping, incl planning/scheduling, access planning, concrete logistics, O&M, security review, soils/geotech coord, utility interference review	5000	1,500	4,000	100				200	200	
Installation of Piping at Cooling Tower Cell interface (w/ valves, motor operators), incl piping support, soils coord, O&M review.	5000	5000	2000	200	1200			400	400	
New Makeup Water Supply Piping & M.O.Valves, incl piping, intake structure mods, restraint dsgn, soils/geotech coord, O&M review, security, coord w/ circ wtr conduits, utility interferences.	1000	1500	1,500	200	1000			200	200	
Installation of makeup water pumps, incl intake structure mods, I.o clrs, O&M review, security, utility interference.	2,000	400	1000	200	600			400	400	
Modification of sodium hypochlorite injection system, incl pipe routing, support, environmental/safety review, O&M review,	2000	1000	1000	500	200		400	200	200	
Power Supply for New Svc Clg Water Seawater Supply & Makeup Pumps, incl 12kV/4kV & 4kv/440v xfms, conduit routing, I&C coord, O&M review, Security & Electr Safety review	2000	600	2000	200	5000			400	400	
Turbine Building Structural Modification to Accommodate new Svc Clg Water Seawater Supply & Return Lines, incl piping & structural support analysis, O&M review, access study, planning & scheduling, temporary equipment relocation, security review	800	2,000	2,000	200	1,000	2,000				
Installation of Svc Clg Water Seawater Supply (SCWSS) Piping & Valves, incl piping, intake structure mods, restraint dsgn, soils/geotech coord, O&M review, security, coord w/ circ wtr conduits, utility interferences.	1,000	3,000	3000	200				200	200	

Appendix A-4
DCPP Cooling Tower Feasibility Study
Design Change Package Estimate

Project Description	Engineering Hours									
	Mechanical	Piping	Civil	I&C	Electrical	Seismic	Environmental	Operating, Loop Test, & STP Procedures	PMT Procedure Preparation	Others
	Installation of SCWSS Pumps, incl intake structure mods, O&M review, security & utility interference reviews, I&C interface to control room, local control stations.	2,000		2000	200	1,000			400	400
Blowdown system piping installation, incl weir discharge structure, pipe routing, O&M review, permit coord w/ Cal Coastal Comm, Regional Water Quality board, diffusion study coord.	1,400	2,000	3,000	200	400		1200	200	200	
Procurement of Circ Water Pumps, incl spec development, interdiscipline coord, O&M review, bidding, evaluation, award, vendor print review, procurement support	4000	200	400	200	2000					1200
Procurement of Makeup Water Pumps, incl spec development, interdiscipline coord, O&M review, bidding, evaluation, award, vendor print review, procurement support	1600	40	200	200	1000					1000
Procurement of Svc Clg Wtr Seawater Supply Pumps, incl spec development, interdiscipline coord, O&M review, bidding, evaluation, award, vendor print review, procurement support	1200	40	200	200	800					800
Procurement of Paralined Steel Piping, incl spec development, mech & piping coord, San Ramon coatings group coord, procurement support	200	1600	200							800
Procurement of (2) 500kV/13.8kV 62 MVA Aux transformers w/ DETC on HV Side, incl spec development, interdiscipline coord, O&M review, bidding, evaluation, award, vendor print review, fire protection & procurement support.	300		800	200	2000					400
Procurement of (6) 13.8kV/4kV 5.4 MVA Aux transformers, oil filled w/ DETC, incl spec development, interdiscipline coord, O&M review, bidding, evaluation, award, vendor print review, fire protection & procurement support.	200		800	200	1600					400

**Appendix A-4
DCPP Cooling Tower Feasibility Study
Design Change Package Estimate**

Project Description	Engineering Hours									
	Mechanical	Piping	Civil	I&C	Electrical	Seismic	Environmental	Operating, Loop Test, & STP Procedures	PMT Procedure Preparation	Others
	Procurement of (2) 12kV/4kV 8.0 MVA Aux transformers, oil filled w/ DETC, for intake structure, incl spec development, interdiscipline coord, O&M review, bidding, evaluation, award, vendor print review, fire protection & procurement support.	200		800	200	1600				
Procurement of (3) SF6500kV breakers, 550kV, 3000 Amps CC, 55 kAIC, 500 Amps, incl spec development, interdiscipline coord, O&M review, bidding, evaluation, award, vendor print review, procurement support.	200		800	200	2000					
Procurement of (2) Clg Twr Electrical Buildings, 177' L x 16'W, incl spec development, interdiscipline coord, O&M review, bidding, evaluation, award, vendor print review, fire protection & procurement support.	400		1600	200	2600					200
Procurement of (1) 500kV Electric Current metering system, incl spec development, interdiscipline coord, O&M review, bidding, evaluation, award, vendor print review, procurement support.	200		400	200	1600					
Procurement of (2) 4kV/460V 550 kVA Aux transformers, oil filled, for intake structure, incl spec development, interdiscipline coord, O&M review, bidding, evaluation, award, vendor print review, fire protection & procurement support.	200		800	200	1200					100
Procurement of Triconex control system, coordination with supplier, drawing review, and factory testing.				2000	200					
Procurement of Bently Nevada vibration monitoring system, coordination with supplier, drawing review, and factory testing.				1000	200					
Procurement of control system UPS's, coordination with supplier, drawing review, and factory testing.				200	1000					

Appendix A-4
DCPP Cooling Tower Feasibility Study
Design Change Package Estimate

Project Description	Engineering Hours									
	Mechanical	Piping	Civil	I&C	Electrical	Seismic	Environmental	Operating, Loop Test, & STP Procedures	PMT Procedure Preparation	Others
	Procurement and drawing review for flowmeters and miscellaneous instrumentation.				500	50				
Preparation of DCPs for control system.			1000	12000	16000	1000		8000	8000	
Licensing Amendment Request and Evaluation	3000	400	2000	1000	2000	400	2000			
Main Condenser Waterbox/Tubesheet/Tube Bundle Modification	3000	400	1000	200	300			400	400	
Turbine Buling Flooding Reanalyses	400		400	400	400					
Special Analyses (such as water hammer, circ pump pit modelling)	2000		1200		1600					1000
Contingency hours (20% of the hours)	10980	4776	11820	4760	12870	1380	880	2600	2640	1600
Total Hours	65,880	28,656	70,920	28,560	77,220	8,280	5,280	15,600	15,840	9,600
Total Hours										325,836

Notes:



1. Technical coordinator, ESC designer, and drafter hours are included in engineering estimates.

**Appendix A-5
DCPP Cooling Tower Feasibility Study
Vendor Pump Quotes**

**Makeup Water Pumps
VERTICAL CIRCULATING PUMP - STYLE AFS**

PRELIMINARY OUTLINE DRAWING

DISCHARGE FLANGE DETAILS	
NOMINAL SIZE	30"
FLANGE O.D.	38 3/4"
Ø BOLT CIRCLE	36"
NO. HOLES	28
Ø HOLES	1 3/8"



RATED OPERATING CONDITIONS	
CAPACITY - GPM	22,500 GPM
TDH IN FEET	150.00 ft
MOTOR HORSEPOWER	1150 HP
SPEED IN RPM	720 RPM

210
216'
1470 HP


Makeup water pumps

NOTE: DIMENSIONS ARE PRELIMINARY AND ARE NOT TO BE USED FOR CONSTRUCTION PURPOSES.

USER: Diablo Canyon Nuclear	DRAWN BY: TMH	DATE: 30JA08	PROP. NO. 0240-70066
LOCATION:			DRAWING NO. SK-1
ENGINEER: Enercon	FLOWSERVE		
PUMP SIZE AND TYPE: 42KXH			

Appendix A-5 DCPP Cooling Tower Feasibility Study Vendor Pump Quotes Service Cooling Water Seawater Supply Pumps


	<p>Customer : Enercon Item number : CWS Pump Service : Cooling Water Supply Vendor reference : 0240-70066 Date : January 31, 2008</p>	<p>Pump size & type : 16ENL Based on curve no. : EC-2339 Number of stages : 1</p>
<p>Capacity : 3150.0 USgpm Specific gravity : 1.000 Head : 86.00 ft Pump speed : 1775 rpm</p>		
<p>CURVES ARE APPROXIMATE. PUMP IS GUARANTEED FOR ONE SET OF CONDITIONS: CAPACITY, HEAD, AND EFFICIENCY.</p>		



Appendix A-5 DCPP Cooling Tower Feasibility Study Vendor Pump Quotes

Service Cooling Water Seawater Supply Pumps

Full Page GA Drawing




All dimensions are in inches unless otherwise specified

Customer : Enercon Item number : CWS Pump Service : Cooling Water Supply Customer PO # : Vendor reference : 0240-70066 Rev. A	Pump size & type : 16ENL Pump speed / Stages : 1775 rpm / 1 Flow / Head : 3150.0 USgpm / 86.00 ft Driver power / Frame : 100 hp / 74.6 kW / - Volts / Phase / Hz : 230/460 / 3 / -	Drawing number : Date : January 31, 2008 Certified by / Date : Seal type : Seal flush plan : None	WinPROS+ V3.2.3 Copyright © 2004, Flowserve. All rights reserved.
---	--	---	--





**Appendix A-5
DCPP Cooling Tower Feasibility Study
Vendor Pump Quotes
Circulating Water Pumps**



Appendix A-5
DCPP Cooling Tower Feasibility Study
Vendor Pump Quotes
Circulating Water Pumps
VERTICAL CIRCULATING PUMP - STYLE AFS

PRELIMINARY OUTLINE DRAWING

DISCHARGE FLANGE DETAILS	
NOMINAL SIZE	78 "
FLANGE O.D.	93 "
Ø BOLT CIRCLE	89 "
NO. HOLES	64
Ø HOLES	2 1/8 "



RATED OPERATING CONDITIONS	
CAPACITY - GPM	215,000 GPM
TDH IN FEET	104.00 ft
MOTOR HORSEPOWER	7200 HP
SPEED IN RPM	327 RPM

NOTE: DIMENSIONS ARE PRELIMINARY AND ARE NOT TO BE USED FOR CONSTRUCTION PURPOSES.

USER: Diablo Canyon Nuclear	DRAWN BY: T. Hunt	DATE: 18JA08	PROP. NO. 0240-70066
LOCATION:			
ENGINEER: Enercon	FLOWSERVE		DRAWING NO. SK-1
PUMP SIZE AND TYPE: 106APH 1-Stg VCT			

Appendix A-6
DCPP Cooling Tower Feasibility Study

I&C Detailed Material and Vendor Engineering Cost Estimate

Assumptions:

1. Valves are covered in other estimates.
2. Vibration, temperature, and other sensors on equipment are included in equipment costs.
3. All costs are in 2008 dollars.

Operator Touchscreens:

Manufacturer	Model Number	Description	Quantity per Unit	Cost per Item	Total Cost per Unit	Total Cost for Both Units	Notes
GE Fanuc	IC5005	15" touchscreen PC operator interface	4	\$7,520	\$30,081	\$60,161	2
Wonderware		Wonderware license			\$5,000	\$10,000	5
Touch Screen Total Cost					\$35,081	\$70,161	

Triconex Supplied Equipment and Engineering:

Manufacturer	Model Number	Description	Quantity per Unit	Cost per Item	Total Cost per Unit	Total Cost for Both Units	Notes
Triconex	8110	Main chassis	1	\$7,778	\$7,778	\$15,556	3
Triconex	8111	Expansion chassis	4	\$6,546	\$26,184	\$52,369	3
Triconex	9000	Expansion chassis IO bus cable	3	\$513	\$1,539	\$3,078	3
Triconex	8310	Chassis power module	10	\$2,303	\$23,026	\$46,053	3
Triconex	3008	Main Processors	3	\$12,982	\$38,946	\$77,893	3
Triconex	4352A	TCM communication module with multimode fiber	4	\$12,040	\$48,158	\$96,316	3
Triconex	3501E/T	Digital input module (32 points)	20	\$5,076	\$101,519	\$203,038	3
Triconex	9563-810	Field termination module for digital inputs (16 points)	40	\$1,013	\$40,511	\$81,022	3
Triconex	3636R/T	Relay output module (32 points)	13	\$5,558	\$72,248	\$144,496	3
Triconex	9668-110	Field termination module for relay outputs (16 points)	26	\$1,013	\$26,332	\$52,664	3
Triconex	3700	0-5 VDC analog input module (32 points)	9	\$9,378	\$84,398	\$168,795	3
Triconex	9771-210	Field termination module for analog inputs (16 points)	18	\$1,013	\$18,230	\$36,460	3
Triconex	3706A	Thermocouple analog input module (32 points)	5	\$9,378	\$46,888	\$93,775	3
Triconex	9764-310	Field termination module for thermocouple inputs (16 points)	10	\$2,491	\$24,914	\$49,828	3
Triconex	3511	Pulse input module (8 points)	2	\$6,100	\$12,199	\$24,398	2

Appendix A-6
DCPP Cooling Tower Feasibility Study

I&C Detailed Material and Vendor Engineering Cost Estimate

Triconex	9753-110	Field termination module for pulse inputs (8 points)	2	\$1,013	\$2,026	\$4,051	4
Triconex	7254-4	Tristation 1131 license	1	\$4,840	\$4,840	\$9,680	3
Triconex	7260	Diagnostics monitor license	1	\$1,210	\$1,210	\$2,420	3
Kepeco	HSP 28-36MR	24 VDC power supply	4	\$2,355	\$9,419	\$18,837	2
Kepeco	HSP 48-36MR	48 VDC field power supply	4	\$2,355	\$9,419	\$18,837	2
Garretcom	6K16	Fiber switches	4	\$975	\$3,901	\$7,802	2
Kontron	Compact PCI	Maintenance PC	1	\$6,299	\$6,299	\$12,599	2
Nematron	LM8006-2WO	Maintenance HMI	1	\$2,570	\$2,570	\$5,140	2
		Cabinet	6	\$5,000	\$30,000	\$60,000	5
		Miscellaneous components	Lot	\$10,000	\$10,000	\$20,000	5
Triconex Total Material Cost					\$652,553	\$1,305,105	
System Integration Engineering (incl factory test)					\$100,000	\$200,000	5
Programming					\$150,000	\$300,000	5
Graphics Development					\$50,000	\$100,000	5
Triconex Total Cost					\$952,553	\$1,905,105	

Bently Nevada Equipment:

Manufacturer	Model Number	Description	Quantity per Unit	Cost per Item	Total Cost per Unit	Total Cost for Both Units	Notes
Bently Nevada	3500/05	3500 rack	7	\$5,000	\$35,000	\$70,000	5
Bently Nevada	3500/15	Power supply	14	\$311	\$4,354	\$8,707	2
Bently Nevada	3500/22	TDI transient data interface module	7	\$4,979	\$34,854	\$69,708	2
Bently Nevada	3500/92	Gateway communications module	7	\$842	\$5,895	\$11,790	2
Bently Nevada	3500/25	Keyphasor module	7	\$1,465	\$10,257	\$20,514	2
Bently Nevada	3500/42	Proximitor/velometer module	27	\$3,290	\$88,830	\$177,659	2
Bently Nevada	3500/42	Proximitor/velometer module with mod for triaxial accelerometers	31	\$4,091	\$126,821	\$253,643	2
Bently Nevada	3500/33	Relay output module	4	\$3,284	\$13,136	\$26,272	2
Bently Nevada	3500/92	VGA module	2	\$1,768	\$3,536	\$7,071	2
Bently Nevada	3500/94	Touchscreen HMI	2	\$8,310	\$16,621	\$33,241	2
		Cabinet	5	\$5,000	\$25,000	\$50,000	5
Bently Nevada		System 1 server	1	\$14,178	\$14,178	\$28,355	2
Bently Nevada		3500 software and licenses and System 1 license	1		\$105,284	\$210,568	6
Bently Nevada Total Material Cost					\$483,764	\$967,529	
System Integration Engineering					\$100,000	\$200,000	5
Bently Nevada Total Cost					\$583,764	\$1,167,529	

**Appendix A-6
DCPP Cooling Tower Feasibility Study**

I&C Detailed Material and Vendor Engineering Cost Estimate

UPS:

Manufacturer	Model Number	Description	Quantity per Unit	Cost per Item	Total Cost per Unit	Total Cost for Both Units	Notes
		5 KVA UPS with 120 VAC input and output and integral sealed batteries	2	\$44,950	\$89,899	\$179,799	7
Total UPS Cost					\$89,899	\$179,799	

Flowmeters:

Manufacturer	Model Number	Description	Quantity per Unit	Cost per Item	Total Cost per Unit	Total Cost for Both Units	Notes
		36" magnetic flowmeter with 300 lb flanges, remote electronics, teflon liner, and epoxy coated carbon steel body.	2	\$69,721	\$139,443	\$278,885	8
Total Flowmeter Cost					\$139,443	\$278,885	

Chemistry Instruments:

Manufacturer	Model Number	Description	Quantity per Unit	Cost per Item	Total Cost per Unit	Total Cost for Both Units	Notes
		Miscellaneous chemistry monitors			\$100,000	\$200,000	5
Total Chemistry Monitor Cost					\$100,000	\$200,000	

Field Instruments:

Manufacturer	Model Number	Description	Quantity per Unit	Cost per Item	Total Cost per Unit	Total Cost for Both Units	Notes
		Temperature transmitters	48	\$500	\$26,400	\$52,800	5
		Miscellaneous instruments			\$100,000	\$200,000	5
Total Field Instrument Cost					\$126,400	\$252,800	

**Appendix A-6
DCPP Cooling Tower Feasibility Study**

I&C Detailed Material and Vendor Engineering Cost Estimate

Cal ISO Interface Equipment:

Manufacturer	Model Number	Description	Quantity per Unit	Cost per Item	Total Cost per Unit	Total Cost for Both Units	Notes
		Servers, communication equipment, etc.			\$100,000	\$200,000	5
Total Cal ISO Interface Cost					\$100,000	\$200,000	

Total I&C Equipment and Vendor Engineering Cost	\$2,127,140	\$4,254,279
--	--------------------	--------------------

Notes:

1. All costs include 10% additional for tax and freight.
2. Cost is based on PIMS inventory parts catalog with 10% escalation and 10% for tax and freight.
3. Triconex material costs are based on 4/3/2007 quotation for another project with escalation of 10% to 2008 dollars and 10% additional for tax and freight.
4. Used 4/3/2007 quotation price for 9771-210 with 10% escalation and 10% tax and freight.
5. Assumed price based on experience.
6. Based on 12/2006 budgetary quote for a similar system. Escalated 10% and added 10% tax and freight.
7. Based on inventory parts catalog for 5KVA UPS. 2003 price was \$21,345. Assumed integral batteries increase price by 50% and escalated price to 2008 at 5% per year. Added 10% tax and freight.
8. Based on verbal quote from Rosemount.



SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP

TABLE of CONTENTS

1. PURPOSE	2
2. BACKGROUND	2
3. ASSUMPTIONS	3
4. DESIGN INPUTS	4
5. METHODOLOGY	9
6. ACCEPTANCE CRITERIA	14
7. CALCULATION	15
8. RESULTS	22
9. MARGIN ASSESSMENT	46
10. CONCLUSIONS	46
11. IMPACT EVALUATION	47
12. REFERENCES.	48
ATTACHMENT 1 - MISCELLANEOUS DATA SOURCES	49
ATTACHMENT 2 - FILES	57



SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP

Record of Revision

Revision 0: Initial Issue

1. PURPOSE

This calculation estimates plume characteristics for cooling towers at the Diablo Canyon Nuclear Power Plant (DCPP) owned by the Pacific Gas and Electric Company (PG&E). The characteristics of interest are visible plume lengths, fogging, and salt deposition on surrounding lands.

2. BACKGROUND

DCPP is located near Avila Beach, California, on the Pacific Coast. Figure 1 shows the site.

Currently, the plant is cooled by a once-through pass of ocean water. Diablo Canyon Power Plant (DCPP) could be subject to a requirement to retrofit the existing once-through cooling system to closed-cycle cooling.

Ongoing development of Federal Clean Water Act Section 316(b) regulations regarding aquatic organism Impingement and Entrainment (I & E) and a California Specific Policy for 316(b) rule implementation may require all coastal power plants to reduce marine I&E to levels commensurate with a closed-cycle cooling system. PG&E is investigating the use of cooling towers; however, cooling towers produce visible plumes and deposition of water and salt on the surrounding lands.

As part of the investigation, plume characteristics are quantified by use of the Seasonal/Annual Cooling Tower Impacts (SACTI) cooling tower plume model. This model was identified in Section 5.3.3.1 of the NRC's standard review plan (Reference 12.6) as an acceptable code for cooling tower plume impacts in the nuclear industry.



Appendix A-7

SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPD

3. ASSUMPTIONS

- 3.1. The meteorological data described in Section 5 are representative of future conditions.
- 3.2. The SACTI computer software is used with all its associated assumptions per Reference 12.2. It is noted that the accuracy of the SACTI code has been recognized by the NRC (Section 5.3.3.1 of Reference 12.6).
- 3.3. The meteorological data is a hybrid of various data sources, but the impact of merging these sources is assumed to be insignificant compared to the inherent uncertainties of predicting future meteorological conditions. The wind speeds and direction are taken from the site meteorology tower (Reference 12.3, referred to here as "site met data"), the temperature, humidity, and cloud cover data are from the Nation Weather Service station KSBP at San Luis Obispo (SLO) airport located 20 miles to the southeast (Reference 12.4), and the mixing height data is purchased from the National Climatic Data Center using their best information, which is upper air conditions at San Diego and surface conditions at SLO (Reference 12.5).
- 3.4. The terrain around DCPD in the direction of most plumes is grassland. Table D-1 of Reference 12.2 recommends use of 3.2 to 3.94 cm for grasslands, so a value of 3.5 cm is used.
- 3.5. A number of required but non-critical data inputs are based on scaling to the LMDCT example in the SACTI manual (Reference 12.2). The Reference 12.2 cell discharge diameter/center-to-center ratio is 9.14/11. The airflow rate to MW heat dissipation is 13818/1400 kg/sMW.
- 3.6. Since the cooling tower design is still in the conceptual phase, various characteristics of the cooling tower must be assumed. Attachment 1 (Reference 12.8) gives some of these values. A critical issue for this calculation is drift. Towers without drift eliminators have drift on the order of 0.01% of circulating water flow rate (Reference 12.7), while those with high efficiency drift eliminators have drift as low as 0.0005% of circulating water flow rate (page B-1-60 of Reference 12.9, reproduced in Attachment 1). This analysis assumes the high efficiency drift eliminators, which will tend to reduce deposition. It is noted that the authors have made this 0.0005% assumption for cooling tower analyses for new nuclear plant license applications.



SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP

4. DESIGN INPUTS

4.1 SITE DATA

- 4.1.1 Latitude: 35° 12' 30"N (Reference 12.1)
- 4.1.2 Longitude: 120° 51' 08"W (Reference 12.1)
- 4.1.3 Ground level elevation: 100' above mean sea level (Reference 12.1)
- 4.1.4 Ground characterization: although there is a steep drop-off to the west to 0' elevation and hills to the east at 800' elevation, the predominant winds blow along the coast line (NW or SE). In 2003, for example, 54% of the winds were from the northwest (+/- 22.5°) blowing towards the southeast and 20% were from the southeast (+/- 22.5°) blowing towards the northwest. These data are from Table 3 below that, despite being based on program output, is really an echo of the meteorological input data. In these NW and SE directions, the ground is relatively flat with grassland and low hills (Reference 12.1). The appropriate roughness is 3.5 cm per assumption 3.4.

Note: the site location is used for meteorological and insolation purposes. Insolation is the sunlight energy deposited at the site and is an input required by the SACTI code. The exact positioning of the towers within the site does not affect the study results, but the orientation with respect to North does.


Appendix A-7



Pacific Gas and Electric Company
Engineering - Calculation Sheet
Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
REV. NO. 0
SHEET NO. 5 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**





Appendix A-7

SUBJECT

Plume Characteristics of Proposed Cooling Towers at DCPD

Figure 1: DCPD Site and Cooling Tower Placement

4.2 METEOROLOGICAL DATA

- 4.2.1. Five years of hourly site met data collected from 1/1/2003 to 12/31/2007 (Reference 12.3)
- 4.2.2. Five years of hourly SLO airport met data, data collected from 1/1/2003 to 12/31/2007 (Reference 12.4)
- 4.2.3. Mixing height data purchased from NCDC from nearest possible sources (SLO ground data and San Diego upper air data). This mixing height data is located in the file dcpmix.txt for use by the code.
- 4.2.4. The tower height at which the met data was collected is about 10 m (Reference 12.8)

4.3 MECHANICAL FORCED-DRAFT COOLING TOWERS

- 4.1.1 The density of the circulation water is 64.5 lbm/ft³ per Reference 12.11, making it more dense than fresh water. The flow rate is 860,000 gpm per Ref. 12.8.
- 4.1.2 Heat rejected: The total heat rejection is 4469 MWs based on two units per Reference 12.15. This is very close to the existing condenser duty in Reference 12.14 ($2 \times 7,559 \text{ MBtu/hr} / 3.412 \text{ MW}/(\text{MBtu/hr}) = 4454 \text{ MWs}$). The loss of efficiency due to higher condenser back pressure due to the cooling towers is offset with a gain in efficiency due to new turbine rotors for a net small impact.
- 4.1.3 Drift is 0.0005% of circulating water flow per assumption 3.6. This makes the drift $.000005 \times 860,000 \text{ gpm/unit} \times 2 \text{ units} = 86 \text{ gpm total}$.
- 4.1.4 There are 20 cells per tower for a total of 80 cells for the site (Figure 1). They are arranged along an axis that is approximately 130 degrees east of north. The center to center distance between adjacent cells is 60 feet per Reference 12.10.
- 4.1.5 Height: 55' (17m) above ground level. This is an average height based on other mechanical draft towers, such as 55.4' for the example tower in Reference 12.2 and 52'7" for Marley mechanical draft towers at the Grand Gulf nuclear power plant.
- 4.1.6 Cell exit diameter: 50' (15m). This is a calculated diameter per assumption 3.5 based on a Reference 12.2 ratio of discharge diameter to center-to-center distance, specifically $9.14/11 \times 60' = 50'$.



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

- 4.1.7 Air flow rate for all cells combined (both units) is 44,100 kg/s. This is a calculated flow rate per assumption 3.5 based on a Reference 12.2 flow to MW ratio, specifically $13818/1400 \times 4469 = 44,100$ kg/s.
- 4.1.8 Sodium salts in cooling water: 40,500 ppm per Reference 12.8 assuming 1.5 concentration factor. By comparison to publish ocean salinity data, this is verified to be ppm by mass, so that the salt concentration can also be expressed as 0.0405 gm/gm.
- 4.1.9 Density of sodium salt: 2.17 gm/cm³. The value of 2.17 gm/cm is a generic value from the plume software manual for salts (pg. 4-54, Reference 12.2).
- 4.1.10 The total dissolved solids are 51,750 ppm or .0518 gm/gm per Reference 12.8.
- 4.1.11 Density of total dissolved solids: 2.17 gm/cm³. This number is developed using the constituencies listed in Reference 12.8 along with a variety of density sources. The development is included at the end of Attachment 1.
- 4.1.12 Drop Mass Spectrum: Values used in previous LMDCT modeling effort based on standard Marley forced draft cooling tower (Reference 12.7). The data provided by Marley did not contain bounding limits for smallest or largest size. Since the program requires this, arbitrary limits were added at half the smallest size and about twice the largest size listed by Marley.

Table 1: Drop Mass Spectrum

Mass in Range	Droplet Size in Microns Provided by Marley	Used in Program
0.12	<10 microns	5-10
0.08	10-15	10-15
0.20	15-35	15-35
0.20	35-65	35-65
0.20	65-115	65-115
0.10	115-170	115-170
0.05	170-230	170-230
0.04	230-375	230-375
0.008	375-525	375-525
0.002	>525	525-1000



SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**




Figure 2: Determination of cooling tower locations

Note: Due to code limitations, it is not possible to model 80 cells. Instead, a representative cell is located at the center of each group of four. The long axis angle based on the data of Table 2 is $90^\circ + \text{atan}(350/390) = 130^\circ$ east of north for three of the four housings, and close to this for the fourth.

Table 2: Approximate Cooling Tower X-Y Locations (ft and meters)

X-value (ft)	Y-Value (ft)	X-value (ft)	Y-Value (ft)	X-value (m)	Y-Value (m)	X-value (m)	Y-Value (m)
-200	450	300	-20	-61.0	137.2	91.4	-6.1
-102.5	362.5	397.5	-107.5	-31.2	110.5	121.2	-32.8
-5	275	495	-195	-1.5	83.8	150.9	-59.4
92.5	187.5	592.5	-282.5	28.2	57.2	180.6	-86.1
190	100	690	-370	57.9	30.5	210.3	-112.8
X-value (ft)	Y-Value (ft)	X-value (ft)	Y-Value (ft)	X-value (m)	Y-Value (m)	X-value (m)	Y-Value (m)
-590	250	-50	-110	-179.8	76.2	-15.2	-33.5
-492.5	162.5	47.5	-197.5	-150.1	49.5	14.5	-60.2
-395	75	145	-285	-120.4	22.9	44.2	-86.9
-297.5	-12.5	242.5	-372.5	-90.7	-3.8	73.9	-113.5
-200	-100	-400	400	-61.0	-30.5	-121.9	121.9



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

5. METHODOLOGY

5.1 Meteorological Data File

The meteorology data is put into the file dcppMet.txt. Its development involved format changes to match the CD144 format required by the SACTI code. The met data consists of downloaded NCDC data from the San Luis Obispo airport (SLO), and site data in Excel files DCP03.xls through DCP07.xls. These data files are included in the companion CD. The site data is used for wind speed and direction, but no data is collected relative to sky coverage or ceiling heights. It was also discovered that the dew point measurement at the site had a high allowable uncertainty associated with it (+/- 10°F) that impacted humidity estimates and therefore plume length estimates. Therefore the nearby SLO data is used for temperatures, humidity, and sky coverage.

San Luis Airport Data (Files 2003.xls, 2004.xls, 2005.xls, 2006.xls and 2007.xls)

The following data was collected from San Luis Obispo airport via the National Climatic Data Center (NCDC) on an hourly basis from 1/1/2003 through 12/31/2007.

sky cover ceiling dewpt drybulb wetbulb humidity

The raw data was down loaded into sixty files named 200301.txt, 200302.txt, 200303.txt ... 200712.txt. These were copied and renamed with the designator for comma separated files (200301.csv, 200302.csv, 200303.csv ... 200712.csv) so that Excel could open them properly. Once opened, all the year 2003 files were collected in order of January to December in the Excel spreadsheet 2003.xls, filling up rows 1 through 10,721. Similar files were created for 2004 through 2007.

Collecting the data for hourly times in columns ab through ah

The data is collected at times, using a 24 hour clock format, of 00:56, 01:56, 02:56 ... 23:56. Other times may appear in the data set when a particular event is noted. That is, many lines of the airport data must be ignored. This is accomplished by converting month/day/time to a single indicating number via the below formula, where B4 is the month (1 to 12), C4 is the day (1 to 31), and D4 is the 24 hour clock format time without the colon, i.e., 56, 156, 256 ... 2356.

$$=B4*10000+C4*100+IF(ROUND(D4/100,0)=24,IF(B4=B5,100,-C4*100+100+10000),(D4-INT(D4/100)*100)/56+INT(D4/100))$$

Thus all indications taken at 56 minutes after the hour give non-decimal numbers, specifically, 10100, 10101, 10102, ... 123123. Moving from right to left through these values, the first two decimals at right are the hours from 00 to 23, the next two are the day from 01 to 31, and the next one or two are the month from 1 to 12. The undesirable



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

data collected at times other than 56 minutes after the hour have digits after the decimal due to the /56 in the formula.

The desired times for the data are listed in cells aa2 through aa8761. Lookup functions then collect the desired data in cells ab2 through ah8761. For example, the raw data dew point is listed in column N. Cell aa4 is date 10104. To collect the desired dew point for January 1 at 4:00 am, the formula is:

= LOOKUP(\$AA4,\$A\$3:\$A\$11200,\$N\$3:\$N\$11200)

which looks for the date in cell aa4 in the column of data a3:a11200, and then returns the value in column N corresponding to that date.

Note that the data each year begins at 00:56 in the morning, so for our purpose, the last datum of the year (12/30 23:56) is interpreted as the first datum of the next year (1/1 00:00). The first datum of 2003 is copied from 1/1 00:56 to avoid look up errors for 1/1/2003 00:00.

Note also that for the leap year 2004, additional rows of data are added for 22900 through 22923, thus instead of 8760 rows of data, there are 8784 rows.

Sky Cover and Ceiling Height

For sky cover, the data key from the NCDC reads:

CLR: CLEAR BELOW 12,000 FT
 FEW: > 0/8 - 2/8 SKY COVER
 SCT SCATTERED: 3/8 - 4/8 SKY COVER
 BKN BROKEN: 5/8 - 7/8 SKY COVER
 OVC OVERCAST: 8/8 SKY COVER
 VVXXX INDICATES INDEFINITE CEILING WITH THE VERTICAL VISIBILITY (XXX)
 LISTED IN HUNDREDS OF FEET.

The spreadsheet converts "clr" to a skycover of 0; "few" to a skycover of 20% or an indicator of 2; "sct" to a skycover of 5; "bkn" to a skycover of 7; and either "ovc" or "vv" to a skycover indicator of "-", which indicates 100% coverage. This is done with a lookup table. The approach is to enter these values in three steps. First, the raw data is selected for the specific hourly rating in column AB:

=IF(LOOKUP(\$AA4,\$A\$3:\$A\$11200,\$G\$3:\$G\$11200)="",AB3,LOOKUP(\$AA4,\$A\$3:\$A\$11200,\$G\$3:\$G\$11200))

Example results here might be CLR, BKN110, SCT100, OVC010, or VV004. The purpose for the check for 45 blanks is that occasionally sky cover data is missing. In 2004, this occurred 10 times. In 2003, it occurred 35 times. It did not occur at all in 2005 or 2006. When missing, the previously recorded sky cover is used.



Appendix A-7

SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP

The second step is to identify the sky cover percentage in column AH using the first letter of the column AB value and a lookup table. The formula is:

=LOOKUP(LEFT(AB4,1),\$AK\$2:\$AK\$7,\$AL\$2:\$AL\$7)

where the lookup in cells ak2:al7 is:

B	7
C	0
F	2
O	-
S	5
V	-

The third step is to record the ceiling height if the AH cell is "-":

=IF(AH3="-",IF(LEFT(AB3)="V",MID(AB3,3,3),MID(AB3,4,3)),"---")

This formula collects the characters 3 through 5 if the initial letter is "V" and characters 4 through 6 otherwise, correctly getting the ceiling height from cell values such as OVC010 or VV00.

Dew Point, Dry Bulb, Wet Bulb, and Humidity

The dew point, dry bulb, wet bulb, and humidity are all selected without manipulation, in columns AD through AG as follows:

=LOOKUP(\$AA4,\$A\$3:\$A\$11200,\$N\$3:\$N\$11200)
 =LOOKUP(\$AA4,\$A\$3:\$A\$11200,\$J\$3:\$J\$11200)
 =LOOKUP(\$AA4,\$A\$3:\$A\$11200,\$L\$3:\$L\$11200)
 =LOOKUP(\$AA4,\$A\$3:\$A\$11200,\$P\$3:\$P\$11200)

Specific Data Manipulation

Occasionally, these formulas will fail to produce the desired result. This is often the fault of bad data or unique situations. They are discovered by searching for the character # in the values in Cells AB2 through AH8761. The following are identified:

2003 Manipulations

None required.

2004 Manipulations

In the month of February, 2004, for some reason the temperature data only appears in Celsius and not Fahrenheit. The Celsius data looks reasonable, so that for this month, the raw data values of "-" were replaced by formula (for example):

=IF(K907="-",K907,ROUND(K907*180/100+32,0))



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

This was also the case for wet bulb only in January 2004. The purpose of the check for "-" was to avoid errors for cases where the temperatures in degrees Celsius are also missing.

2005 Manipulations

The data format and columns changed in 2005 (also applies to 2006). The year month and day are all in column C in a format such as 20050101, while the time is in column D. So the new date value generation equation is:

$$=RIGHT(C4,4)*100+IF(INT(D4/100)+RIGHT(D4,2)/56=24,100,INT(D4/100)+RIGHT(D4,2)/56)$$

The sky cover moves from column G to column F
The dew point moves from column N to column T
The dry bulb temperature moves from column J to column L
The wet bulb temperature moves from column L to column P
The humidity moves from column P to column X

The greater number of columns causes the desired data to be relocated from columns AA through AH to columns BA through BH. Other than these location changes, there were no other changes and no unusual data required manipulation.

Note: missing data was represented by "M" instead of "-" in 2005-2006. This results in some data in the final columns to consist of the letter M.

2006 Manipulations

No data manipulation required other than what is described above for 2005.

2007 Manipulations

No data manipulation required other than what is described above for 2005.

Site Data (Files DCP03.xls, DCP04.xls, DCP05.xls, DCP06.xls, and DCP07 JANTDEC.xls)

The site data provides hourly wind speed and wind direction. The data at 10m is used. The 2007 data was supplied at a later time causing a different file name format, but no other impact. Only the two columns F and H, wind speed and wind direction at 10m, are utilized. Fortunately, the data is provided one row per hour, so no manipulation is required.

Site Data combined with SLO data (Files DCP2003.xls, DCP2004.xls, DCP2005.xls, DCP2006.xls, and DCP2007.xls)

The two site columns F and H, wind speed and wind direction, are copied into files DCP2003.xls through DCP2007.xls, into columns E&F (note: row1 data for 1/1 0:00 come from the last row of the previous year). The first few columns, A through D, are date columns indentifying each hour in the same manner as in the files 2003.xls through 2007.xls, that is, year (2003 to 2007), month (1 to 12), day (1 to 31) , and hour (0 to 23).



SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**

5.2 SACTI Input File

The data of Section 4 is used to develop the SACTI input file in Section 7. The SACTI file interacts with the Met data file to predict plume characteristics. The line by line development of the input file is described in Section 7.

6. ACCEPTANCE CRITERIA

There are no explicit acceptance criteria for plume characteristics.



Appendix A-7

SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP

7. CALCULATION

7.1 BACKGROUND

The plumes are modeled with the SACTI computer programs originally developed by the Electric Power Research Institute (EPRI). A copy of this code has been purchased directly from the author for use in analyses such as this one. The meteorological data is described in Section 5.1.

7.2 LMDCT MODEL DESCRIPTION

The Linear Mechanical Draft Fan Tower (LMDCT) has 80 cells in 4 housings. Unfortunately, SACTI is limited to just 20 as a practical maximum. The advised approach is to model the LMDCT with larger cells that represent the adjacent ones in the same number of housings. In this case, each housing, which is in reality two rows of 10 cells each, is modeled with one row of 5 cells. This simplification is a necessity of the code. Since the total mass and energy release is correct, and since the plumes will merge in a relatively short distance, the impact of the simplification is acceptable.

PREP (reads and analyzes met data, defines plume categories)

- card 1: Diablo Canyon: Linear Mechanical Cooling Tower Plume Model (80 cells)
card 2: ISTOP: Number of days in record period (43824 for the records available from the five years 2003 to 2007)
ISKIP: 1 to process every record
IOUT: 0 to generate full listing (1 to suppress)
IMIX: 2 to use daily mixing height data
IUR: 1 to use rural terrain
IWIND: 2 to use delta-T stability class method (sigma-T data is not available)
NFOG: 1 to calculate fogging and icing
NDRIFT: 1 to calculate drift
ITOWER: 3 to model linear mechanical draft cooling towers
ITAPE: 1 since data is in cd144 format
IZONE: 8 since Pacific Time Zone
card 3: ALAT: 35.21 (equals $35+12/60+30/3600$ from Input 4.1.1)
ALONG: 120.58 (equals $120+51/60+8/3600$ from Input 4.1.2)
ROUGHT: 3.5 cm per input 4.1.4
HREF: 10 m met tower per input 4.2.4
HTERR: 0 m terrain modification due to flat terrain
card 4: TWRHT: m tower height is 17m per input 4.3.5.
TWRDM: m effective diameter ($=\sqrt{\text{total area} \cdot 4/\pi}$) so $\pi D_e^2/4 = \text{total area}$). The single top diameter is 15m by input 4.3.6, giving a single cell area of $\pi 15^2/4$ so the effective diameter is $\sqrt{80 \cdot 15^2} = 134\text{m}$.



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**

TWRHE: Total heat dissipated is 4469 MWt as developed per input 4.3.1.

TWRAF: Total airflow is 50,000 kg/s per input 4.3.7.

card 5: Twelve monthly clearness index based on Santa Maria, CA data contained in the SACTI Manual (Reference 12.2) Appendix B. Values are, January to December:

.60 .63 .69 .66 .67 .71 .71 .69 .69 .70 .67 .62

card 6: Twelve monthly values for average daily insolation based on Santa Maria, CA data contained in the SACTI Manual (Reference 12.2) Appendix B. Values are, from January to December:

11.08 14.64 20.32 23.42 26.64 29.11 28.48 25.59 21.91 17.48 13.01 10.58

cards 7 to 12: Names of files containing data or being written. Note that the met data is in dcppMet.txt and the mixing height data is in dcppmix.txt.

The input file prep.usr is as follows:

```
Diablo Canyon: Linear Mechanical Cooling Tower Plume Model (80 cells)
35064      1 0 2 1 2 1 1 3 1 8
 35.21     120.58      3.5      10.0      0.0
 17.0      134.0      4469.0      44100.0
.60.63.69.66.67.71.71.69.69.70.67.62
11.0814.6420.3223.4226.6429.1128.4825.5921.9117.4813.0110.58
dcppMet.txt
fort.2
fort.3
fort.4
prep.out
dcppmix.txt
```

The input echo is repeated here to demonstrate correct input:

```
*****
*****
EPRI PLUME AND DRIFT ANALYSIS SYSTEM PREPROCESSOR CODE, PRE-RELEASE VERSION 09-01-90
CASE STUDY: Diablo Canyon: Linear Mechanical Cooling Tower Plume Model (80 cells)
*****
*****
```

INPUT INFORMATION

```
SURFACE TAPE TYPE:          CD144
TOWER TYPE:                 LINEAR MECHANICAL DRAFT
TOWER HEIGHT (M):          17.00
TOWER DIAMETER (M):        134.00
TOWER HEAT (KW):           4469000.00
TOWER AIR FLOW (KG/S):     44100.00
SITE LATITUDE:             35.21
SITE LONGITUDE:            120.58
SITE TIME ZONE:            PACIFIC
ROUGHNESS HEIGHT (CM):     3.50
REFERENCE HEIGHT (M):      10.00

RECORD STOPPING SWITCH:    43824
RECORD SKIPPING FACTOR:    1
HOURLY RECORD PRINT LOG:   NOT SELECTED
BI-DAILY MIXING HEIGHT TAPE: SELECTED
```


Appendix A-7



Pacific Gas and Electric Company
Engineering - Calculation Sheet
Project: Diablo Canyon Unit ()1 ()2 (X)1&2

CALC. NO. N/A (Study Only)
REV. NO. 0
SHEET NO. 18 OF 57

SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP

The MULT program runs the plume code for the multiple sources. Its input is described as follows.

MULT (analyzes each plume)

cards 1 to 3: Names of files containing data or being written

card 4: Title: DCPP: Linear Mechanical Cooling Towers (80 cells)

card 5: IOUT: 2 for maximum printout

NFOG: 1 to run fogging cases

NDRIFT: 1 to run drift analysis

NFRAD: Fogging, Ice radials. 0 leads to a default of 16, with each radial distance 100m out to 1600m.

SMAXP: 10000 m maximum distance to calculate plume

SMAXF: 1600 m maximum distance for fogging analysis

NPORTS: 20 cells (maximum allowed by code)

NPLATE: 0 defaults to equal NPORTS

NTWRS: 4 tower housing for LMDCTs

ISOURC: 0 for multiple ports (would be 1 for a single tower)

NEXPL: 0 external plates for direct user input (no building wakes modeled)

cards 6 to 25: X, Y coordinates of tower cells in meters from center point (see Table 2 for values)

card 26: NWD: Number of critical wind directions (3), followed by values in degrees east of North: (0 degrees, 130 degrees to represent plumes headed up the coast towards the power plant, and 315 degrees to represent plumes headed down the coast towards Avila Beach)

card 27: Wind Equivalent Array for 16 wind direction starting with north and moving clockwise in 22.5° increments 2333211123332112. Here 1 is parallel to the axis, 2 is roughly 30° to axis, and 3 is cross axis (See below Figure 3).




Figure 3: Showing Wind Direction Axes Relative to LMDCT Axis



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

card 28: TWRADM: Left blank, this is the diameter of a circular mechanical draft cooling tower.

DA: Length of each Linear mechanical draft tower housing (600' or 183m).

DB: Width of linear mechanical draft towers (120' or 36.6m).

THTWR: Degrees east of north of the LMDCT long axis (130).

cards 29 - 32: XTWR: m X-coordinate of the center of the LMDCT houses from Table 2.

YTWR: m Y-coordinate of the center of the LMDCT houses from Table 2.

card 33: Label to identify drift data. DRIFT DEPOSITION SPECTRUM

card 34: NDROPS: # of drop sizes (11)

DRIFTR: gm/s total drift rate from all sources. This value is 86 gpm per input 4.3.3. At 64.5 lbm/ft³ density per input 4.3.1, this is:

$$86 \text{ gpm} / 7.481 \text{ gal/ft}^3 * 64.5 \text{ lbm/ft}^3 * 1 \text{ min} / 60 \text{ s} * 453.59 \text{ gm/lbm} = 5600 \text{ gm/s}$$

CWSC: gm salt/gm solution. This is .0405 gm/gm by input 4.3.8

SDENS: gm/cm TDS density equal to 2.17 g/cm³ by input 4.3.9.

cards 35 to end: DROPS(I) lth drop diameter (µm). The data is from Table 1.

The mult.usr input file is as follows:

```
fort.3
mult.out
fort.8
DCPP: Linear Mechanical Cooling Towers (80 cells)
  2  1  1  0  10000.0  1600.0  20  0  4  0  0
    -61.0    137.2
    -31.2    110.5
     -1.5     83.8
    28.2     57.2
    57.9     30.5
    91.4     -6.1
   121.2    -32.8
   150.9    -59.4
   180.6    -86.1
   210.3   -112.8
  -179.8     76.2
  -150.1     49.5
  -120.4     22.9
   -90.7     -3.8
   -61.0    -30.5
   -15.2    -33.5
    14.5    -60.2
    44.2   -86.9
    73.9  -113.5
  -121.9    121.9
  3      0.0    130.0    315.0
  2  3  3  3  2  1  1  1  2  3  3  3  2  1  1  2
          183.0    36.6    130.0
    -1.5     83.8
   150.9    -59.4
```



SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**

	-120.4	22.9	
	44.2	-86.9	
SALTS: DRIFT DEPOSITION SPECTRUM			
11	5600.0	.0405	2.17
	5.0	0.00	0.0
	10.0	0.12	0.0
	15.0	0.08	0.0
	35.0	0.20	0.0
	65.0	0.20	0.0
	115.0	0.20	0.0
	170.0	0.10	0.0
	230.0	0.05	0.0
	375.0	0.04	0.0
	525.0	0.008	0.0
	1000.0	0.002	0.0

The TABLES program summarizes the MULT output for the seasons and places it into more convenient tabular format. Its input is described as follows.

TABLES (averages plume results and presents results)

- cards 1 to 5: Names of files containing data or being written
- card 6: NSEASNQ: 5 seasons to be examined (the 5th is "Annual")
 - MM: Number of sector partitions to use in shadowing (0 results in the default of 13)
- cards 7 to 16: The first card names the season, the second gives the first and last Julian day of the season.
- card 17: RSTAR: Effective radius of the combined plume source, 0 leaves it to be calculated
- card 18: NXL: Number of grids for length frequency (0 results in default of 100)
 - NXH: Number of grids for height frequency (0 results in default of 100)
 - NXR: Number of grids for radius frequency (0 results in default of 100)
 - NXS: Number of grids for shadowing table (0 results in default of 40)
 - NXD: Number of grids for deposition table (0 results in default of 40)

Print out of Tables.usr:

```

fort.2
fort.4
tables.out
fort.8
fort.9
  5  0
WINTER
                                335  59
SPRING
                                60  151
SUMMER
                                152  243
  
```



Appendix A-7

SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP

FALL		244	334
ANNUAL		0	0
0.0			
0	0	0	0

Total Dissolved Solids and PM10 Cases

An additional case is run to supply the data for Table 9b below. In the main run, the mult.usr line relating to solids deposition is:

```
SALTS: DRIFT DEPOSITION SPECTRUM
11      5600.0   .0405      2.17
```

The only change for TDS is in the concentration (per input 4.3.10) since the density is the same (input 4.3.11):

```
TDS: DRIFT DEPOSITION SPECTRUM
11      5600.0   .0518      2.17
```

This change to the mult.usr file results in a new mult.out (renamed multTDS.out) and, after running through the Tables program, a new tables.out file (renamed tablesTDS.out). The output is store on a worksheet in DCPPplumeResults.xls.

An additional case is run to supply the data for Table 9c below for PM10 results.

The PM10 case is for particulates of 10 microns or less, which are significant because they cause irritation to the lungs. Since the Table 1 indication is that these make up 12% of the total TDS, the input change is to multiply the concentration .0518 by 0.12 to obtain $.12 * .0518 = .0062$. The input to that case is as follows:

```
PM10: DRIFT DEPOSITION SPECTRUM
11      5600.0   .0062      2.17
```

This change to the mult.usr file results in a new mult.out (renamed multPM10.out) and, after running through the Tables program, a new tables.out file (renamed tablesPM10.out). The output is store on a worksheet in DCPPplumeResults.xls.



SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP

8. RESULTS

8.1 RESULTS

The input files described above were run on a PC. The results are contained in the output files listed in Attachment 2. They are summarized here.

8.2 VISIBLE PLUMES

Tables 4a and 4b present the plume lengths by season. The average length in meters in Table 4a is calculated in file results.xls by summing up the length*frequency change, and then dividing by the total frequency in the given direction. For example, if the lengths in meters were 1000, 2000, 3000, 4000, and the frequencies of being at least that long were 1.5, 0.8, 0.4, 0, respectively, then the average length would be calculated as $[1000*(1.5-.8) + 2000*(.8-.4) + 3000*(.4-0)]/1.5 = 1800$ m. Note: the actual lengths produced by SACTI are given in divisions of 100 meters each, so the round off error is much smaller than in this example. Table 4b is identical to Table 4a, except that the length unit is miles (generated by multiplying the length in meters by $(1\text{ft}/.3048\text{m}*1\text{mile}/5280\text{ft})$). Table 4c indicates length versus frequency on an annual basis. Tables 4d and 4e give plume heights and radii.

Tables 5 through 8 present the percent frequency of plume lengths versus direction on a seasonal basis.

The total sodium salt deposition rates are described in Table 9a. The SACTI code produces salt deposition in units of $\text{kg}/\text{km}^2\text{-month}$. These can be converted to English units of $\text{lbm}/(100\text{-acre-months})$ by multiplying by $(2.205 \text{ lbm}/\text{kg})*(1/2.471 \text{ km}^2/100 \text{ acres}) = 0.893 (\text{lbm- km}^2/100\text{-acre-kg})$.

Table 9b is the total dissolved solids deposition, in the same units as sodium salt deposition. Table 9c is the deposition of particles of 10 microns or less, which is significant because these small particles can cause irritation to the lungs.

Water deposition is shown in Table 10. These data can be converted into inches per year by $0.893 (\text{lbm- km}^2/100\text{-acre-kg})*1\text{ft}^3/62.4 \text{ lbm (freshwater)} * 1/100 \text{ acre} * 1 \text{ acre}/43560 \text{ ft}^2 * 12 \text{ inch}/\text{ft} * 12 \text{ months}/\text{yr} = 4.7\text{e-}7$. Results show all areas beyond a quarter mile of the towers see less than 1/1000 in/yr added precipitation.

Plume shadowing is presented in Table 11. Fogging is shown in Table 12. It is seen that fogging will occur on occasion out to a full mile from the cooling towers usually to the NW or SE.



SUBJECT Plume Characteristics of Proposed Cooling Towers at DCP

Table 4a: Average Plume Lengths in Meters

	Winter	Spring	Summer	Fall	Annual
Plume from LMDCT moving in the indicated direction					
S	2780	3460	3170	2520	2900
SSW	2750	3510	3170	2730	2930
SW	2820	3560	2870	2530	2870
WSW	2890	3600	2810	2430	2860
W	3090	3670	2720	2380	2970
WNW	3790	4300	3040	3170	3680
NW	3710	3990	2930	2660	3360
NNW	2270	2530	1980	1870	2170
N	1920	1860	1470	1280	1620
NNE	2420	1910	1540	1650	1840
NE	1720	1990	1860	1860	1860
ENE	1370	1880	1890	1450	1660
E	1670	1790	1660	1100	1560
ESE	1370	1380	1270	1070	1280
SE	2230	2530	2080	1930	2190
SSE	3520	3980	3030	2640	3310
All	2710	2720	2050	2070	2380

Table 4b: Average Plume Lengths in Miles

	Winter	Spring	Summer	Fall	Annual
Plume from LMDCT moving in the indicated direction					
S	1.73	2.15	1.97	1.57	1.8
SSW	1.71	2.18	1.97	1.7	1.82
SW	1.75	2.21	1.78	1.57	1.78
WSW	1.8	2.24	1.75	1.51	1.78
W	1.92	2.28	1.69	1.48	1.85
WNW	2.35	2.67	1.89	1.97	2.29
NW	2.31	2.48	1.82	1.65	2.09
NNW	1.41	1.57	1.23	1.16	1.35
N	1.19	1.16	0.91	0.8	1.01
NNE	1.5	1.19	0.96	1.03	1.14
NE	1.07	1.24	1.16	1.16	1.16
ENE	0.85	1.17	1.17	0.9	1.03
E	1.04	1.11	1.03	0.68	0.97
ESE	0.85	0.86	0.79	0.66	0.8
SE	1.39	1.57	1.29	1.2	1.36
SSE	2.19	2.47	1.88	1.64	2.06
All	1.68	1.69	1.27	1.29	1.48



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

Table 4c: Annual Plume Percent Frequency by Length and Direction

Heading	<500m (<1/3 mile)	500 - <3200m (1/3 - 2 miles)	3200-<8000m (2- 5 miles)	8000m or longer (>5 miles)	Total
S	0.47	1.36	1.08	0.09	3
SSW	0.33	1.34	0.77	0.09	2.53
SW	0.43	1.63	0.93	0.11	3.1
WSW	0.44	1.43	0.82	0.09	2.78
W	0.45	1.5	1.13	0.13	3.21
WNW	0.41	1.82	2.09	0.24	4.56
NW	1.14	3.49	3.36	0.4	8.39
NNW	2.37	2.84	1.5	0.23	6.94
N	1.77	1.5	0.64	0.06	3.97
NNE	0.65	0.76	0.24	0.05	1.7
NE	0.54	0.63	0.23	0.04	1.44
ENE	0.61	0.53	0.21	0.03	1.38
E	1.52	1.13	0.56	0.03	3.24
ESE	9.1	2.74	1.64	0.2	13.68
SE	15.13	6.7	8.2	0.67	30.7
SSE	1.54	3.34	4.05	0.45	9.38
All	36.9	32.74	27.45	2.91	100

Table 4d: Plume Centerline Heights

Heading	<100m (<330 ft)	100 - <500m (330 - 1640 ft)	500-<750m (1640 - 2460 ft)	750 - 810m (2460 - 2700 ft)	Total
S	0.43	0.36	0.71	1.5	3
SSW	0.26	0.39	0.66	1.22	2.53
SW	0.35	0.49	0.86	1.4	3.1
WSW	0.39	0.42	0.67	1.3	2.78
W	0.38	0.4	0.83	1.6	3.21
WNW	0.23	0.78	1	2.55	4.56
NW	0.56	1.89	1.94	4	8.39
NNW	1.24	2.51	1.26	1.93	6.94
N	1.36	1.02	0.62	0.97	3.97
NNE	0.43	0.52	0.3	0.45	1.7
NE	0.36	0.44	0.27	0.37	1.44
ENE	0.43	0.42	0.22	0.31	1.38
E	1.24	0.75	0.49	0.76	3.24
ESE	7.44	2.87	1.29	2.08	13.68
SE	13.81	3.34	3.8	9.75	30.7
SSE	1.44	0.71	1.87	5.36	9.38
All	30.35	17.31	16.79	35.55	100



SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**

Table 4e: Plume Radii By Direction that the Plume is Headed

Heading	<50m (<160 ft)	50 - <200m (160 - 660 ft)	200-<300m (660 - 980 ft)	300 - <355m (980 - 1160 ft)	Total
S	0.47	0.66	1.69	0.18	3
SSW	0.33	0.71	1.25	0.24	2.53
SW	0.43	0.93	1.46	0.28	3.1
WSW	0.44	0.81	1.24	0.29	2.78
W	0.45	0.82	1.7	0.24	3.21
WNW	0.34	0.85	2.19	1.18	4.56
NW	0.89	1.92	3.41	2.17	8.39
NNW	2	2.01	1.85	1.08	6.94
N	1.76	1.02	1.07	0.12	3.97
NNE	0.65	0.52	0.41	0.12	1.7
NE	0.54	0.45	0.37	0.08	1.44
ENE	0.61	0.38	0.31	0.08	1.38
E	1.52	0.73	0.91	0.08	3.24
ESE	8.59	1.99	2.11	0.99	13.68
SE	14.55	3.18	8.69	4.28	30.7
SSE	1.54	1.51	5.46	0.87	9.38
All	35.11	18.49	34.12	12.28	100



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

Table 5: Winter Plume Percent Frequency by Length and Direction
 (Note bolded plumes, which total 1.4%, are visible from Avila Beach)

	0 - <500 m (0 to 1/3 mile)	500 - <3200 m (1/3 - 2 mile)	3200 - <8000 m (2 - 5 miles)	8000 m and longer (>5 miles)	Total Freq
Plume from LMDCT moving in the indicated direction					
S	0.66	1.87	1.24	0.13	3.9
SSW	0.49	2.62	1.02	0.12	4.25
SW	0.72	3.54	1.84	0.21	6.31
WSW	0.86	3.13	1.73	0.22	5.94
W	0.83	3.18	2.38	0.3	6.69
WNW	0.71	3.33	4.21	0.49	8.74
NW	1.75	4.41	5.83	0.88	12.87
NNW	2.36	3.53	1.8	0.27	7.96
N	1.68	1.58	0.89	0.11	4.26
NNE	0.55	0.69	0.31	0.11	1.66
NE	0.54	0.61	0.22	0.03	1.4
ENE	0.65	0.45	0.15	0.03	1.28
E	1.5	1.01	0.68	0.04	3.23
ESE	5.62	2.14	1.06	0.22	9.04
SE	6.75	3.75	3.61	0.49	14.6
SSE	1.22	2.7	3.3	0.65	7.87
All	26.9	38.5	30.3	4.3	100



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

Table 6: Spring Plume Percent Frequency by Length and Direction
 (Note bolded plumes, which total 2.1%, are visible from Avila Beach)

	0 - <500 m (0 to 1/3 mile)	500 - <3200 m (1/3 - 2 mile)	3200 - <8000 m (2 - 5 miles)	8000 m and longer (>5 miles)	Total Freq
Plume from LMDCT moving in the indicated direction					
S	0.28	1.16	1.19	0.18	2.81
SSW	0.2	0.88	0.82	0.12	2.02
SW	0.16	1.02	0.84	0.11	2.13
WSW	0.17	0.68	0.69	0.08	1.62
W	0.15	0.81	1.16	0.13	2.25
WNW	0.14	1.27	2.33	0.21	3.95
NW	0.65	2.52	3.48	0.47	7.12
NNW	2.09	2.44	1.64	0.37	6.54
N	1.22	1.45	0.63	0.06	3.36
NNE	0.47	0.6	0.19	0.03	1.29
NE	0.39	0.53	0.22	0.03	1.17
ENE	0.38	0.54	0.14	0.06	1.12
E	1.27	1.38	0.59	0.05	3.29
ESE	11.07	3.19	2.2	0.36	16.82
SE	15.1	6.66	10.63	0.96	33.35
SSE	1.27	3.03	6.04	0.81	11.15
All	35.0	28.2	32.8	4.0	100



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

Table 7: Summer Plume Percent Frequency by Length and Direction
 (Note bolded plumes, which total 0.9%, are visible from Avila Beach)

	0 - <500 m (0 to 1/3 mile)	500 - <3200 m (1/3 - 2 mile)	3200 - <8000 m (2 - 5 miles)	8000 m and longer (>5 miles)	Total Freq
Plume from LMDCT moving in the indicated direction					
S	0.04	0.78	0.48	0	1.3
SSW	0.04	0.56	0.31	0.04	0.95
SW	0.04	0.61	0.24	0	0.89
WSW	0.02	0.53	0.16	0	0.71
W	0.05	0.42	0.18	0	0.65
WNW	0.07	0.66	0.28	0.06	1.07
NW	0.49	2.31	1.47	0.06	4.33
NNW	2.49	2.86	1.42	0.13	6.9
N	2.06	1.86	0.58	0.06	4.56
NNE	0.72	0.94	0.23	0.01	1.9
NE	0.58	0.83	0.26	0.04	1.71
ENE	0.64	0.64	0.32	0.02	1.62
E	1.47	1.28	0.62	0.02	3.39
ESE	10.44	3.04	2.08	0.13	15.69
SE	23.85	9.73	12.46	0.62	46.66
SSE	1.14	3.24	3.19	0.1	7.67
All	44.2	30.3	24.3	1.3	100



SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPD

Table 8: Fall Plume Percent Frequency by Length and Direction
 (Note bolded plumes, which total 0.9%, are visible from Avila Beach)

	0 - <500 m (0 to 1/3 mile)	500 - <3200 m (1/3 - 2 mile)	3200 - <8000 m (2 - 5 miles)	8000 m and longer (>5 miles)	Total Freq
Plume from LMDCT moving in the indicated direction					
S	0.95	1.71	1.43	0.06	4.15
SSW	0.59	1.48	0.94	0.11	3.12
SW	0.86	1.58	0.93	0.14	3.51
WSW	0.77	1.64	0.81	0.07	3.29
W	0.81	1.86	0.96	0.1	3.73
WNW	0.76	2.24	1.78	0.25	5.03
NW	1.79	4.86	2.99	0.24	9.88
NNW	2.58	2.6	1.15	0.15	6.48
N	2.08	1.12	0.47	0.03	3.7
NNE	0.86	0.78	0.24	0.06	1.94
NE	0.64	0.54	0.23	0.06	1.47
ENE	0.76	0.5	0.19	0.03	1.48
E	1.85	0.83	0.34	0.02	3.04
ESE	8.81	2.48	1.13	0.09	12.51
SE	13.77	6.25	5.39	0.6	26.01
SSE	2.51	4.34	3.55	0.24	10.64
All	40.4	34.8	22.5	2.2	100

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 30 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

Table 9a: Annual Sodium Salt Deposition in kg/(km²-month).
 Directions are directions that the plume is headed. Values can be converted to lbm/100-acre-month by multiplying by 0.893.

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
0.06	100	785.0	345.0	511.0	450.0	921.0	763.0	1903	2426	6285	1915	1536	1690	5029	22693	55965	2062
0.12	200	443.0	190.0	323.0	364.0	504.0	181.0	532	943	1135	41	34	58	993	5345	8746	1553
0.19	300	140.9	62.0	100.0	100.1	136.0	90.3	237.4	297.3	116.3	28.0	25.9	32.0	138.9	402.6	629.0	548.1
0.25	400	59.5	39.1	60.2	52.3	64.9	64.4	146.2	166.1	94.4	25.7	24.6	27.1	52.0	220.8	421.4	148.9
0.31	500	59.5	39.1	56.2	52.3	64.9	52.7	99.9	97.2	86.2	25.7	24.6	27.1	51.9	136.4	325.5	148.8
0.37	600	57.4	37.2	49.4	52.3	60.6	56.9	94.4	84.2	70.5	25.3	23.3	27.1	49.8	139.5	332.3	144.6
0.43	700	57.4	33.7	44.9	38.8	60.6	56.9	94.4	84.2	70.5	25.2	23.1	22.6	49.8	139.5	332.3	144.6
0.5	800	57.4	33.1	43.9	36.7	60.6	56.2	93.6	83.5	70.5	24.6	22.0	20.9	49.8	139.5	330.8	144.6
0.56	900	56.5	32.6	43.1	36.2	59.9	51.5	91.9	82.4	70.2	23.3	19.4	18.3	49.7	136.5	323.1	143.8
0.62	1000	53.1	32.6	43.1	36.2	57.1	47.6	90.8	81.8	69.1	23.3	19.4	18.3	49.1	133.7	317.1	141.0
0.68	1100	53.1	32.6	43.1	36.2	57.1	47.6	90.8	81.8	69.1	23.3	19.4	18.3	49.1	133.7	317.1	141.0
0.75	1200	51.4	32.6	43.1	36.2	55.6	47.6	90.8	81.8	66.1	23.3	19.4	18.3	46.8	133.7	317.1	137.8
0.81	1300	44.9	32.6	41.1	36.2	49.4	47.6	88.8	77.9	53.8	23.3	19.4	18.3	39.8	133.7	317.1	125.2
0.87	1400	43.2	32.6	41.1	36.2	46.8	47.6	88.8	77.9	51.8	23.3	19.4	18.3	38.2	133.7	317.1	120.5
0.93	1500	40.3	32.6	41.1	36.2	42.9	47.6	88.8	77.9	48.2	23.3	19.4	18.3	36.0	133.7	317.1	113.5
0.99	1600	37.8	31.5	39.7	35.0	40.5	47.6	88.8	77.9	43.9	22.1	18.5	17.5	32.6	133.7	317.1	107.6
1.06	1700	36.0	29.6	37.1	32.9	38.6	47.6	88.8	77.9	42.5	20.3	17.0	16.3	31.4	133.7	317.1	103.4
1.12	1800	35.5	29.2	36.6	32.4	38.2	47.6	88.8	77.8	42.1	20.0	16.7	16.0	31.1	133.7	317.0	102.2
1.18	1900	35.5	28.6	35.9	31.8	38.2	47.6	88.7	76.9	42.2	19.1	16.0	15.2	31.1	132.5	316.8	102.2
1.24	2000	35.5	28.1	35.4	31.5	38.2	47.1	87.4	73.3	42.2	18.1	15.1	14.2	31.1	128.6	314.5	102.2
1.3	2100	35.5	27.8	34.9	31.3	38.3	47.1	87.5	70.2	42.2	17.7	14.7	13.7	31.1	125.6	315.6	102.4
1.37	2200	35.7	28.0	35.1	31.5	38.4	47.9	89.1	71.3	42.3	17.7	14.8	13.8	31.2	126.7	318.4	102.8
1.43	2300	35.7	28.1	35.3	31.6	38.5	49.4	92.5	74.0	42.3	17.8	14.8	13.8	31.2	128.9	323.6	103.0
1.49	2400	36.0	28.4	35.6	31.8	38.7	55.7	103.2	79.8	42.4	17.9	14.8	13.8	31.3	133.0	345.6	103.8
1.55	2500	36.1	28.4	35.6	31.8	38.8	61.1	111.4	83.8	42.5	17.9	14.8	13.8	31.4	136.2	365.1	104.4
1.62	2600	36.6	28.7	36.1	32.1	39.1	62.8	114.3	85.3	42.2	17.9	15.0	13.9	31.3	137.7	372.0	106.1
1.68	2700	38.4	30.1	37.8	33.3	40.6	65.8	120.6	87.2	42.3	17.7	15.3	13.9	31.7	136.9	380.9	111.4
1.74	2800	39.3	32.9	41.1	36.3	41.8	65.8	120.6	87.2	42.9	18.5	16.0	14.6	32.1	136.9	380.9	115.4
1.8	2900	39.4	32.9	41.1	36.3	41.8	65.8	120.6	87.2	43.0	18.5	16.0	14.6	32.2	136.9	380.9	115.6
1.86	3000	39.4	32.9	41.1	36.3	41.8	65.8	120.6	87.2	43.0	18.5	16.0	14.6	32.2	136.9	380.9	115.6
1.93	3100	39.4	33.5	41.1	36.8	41.8	67.1	122.5	86.9	41.6	18.7	16.2	14.8	32.2	137.9	386.6	115.6
1.99	3200	39.6	33.9	41.5	37.3	42.1	67.7	123.6	87.2	41.6	18.8	16.4	14.9	32.3	138.4	389.4	116.8
2.05	3300	39.7	34.3	41.8	37.6	42.3	67.7	123.6	87.2	41.5	18.8	16.5	15.0	32.3	138.4	389.4	117.3
2.11	3400	39.7	34.3	41.8	37.6	42.2	67.7	123.6	87.2	40.1	18.8	16.5	15.0	31.7	138.4	389.4	117.3

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 31 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

Table 9a (continued): Annual Sodium Salt Deposition in kg/(km²-month).
 Directions are directions that the plume is headed. Values can be converted to lbm/100-acre-month by multiplying by 0.893

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
2.17	3500	39.7	34.3	41.8	37.6	42.2	67.7	123.6	87.2	40.1	18.8	16.5	15.0	31.7	138.4	389.4	117.3
2.24	3600	39.7	34.8	42.4	38.1	42.3	70.7	128.2	89.6	40.1	18.4	16.2	14.8	31.7	140.7	398.1	117.7
2.3	3700	40.5	36.4	44.1	39.7	43.3	73.7	132.2	91.5	40.7	19.1	16.7	15.4	31.9	142.7	407.2	122.0
2.36	3800	40.5	36.6	44.4	40.1	43.3	73.7	132.2	91.5	40.7	19.2	16.7	15.4	31.9	142.7	407.2	122.0
2.42	3900	40.6	36.6	44.5	39.6	43.4	73.2	131.1	90.7	40.7	19.4	16.8	15.2	32.0	142.0	404.9	122.3
2.49	4000	40.5	36.1	43.9	38.7	43.3	72.5	129.9	89.7	40.6	19.1	16.7	14.9	31.9	141.0	402.1	121.9
2.55	4100	39.6	34.8	42.3	37.3	42.3	69.6	124.9	86.3	39.9	18.5	16.2	14.5	31.4	137.1	391.5	119.7
2.61	4200	37.8	32.0	38.5	34.5	40.3	61.0	108.4	73.3	38.3	17.0	14.8	13.5	30.3	124.7	361.8	115.2
2.67	4300	34.2	30.8	37.2	33.2	35.8	57.7	101.4	67.2	34.5	16.5	14.4	13.2	27.2	115.1	338.1	106.5
2.73	4400	33.1	30.5	36.8	32.9	34.6	56.3	98.4	64.5	33.4	16.4	14.3	13.1	26.1	75.6	223.9	104.2
2.8	4500	32.0	29.5	35.7	31.7	33.7	54.8	95.0	61.4	31.4	15.7	13.5	12.4	24.7	72.7	217.7	102.3
2.86	4600	30.9	28.7	35.0	30.9	32.5	52.1	90.3	58.1	30.4	15.4	13.3	12.2	23.9	69.5	207.4	99.1
2.92	4700	30.4	26.7	32.4	28.7	32.1	51.5	89.4	57.6	30.1	14.3	12.3	11.3	23.7	69.0	205.0	97.7
2.98	4800	30.1	26.4	31.9	28.3	31.7	51.0	88.7	57.3	29.9	14.2	12.1	11.2	23.6	68.6	203.3	96.7
3.04	4900	29.9	26.1	31.5	27.9	31.4	50.9	88.7	57.3	29.8	14.1	12.1	11.1	23.5	68.6	203.2	96.0
3.11	5000	29.9	26.1	31.5	27.9	31.4	50.9	88.6	57.3	29.8	14.1	12.1	11.1	23.5	68.6	203.1	95.7
3.17	5100	29.7	25.7	31.0	27.5	31.2	50.5	88.0	57.0	29.7	14.0	11.9	11.0	23.4	68.3	201.2	95.0
3.23	5200	29.5	25.6	30.9	27.4	31.0	50.3	87.7	56.9	29.5	14.0	11.9	11.0	23.3	68.1	200.1	94.1
3.29	5300	29.5	25.6	30.9	27.4	31.0	50.2	87.5	56.8	29.6	14.0	11.9	11.0	23.3	68.0	199.5	94.3
3.36	5400	29.8	25.4	30.7	27.2	31.3	49.0	84.8	53.8	29.7	13.9	11.9	10.9	23.4	63.9	193.1	95.3
3.42	5500	29.8	25.3	30.6	27.1	31.3	49.0	84.8	53.8	29.7	13.9	11.8	10.9	23.4	63.9	193.1	95.4
3.48	5600	29.8	25.3	30.6	27.1	31.3	49.0	84.8	53.8	29.7	13.9	11.8	10.9	23.4	63.9	193.1	95.4
3.54	5700	29.8	25.3	30.6	27.1	31.3	49.0	84.8	53.8	29.7	13.9	11.8	10.9	23.4	63.9	193.1	95.4
3.6	5800	29.8	25.3	30.6	27.0	31.4	49.1	85.0	53.9	29.8	13.8	11.7	10.8	23.5	64.0	193.6	95.7
3.67	5900	29.9	25.2	30.5	27.0	31.5	49.0	85.4	54.1	29.8	13.0	11.1	10.0	23.5	63.9	194.0	96.0
3.73	6000	29.9	25.2	30.5	27.0	31.5	48.9	85.3	54.0	29.8	13.0	11.1	10.0	23.5	63.8	193.8	96.0
3.79	6100	29.9	25.2	30.5	27.0	31.4	48.9	85.3	54.0	29.7	13.0	11.1	10.0	23.4	63.8	193.8	95.9
3.85	6200	29.6	25.1	30.4	26.9	30.9	48.9	85.3	54.0	28.6	12.9	11.1	10.0	22.6	63.8	193.8	95.2
3.91	6300	28.9	24.7	29.9	26.5	30.4	48.9	85.3	54.0	27.4	12.6	10.7	9.6	21.7	63.8	193.8	94.2
3.98	6400	28.7	24.7	29.9	26.5	30.2	48.9	85.3	54.0	26.9	12.6	10.7	9.6	21.3	63.8	193.8	93.8
4.04	6500	28.7	24.7	29.9	26.5	30.2	48.4	84.3	52.5	26.9	12.6	10.7	9.6	21.3	62.4	192.3	93.8
4.1	6600	28.7	24.6	29.8	26.4	30.2	48.4	84.2	52.3	26.9	12.3	10.5	9.4	21.3	62.3	192.1	93.8
4.16	6700	28.7	24.1	29.2	26.0	30.2	48.4	84.2	52.3	26.9	11.5	9.9	8.8	21.3	62.3	192.1	93.8

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 32 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**

Table 9a (continued): Annual Sodium Salt Deposition in kg/(km²-month).
 Directions are directions that the plume is headed. Values can be converted to lbm/100-acre-month by multiplying by 0.893

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
4.23	6800	28.7	24.1	29.2	26.0	30.2	48.4	84.2	52.3	26.1	11.5	9.9	8.8	20.6	62.3	192.1	93.8
4.29	6900	28.5	24.1	29.2	26.0	29.9	48.3	84.2	52.2	24.5	11.5	9.9	8.8	19.4	62.1	192.1	93.5
4.35	7000	28.5	24.1	29.2	26.0	29.9	48.3	84.1	51.9	24.4	11.5	9.9	8.8	19.3	61.7	192.0	93.5
4.41	7100	28.5	24.1	29.2	26.0	29.9	48.2	83.9	51.2	24.4	11.5	9.9	8.8	19.3	61.0	191.6	93.5
4.47	7200	28.5	24.1	29.2	26.0	29.9	48.0	83.4	49.3	24.4	11.5	9.9	8.7	19.3	57.7	190.1	93.5
4.54	7300	27.9	23.9	28.9	25.8	29.4	47.7	82.6	49.0	24.2	11.4	9.7	8.6	18.9	57.4	189.1	90.7
4.6	7400	26.8	23.2	27.9	24.9	28.6	46.6	79.6	47.5	23.7	11.3	9.5	8.4	18.3	56.3	185.3	87.1
4.66	7500	26.8	23.0	27.5	24.5	28.6	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.3	56.3	185.3	87.1
4.72	7600	26.8	23.0	27.5	24.5	28.6	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.3	56.3	185.3	87.1
4.78	7700	26.8	23.0	27.5	24.5	28.6	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.3	56.3	185.3	87.1
4.85	7800	26.8	23.0	27.5	24.5	28.6	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.3	56.3	185.3	87.1
4.91	7900	26.8	23.0	27.5	24.5	28.6	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.3	56.3	185.3	87.1
4.97	8000	26.8	23.0	27.5	24.5	28.6	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.3	56.3	185.3	87.1
5.03	8100	26.8	23.0	27.5	24.5	28.5	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.3	56.3	185.3	87.0
5.1	8200	26.7	23.0	27.5	24.5	28.5	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.2	56.3	185.3	87.0
5.16	8300	26.7	23.0	27.5	24.5	28.5	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.2	56.3	185.3	87.0
5.22	8400	26.7	23.0	27.5	24.5	28.5	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.2	56.3	185.3	87.0
5.28	8500	26.7	23.0	27.5	24.5	28.5	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.2	56.3	185.3	87.0
5.34	8600	26.7	23.0	27.5	24.5	28.5	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.2	56.3	185.3	87.0
5.41	8700	26.7	22.9	27.5	24.5	28.5	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.2	56.3	185.3	87.0
5.47	8800	26.7	22.9	27.5	24.5	28.5	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.2	56.3	185.3	87.0
5.53	8900	26.7	22.9	27.5	24.5	28.5	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.2	56.3	185.3	87.0
5.59	9000	26.7	22.9	27.5	24.5	28.5	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.2	56.3	185.3	87.0
5.65	9100	26.7	22.9	27.5	24.5	28.5	46.6	79.6	47.5	23.7	11.2	9.5	8.4	18.2	56.3	185.3	87.0
5.72	9200	26.7	22.9	27.5	24.5	28.5	46.6	79.6	47.5	23.6	11.2	9.5	8.4	18.2	56.3	185.3	87.0
5.78	9300	26.6	22.9	27.4	24.3	28.4	46.6	79.6	47.5	23.2	11.1	9.4	8.3	17.9	56.3	185.3	86.7
5.84	9400	26.6	22.8	27.3	24.0	28.4	46.5	79.3	47.0	23.2	11.0	9.3	8.1	17.9	55.0	184.5	86.7
5.9	9500	26.6	22.8	27.3	24.0	28.4	46.5	79.3	47.0	23.2	11.0	9.3	8.1	17.9	55.0	184.5	86.7
5.97	9600	26.6	22.8	27.3	24.0	28.4	46.5	79.3	47.0	23.2	11.0	9.3	8.1	17.9	55.0	184.5	86.7
6.03	9700	26.6	22.8	27.3	24.0	28.4	46.5	79.3	47.0	23.2	11.0	9.3	8.1	17.9	55.0	184.5	86.7
6.09	9800	26.6	22.8	27.3	24.0	28.4	45.9	78.4	46.5	23.2	11.0	9.3	8.1	17.9	54.6	183.0	86.7
6.15	9900	26.6	22.3	26.7	23.5	28.4	45.1	77.1	45.7	23.2	10.7	9.1	7.9	17.9	53.9	180.7	86.7
6.21	1e4	26.4	22.2	26.5	23.5	28.0	44.8	76.2	44.9	22.7	10.7	9.1	7.9	17.8	53.4	179.2	85.5

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 33 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

Table 9b: Annual Total Dissolved Solids Deposition in kg/(km²-month).

Directions are directions that the plume is headed. Values can be converted to lbm/100-acre-month by multiplying by 0.893.

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
0.06	100	1023	444	658	579	1201	995	2487	3194	8117	2448	1964	2160	6488	29774	73107	2700
0.12	200	573	246	423	469	650	228	678	1201	1448	55	45	76	1260	6615	10757	2018
0.19	300	327.0	82.0	139.0	131.0	321.0	119.0	319.0	404.0	186.0	38.0	36.0	43.0	289.0	562.0	929.0	1541
0.25	400	308.0	52.0	85.0	69.0	316.0	85.0	198.0	229.0	162.0	35.0	34.0	36.0	242.0	326.0	659.0	1535
0.31	500	308.0	52.0	67.0	69.0	315.0	71.0	128.0	118.0	126.0	35.0	33.0	36.0	242.0	221.0	541.0	1535
0.37	600	101.2	49.7	67.5	69.4	105.8	77.2	129.6	118.5	104.2	34.6	31.5	36.5	86.7	225.7	550.1	328.7
0.43	700	78.2	45.3	61.7	52.0	82.8	77.2	129.6	118.5	102.0	34.6	31.5	30.6	69.5	225.7	550.1	193.6
0.5	800	78.2	44.7	60.7	50.1	82.8	75.4	127.8	116.6	102.0	33.8	30.0	28.6	69.5	225.7	546.4	193.6
0.56	900	76.0	44.1	59.7	49.5	81.0	67.1	125.4	115.4	101.2	32.3	26.8	25.4	69.2	219.8	533.5	191.8
0.62	1000	72.7	44.1	59.7	49.5	78.2	64.4	124.6	115.0	100.1	32.3	26.8	25.4	68.6	217.8	529.2	189.0
0.68	1100	72.7	44.1	56.4	49.5	78.2	64.4	121.4	108.5	93.6	32.3	26.8	25.4	68.6	217.8	529.2	189.0
0.75	1200	65.2	44.1	56.1	49.5	71.8	64.4	121.0	107.9	81.0	32.3	26.8	25.4	59.4	217.8	529.2	175.4
0.81	1300	59.8	44.1	56.1	49.5	65.4	64.4	121.0	107.9	75.3	32.3	26.8	25.4	54.2	217.8	529.2	163.0
0.87	1400	56.0	44.1	56.1	49.5	60.0	64.4	121.0	107.9	70.7	32.3	26.8	25.4	51.4	217.8	529.2	153.5
0.93	1500	52.8	43.9	55.8	49.3	56.3	64.4	121.0	107.9	66.1	32.0	26.6	25.3	48.1	217.8	529.2	145.8
0.99	1600	49.6	40.2	50.8	45.2	53.3	64.4	121.0	107.9	62.1	28.2	23.7	22.8	44.7	217.8	529.2	138.6
1.06	1700	47.4	39.8	50.2	44.7	51.2	64.4	121.0	107.8	60.4	28.0	23.4	22.6	43.3	217.8	529.1	133.5
1.12	1800	47.4	39.0	49.1	43.7	51.2	64.4	120.9	107.3	60.4	27.5	22.9	22.1	43.3	217.2	529.0	133.3
1.18	1900	47.3	38.2	48.3	43.1	51.0	64.3	120.5	105.5	60.3	26.0	21.7	20.7	43.3	214.7	528.5	132.9
1.24	2000	47.2	38.0	48.1	43.0	50.9	63.9	119.5	101.3	60.2	25.3	21.2	20.0	43.2	210.5	526.7	132.7
1.3	2100	47.1	37.9	47.9	42.9	50.8	64.5	120.8	99.7	60.2	25.0	20.9	19.7	43.2	209.1	529.9	132.4
1.37	2200	47.1	37.9	47.9	42.9	50.8	65.8	123.8	101.6	60.2	25.0	20.9	19.7	43.2	209.1	533.9	132.4
1.43	2300	47.3	38.2	48.4	43.2	51.0	71.0	133.5	107.0	60.3	25.2	20.9	19.8	43.3	211.5	551.1	133.1
1.49	2400	47.4	38.3	48.5	43.3	51.1	77.5	144.0	113.5	60.4	25.2	21.0	19.8	43.3	218.5	574.8	133.5
1.55	2500	47.7	38.3	48.5	43.3	51.3	83.0	152.4	118.1	60.5	25.2	21.0	19.8	43.5	223.2	595.6	134.6
1.62	2600	48.1	39.6	49.2	44.5	51.5	85.7	156.2	118.4	58.0	25.2	21.3	19.9	42.8	224.0	605.7	135.7
1.68	2700	50.6	41.7	51.3	46.5	53.7	89.0	162.9	119.7	57.7	25.4	21.9	20.2	43.9	224.6	615.7	143.4
1.74	2800	51.8	44.4	54.5	49.3	55.2	89.0	162.9	119.7	58.5	26.2	22.6	21.0	44.5	224.6	615.7	148.4
1.8	2900	51.8	44.4	54.5	49.3	55.2	89.0	162.9	119.7	58.5	26.2	22.6	21.0	44.5	224.6	615.7	148.4
1.86	3000	51.8	45.3	55.6	50.2	55.2	90.4	165.7	120.9	57.6	26.4	22.9	21.3	44.2	225.7	622.3	148.6
1.93	3100	52.1	45.8	56.0	50.7	55.6	91.3	167.5	121.7	56.4	26.5	23.1	21.3	43.8	226.4	625.8	150.3
1.99	3200	51.9	46.0	56.1	50.8	55.2	91.3	167.5	121.7	56.2	25.9	22.6	21.1	43.6	226.4	625.8	149.9
2.05	3300	51.8	46.0	56.1	50.8	55.1	91.3	167.5	121.7	56.2	25.5	22.3	20.9	43.6	226.4	625.8	149.8
2.11	3400	51.8	45.5	55.8	49.9	55.1	88.7	161.8	116.6	56.2	25.5	22.3	20.6	43.6	150.1	405.5	149.8

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 34 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**

Table 9b (continued): Annual Total Dissolved Solids Deposition in kg/(km²-month).
 Directions are directions that the plume is headed. Values can be converted to lbm/100-acre-month by multiplying by 0.893

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
2.17	3500	51.8	45.3	55.5	48.7	55.1	88.0	160.4	115.3	56.2	25.5	22.3	20.1	43.6	131.4	351.2	149.8
2.24	3600	52.2	47.1	57.6	50.8	55.7	91.9	166.5	118.8	56.4	26.4	22.9	20.7	43.7	134.5	362.1	151.8
2.3	3700	53.1	48.5	59.1	52.2	57.0	96.0	171.8	120.8	57.1	27.0	23.4	21.1	44.0	136.8	375.1	156.4
2.36	3800	53.1	48.5	59.1	52.2	57.0	96.0	171.8	120.8	57.1	27.0	23.4	21.1	44.0	136.8	375.1	156.4
2.42	3900	53.4	48.7	59.3	52.3	57.2	95.4	170.5	119.8	57.2	27.1	23.5	21.2	44.2	135.8	372.0	157.1
2.49	4000	53.0	47.4	57.8	50.9	56.7	94.0	168.3	118.2	56.9	26.4	23.0	20.8	43.9	133.9	367.3	156.0
2.55	4100	52.0	45.0	54.4	48.5	55.5	84.3	149.8	103.5	55.9	25.0	21.7	19.9	43.3	119.6	334.0	153.4
2.61	4200	46.8	43.3	52.4	46.9	49.2	78.9	138.5	94.1	50.6	24.3	21.0	19.4	38.8	111.4	314.9	141.3
2.67	4300	45.0	42.3	51.3	45.6	47.5	78.0	136.5	92.2	47.7	23.7	20.4	18.8	36.6	109.7	311.7	137.7
2.73	4400	44.3	41.6	50.3	44.6	47.0	76.1	132.0	87.7	46.4	23.2	19.8	18.3	35.7	105.8	304.4	136.5
2.8	4500	44.1	40.2	48.4	42.9	46.8	75.2	130.6	87.0	46.3	22.2	18.8	17.5	35.6	105.0	300.7	136.0
2.86	4600	43.5	38.9	47.1	41.6	46.2	74.1	129.0	86.1	46.0	21.7	18.4	17.1	35.4	104.0	296.4	134.3
2.92	4700	43.5	38.7	46.8	41.4	46.1	74.1	129.0	86.0	45.9	21.6	18.4	17.1	35.3	104.0	296.5	134.1
2.98	4800	43.4	38.4	46.4	41.1	46.0	74.1	129.0	86.0	45.9	21.6	18.3	17.0	35.3	104.0	296.5	133.7
3.04	4900	43.4	38.3	46.4	41.0	46.0	74.1	129.0	86.0	45.9	21.6	18.3	17.0	35.3	104.0	296.5	133.7
3.11	5000	43.4	38.3	46.3	40.9	45.9	73.6	127.2	83.4	45.9	21.5	18.3	17.0	35.3	100.3	292.3	133.6
3.17	5100	43.3	38.1	46.1	40.8	45.9	73.1	126.3	82.2	45.8	21.5	18.2	16.9	35.2	98.6	290.1	133.3
3.23	5200	43.3	38.1	46.1	40.8	45.8	73.1	127.0	82.6	45.8	21.3	18.1	16.8	35.2	98.6	290.9	133.2
3.29	5300	43.8	38.2	46.3	40.9	46.4	72.8	126.7	82.5	46.2	20.3	17.2	15.7	35.5	98.5	289.9	135.8
3.36	5400	44.1	38.1	46.1	40.8	46.7	72.6	126.4	82.4	46.3	20.2	17.2	15.6	35.6	98.3	289.2	137.2
3.42	5500	43.1	38.1	46.1	40.8	45.4	72.6	126.4	82.4	44.2	20.2	17.2	15.6	34.2	98.3	289.2	135.5
3.48	5600	43.1	37.4	45.3	40.1	45.4	72.6	126.4	82.4	44.2	19.6	16.6	15.1	34.2	98.3	289.2	135.5
3.54	5700	42.7	37.3	45.2	40.1	45.1	72.4	126.0	81.8	42.8	19.6	16.6	15.0	33.0	97.8	288.7	134.8
3.6	5800	42.6	37.4	45.3	40.2	45.1	72.4	126.1	80.2	42.0	19.6	16.6	15.0	32.4	96.2	289.3	135.3
3.67	5900	42.6	37.2	45.2	40.1	45.1	72.4	126.1	80.2	42.0	19.3	16.4	14.7	32.4	96.2	289.3	135.3
3.73	6000	42.6	36.8	44.7	39.7	45.1	72.4	126.1	80.2	42.0	18.4	15.7	14.0	32.4	96.2	289.3	135.3
3.79	6100	42.5	36.4	44.2	39.3	45.0	72.4	126.1	80.2	40.3	17.9	15.4	13.7	30.9	96.2	289.3	135.1
3.85	6200	42.3	36.4	44.2	39.3	44.7	72.4	126.0	79.8	38.2	17.9	15.4	13.7	29.4	95.7	289.2	134.7
3.91	6300	42.3	36.4	44.2	39.3	44.7	72.2	125.6	78.6	38.2	17.9	15.4	13.7	29.4	94.4	288.6	134.7
3.98	6400	42.3	36.4	44.2	39.3	44.7	71.9	124.9	76.0	38.2	17.9	15.3	13.6	29.4	90.3	286.6	134.7
4.04	6500	42.3	36.4	44.1	39.3	44.7	71.9	124.8	75.5	38.2	17.9	15.2	13.6	29.4	89.1	286.1	134.7
4.1	6600	42.3	36.4	44.1	39.3	44.7	71.9	124.8	75.5	38.2	17.9	15.2	13.6	29.4	89.1	286.1	134.7
4.16	6700	42.3	36.4	44.1	39.3	44.7	71.9	124.8	75.5	38.2	17.9	15.2	13.6	29.4	89.1	286.1	134.7

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 35 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**

Table 9b (continued): Annual Total Dissolved Solids Deposition in kg/(km²-month).
 Directions are directions that the plume is headed. Values can be converted to lbm/100-acre-month by multiplying by 0.893

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
4.23	6800	42.3	36.4	44.1	39.3	44.7	71.9	124.8	75.5	38.2	17.9	15.2	13.6	29.4	89.1	286.1	134.7
4.29	6900	42.3	36.4	44.1	39.3	44.7	71.9	124.8	75.5	38.2	17.9	15.2	13.6	29.4	89.1	286.1	134.7
4.35	7000	42.2	36.4	44.1	39.3	44.5	71.9	124.8	75.5	38.1	17.9	15.2	13.6	29.3	89.1	286.1	134.5
4.41	7100	42.2	36.4	44.1	39.3	44.5	71.9	124.8	75.5	38.1	17.9	15.2	13.6	29.3	89.1	286.1	134.5
4.47	7200	41.4	35.8	43.3	38.7	44.0	70.9	122.2	74.2	37.7	17.7	14.9	13.4	28.9	88.1	282.9	132.7
4.54	7300	40.9	35.1	42.1	37.4	43.7	70.2	120.5	73.4	37.5	17.6	14.8	13.2	28.7	87.5	280.8	131.5
4.6	7400	40.9	35.0	42.1	37.4	43.7	70.2	120.5	73.4	37.5	17.6	14.8	13.2	28.7	87.5	280.8	131.5
4.66	7500	40.9	35.0	42.1	37.4	43.7	70.2	120.5	73.4	37.5	17.6	14.8	13.2	28.7	87.5	280.8	131.5
4.72	7600	40.9	35.0	42.1	37.4	43.7	70.2	120.5	73.4	37.5	17.6	14.8	13.2	28.7	87.5	280.8	131.5
4.78	7700	40.9	35.0	42.1	37.4	43.7	70.2	120.5	73.4	37.5	17.6	14.8	13.2	28.7	87.5	280.8	131.5
4.85	7800	40.9	35.0	42.1	37.4	43.7	70.2	120.5	73.4	37.5	17.6	14.8	13.2	28.7	87.5	280.8	131.5
4.91	7900	40.9	35.0	42.1	37.4	43.7	70.2	120.5	73.4	37.5	17.6	14.8	13.2	28.7	87.5	280.8	131.5
4.97	8000	40.9	34.9	42.0	37.1	43.7	70.2	120.5	73.4	37.5	17.6	14.8	13.1	28.7	87.5	280.8	131.5
5.03	8100	40.9	34.9	41.9	36.8	43.7	70.2	120.5	73.4	37.5	17.6	14.8	13.0	28.7	87.5	280.8	131.5
5.1	8200	40.9	34.9	41.9	36.8	43.7	70.2	120.5	73.4	37.4	17.6	14.8	13.0	28.6	87.5	280.8	131.5
5.16	8300	40.8	34.8	41.8	36.8	43.5	70.2	120.5	73.4	36.6	17.5	14.7	12.9	28.2	87.5	280.8	131.1
5.22	8400	40.8	34.7	41.6	36.7	43.5	70.1	119.9	72.5	36.4	17.2	14.6	12.7	28.2	85.7	279.6	131.1
5.28	8500	40.8	34.7	41.5	36.7	43.5	70.1	119.7	72.1	36.1	17.2	14.6	12.7	28.2	85.6	279.5	131.1
5.34	8600	40.8	34.7	41.5	36.7	43.5	70.1	119.7	72.1	36.1	17.2	14.6	12.7	28.2	85.6	279.5	131.1
5.41	8700	40.8	34.7	41.5	36.7	43.5	70.1	119.7	72.1	36.1	17.2	14.6	12.7	28.2	85.6	279.5	131.1
5.47	8800	40.8	34.7	41.5	36.7	43.5	70.1	119.7	72.1	36.1	17.2	14.6	12.7	28.2	85.6	279.5	131.1
5.53	8900	40.8	34.7	41.5	36.7	43.5	70.1	119.7	72.1	36.1	17.2	14.6	12.7	28.2	85.6	279.5	131.1
5.59	9000	40.8	34.7	41.5	36.7	43.5	70.1	119.7	72.1	36.1	17.2	14.6	12.7	28.2	85.6	279.5	131.1
5.65	9100	40.8	34.7	41.5	36.7	43.5	70.0	119.7	72.0	36.1	17.2	14.6	12.7	28.2	85.6	279.4	131.1
5.72	9200	40.8	34.7	41.5	36.7	43.5	70.0	119.7	72.0	36.1	17.2	14.6	12.7	28.2	85.6	279.4	131.1
5.78	9300	40.8	34.7	41.5	36.7	43.5	68.4	116.0	69.5	36.1	17.2	14.6	12.7	28.2	83.3	272.0	131.1
5.84	9400	40.8	34.7	41.5	36.7	43.5	68.4	116.0	69.5	36.1	17.2	14.6	12.7	28.2	83.3	272.0	131.1
5.9	9500	40.8	34.7	41.5	36.7	43.5	68.4	116.0	69.5	36.1	17.2	14.6	12.7	28.2	83.3	272.0	131.1
5.97	9600	39.2	33.1	39.5	35.1	42.1	67.1	113.9	68.3	34.9	16.5	14.1	12.4	27.3	82.3	268.4	127.3
6.03	9700	38.0	32.2	38.5	34.2	40.6	65.3	111.0	66.4	34.1	16.1	13.8	12.1	26.8	80.3	261.6	122.6
6.09	9800	37.4	31.4	37.8	33.4	40.0	65.1	110.8	66.2	33.8	15.8	13.5	11.9	26.5	80.1	261.0	120.6
6.15	9900	37.4	31.3	37.7	33.3	40.0	63.9	108.7	64.9	33.8	15.7	13.5	11.9	26.5	79.0	256.7	120.6
6.21	1e4	37.4	30.5	36.8	32.2	40.0	59.5	101.8	61.2	33.8	15.2	13.1	11.5	26.5	74.6	241.2	120.6

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 36 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPD**

Table 9c: Annual Total <10 micron Solids Deposition in kg/(km²-month).

Directions are directions that the plume is headed. Values can be converted to lbm/100-acre-month by multiplying by 0.893.

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
0.06	100	106	50	76	67	120	105	255	314	908	289	231	256	731	3211	8096	277
0.12	200	65	28	46	54	75	23	62	118	175	6	5	8	154	842	1415	225
0.19	300	22.2	8.98	12.84	14.8	22.24	7.13	12.43	10.48	16.02	3.34	3.05	4.06	23.56	14.74	36.25	90.6
0.25	400	6.96	5.22	6.3	7.15	7.65	7.11	12.4	10.45	7.3	2.96	2.82	3.35	5.51	14.74	36.21	17.85
0.31	500	6.96	5.22	6.3	7.15	7.65	7.04	12.33	10.38	7.3	2.96	2.82	3.35	5.51	14.74	36.06	17.85
0.37	600	6.72	5.04	6.3	7.15	7.18	6.91	12.3	10.36	7.06	2.96	2.82	3.35	5.27	14.65	35.87	17.38
0.43	700	6.64	4.44	5.67	5.28	7	6.91	12.29	10.36	6.97	2.95	2.79	2.73	5.19	14.64	35.86	17.21
0.5	800	6.64	4.25	5.44	4.57	7	6.91	12.29	10.36	6.97	2.92	2.68	2.5	5.19	14.64	35.86	17.21
0.56	900	6.64	4.23	5.41	4.56	7	6.91	12.29	10.36	6.97	2.88	2.6	2.42	5.19	14.64	35.86	17.21
0.62	1000	6.64	4.17	5.3	4.49	7	6.91	12.29	10.36	6.97	2.69	2.23	2.05	5.19	14.64	35.86	17.21
0.68	1100	6.64	4.17	5.3	4.49	7	6.91	12.29	10.36	6.97	2.69	2.23	2.05	5.19	14.64	35.86	17.21
0.75	1200	6.43	4.17	5.3	4.49	6.83	6.91	12.29	10.36	6.9	2.69	2.23	2.05	5.15	14.64	35.86	17.03
0.81	1300	6.22	4.17	5.3	4.49	6.66	6.61	12.21	10.32	6.84	2.69	2.23	2.05	5.12	14.43	35.4	16.86
0.87	1400	5.86	4.17	5.3	4.49	6.36	6.38	12.11	10.24	6.19	2.69	2.23	2.05	4.64	14.3	35	16.21
0.93	1500	4.98	4.17	5.3	4.49	5.45	6.37	12.1	10.24	5.11	2.69	2.23	2.05	3.7	14.3	34.99	14.4
0.99	1600	4.82	4.17	5.3	4.49	5.22	6.37	12.1	10.23	4.93	2.69	2.23	2.05	3.56	14.29	34.99	13.98
1.06	1700	4.48	4.17	5.21	4.49	4.77	6.36	11.99	10.04	4.32	2.69	2.23	2.05	3.3	14.28	34.98	13.17
1.12	1800	4.15	3.9	4.82	4.23	4.46	6.36	11.96	9.96	3.63	2.44	2.04	1.89	2.83	14.28	34.98	12.42
1.18	1900	4.01	3.62	4.42	3.88	4.32	6.2	11.39	9.15	3.53	2.17	1.8	1.7	2.73	13.15	33.68	12.1
1.24	2000	3.98	3.42	4.18	3.65	4.29	6.18	11.33	9.06	3.51	1.93	1.59	1.46	2.71	13.03	33.54	12.04
1.3	2100	4	3.28	4.02	3.53	4.32	6.11	11.15	8.89	3.52	1.67	1.38	1.22	2.72	12.88	33.27	12.11
1.37	2200	4.01	3.15	3.87	3.42	4.33	5.88	10.62	7.88	3.53	1.56	1.26	1.1	2.73	11.95	32.52	12.14
1.43	2300	4.04	3.25	3.97	3.52	4.36	5.76	10.37	7.11	3.54	1.6	1.3	1.13	2.74	11.2	32.19	12.22
1.49	2400	4.13	3.25	3.97	3.52	4.45	5.93	10.7	7.35	3.6	1.6	1.3	1.13	2.78	11.46	32.95	12.48
1.55	2500	4.16	3.28	4.01	3.54	4.48	6.63	11.86	8.1	3.62	1.61	1.3	1.13	2.81	12.23	35.39	12.58
1.62	2600	4.22	3.32	4.06	3.58	4.53	7.18	12.68	8.58	3.65	1.63	1.31	1.14	2.83	12.75	37.49	12.75
1.68	2700	4.48	3.45	4.25	3.69	4.74	7.71	13.71	9.06	3.79	1.67	1.38	1.19	2.96	13.23	39.42	13.48
1.74	2800	4.68	3.73	4.54	3.95	4.96	7.9	14.19	9.29	3.92	1.76	1.47	1.27	3.06	13.41	40.03	14.19
1.8	2900	4.66	3.88	4.68	4.12	4.94	7.94	14.26	9.32	3.83	1.81	1.51	1.3	3	13.45	40.21	14.15
1.86	3000	4.7	3.86	4.65	4.09	4.98	8.06	14.32	9.12	3.69	1.68	1.43	1.22	2.92	12.9	40.47	14.45
1.93	3100	4.71	3.86	4.65	4.09	4.98	8.05	14.29	9.01	3.69	1.68	1.43	1.22	2.93	12.73	40.41	14.5
1.99	3200	4.76	3.96	4.89	4.23	5.03	8.05	14.29	9.01	3.72	1.69	1.47	1.23	2.95	12.73	40.41	14.71
2.05	3300	4.81	3.96	4.89	4.23	5.07	8.05	14.29	9.01	3.74	1.69	1.47	1.23	2.98	12.73	40.41	14.92
2.11	3400	4.81	3.96	4.89	4.23	5.07	8.05	14.29	9.01	3.74	1.69	1.47	1.23	2.98	12.73	40.41	14.92

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 37 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

Table 9c (continued): Annual Total <10 micron Solids Deposition in kg/(km²-month).
 Directions are directions that the plume is headed. Values can be converted to lbm/100-acre-month by multiplying by 0.893

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
2.17	3500	4.81	4.06	5.01	4.33	5.07	8.05	14.29	9.01	3.74	1.72	1.5	1.27	2.98	12.73	40.41	14.92
2.24	3600	4.81	4.11	5.06	4.38	5.07	8.13	14.44	9.08	3.74	1.73	1.52	1.29	2.98	12.79	40.67	14.92
2.3	3700	4.87	4.41	5.37	4.66	5.15	9.02	15.88	9.77	3.78	1.84	1.63	1.36	3	13.45	43.64	15.2
2.36	3800	4.95	4.53	5.49	4.78	5.27	9.37	16.45	10.01	3.84	1.89	1.66	1.4	3.03	13.7	45.04	15.61
2.42	3900	4.95	4.53	5.49	4.78	5.27	9.37	16.45	10.01	3.84	1.89	1.66	1.4	3.03	13.7	45.04	15.61
2.49	4000	4.98	4.55	5.53	4.83	5.32	9.35	16.4	9.98	3.86	1.91	1.66	1.4	3.04	13.67	44.97	15.8
2.55	4100	5.04	4.58	5.57	4.89	5.39	8.98	15.59	9.43	3.89	1.92	1.67	1.41	3.07	13.2	43.39	16.09
2.61	4200	5.01	4.51	5.49	4.83	5.36	8.9	15.4	9.3	3.86	1.9	1.65	1.39	3.05	13.08	43.01	16
2.67	4300	4.7	4.09	4.98	4.37	5.08	8.57	14.82	8.87	3.59	1.69	1.5	1.28	2.88	12.63	41.84	15.25
2.73	4400	4.47	3.89	4.77	4.13	4.82	7.15	12.43	7.23	3.42	1.59	1.43	1.22	2.76	10.92	36.44	14.58
2.8	4500	3.89	3.54	4.4	3.77	4.2	7.1	12.34	7.11	2.95	1.46	1.32	1.13	2.43	10.68	36.2	13.08
2.86	4600	3.67	3.49	4.35	3.72	3.94	7.09	12.32	7.03	2.8	1.44	1.3	1.11	2.22	10.5	36.12	12.53
2.92	4700	3.62	3.23	3.97	3.42	3.89	6.55	11.39	6.47	2.77	1.3	1.18	1.03	2.19	9.89	34.04	12.4
2.98	4800	3.25	2.93	3.6	3.1	3.46	5.67	9.96	5.62	2.57	1.16	1.07	0.93	1.99	8.98	30.79	11.3
3.04	4900	2.96	2.4	3.05	2.59	3.19	4.96	8.99	5.18	2.39	0.98	0.94	0.8	1.88	8.49	28.29	10.43
3.11	5000	2.58	2.07	2.54	2.25	2.65	4.57	8.29	4.73	2.03	0.86	0.82	0.7	1.67	8.11	26.93	9.3
3.17	5100	2.41	1.87	2.27	2.02	2.45	4.42	7.92	4.42	1.9	0.8	0.76	0.66	1.58	7.88	26.38	8.77
3.23	5200	2.32	1.87	2.27	2.02	2.36	4.39	7.87	4.39	1.83	0.8	0.76	0.66	1.53	7.85	26.23	8.33
3.29	5300	2.22	1.58	1.91	1.74	2.27	3.92	7.14	4.07	1.77	0.71	0.66	0.56	1.48	7.4	24.04	7.88
3.36	5400	2.02	1.56	1.89	1.73	2.06	3.53	6.42	3.76	1.63	0.71	0.66	0.55	1.35	7.07	22.24	7.12
3.42	5500	1.85	1.45	1.77	1.62	1.84	3.18	5.9	3.54	1.47	0.67	0.61	0.53	1.22	6.83	21	6.52
3.48	5600	1.66	1.28	1.61	1.45	1.65	2.97	5.64	3.43	1.36	0.61	0.56	0.49	1.12	6.7	20.34	5.63
3.54	5700	1.66	1.25	1.58	1.42	1.65	2.97	5.64	3.43	1.36	0.6	0.55	0.48	1.12	6.7	20.34	5.63
3.6	5800	1.66	1.25	1.58	1.42	1.65	2.97	5.64	3.43	1.36	0.6	0.55	0.48	1.12	6.7	20.34	5.63
3.67	5900	1.66	1.25	1.58	1.42	1.65	2.97	5.64	3.43	1.36	0.6	0.55	0.48	1.12	6.7	20.34	5.63
3.73	6000	1.59	1.19	1.49	1.31	1.58	2.88	5.45	3.35	1.32	0.57	0.54	0.47	1.09	6.63	19.96	5.34
3.79	6100	1.55	1.19	1.49	1.31	1.52	2.79	5.25	3.27	1.29	0.57	0.54	0.47	1.07	6.56	19.59	5.14
3.85	6200	1.55	1.19	1.49	1.31	1.52	2.69	5.05	3.09	1.29	0.57	0.54	0.47	1.07	3.82	11.67	5.14
3.91	6300	1.55	1.19	1.49	1.31	1.52	2.56	4.79	2.84	1.29	0.57	0.54	0.47	1.07	2.94	9.38	5.14
3.98	6400	1.55	1.19	1.49	1.31	1.52	2.49	4.65	2.71	1.29	0.57	0.54	0.47	1.07	2.81	9.16	5.14
4.04	6500	1.55	1.19	1.49	1.31	1.52	2.49	4.65	2.71	1.29	0.57	0.54	0.47	1.07	2.81	9.16	5.14
4.1	6600	1.55	1.19	1.49	1.31	1.52	2.49	4.65	2.71	1.29	0.57	0.54	0.47	1.07	2.81	9.16	5.14
4.16	6700	1.55	1.19	1.49	1.31	1.52	2.49	4.65	2.71	1.29	0.57	0.54	0.47	1.07	2.81	9.16	5.14



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

Table 9c (continued): Annual Total <10 micron Solids Deposition in kg/(km²-month).
 Directions are directions that the plume is headed. Values can be converted to lbm/100-acre-month by multiplying by 0.893

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
4.23	6800	1.55	1.19	1.49	1.31	1.52	2.49	4.65	2.71	1.29	0.57	0.54	0.47	1.07	2.81	9.16	5.14
4.29	6900	1.55	1.19	1.49	1.31	1.52	2.49	4.65	2.71	1.29	0.57	0.54	0.47	1.07	2.81	9.16	5.14
4.35	7000	1.55	1.19	1.49	1.31	1.52	2.49	4.65	2.71	1.29	0.57	0.54	0.47	1.07	2.81	9.16	5.14
4.41	7100	1.55	1.19	1.49	1.31	1.52	2.49	4.65	2.71	1.29	0.57	0.54	0.47	1.07	2.81	9.16	5.14
4.47	7200	1.55	1.19	1.49	1.31	1.52	2.49	4.65	2.71	1.29	0.57	0.54	0.47	1.07	2.81	9.16	5.14
4.54	7300	1.53	1.19	1.49	1.31	1.51	2.49	4.65	2.71	1.28	0.57	0.54	0.47	1.05	2.81	9.16	5.11
4.6	7400	1.45	1.19	1.49	1.31	1.44	2.49	4.65	2.71	1.2	0.57	0.54	0.47	0.98	2.81	9.16	4.97
4.66	7500	1.45	1.19	1.49	1.31	1.44	2.49	4.65	2.71	1.2	0.57	0.54	0.47	0.98	2.81	9.16	4.97
4.72	7600	1.45	1.19	1.49	1.31	1.44	2.49	4.65	2.71	1.2	0.57	0.54	0.47	0.98	2.81	9.16	4.97
4.78	7700	1.45	1.19	1.49	1.31	1.44	2.49	4.65	2.71	1.2	0.57	0.54	0.47	0.98	2.81	9.16	4.97
4.85	7800	1.45	1.19	1.49	1.31	1.44	2.49	4.65	2.71	1.2	0.57	0.54	0.47	0.98	2.81	9.16	4.97
4.91	7900	1.35	1.14	1.43	1.27	1.34	2.41	4.45	2.62	1.18	0.55	0.51	0.45	0.9	2.74	8.91	4.43
4.97	8000	1.08	1.04	1.28	1.18	1.16	2.11	3.68	2.24	1.05	0.52	0.45	0.42	0.77	2.44	7.93	3.76
5.03	8100	1.08	0.98	1.19	1.07	1.16	2.11	3.68	2.24	1.05	0.52	0.45	0.41	0.77	2.44	7.93	3.76
5.1	8200	1.08	0.97	1.17	1.04	1.16	2.11	3.68	2.24	1.05	0.52	0.45	0.4	0.77	2.44	7.93	3.76
5.16	8300	1.08	0.97	1.17	1.04	1.16	2.11	3.68	2.24	1.05	0.52	0.45	0.4	0.77	2.44	7.93	3.76
5.22	8400	1.08	0.97	1.17	1.04	1.16	2.11	3.68	2.24	1.01	0.52	0.45	0.4	0.76	2.44	7.93	3.76
5.28	8500	1.08	0.93	1.13	1	1.16	2.11	3.68	2.24	1	0.49	0.42	0.38	0.75	2.44	7.93	3.76
5.34	8600	1.08	0.93	1.12	1	1.16	2.11	3.68	2.24	1	0.49	0.42	0.37	0.75	2.44	7.93	3.76
5.41	8700	1.08	0.93	1.12	1	1.16	2.11	3.68	2.24	1	0.49	0.42	0.37	0.75	2.44	7.93	3.76
5.47	8800	1.08	0.93	1.12	1	1.16	2.11	3.68	2.24	1	0.49	0.42	0.37	0.75	2.44	7.93	3.76
5.53	8900	1.08	0.93	1.12	1	1.16	2.1	3.64	2.21	1	0.49	0.42	0.37	0.75	2.42	7.88	3.76
5.59	9000	1.08	0.93	1.12	1	1.16	2.05	3.51	2.08	1	0.48	0.41	0.37	0.75	2.3	7.67	3.76
5.65	9100	1.04	0.93	1.12	1	1.13	2.05	3.51	2.08	0.92	0.47	0.4	0.36	0.7	2.3	7.67	3.68
5.72	9200	1.03	0.93	1.12	1	1.12	2.05	3.51	2.08	0.91	0.47	0.4	0.36	0.69	2.3	7.67	3.67
5.78	9300	1.03	0.93	1.12	1	1.12	2.05	3.51	2.08	0.91	0.47	0.4	0.36	0.69	2.3	7.67	3.67
5.84	9400	1.03	0.93	1.12	1	1.12	2.05	3.51	2.08	0.91	0.47	0.4	0.36	0.69	2.3	7.67	3.67
5.9	9500	1.03	0.93	1.12	1	1.12	2.05	3.51	2.08	0.91	0.47	0.4	0.36	0.69	2.3	7.67	3.67
5.97	9600	1.03	0.93	1.12	1	1.12	2.05	3.51	2.08	0.91	0.47	0.4	0.36	0.69	2.3	7.67	3.67
6.03	9700	1.03	0.93	1.12	1	1.12	2.05	3.51	2.08	0.91	0.47	0.4	0.36	0.69	2.3	7.67	3.67
6.09	9800	1.03	0.93	1.12	1	1.12	2.05	3.51	2.08	0.91	0.47	0.4	0.36	0.69	2.3	7.67	3.67
6.15	9900	1.03	0.93	1.12	1	1.12	2.05	3.51	2.08	0.91	0.47	0.4	0.36	0.69	2.3	7.67	3.67
6.21	1e4	1.03	0.93	1.12	1	1.12	2.05	3.51	2.08	0.91	0.47	0.4	0.36	0.69	2.3	7.67	3.67

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 39 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPD**

Table 10: Annual Water Deposition in kg/(km²-month).

Directions are directions that the plume is headed.

Note: these can be converted to inches/yr of increased precipitation by multiplying by 4.7x10⁻⁷

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
0.06	100	.18E+05	.79E+04	.11E+05	.11E+05	.21E+05	.18E+05	.45E+05	.56E+05	.14E+06	.42E+05	.33E+05	.37E+05	.11E+06	.54E+06	.13E+07	.48E+05
0.12	200	.10E+05	.44E+04	.74E+04	.87E+04	.12E+05	.43E+04	.12E+05	.22E+05	.25E+05	.85E+03	.69E+03	.13E+04	.23E+05	.13E+06	.21E+06	.37E+05
0.19	300	.32E+04	.14E+04	.20E+04	.23E+04	.30E+04	.21E+04	.53E+04	.63E+04	.20E+04	.54E+03	.50E+03	.63E+03	.31E+04	.92E+04	.15E+05	.13E+05
0.25	400	.12E+04	.80E+03	.11E+04	.10E+04	.13E+04	.14E+04	.31E+04	.32E+04	.15E+04	.48E+03	.47E+03	.49E+03	.10E+04	.48E+04	.97E+04	.32E+04
0.31	500	.12E+04	.80E+03	.10E+04	.10E+04	.13E+04	.11E+04	.20E+04	.16E+04	.14E+04	.48E+03	.47E+03	.49E+03	.10E+04	.28E+04	.73E+04	.32E+04
0.37	600	.12E+04	.77E+03	.98E+03	.10E+04	.13E+04	.11E+04	.20E+04	.15E+04	.13E+04	.48E+03	.44E+03	.49E+03	.10E+04	.28E+04	.73E+04	.32E+04
0.43	700	.12E+04	.71E+03	.90E+03	.80E+03	.13E+04	.11E+04	.20E+04	.15E+04	.13E+04	.47E+03	.44E+03	.41E+03	.10E+04	.28E+04	.73E+04	.32E+04
0.5	800	.12E+04	.70E+03	.88E+03	.76E+03	.13E+04	.11E+04	.19E+04	.15E+04	.13E+04	.46E+03	.42E+03	.38E+03	.10E+04	.28E+04	.73E+04	.32E+04
0.56	900	.12E+04	.69E+03	.86E+03	.75E+03	.13E+04	.11E+04	.19E+04	.15E+04	.13E+04	.44E+03	.37E+03	.33E+03	.10E+04	.27E+04	.72E+04	.32E+04
0.62	1000	.12E+04	.69E+03	.86E+03	.75E+03	.12E+04	.10E+04	.19E+04	.15E+04	.13E+04	.44E+03	.37E+03	.33E+03	.99E+03	.27E+04	.71E+04	.31E+04
0.68	1100	.12E+04	.69E+03	.86E+03	.75E+03	.12E+04	.10E+04	.19E+04	.15E+04	.13E+04	.44E+03	.37E+03	.33E+03	.99E+03	.27E+04	.71E+04	.31E+04
0.75	1200	.11E+04	.69E+03	.86E+03	.75E+03	.12E+04	.10E+04	.19E+04	.15E+04	.12E+04	.44E+03	.37E+03	.33E+03	.93E+03	.27E+04	.71E+04	.30E+04
0.81	1300	.93E+03	.69E+03	.86E+03	.75E+03	.10E+04	.10E+04	.19E+04	.15E+04	.95E+03	.44E+03	.37E+03	.33E+03	.73E+03	.27E+04	.71E+04	.27E+04
0.87	1400	.88E+03	.69E+03	.86E+03	.75E+03	.95E+03	.10E+04	.19E+04	.15E+04	.89E+03	.44E+03	.37E+03	.33E+03	.68E+03	.27E+04	.71E+04	.25E+04
0.93	1500	.78E+03	.69E+03	.86E+03	.75E+03	.82E+03	.10E+04	.19E+04	.15E+04	.77E+03	.44E+03	.37E+03	.33E+03	.61E+03	.27E+04	.71E+04	.23E+04
0.99	1600	.71E+03	.66E+03	.81E+03	.72E+03	.75E+03	.10E+04	.19E+04	.15E+04	.66E+03	.40E+03	.34E+03	.31E+03	.52E+03	.27E+04	.71E+04	.21E+04
1.06	1700	.63E+03	.59E+03	.72E+03	.64E+03	.66E+03	.10E+04	.19E+04	.15E+04	.59E+03	.35E+03	.29E+03	.27E+03	.46E+03	.27E+04	.71E+04	.19E+04
1.12	1800	.60E+03	.56E+03	.68E+03	.61E+03	.64E+03	.10E+04	.19E+04	.15E+04	.57E+03	.33E+03	.27E+03	.25E+03	.45E+03	.27E+04	.71E+04	.19E+04
1.18	1900	.59E+03	.48E+03	.59E+03	.52E+03	.63E+03	.10E+04	.19E+04	.15E+04	.57E+03	.28E+03	.23E+03	.21E+03	.44E+03	.27E+04	.71E+04	.18E+04
1.24	2000	.59E+03	.46E+03	.56E+03	.50E+03	.62E+03	.10E+04	.18E+04	.14E+04	.56E+03	.25E+03	.21E+03	.19E+03	.44E+03	.26E+04	.70E+04	.18E+04
1.3	2100	.57E+03	.43E+03	.53E+03	.47E+03	.60E+03	.97E+03	.17E+04	.12E+04	.56E+03	.23E+03	.19E+03	.17E+03	.43E+03	.25E+04	.69E+04	.18E+04
1.37	2200	.55E+03	.43E+03	.53E+03	.47E+03	.59E+03	.94E+03	.17E+04	.12E+04	.54E+03	.23E+03	.19E+03	.17E+03	.42E+03	.24E+04	.68E+04	.17E+04
1.43	2300	.55E+03	.43E+03	.53E+03	.47E+03	.59E+03	.92E+03	.17E+04	.11E+04	.54E+03	.23E+03	.19E+03	.17E+03	.42E+03	.24E+04	.67E+04	.17E+04
1.49	2400	.55E+03	.43E+03	.52E+03	.47E+03	.58E+03	.94E+03	.17E+04	.11E+04	.54E+03	.23E+03	.19E+03	.17E+03	.42E+03	.23E+04	.68E+04	.17E+04
1.55	2500	.55E+03	.43E+03	.52E+03	.47E+03	.58E+03	.98E+03	.17E+04	.11E+04	.54E+03	.23E+03	.19E+03	.17E+03	.42E+03	.23E+04	.69E+04	.17E+04
1.62	2600	.55E+03	.43E+03	.53E+03	.47E+03	.59E+03	.99E+03	.18E+04	.12E+04	.53E+03	.23E+03	.19E+03	.17E+03	.42E+03	.23E+04	.69E+04	.17E+04
1.68	2700	.59E+03	.45E+03	.56E+03	.49E+03	.61E+03	.11E+04	.19E+04	.12E+04	.54E+03	.22E+03	.20E+03	.17E+03	.43E+03	.23E+04	.71E+04	.18E+04
1.74	2800	.60E+03	.49E+03	.60E+03	.52E+03	.63E+03	.11E+04	.19E+04	.12E+04	.55E+03	.23E+03	.20E+03	.18E+03	.43E+03	.23E+04	.71E+04	.19E+04
1.8	2900	.60E+03	.49E+03	.60E+03	.52E+03	.63E+03	.11E+04	.19E+04	.12E+04	.55E+03	.23E+03	.20E+03	.18E+03	.43E+03	.23E+04	.71E+04	.19E+04
1.86	3000	.60E+03	.49E+03	.60E+03	.52E+03	.63E+03	.11E+04	.19E+04	.12E+04	.55E+03	.23E+03	.20E+03	.18E+03	.43E+03	.23E+04	.71E+04	.19E+04
1.93	3100	.60E+03	.49E+03	.61E+03	.53E+03	.63E+03	.11E+04	.19E+04	.12E+04	.54E+03	.23E+03	.21E+03	.18E+03	.43E+03	.23E+04	.72E+04	.19E+04
1.99	3200	.61E+03	.50E+03	.61E+03	.54E+03	.64E+03	.11E+04	.20E+04	.12E+04	.54E+03	.23E+03	.21E+03	.18E+03	.43E+03	.23E+04	.73E+04	.19E+04
2.05	3300	.61E+03	.51E+03	.62E+03	.55E+03	.64E+03	.11E+04	.20E+04	.12E+04	.54E+03	.24E+03	.21E+03	.18E+03	.44E+03	.23E+04	.73E+04	.19E+04
2.11	3400	.61E+03	.51E+03	.62E+03	.55E+03	.64E+03	.11E+04	.20E+04	.12E+04	.52E+03	.24E+03	.21E+03	.18E+03	.43E+03	.23E+04	.73E+04	.19E+04
2.17	3500	.61E+03	.51E+03	.62E+03	.55E+03	.64E+03	.11E+04	.20E+04	.12E+04	.52E+03	.24E+03	.21E+03	.18E+03	.43E+03	.23E+04	.73E+04	.19E+04
2.24	3600	.61E+03	.52E+03	.63E+03	.56E+03	.64E+03	.12E+04	.21E+04	.13E+04	.52E+03	.23E+03	.21E+03	.18E+03	.43E+03	.24E+04	.75E+04	.19E+04
2.3	3700	.63E+03	.56E+03	.67E+03	.59E+03	.67E+03	.12E+04	.22E+04	.13E+04	.54E+03	.25E+03	.22E+03	.19E+03	.43E+03	.24E+04	.76E+04	.20E+04
2.36	3800	.63E+03	.56E+03	.67E+03	.60E+03	.67E+03	.12E+04	.22E+04	.13E+04	.54E+03	.25E+03	.22E+03	.19E+03	.43E+03	.24E+04	.76E+04	.20E+04
2.42	3900	.63E+03	.56E+03	.68E+03	.60E+03	.67E+03	.12E+04	.21E+04	.13E+04	.54E+03	.25E+03	.22E+03	.19E+03	.43E+03	.24E+04	.76E+04	.20E+04
2.49	4000	.62E+03	.55E+03	.66E+03	.58E+03	.66E+03	.12E+04	.21E+04	.13E+04	.53E+03	.24E+03	.22E+03	.19E+03	.43E+03	.24E+04	.75E+04	.20E+04
3.11	5000	.36E+03	.31E+03	.37E+03	.33E+03	.37E+03	.69E+03	.12E+04	.65E+03	.31E+03	.14E+03	.13E+03	.11E+03	.25E+03	.74E+03	.27E+04	.13E+04

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 40 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

6.21	10000	.26E+03	.21E+03	.25E+03	.22E+03	.27E+03	.47E+03	.81E+03	.42E+03	.18E+03	.83E+02	.75E+02	.63E+02	.14E+03	.50E+03	.19E+04	.90E+03
------	-------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

Table 11: Annual Hours/yr of Plume Shadow. Directions are directions from the tower.

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
0.12	200	6005	5200	5080	4788	5043	5671	5656	5561	5128	5166	6140	8000	8760	8760	8760	8760
0.25	400	1652	1671	1870	1921	2231	2959	3209	2267	1708	1318	1273	1978	2939	5390	2633	1720
0.37	600	1108	1204	1282	1341	1529	2043	1920	1318	864	688	628	1096	1473	1345	907	1051
0.5	800	829	924.5	996.3	1009	1167	1571	1306	906	554.6	410.5	385.1	647.5	770	708.7	543.7	714.9
0.62	1000	678.8	743.5	799.4	837	985.7	1286	964.8	640.7	382.8	284.8	281.2	442.3	536.3	445.4	361.8	538.6
0.75	1200	581.9	623.2	667.7	723.3	863.6	1090	793.9	498.3	293.7	218.8	211.6	363.7	377.5	360.8	239.7	436.7
0.87	1400	507.8	542.3	580.9	621.7	769.5	921.6	697.5	387.7	241.9	172.7	165	295.5	299.2	287.4	186.5	361.8
0.99	1600	456.3	481.1	515.5	544	684.6	811.6	626.8	356.8	214.6	137.4	135.1	249.1	250.8	234.8	142.5	303.1
1.12	1800	402.7	425.7	458.4	475.5	617.6	726	578.5	314.7	183.5	121	106.2	202.6	215.2	207.8	112.4	253.5
1.24	2000	356.1	382.4	421.5	435.3	560.2	647.1	540.5	281.8	166.6	103.7	93.3	168.6	188.5	173.9	85.2	214.4
1.37	2200	311.9	341.5	376.4	385.6	515.8	579.1	510.9	262.1	141.7	88.4	78	138.4	161.6	145	74.7	196.3
1.49	2400	275.2	304.7	345.4	356	471.1	542.8	466.2	235.7	124.2	75.7	68.7	125.4	147.1	130	64.8	174.9
1.62	2600	245.7	262.9	318.8	325	430.7	507.5	436.1	211.7	112.2	68.6	56.9	108.5	129.5	119.9	54.9	155.7
1.74	2800	219.6	231.4	294.9	302.8	392.2	477.5	398.5	178.9	98.8	62	48.3	93.9	115.3	106.2	43.9	148.2
1.86	3000	199.8	206.5	273	276.8	370.1	453.8	368.1	150.9	87.8	52.2	43.7	85.3	108.4	98.2	36.8	135.6
1.99	3200	186.6	183.1	247	251.2	335.8	434.1	324	135.8	75.9	42.7	40	74.8	101.7	89.9	35.8	122.6
2.11	3400	167.5	162.3	234.6	237.5	305.9	405	292.4	118.8	63.6	38.3	36.1	70.1	92	80.9	34.8	111.6
2.24	3600	157.1	151	204.4	221.6	291.6	380.1	265.8	110.9	55.6	29.2	31.5	59.6	83.2	71.7	29.8	103.6
2.36	3800	144.9	132.9	191.3	212.5	279.3	355.3	246.3	102.6	45.6	24.6	31.5	53.8	74.6	66.9	27.8	90.1
2.49	4000	131.1	122.3	181.1	202.8	261.2	338	223.1	94.6	41.5	22.6	28.4	51	67.1	59.5	24.7	81.1
2.61	4200	121.7	116.8	168.7	191.4	242.6	312.2	204.7	83.6	40.5	22.6	25.8	47.1	62.5	56.7	17.7	76.1
2.73	4400	110.9	103.7	155.8	181.8	227	290.2	194.7	73.4	38.5	20.5	23.8	42.8	57.9	50	14.5	66.2
2.86	4600	100.4	90.7	143.9	176	209.9	273.3	185.5	68.1	35.2	15.1	22.8	40.1	55.3	50	12	60.4
2.98	4800	91.8	79.9	123.2	166.8	199.5	255.4	166.8	59.7	28.9	13.1	22.8	38.2	47	46.1	10	55.4
3.11	5000	84	69.9	114.7	157.5	185.5	238	149.5	54.3	26.7	12.1	20.4	37.7	44.6	44.5	10	48.6
3.23	5200	70.5	54.5	103	146.6	173.2	224.3	141.5	46.7	25.4	12.1	16.6	36.4	40.9	39.1	10	41.8
3.36	5400	66.2	52.4	94.7	141.6	166.5	215.6	127.5	40.8	20.8	12.1	16.6	35.8	38.9	38.6	10	37.8
3.48	5600	55.4	47.7	87.1	137.7	162.7	205	119.3	38.3	18.8	12.1	14.4	32.3	37.9	38.1	10	36.8
3.6	5800	47.9	44.8	82.3	134.2	153.2	195.5	108.7	38.3	15.8	9.5	13.6	30.5	32.3	35.6	9	32.3
3.73	6000	44	43.8	75.7	127.9	147.2	188	102.7	35.8	14	9.5	10.7	28.7	28.2	33.2	9	28.3
3.85	6200	39.6	34.3	72.2	120.6	131.3	178.2	94.7	31.8	14	9.5	9.8	27.6	27.7	30.4	9	24.2
3.98	6400	34.5	33.3	70.3	114	123.6	170.9	90.4	26.5	10.7	9.5	8.8	27.1	26.4	28.9	9	21.8
4.1	6600	32.5	30.1	68.1	108.8	112.2	160.6	87.4	23.2	10.7	8.5	8.8	25.5	20.6	27.9	7	18.3
4.23	6800	29	27.1	64.2	104.2	105.5	150.2	78.8	22.2	9.7	7.5	7.3	24.8	20.6	24.9	7	13.3
4.35	7000	24.7	27.1	59.3	101.9	99.3	140	73.1	21.2	8.7	7.5	7.3	24.1	20	24.3	6	12.3
4.47	7200	22.5	25.8	53.9	99	94.9	125.3	66.6	21.2	8.7	6.5	6	23.3	16.9	24.3	6	12.3
4.6	7400	16.1	25.8	51.8	97.8	89.3	117.2	63.9	18.7	8.7	6.5	4.9	22.4	16.9	21.9	6	11.3
4.72	7600	11.9	24.7	48.4	90.1	82.2	106.1	61.9	16.8	7.3	6.5	4.9	21.2	16.3	18.4	6	7.6
4.85	7800	8.7	22.9	44.3	88.9	78.5	101	59.9	14.4	7.3	6.5	4.9	21.2	15.3	16.6	5	6.4

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 41 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**

Table 12: Annual Hours/yr of Fogging. Directions are directions from the tower.

(mi)	(m)	S	SSW	SW	WSW	W	WNW	NW	NNW	N	NNE	NE	ENE	E	ESE	SE	SSE
0.06	100	0	0.2	0	0.2	0	2	9.8	12.3	0	0	0	0	0	12.3	51.8	0
0.12	200	1.1	3.6	0.8	1.4	2.1	18.3	56.8	55.9	16.6	25.3	0	0	20.1	235.2	672.4	243.2
0.19	300	3.9	3.7	1.2	1.8	1.9	17	52	54.1	14.8	24.7	0.7	0	19.4	173.4	555.1	224.9
0.25	400	2.8	3.9	1.4	2.4	0.9	9.8	37	36.6	8.9	21.9	0	0	12	142.3	484.7	181
0.31	500	0.9	3	1.4	2	0.3	5.7	26.5	30.7	6.3	15	2.5	0	6.8	95	402	139.1
0.37	600	0	2.2	0.7	1.2	0	3	23	28	1	14	0	0	2.2	31	397	55.8
0.43	700	0	1.6	0.4	0.6	0	3	23	28	1	12.5	0	0	0.7	31	397	28
0.5	800	0	1	0	0	0	3	18	24	1	11	0	0	0	23.5	242.7	14.6
0.56	900	0	1	0	0	0	1.5	11.7	14.5	0.5	11	0	0	0	16.3	202.9	6
0.62	1000	0	0.9	0	0	0	1.5	6.5	10	0.5	9.6	0	0	0	8.5	45.5	6
0.68	1100	0	0.5	0	0	0	1.5	6.5	10	0.5	5.5	0	0	0	8.5	45.5	6
0.75	1200	0	0.5	0	0	0	1.5	6.5	10	0.5	5.5	0	0	0	8.5	45.5	5.2
0.81	1300	0	0.5	0	0	0	1.5	5.7	8.5	0.5	5.5	0	0	0	5.6	30.8	4.5
0.87	1400	0	0.5	0	0	0	1.5	5.5	8	0.5	5.5	0	0	0	4	23	4.5
0.93	1500	0	0.5	0	0	0	1.1	4.1	5.9	0.5	5.5	0	0	0	3	16.7	4.5
0.99	1600	0	0.4	0	0	0	0	0	0	0.5	4.1	0	0	0	0	0	4.5

8.1. Visibility of Plume from San Luis and Avila Beach

Figure 4 shows a map of the local region. The most common direction for the plume to travel is SE towards Port San Luis, particularly in the summertime when the plumes travel either ESE or SE over 60% of the time. But in all four seasons, the plumes extend in this direction (within a 1/16th quadrant) over 5 miles approximately 1.3% of the time (as seen in Tables 5 through 8, where plumes of longer than 5 miles exist in the SSE to ESE direction 1.4% in winter, 2.1% in spring, 0.9% in summer and 0.9% in fall). As seen in Figure 4, plumes would be visible from Avila Beach if they extended about 5 miles in this direction and are high over the hills.

Table 13 presents the plume characteristics when wind is coming from the NW and the plume is headed SE. The frequencies in Table 13 are the summation of annual frequencies in the ESE, SE, and SSE directions. As is seen in Table 13, the annual frequency of plumes extending to Port San Luis totals the frequency of plumes in this direction of about 6 miles, which is 0.9% of the time. It is noted that the data of Table 13 is for one specific wind direction (315° east of north) and that category 43 plumes are longer when wind blows from closer to the north. That is, Table 13 does not contradict the previous paragraph's conclusion of 1.3% of plumes longer than 5 miles in the SE direction. Also, it is noted that the category 43 plumes, which extend 4.7 miles, are 2600 ft in centerline altitude and 1000 feet in diameter. These would also be visible from Avila Beach, hence the total frequency of visible plumes is estimated at 1.92% of the time, with 0.9% of these encroaching over the Port San Luis area.

It is also cautioned that the plume lengths are best estimate with a good deal of variation in practice. Thus the 5.7 miles for category 44 plumes is a mean length for plumes when these general weather conditions exist - actual plumes will be both shorter and longer. Thus the final



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**

conclusion is that plumes will occasionally extend far enough to be visible from Avila Beach with a frequency on the order of 1.9% of the year.

The SACTI code does not provide information about the time of day or days per year of plume visibility. Results can be inferred from the meteorological data, but these are not code predictions. To estimate plume visibility from Avila Beach, the wind data was queried as to the hours per day that winds blew in the ESE to SSE direction with stronger than 1.2*average wind speed and greater than 90% humidity. This combination of criteria was selected since it promotes plumes in the direction of Avila Beach and totals 1.7% of the time, which is close to the 1.9% just described above. These conditions occurred 80 times per year for a cumulative 150 hours per year, with a maximum duration of 12 hours. The mean time was 1.9 hours with a standard deviation of 1.5 hours. The conclusion is that weather conditions are favorable to produce plumes that might be within view of Avila Beach approximately 80 times per year, but typically only for 0.4 to 3.4 hours at a time. Again, this is not an output of the SACTI code, but is rather an estimate based on evaluation of the meteorological data.

Figure 4 shows that San Luis will be able to see the plumes when visibility is about 12 miles or greater, and the plumes are higher than the intervening mountains. The height of the mountains can be estimated at 1600' (500 m) at roughly 8/12 or 2/3rds of the distance. Thus only plumes that are higher than $500 * 3/2 = 750$ m would be visible from San Luis. Table 13 lists both the height of the plume centerline and the radius. It is seen that the plumes will be visible to San Luis fairly frequently over the tops of the hills. The table predicts that SE directional plumes will exceed 750m in height (that is, the height+radius>750m) about 19% of the year.

To estimate the number of times per year plumes occur that could be seen from San Luis Obispo, the meteorology data was queried for all winds (any direction) above average velocity during humidities above 75%. This condition exists for 17.3% of the time, which is close to the 19% calculated above, and is conducive to greater plume formation. Higher winds were selected because it is noted in Table 13 that higher plumes are associated with longer plumes, which are associated with above average wind. The defined meteorological criteria was met an average of 270 days per year in the 5 year meteorological data base, with an average duration of 3.6 hours and a standard deviation of 3.3 hours.

The conclusion is that weather conditions are favorable to produce plumes that might be within view of San Luis Obispo approximately 270 days per year, for typically about 3.6 hours at a time. Again, this is not an output of the SACTI code, but is rather an estimate based on evaluation of the meteorological data.

The time of day in which the longest plumes appear will be during periods of high humidity. Higher humidities occur in the early morning, late evenings, and nighttime. Plots of the meteorological conditions described above are presented in Figures 5 and 6. These figures show on a time versus day of year scale for the meteorological data of the year 2003 when conditions are conducive for the plumes.

Appendix A-7



Pacific Gas and Electric Company
Engineering - Calculation Sheet
Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
REV. NO. 0
SHEET NO. 43 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**




Figure 4: Each node is 2 miles. The elevation of Saddle Peak is 1600'

It is observed in Figures 5 and 6 that the period of visible plumes is expected to be near sunrise and sunset, without a strong dependency on time of year. The data used to draw Figure 5 indicate the possibility of visible plumes within site of Avila Beach within 1 hour of sunrise or sunset to have occurred 45 times in the year 2003. The data used to draw Figure 6 indicate the possibility of visible plumes within site of San Luis Obispo within 1 hour of sunrise or sunset to have occurred 327 times in the year 2003. Of these occurrences, 203 were associated with sunset time.



SUBJECT

Plume Characteristics of Proposed Cooling Towers at DCP

Table 13: Annual Characteristics of Plumes in the SE Direction

Category	LENGTH (m)	LENGTH (miles)	HEIGHT (m)	RADIUS (m)	Frequency	Top>750m Freq
11	46.5	0.03	31.3	15.7	1.98	0
12	48.3	0.03	11.1	9.9	5.92	0
13	123.8	0.08	16.3	13.5	13.8	0
14	71.3	0.04	31.4	14.5	0.04	0
15	88.2	0.05	106	27.7	0.1	0
16	64.3	0.04	97.1	19.9	0	0
17	45.1	0.03	154.9	56.7	0	0
18	89.9	0.06	56.9	25	0.37	0
19	89.4	0.06	56.8	24.4	0	0
20	121.8	0.08	78.3	22.5	0	0
21	170	0.11	80.2	30.9	1.3	0
22	211.6	0.13	145.2	39.4	1.01	0
23	507.7	0.32	207.3	47.3	1.25	0
24	561.2	0.35	362	77	0.91	0
25	819.9	0.51	363.9	79	1	0
26	1010.5	0.63	424.7	87.8	0.96	0
27	2271.9	1.41	714.6	116.3	0.94	0.94
28	2261.8	1.41	731.7	174.7	0.93	0.93
29	2271.7	1.41	710.9	192.1	0.93	0.93
30	2071.7	1.29	709.1	193.5	1.07	1.07
31	2256.4	1.40	748.5	253.5	0.86	0.86
32	2453.2	1.52	748.5	265.7	0.98	0.98
33	2590.1	1.61	724.8	262.4	1.08	1.08
34	2959.7	1.84	744.3	262.1	0.91	0.91
35	3059.3	1.90	776	261.9	1.02	1.02
36	3359.4	2.09	770	265.4	1.03	1.03
37	3892.2	2.42	748	273.7	1.32	1.32
38	4075.1	2.53	761.9	267.6	1.01	1.01
39	4382.2	2.72	746.6	270.1	1.04	1.04
40	4892.4	3.04	738.9	273.8	1.27	1.27
41	5690.6	3.54	763	293.2	0.99	0.99
42	6382	3.97	787.9	307.2	1.11	1.11
43	7594.6	4.72	793.9	322	1.02	1.02
44	9183.2	5.71	772.9	345.2	0.9	0.9
45	4455.2	2.77	694.5	276.4	0.58	0.58
TOTALS					47.6	18.99

Appendix A-7



Pacific Gas and Electric Company
Engineering - Calculation Sheet
Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
REV. NO. 0
SHEET NO. 45 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**




Figure 5: Periods of Humidity and Wind and Wind Direction conducive to long plumes extending towards Avila Beach




Figure 6: Periods of Humidity and Wind conducive to plume visibility from San Luis Obispo



Appendix A-7

SUBJECT Plume Characteristics of Proposed Cooling Towers at DCP

9. MARGIN ASSESSMENT

This calculation does not impact any design or licensing basis margin.

10. CONCLUSIONS

A summary of Plume lengths is presented in Table 14. In most cases, the plumes tend to lie either towards the Northwest (over the plant itself, especially in the winter) or to the Southeast (along the access road from Avila Beach).

Table 14: Visible Plume Length Summary

	Winter	Spring	Summer	Fall
Most Frequent Plume Heading Directions	NW,SE	SE,ESE,SSE	SE,ESE	SE,ESE,SSE
Percent of Plumes < 1/3 miles	26.9	35.0	44.2	40.4
Percent of Plumes >1/3 to 2 mile	38.5	28.2	30.3	34.8
Percent of Plumes >2 to 5 miles	30.3	32.8	24.3	22.5
Percent of Plumes >5 Miles	4.3	4.0	1.3	2.2

Estimates of salt, TDS, PM10, and water deposits are given in Tables 9a, 9b, 9c, and 10, respectively. Due to the use of salt water, the salt deposition rates are notable for some distance. The length of the access road, once it reaches the coastline, will be exposed to some amount of salt. The makeup of the TDS is over 3/4ths sodium salt.

Shading and fog from the plumes are given in Tables 11 and 12. There will be some loss of sunlight near the towers. The fogging is predicted to interact with plant components to the NW and plant worker vehicles approaching from the SE.

Plumes are predicted to occasionally (about 1.9% of the time) be long enough to be visible from the recreational area around Avila Beach. Plumes will be large enough to be visible over the tops of the coastal hills from San Luis approximately 19% of the year. The time of day that plumes appear is not estimated by the SACTI code, but evaluation of meteorological data imply most plumes will occur at night or near the



Pacific Gas and Electric Company
Engineering - Calculation Sheet

Project: Diablo Canyon Unit ()1 ()2 (X)1&2

Appendix A-7

CALC. NO. N/A (Study Only)

REV. NO. 0

SHEET NO. 47 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**

sunrise or sunset. Meteorological conditions conducive to plumes visible from Avila Beach near sunrise or sunset are estimated to occur on the order of 45 times per year, while conditions for plumes to be visible from San Luis on are the order of 300 times per year, and roughly 200 sunsets per year.

11. **IMPACT EVALUATION**

This calculation does not impact any design or licensing basis document associated with DCPP. Its purpose is solely to support the assessment of the impacts associated with cooling tower operation at the site.



SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**

12. REFERENCES.

1. Google Earth (for site location and images showing general site topography)
2. SACTI User's Manual: Cooling-Tower-Plume Prediction Code, EPRI CS-3403-CCM, April 1984
3. Site meteorology data, hourly observations, years 2003 through 2006, transmitted by Email, McCarthy to Berger, 2/12/2008 12:40 pm (data in project files listed in Attachment 2). The data for 2007 was by Email, McCarthy to Berger, 5/8/2008 7:31 pm, and is also in the project files.
4. SLO meteorological data, purchased and downloaded from NCDC 2/8/2008 (data in project files listed in Attachment 2)
5. SLO/San Diego mixing height data, purchased and downloaded from NCDC 2/25/2008 (data in project files listed in Attachment 2)
6. NRC Environmental Standard Review Plan, NUREG-1555
7. Cooling Tower Drift Mass Distribution, Excel Drift Eliminators, Marley Cooling Technologies Sales Brochure, faxed to Enercon 12/4/2001. (Note: the same drop spectrum data is available online at pg 4 of <http://awmasandiego.org/SDC-2002/4-1-lindahl.pdf>.)
8. Email Denicke to Berger, 2/4/2008 transmitting tower height information and meteorology data (contained in Attachment 1)
9. Pacific Mountain Energy Center, ESFEC Application 2006-1, obtained 2/22/2008 from <http://www.efsec.wa.gov/PMEC/App/PMEC%20Appx%20B.pdf>
10. Email Denicke to Berger, 2/22/2008 transmitting tower dimensional information (contained in Attachment 1)
11. Email Denicke to Berger 2/25/2008 transmitting estimated concentrated seawater density
12. Donald Connors, On the Enthalpy of Seawater, US Naval Underwater Weapons Research and Engineering Station, Newport, Rhode Island
13. Heat Balance Diagrams for DCPP, Unit 1 DC 6021770-5 and Unit 2 DC 6021770-22
14. Existing Condenser duty from DC 663041-35-2
15. Email, Clark to Berger, 5/30/2008 3:34 PM



SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP

ATTACHMENT 1 - Miscellaneous Data Sources

Reference 12.8

From: Martin Denicke [mdenicke@enercon.com]
 Sent: Monday, February 04, 2008 4:27 PM
 To: 'Ralph Berger'
 Cc: rclark@enercon.com
 Subject: Cooling Tower Location for Plume Study

Attachments: SKMBT_C35208020111010.pdf

Ralph, attached is a sketch showing the location of the cooling towers.

1. Each unit has 40 cells, with a combined evaporation of 12,600 gpm (assumed evenly distributed among the 40 cells).
2. The hot water temperature entering the cooling tower is 96F, and it is cooled to 78F, with an ambient wet bulb of 61F.
3. The cooling tower flow is approximately 860,000 gpm per unit, having a saltwater concentration of 1.5 x normal seawater (typical breakdown by chemical constituent given below), with a density of 64.9 lb/cu ft at 78F and 64.5 lb/cu ft at 96F. I obtained the density values from a curve excerpted from an article entitled "The Use of Cooling Towers for Salt Water Heat Rejection" by D.M. Suptic, P.E., Marley Cooling Tower Company, 1991.
4. Cooling Tower Chemistry is as follows:

Constituent	Seawater		
Cooling tower Water			
Ca(HCO3)2	185 ppm	x1.5=	278
ppm			
CaSO4	1200 ppm	x1.5=	1800
ppm			
MgSO4	2150 ppm	x1.5=	3225
ppm			
MgCl2	3250 ppm	x1.5=	4875
ppm			
NaCl	27000 ppm	x1.5=	40500
ppm			
KCl	500 ppm	x1.5=	750
ppm			
KBr	100 ppm	x1.5=	150



Appendix A-7

SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP

ppm			
CaCO ₃	115 ppm	x1.5=	173
ppm			
	Total TDS	34,500 ppm	51,751
ppm			
pH		about 8	
about 8			

These values are given in an article "Cooling Towers & Salt Water" by J.A. Nelson, The Marley Cooling Tower Company, 11/5/1986.

Calculation of TDS Density based on component constituents in 12.8 and Miscellaneous Data Sources

CaCO₃ density is 2.71 gm/cm³ at 300K (173/51751 = .0033 fraction total)

Source: <http://www.almazoptics.com/CaCO3.htm>

KBr density is 2.75 gm/cm³ (150/51751 = .0029 fraction total)

Source: http://www.hilger-crystals.co.uk/prior/mat_kbr.htm

NaCl density is 2.17 gm/cm³ (40500/51751 = .7826 fraction total)

Source: Input 4.3.9, verified to within .01 at http://www.hilger-crystals.co.uk/prior/mat_nacl.htm

KCl density is 1.99 gm/cm³ (750/51751 = .0145 fraction total)

Source: http://www.hilger-crystals.co.uk/prior/mat_kcl.htm

MgSO₄ density is 2.66 gm/cm³ (3225/51751 = .0623 fraction total)

Source: <http://www.thekrib.com/Plants/CO2/rift.html>

MgCl₂ density is 1.57 gm/cm³ (4875/51751 = .0942 fraction total)

Source: <http://bulkpharm.mallinckrodt.com/attachments/msds/m0156.htm>

CaSO₄ density is 2.96 gm/cm³ (1800/51751 = .0348 fraction total)

Source: <http://www.itbaker.com/msds/englishhtml/C0497.htm>

Ca(HCO₃)₂ density was not located, so total constituents identified add to 0.9946 of total.

The averaged density is therefore:

$$(.0033*2.71+.0029*2.75+.7826*2.17+.0145*1.99+.0623*2.66+.0942*1.57+.0348*2.96)/.9946$$

$$= 2.17 \text{ gm/cm}^3$$



Appendix A-7

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCPP**
Reference 12.9

Table B-1-14 summarizes recent BACT determinations for utility-scale mechanical draft cooling towers. The commercially available techniques listed to limit drift PM₁₀ releases from utility-scale cooling towers include:

- Use of Dry Cooling (no water circulation) Heat Exchanger Units
- High-Efficiency Drift Eliminators, as low as 0.0005% of circulating flow
- Limitations on TDS concentrations in the circulating water
- Combinations of Drift Eliminator efficiency rating and TDS limit
- Installation of Drift Eliminators (no efficiency specified)

The use of high-efficiency drift eliminating media to de-entrain aerosol droplets from the air flow exiting the wetted-media tower is commercially proven technique to reduce PM₁₀ emissions. Compared to "conventional" drift eliminators, advanced drift eliminators reduce the PM₁₀ emission rate by more than 90 percent.

In addition to the use of high efficiency drift eliminators, management of the tower water balance to control the concentration of dissolved solids in the cooling water can also reduce particulate emissions. Dissolved solids accumulate in the cooling water due to increasing concentration of dissolved solids in the make-up water as the circulating water evaporates, and, secondarily, to addition of anti-corrosion, anti-biocide additives. However, to maintain reliable operation of the tower without the environmental impact of frequent acid wash cleanings, the water balance must be considered. The proposed PMEC tower will be based on 12 cycles of concentration, that is, the circulating water will be on average 12 times the dissolved solids concentration of the make-up water that is introduced. The proposed cooling tower is to be operated at a design level of total dissolved solids (TDS) concentration of 2,400 ppmw in the cooling water, based on 200 ppmw in the make up water.

Lastly, the substitution of a dry cooling tower is a commercially available option that has been adopted (usually because of concerns other than air emissions) by utility-scale combined cycle plants in arid climates. This option involves use of a very large, finned-tube water-to-air heat exchanger through which one or more large fans force a stream of ambient dry air to remove heat from the circulating water in the tube-side of the exchanger.

B-1.15.3 INFEASIBLE CONTROL MEASURES

One measure that has been adopted in arid, low precipitation climates is the use of a dry, i.e., non-evaporative cooling tower for heat rejection from combined-cycle power plants. Where it has been adopted, this measure is usually a means to reduce the water consumption of the plant, rather than as BACT for PM₁₀ emissions. There is a very substantial capital cost penalty in adopting this technology, in addition to the process changes (e.g., operating pressures) necessary to condense water at the ambient dry bulb temperature, rather than at ambient wet bulb temperature. The plants for which this measure has been used are, with few exceptions, smaller capacity combined-cycle plants (smaller than the PMEC facility).



Pacific Gas and Electric Company
Engineering - Calculation Sheet
Project: Diablo Canyon Unit ()1 ()2 (X)1&2

Appendix A-7

CALC. NO. N/A (Study Only)
REV. NO. 0
SHEET NO. 52 OF 57

SUBJECT Plume Characteristics of Proposed Cooling Towers at DCP
Reference 12.10

From: Martin Denicke [mdenicke@enercon.com]
Sent: Friday, February 22, 2008 11:31 AM
To: 'Ralph Berger'
Subject: FW: Diablo Canyon

Attachments: Diablo Canyon Back-Back Layout-40 Cells.jpg

From: Jim Hubbard [mailto:jhubbard@enercon.com]
Sent: Tuesday, January 29, 2008 9:16 AM
To: 'Martin Denicke'
Subject: FW: Diablo Canyon

This is the information from SPX.

Jim,
Wet Selection:
HWT= 96.0 deg. F
CWT = 78.0 deg. F
IWBT = 61 deg F + 2 deg. F recirculation & interference = 63 deg. F
Range = 18.0 deg. F
Approach to IWBT = 15 deg. F
Cycles of Concentration = 1.5

Arrangement: Back-Back FRP
Cell Size = 60 ft x 60 ft
Basin Width = 140 ft
Basin Depth = 4 ft
No. Cells = 20 per Unit
Motor Output Power = 300 HP = 6000 HP/ Unit
Pump Head = 36.5 ft referenced to top of curb
Materials; Suitable for 1.5 cyc salt water

Budgetary Price = [] for two units
See attached arrangement.



Pacific Gas and Electric Company
Engineering - Calculation Sheet
Project: Diablo Canyon Unit ()1 ()2 (X)1&2

Appendix A-7

CALC. NO. N/A (Study Only)
REV. NO. 0
SHEET NO. 53 OF 57

SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP
Reference 12.11

From: Martin Denicke [mdenicke@enercon.com]
Sent: Monday, February 25, 2008 3:28 PM
To: 'Ralph Berger'
Subject: Comments on Plume Characteristics Calc

Hi Ralph. I have the following questions re your plume study:

- 1) item 4.3.1, p.6: you give a density for the water of 62.05 lb/cu ft. Shouldn't this be about 64.5 for our concentrated seawater?
- 2) item 4.3.2, p.6: is the 4000 mg/l TDS level right? If I have ~53,000ppm TDS, that's a concentration of .053, or 5.3%, so one liter would have 53 grams of salt, or 53,000 mg of salt (as you mention on the next page in item 4.3.10).

That's as far as I got today...

- Martin



SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP
 Reference 12.14

STEAM INLET EXPANSION JOINT

The steam inlet expansion joint is a rubber belt type with welded connection to the surface condenser and turbine exhaust. There is a water tray on the external periphery of the expansion joint. The expansion joint is manufactured by Process Engineering Company, Inc. (Drawing EB-69351)

MOVEMENTS

Axial Deflection	- 5/32" normal	53/64 emergency
Lateral Deflection	- 3/32" normal	17/32 emergency
Axial Forces	- 5/32" 8,000 Lbs.	53/64 45,900 Lbs.
Lateral Forces	- 3/32" 4,400 Lbs.	17/32 25,300 Lbs.

Normal operating conditions: 100° - 115°F. Emergency conditions for periods of time up to two (2) hours with temperature of 230°F.

Expansion joint is to be suitable for 30" Hg. internal vacuum with atmospheric pressure outside, also suitable for internal pressure of 15 PSIG with atmospheric pressure outside.

PERFORMANCE DATA - CONDENSER

Percent Cleanliness	85 & 90	△
Heat Load BTU/Hr.	7,599,000,000	
Abs. Pressure In. Hg.	1.71 & 1.64	△
Circulating Water Temperature, Deg. F.	56.5	
Circulating Water Quantity, G.P.M.	862,690	
Water Velocity, Ft. per Sec.	6.791	△
Friction in Water Circuit, Ft.	10.6 Ft. @ 56.5° F	

PACIFIC GAS & ELECTRIC CO.	
ACCEPTED FOR CONSTRUCTION	
ENGINEERING DEPARTMENT	
DATE	11-9-83
BY	<i>[Signature]</i>

APPROVED FOR	
NOV 15 1983	
MICROFILMING	

RECORD No. Sh. Ch.

DC 663041-35-2



SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCP**
Reference 12.15

From: Rich Clark <richclark331@sbcglobal.net>
 To: rberger@sbcglobal.net
 Cc: rclark@enercon.com
 Sent: Friday, May 30, 2008 3:34:55 PM
 Subject: Condenser Duty

Ralph,

The attached excel file calculates an average 2 unit condenser duty of 4469 MW with cooling towers installed. The calculation uses the measured steam generator thermal megawatts and the main generator output from the Unit 1 & 2 main turbine post-retrofit performance tests conducted in 2006 after installation of the new Alstom LP turbines.

Thanks,

Rich

Spread sheet attached to Ref. 12.15 email

Condenser Duty			
Unit 1 Run #1 Corrected 1/8/2006			
	kw	btu/kw-hr	btu/hr
Reactor Onput	3,425,000	3,412.14	11,686,579,500
Elect Gen Output	1,203,050	3,412.14	4,104,975,027
Mech losses	3,600	3,412.14	12,283,704
Gen losses	15,399	3,412.14	52,543,680
Condenser Q			7,516,777,089
Unit 1 Run #2 Corrected 1/8/2006			
	kw	btu/kw-hr	btu/hr
Reactor Onput	3,425,000	3,412.14	11,686,579,500
Elect Gen Output	1,198,670	3,412.14	4,090,029,854
Mech losses	3,600	3,412.14	12,283,704
Gen losses	15,343	3,412.14	52,352,382
Condenser Q			7,531,913,560

Appendix A-7



Pacific Gas and Electric Company
 Engineering - Calculation Sheet
 Project: Diablo Canyon Unit () 1 () 2 (X) 1&2

CALC. NO. N/A (Study Only)
 REV. NO. 0
 SHEET NO. 56 OF 57

SUBJECT **Plume Characteristics of Proposed Cooling Towers at DCCP**

Unit 2 Run #1 Corrected 6/25/06			
	kw	btu/kw-hr	btu/hr
Reactor Onput	3,425,000	3,412.14	11,686,579,500
Elect Gen Output	1,198,670	3,412.14	4,090,029,854
Mech losses	3,600	3,412.14	12,283,704
Gen losses	14,684	3,412.14	50,102,866
Condenser Q			7,534,163,076
Unit 2 Run #2 Corrected 6/25/06			
	kw	btu/kw-hr	btu/hr
Reactor Onput	3,425,000	3,412.14	11,686,579,500
Elect Gen Output	1,198,430	3,412.14	4,089,210,940
Mech losses	3,600	3,412.14	12,283,704
Gen losses	14,681	3,412.14	50,092,834
Condenser Q			7,534,992,022
Average Condenser Duty BTU/hr per Unit			7,529,461,437
Average Condenser Duty - MW per Unit			2206.668377
Average Condenser Duty - MW per 2 Units			4413.336755
Approx average MW loss per unit with cooling towers			27.6
Approx average MW loss per 2 units with cooling towers			55.2
Avg Condenser Duty with cooling towers -MW per unit			2234
Avg Condenser Duty with cooling towers - MW per 2 units			4469



SUBJECT Plume Characteristics of Proposed Cooling Towers at DCPP

ATTACHMENT 2 - Files

Met Data

- dcppMet.txt - Met data in CD144 format for use by SACTI
- dcpp2003.xls, dcpp2004.xls, dcpp2005.xls, dcpp2006.xls, dcpp2007.xls - Final Met Data Excel Files
- DCPP03.xls, DCPP04.xls, DCPP05.xls, DCPP06.xls, DCPP07_JANTDEC.xls - Site Met Data
- 2003.xls, 2004.xls, 2005.xls, 2006.xls, 2007.xls - SLO Met Data combined
- 200301.txt, 200302.txt, ... 200712.txt - SLO raw data purchased from NCDC
- dcppmix.txt - mixing height data in format for use by SACTI
- mixheight.xls - Excel program used to create dcppmix.txt
- mixheights1.txt, mixheights2.txt - SLO/SanDiego mix height data purchased from NCDC

SACTI files

- prep.usr - preparation file that analyses met data
- mult.usr - input files with cooling tower specifics
- tables.usr - defines tables to be produced
- prep.out, mult.out, Tables.out - output files created by SACTI
- multTDS.usr and multPM10.usr - input files for TDS and PM10 deposition rates
- multTDS.out and TablesTDS.out - output associated with Table 9b
- multPM10.out and TablesPM10.out - output associated with Table 9c
- DCPPplumeResults.xls - Excel file that creates Tables 4 through 14 from the output files

**Appendix A-8
DCPP Cooling Tower Study**

Summary of Civil Quantities

Descriptions	Soil Excavation	Rock Excavation	Soil Backfill	4000 psi Concrete	Hand Rail	Trash Rack	Grating	Two Lane Pavement	6" dia.	8" dia.	36" dia.	Pipe exp.Joints
Unit	C.Y.	C.Y.	C.Y.	C.Y.	Lin. Ft	S. Ft	S. Ft	Lin. Ft	Lin. Ft	Lin. Ft	Lin. Ft	
Above EL. 85	766363	328441										
Basin		64142	1318	18472								
Pump pits		45906	22133	9356	600	6480	7344					
Concrete pipes		347962	187232	90336								Lump Sum
Retaining wall		6750	4492	2258								
IFISI Road								1400				
Drainage M.H.		142		213								
Drainage pipes		4184	4208						1230	480		
Elec. EQ. Rm	227			393								
Blow down		26500	25466								3950	
Total	766590	824027	244849	121028	600	6480	7344	1400	1230	480	3950	Lump Sum

**Appendix A-9
DCPP Cooling Tower Study
Cable Estimate (part 1 of 2)**

Item Description	Size	Power 5Kv Cable, MV-105	Power Cable length	Fan Control Cable	Fan Control Cable Length	Motor Operated Valve 480 V Power Cable	MOV Power Cable Length	MOV Control Cable	MOV Control Cable Length	Instr. Cable	Instr. Cable Length	Lighting Power Cable	Lighting Power Cable Length	GAI-Tronics Comm. Cable	GAI-Tronics Comm. Cable Length
Cooling Twr U1 Fan 1	300 hp	1-3/C #6 Shielded	460.00	1-12/C # 12	460.00	1-3/C #6	460.00	1-12/C # 12	460.00	1-4/C #16	460.00	1-3/C #12	460.00	3/C#14,3/C#18	460.00
Cooling Twr U1 Fan 2	300 hp	1-3/C #6 Shielded	530.00	1-12/C # 12	530.00	1-3/C #6	530.00	1-12/C # 12	530.00	1-4/C #16	530.00				
Cooling Twr U1 Fan 3	300 hp	1-3/C #6 Shielded	600.00	1-12/C # 12	600.00	1-3/C #6	600.00	1-12/C # 12	600.00	1-4/C #16	600.00				
Cooling Twr U1 Fan4	300 hp	1-3/C #6 Shielded	670.00	1-12/C # 12	670.00	1-3/C #6	670.00	1-12/C # 12	670.00	1-4/C #16	670.00				
Cooling Twr U1 Fan 5	300 hp	1-3/C #6 Shielded	740.00	1-12/C # 12	740.00	1-3/C #6	740.00	1-12/C # 12	740.00	1-4/C #16	740.00	1-3/C #12	775.00		
Cooling Twr U1 Fan 6	300 hp	1-3/C #6 Shielded	810.00	1-12/C # 12	810.00	1-3/C #6	810.00	1-12/C # 12	810.00	1-4/C #16	810.00				
Cooling Twr U1 Fan 7	300 hp	1-3/C #6 Shielded	880.00	1-12/C # 12	880.00	1-3/C #6	880.00	1-12/C # 12	880.00	1-4/C #16	880.00				
Cooling Twr U1 Fan 8	300 hp	1-3/C #6 Shielded	950.00	1-12/C # 12	950.00	1-3/C #6	950.00	1-12/C # 12	950.00	1-4/C #16	950.00				
Cooling Twr U1 Fan 9	300 hp	1-3/C #6 Shielded	1,020.00	1-12/C # 12	1,020.00	1-3/C #6	1,020.00	1-12/C # 12	1,020.00	1-4/C #16	1,020.00				
Cooling Twr U1 Fan 10	300 hp	1-3/C #6 Shielded	1,090.00	1-12/C # 12	1,090.00	1-3/C #6	1,090.00	1-12/C # 12	1,090.00	1-4/C #16	1,090.00	1-3/C #12	1,090.00		
Cooling Twr U1 Fan 11	300 hp	1-3/C #6 Shielded	460.00	1-12/C # 12	460.00	1-3/C #6	460.00	1-12/C # 12	460.00	1-4/C #16	460.00	1-3/C #12	460.00		
Cooling Twr U1 Fan 12	300 hp	1-3/C #6 Shielded	530.00	1-12/C # 12	530.00	1-3/C #6	530.00	1-12/C # 12	530.00	1-4/C #16	530.00				
Cooling Twr U1 Fan 13	300 hp	1-3/C #6 Shielded	600.00	1-12/C # 12	600.00	1-3/C #6	600.00	1-12/C # 12	600.00	1-4/C #16	600.00				
Cooling Twr U1 Fan 14	300 hp	1-3/C #6 Shielded	670.00	1-12/C # 12	670.00	1-3/C #6	670.00	1-12/C # 12	670.00	1-4/C #16	670.00				
Cooling Twr U1 Fan 15	300 hp	1-3/C #6 Shielded	740.00	1-12/C # 12	740.00	1-3/C #6	740.00	1-12/C # 12	740.00	1-4/C #16	740.00	1-3/C #12	775.00		
Cooling Twr U1 Fan 16	300 hp	1-3/C #6 Shielded	810.00	1-12/C # 12	810.00	1-3/C #6	810.00	1-12/C # 12	810.00	1-4/C #16	810.00				
Cooling Twr U1 Fan 17	300 hp	1-3/C #6 Shielded	880.00	1-12/C # 12	880.00	1-3/C #6	880.00	1-12/C # 12	880.00	1-4/C #16	880.00				
Cooling Twr U1 Fan 18	300 hp	1-3/C #6 Shielded	950.00	1-12/C # 12	950.00	1-3/C #6	950.00	1-12/C # 12	950.00	1-4/C #16	950.00				
Cooling Twr U1 Fan 19	300 hp	1-3/C #6 Shielded	1,020.00	1-12/C # 12	1,020.00	1-3/C #6	1,020.00	1-12/C # 12	1,020.00	1-4/C #16	1,020.00				
Cooling Twr U1 Fan 20	300 hp	1-3/C #6 Shielded	1,090.00	1-12/C # 12	1,090.00	1-3/C #6	1,090.00	1-12/C # 12	1,090.00	1-4/C #16	1,090.00	1-3/C #12	1,090.00	3/C#14,3/C#18	1,090.00
Cooling Twr U1 Fan 21	300 hp	1-3/C #6 Shielded	1,190.00	1-12/C # 12	1,190.00	1-3/C #6	1,190.00	1-12/C # 12	1,190.00	1-4/C #16	1,190.00	1-3/C #12	1,190.00	3/C#14,3/C#18	1,190.00
Cooling Twr U1 Fan 22	300 hp	1-3/C #6 Shielded	1,260.00	1-12/C # 12	1,260.00	1-3/C #6	1,260.00	1-12/C # 12	1,260.00	1-4/C #16	1,260.00				
Cooling Twr U1 Fan 23	300 hp	1-3/C #6 Shielded	1,330.00	1-12/C # 12	1,330.00	1-3/C #6	1,330.00	1-12/C # 12	1,330.00	1-4/C #16	1,330.00				
Cooling Twr U1 Fan24	300 hp	1-3/C #6 Shielded	1,400.00	1-12/C # 12	1,400.00	1-3/C #6	1,400.00	1-12/C # 12	1,400.00	1-4/C #16	1,400.00				
Cooling Twr U1 Fan 25	300 hp	1-3/C #6 Shielded	1,470.00	1-12/C # 12	1,470.00	1-3/C #6	1,470.00	1-12/C # 12	1,470.00	1-4/C #16	1,470.00	1-3/C #12	1,505.00		
Cooling Twr U1 Fan 26	300 hp	1-3/C #6 Shielded	1,540.00	1-12/C # 12	1,540.00	1-3/C #6	1,540.00	1-12/C # 12	1,540.00	1-4/C #16	1,540.00				
Cooling Twr U1 Fan 27	300 hp	1-3/C #6 Shielded	1,610.00	1-12/C # 12	1,610.00	1-3/C #6	1,610.00	1-12/C # 12	1,610.00	1-4/C #16	1,610.00				
Cooling Twr U1 Fan 28	300 hp	1-3/C #6 Shielded	1,680.00	1-12/C # 12	1,680.00	1-3/C #6	1,680.00	1-12/C # 12	1,680.00	1-4/C #16	1,680.00				
Cooling Twr U1 Fan 29	300 hp	1-3/C #6 Shielded	1,750.00	1-12/C # 12	1,750.00	1-3/C #6	1,750.00	1-12/C # 12	1,750.00	1-4/C #16	1,750.00				
Cooling Twr U1 Fan 30	300 hp	1-3/C #6 Shielded	1,820.00	1-12/C # 12	1,820.00	1-3/C #6	1,820.00	1-12/C # 12	1,820.00	1-4/C #16	1,820.00	1-3/C #12	1,820.00		
Cooling Twr U1 Fan 31	300 hp	1-3/C #6 Shielded	1,190.00	1-12/C # 12	1,190.00	1-3/C #6	1,190.00	1-12/C # 12	1,190.00	1-4/C #16	1,190.00	1-3/C #12	1,190.00		
Cooling Twr U1 Fan 32	300 hp	1-3/C #6 Shielded	1,260.00	1-12/C # 12	1,260.00	1-3/C #6	1,260.00	1-12/C # 12	1,260.00	1-4/C #16	1,260.00				
Cooling Twr U1 Fan 33	300 hp	1-3/C #6 Shielded	1,330.00	1-12/C # 12	1,330.00	1-3/C #6	1,330.00	1-12/C # 12	1,330.00	1-4/C #16	1,330.00				
Cooling Twr U1 Fan 34	300 hp	1-3/C #6 Shielded	1,400.00	1-12/C # 12	1,400.00	1-3/C #6	1,400.00	1-12/C # 12	1,400.00	1-4/C #16	1,400.00				

**Appendix A-9
DCPP Cooling Tower Study
Cable Estimate (part 1 of 2)**

Cooling Twr U1 Fan 35	300 hp	1-3/C #6 Shielded	1,470.00	1-12/C # 12	1,470.00	1-3/C #6	1,470.00	1-12/C # 12	1,470.00	1-4/C #16	1,470.00	1-3/C #12	1,505.00		
Cooling Twr U1 Fan 36	300 hp	1-3/C #6 Shielded	1,540.00	1-12/C # 12	1,540.00	1-3/C #6	1,540.00	1-12/C # 12	1,540.00	1-4/C #16	1,540.00				
Cooling Twr U1 Fan 37	300 hp	1-3/C #6 Shielded	1,610.00	1-12/C # 12	1,610.00	1-3/C #6	1,610.00	1-12/C # 12	1,610.00	1-4/C #16	1,610.00				
Cooling Twr U1 Fan 38	300 hp	1-3/C #6 Shielded	1,680.00	1-12/C # 12	1,680.00	1-3/C #6	1,680.00	1-12/C # 12	1,680.00	1-4/C #16	1,680.00				
Cooling Twr U1 Fan 39	300 hp	1-3/C #6 Shielded	1,750.00	1-12/C # 12	1,750.00	1-3/C #6	1,750.00	1-12/C # 12	1,750.00	1-4/C #16	1,750.00				
Cooling Twr U1 Fan 40	300 hp	1-3/C #6 Shielded	1,820.00	1-12/C # 12	1,820.00	1-3/C #6	1,820.00	1-12/C # 12	1,820.00	1-4/C #16	1,820.00	1-3/C #12	1,820.00	3/C#14,3/C#18	1,820.00
Cooling Twr U2 Fan 1	300 hp	1-3/C #6 Shielded	460.00	1-12/C # 12	460.00	1-3/C #6	460.00	1-12/C # 12	460.00	1-4/C #16	460.00	1-3/C #12	460.00	3/C#14,3/C#18	460.00
Cooling Twr U2 Fan 2	300 hp	1-3/C #6 Shielded	530.00	1-12/C # 12	530.00	1-3/C #6	530.00	1-12/C # 12	530.00	1-4/C #16	530.00				
Cooling Twr U2 Fan 3	300 hp	1-3/C #6 Shielded	600.00	1-12/C # 12	600.00	1-3/C #6	600.00	1-12/C # 12	600.00	1-4/C #16	600.00				
Cooling Twr U2 Fan4	300 hp	1-3/C #6 Shielded	670.00	1-12/C # 12	670.00	1-3/C #6	670.00	1-12/C # 12	670.00	1-4/C #16	670.00				
Cooling Twr U2 Fan 5	300 hp	1-3/C #6 Shielded	740.00	1-12/C # 12	740.00	1-3/C #6	740.00	1-12/C # 12	740.00	1-4/C #16	740.00	1-3/C #12	775.00		
Cooling Twr U2 Fan 6	300 hp	1-3/C #6 Shielded	810.00	1-12/C # 12	810.00	1-3/C #6	810.00	1-12/C # 12	810.00	1-4/C #16	810.00				
Cooling Twr U2 Fan 7	300 hp	1-3/C #6 Shielded	880.00	1-12/C # 12	880.00	1-3/C #6	880.00	1-12/C # 12	880.00	1-4/C #16	880.00				
Cooling Twr U2 Fan 8	300 hp	1-3/C #6 Shielded	950.00	1-12/C # 12	950.00	1-3/C #6	950.00	1-12/C # 12	950.00	1-4/C #16	950.00				
Cooling Twr U2 Fan 9	300 hp	1-3/C #6 Shielded	1,020.00	1-12/C # 12	1,020.00	1-3/C #6	1,020.00	1-12/C # 12	1,020.00	1-4/C #16	1,020.00				
Cooling Twr U2 Fan 10	300 hp	1-3/C #6 Shielded	1,090.00	1-12/C # 12	1,090.00	1-3/C #6	1,090.00	1-12/C # 12	1,090.00	1-4/C #16	1,090.00	1-3/C #12	1,090.00		
Cooling Twr U2 Fan 11	300 hp	1-3/C #6 Shielded	460.00	1-12/C # 12	460.00	1-3/C #6	460.00	1-12/C # 12	460.00	1-4/C #16	460.00	1-3/C #12	460.00		
Cooling Twr U2 Fan 12	300 hp	1-3/C #6 Shielded	530.00	1-12/C # 12	530.00	1-3/C #6	530.00	1-12/C # 12	530.00	1-4/C #16	530.00				
Cooling Twr U2 Fan 13	300 hp	1-3/C #6 Shielded	600.00	1-12/C # 12	600.00	1-3/C #6	600.00	1-12/C # 12	600.00	1-4/C #16	600.00				
Cooling Twr U2 Fan 14	300 hp	1-3/C #6 Shielded	670.00	1-12/C # 12	670.00	1-3/C #6	670.00	1-12/C # 12	670.00	1-4/C #16	670.00				
Cooling Twr U2 Fan 15	300 hp	1-3/C #6 Shielded	740.00	1-12/C # 12	740.00	1-3/C #6	740.00	1-12/C # 12	740.00	1-4/C #16	740.00	1-3/C #12	775.00		
Cooling Twr U2 Fan 16	300 hp	1-3/C #6 Shielded	810.00	1-12/C # 12	810.00	1-3/C #6	810.00	1-12/C # 12	810.00	1-4/C #16	810.00				
Cooling Twr U2 Fan 17	300 hp	1-3/C #6 Shielded	880.00	1-12/C # 12	880.00	1-3/C #6	880.00	1-12/C # 12	880.00	1-4/C #16	880.00				
Cooling Twr U2 Fan 18	300 hp	1-3/C #6 Shielded	950.00	1-12/C # 12	950.00	1-3/C #6	950.00	1-12/C # 12	950.00	1-4/C #16	950.00				
Cooling Twr U2 Fan 19	300 hp	1-3/C #6 Shielded	1,020.00	1-12/C # 12	1,020.00	1-3/C #6	1,020.00	1-12/C # 12	1,020.00	1-4/C #16	1,020.00				
Cooling Twr U2 Fan 20	300 hp	1-3/C #6 Shielded	1,090.00	1-12/C # 12	1,090.00	1-3/C #6	1,090.00	1-12/C # 12	1,090.00	1-4/C #16	1,090.00	1-3/C #12	1,090.00	3/C#14,3/C#18	1,090.00
Cooling Twr U2 Fan 21	300 hp	1-3/C #6 Shielded	1,190.00	1-12/C # 12	1,190.00	1-3/C #6	1,190.00	1-12/C # 12	1,190.00	1-4/C #16	1,190.00	1-3/C #12	1,190.00	3/C#14,3/C#18	1,190.00
Cooling Twr U2 Fan 22	300 hp	1-3/C #6 Shielded	1,260.00	1-12/C # 12	1,260.00	1-3/C #6	1,260.00	1-12/C # 12	1,260.00	1-4/C #16	1,260.00				
Cooling Twr U2 Fan 23	300 hp	1-3/C #6 Shielded	1,330.00	1-12/C # 12	1,330.00	1-3/C #6	1,330.00	1-12/C # 12	1,330.00	1-4/C #16	1,330.00				
Cooling Twr U2 Fan24	300 hp	1-3/C #6 Shielded	1,400.00	1-12/C # 12	1,400.00	1-3/C #6	1,400.00	1-12/C # 12	1,400.00	1-4/C #16	1,400.00				
Cooling Twr U2 Fan 25	300 hp	1-3/C #6 Shielded	1,470.00	1-12/C # 12	1,470.00	1-3/C #6	1,470.00	1-12/C # 12	1,470.00	1-4/C #16	1,470.00	1-3/C #12	1,505.00		
Cooling Twr U2 Fan 26	300 hp	1-3/C #6 Shielded	1,540.00	1-12/C # 12	1,540.00	1-3/C #6	1,540.00	1-12/C # 12	1,540.00	1-4/C #16	1,540.00				
Cooling Twr U2 Fan 27	300 hp	1-3/C #6 Shielded	1,610.00	1-12/C # 12	1,610.00	1-3/C #6	1,610.00	1-12/C # 12	1,610.00	1-4/C #16	1,610.00				
Cooling Twr U2 Fan 28	300 hp	1-3/C #6 Shielded	1,680.00	1-12/C # 12	1,680.00	1-3/C #6	1,680.00	1-12/C # 12	1,680.00	1-4/C #16	1,680.00				
Cooling Twr U2 Fan 29	300 hp	1-3/C #6 Shielded	1,750.00	1-12/C # 12	1,750.00	1-3/C #6	1,750.00	1-12/C # 12	1,750.00	1-4/C #16	1,750.00				
Cooling Twr U2 Fan 30	300 hp	1-3/C #6 Shielded	1,820.00	1-12/C # 12	1,820.00	1-3/C #6	1,820.00	1-12/C # 12	1,820.00	1-4/C #16	1,820.00	1-3/C #12	1,820.00		
Cooling Twr U2 Fan 31	300 hp	1-3/C #6 Shielded	1,190.00	1-12/C # 12	1,190.00	1-3/C #6	1,190.00	1-12/C # 12	1,190.00	1-4/C #16	1,190.00	1-3/C #12	1,190.00		

**Appendix A-9
DCPP Cooling Tower Study
Cable Estimate (part 1 of 2)**

Cooling Twr U2 Fan 32	300 hp	1-3/C #6 Shielded	1,260.00	1-12/C # 12	1,260.00	1-3/C #6	1,260.00	1-12/C # 12	1,260.00	1-4/C #16	1,260.00				
Cooling Twr U2 Fan 33	300 hp	1-3/C #6 Shielded	1,330.00	1-12/C # 12	1,330.00	1-3/C #6	1,330.00	1-12/C # 12	1,330.00	1-4/C #16	1,330.00				
Cooling Twr U2 Fan 34	300 hp	1-3/C #6 Shielded	1,400.00	1-12/C # 12	1,400.00	1-3/C #6	1,400.00	1-12/C # 12	1,400.00	1-4/C #16	1,400.00				
Cooling Twr U2 Fan 35	300 hp	1-3/C #6 Shielded	1,470.00	1-12/C # 12	1,470.00	1-3/C #6	1,470.00	1-12/C # 12	1,470.00	1-4/C #16	1,470.00	1-3/C #12	1,505.00		
Cooling Twr U2 Fan 36	300 hp	1-3/C #6 Shielded	1,540.00	1-12/C # 12	1,540.00	1-3/C #6	1,540.00	1-12/C # 12	1,540.00	1-4/C #16	1,540.00				
Cooling Twr U2 Fan 37	300 hp	1-3/C #6 Shielded	1,610.00	1-12/C # 12	1,610.00	1-3/C #6	1,610.00	1-12/C # 12	1,610.00	1-4/C #16	1,610.00				
Cooling Twr U2 Fan 38	300 hp	1-3/C #6 Shielded	1,680.00	1-12/C # 12	1,680.00	1-3/C #6	1,680.00	1-12/C # 12	1,680.00	1-4/C #16	1,680.00				
Cooling Twr U2 Fan 39	300 hp	1-3/C #6 Shielded	1,750.00	1-12/C # 12	1,750.00	1-3/C #6	1,750.00	1-12/C # 12	1,750.00	1-4/C #16	1,750.00				
Cooling Twr U2 Fan 40	300 hp	1-3/C #6 Shielded	1,820.00	1-12/C # 12	1,820.00	1-3/C #6	1,820.00	1-12/C # 12	1,820.00	1-4/C #16	1,820.00	1-3/C #12	1,820.00	3/C#14,3/C#18	1,820.00
Cable SubTotals			91,200.00		91,200.00		91,200.00		91,200.00		91,200.00		27,360.00		9,120.00

**Appendix A-9
DCPP Cooling Tower Study
Tray Conduit Estimates (part 2 of 2)**

Function	Cable Type	Voltage	Cables	OD(in)	Area (in^2)	Total Area	Raceway Type	Allowance	Size rqrd(in)	Tray Size	length(ft) each run	actual percent fill	Total Length
Fan Power	1-3/C #6 Shielded	4160	20	1.34	-	-	Tray	eq dia spacing	53.6	2 - 36" tray	1090	-	1090
Fan Power	1-3/C #6 Shielded	4160	20	1.34	-	-	Tray	eq dia spacing	53.6	2 - 36" tray	1820	-	1820
Fan Power	1-3/C #6 Shielded	4160	40	1.34	1.4103	-	Conduit	53% fill	Use Table	40 - 2" RMC	175	41.38%	7000
Fan Control	1-12/C # 12	600	40	0.76	0.4536	-	Conduit	53% fill	Use Table	40 - 1" RMC	175	51.14%	7000
Fan Control	1-12/C # 12	600	40	0.76	0.4536	36.292	Tray	50% fill	~18" width	1 - 24" 4" deep cable tray	1820	37.80%	1820
MOV Control	1-12/C # 12	600	40	0.76	0.4536	-	Conduit	53% fill	Use Table	40 - 1" RMC	175	51.14%	7000
MOV Power	1-3/C #6	600	40	0.72	0.4072	-	Conduit	53% fill	Use Table	40 - 1" RMC	175	45.90%	7000
MOV Power	1-3/C #6	600	40	0.72	0.4072	17.949	Tray	Use Table	< =18" width	1 - 24" 4" deep	1820	18.70%	1820
Lighting	1-3/C #12	480	12	0.42	0.1385	-	Conduit	53% fill	Use Table	11 - 3/4" RMC	175	25.24%	2100
Lighting	1-3/C #12	480	12	0.42	0.1385	-	Conduit	53% fill	Use Table	11 - 3/4" RMC	175	25.24%	2100
Instrument	1-4/C #16	600	40	0.36	0.1018	-	Conduit	53% fill	Use Table	40 - 3/4" RMC	175	18.54%	7000
Instrument	1-4/C #16	600	40	0.36	0.1018	5.5029	Tray	50% fill	any width	1 - 24" 4" deep	1820	5.73%	1820
GAI-Tronics	3/C#14,3/C#18	600	4	0.675	0.3578	-	Conduit	53% fill	Use Table	4 - 1" RMC	175	40.34%	700
GAI-Tronics	3/C#14,3/C#18	600	4	0.675	0.3578	-	Conduit	53% fill	Use Table	4 - 1" RMC	175	40.34%	700

CABLES

Type	Voltage	Length
1-3/C #6 Shielded	5000	91200
1-12/C # 12	600	182400
1-3/C #6	600	91200
1-4/C #16	600	91200
1-3/C #12	600	27360
3/C#14,3/C#18	600	9120

Type	Size	Length	Total	Type	Size	Length	Total
Tray	36"	5820	11640	Conduit	2" RSG	7000	14000
Tray	24"	5460	10920	Conduit	1" RSG	21700	43400
				Conduit	3/4" RSG	9100	18200

Appendix A-10
DCPP Cooling Tower Feasibility Study
Fuel Consumption Summary

Hauling of Excavations, Backfill, Concrete

Excavation Removed from Site	2,010,800	Cubic Yards (CY)
Backfill Imported to Site	300,000	CY
Concrete - Material to Site	200,000	CY
Total CY	2,510,800	CY
Truckloads of Material (10 CY/truck)	251,080	Trucks (Round Trips)
Total Miles (70 Miles per Round Trip)	17,575,600	Miles Driven
Diesel Fuel (@ 6 MPG)***	2,929,267	Gallons Fuel

Material / Equipment Deliveries

Cooling Tower	1,440	Deliveries
Mechanical Equipment	400	Deliveries
Electrical Equipment	150	Deliveries
Total Round Trips	1,990	Round Trips
Total Miles (RTs from LA x 400 Miles)	796,000	Miles
Diesel Fuel (@ 6 MPG)***	132,667	Gallons Fuel

Site Equipment Fuel/Day

Including Excavating Equipment, Concrete trucks (To and From Batch Plant), Cranes, Pick-Ups, Other equipment		
Gallons of Diesel Fuel per Day - 1 Year	1,000	Gallons/Day for 1 Yr
Gallons of Diesel Fuel per Day - 2 Years	500.00	Gallons/Day for 2 Yrs
Total Gallons of Diesel Fuel	730,000	Gallons Fuel Total

Buses for Craft Workers*

1 Year /1500 Craft / 50 Craft per Bus / 30 RTs per day	9,360.00	Bus Trips
1.5 Years / 3000 Craft / 50 Craft per Bus / 60 RTs per day	28,080.00	Bus Trips
9 Months /1000 Craft / 50 Craft per Bus / 20 RTs per day	4,680.00	Bus Trips
25% Return Trips - Buses not full	10,530.00	Bus Trips
Total Bus Trips	52,650.00	Total Bus Trips
AVG. 120 Miles Per Trip (In full, out empty, in empty, out full - all buses park offsite)	6,318,000.00	Total Miles
Diesel Fuel (@ 10 MPG)***	631,800	Gallons Fuel

Total

Total Miles (Trucks plus Buses)	24,689,600	Miles Trucks plus Buses
Gallons Fuel - Trucks plus Buses plus Site Equipment	4,423,733	Gallons Fuel

* Number of bus trips based on the Replacement Steam Generator Project experience

** Number of cooling tower deliveries based on input from Marley (18 truck loads/cell x 80 cells)

***The California Air Resource Board (CARB) estimates a statewide average of 5.6 miles per gallon for class eight vehicles (GVWR 33,000 lb and up). PG&E estimates the fuel consumption at 4.5 miles per gallon for their fleet of heavy line trucks. For conservatism this study assumes a truck MPG at 6 miles per gallon and bus MPG at 10 miles per gallon.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project : Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate

Capital Project Costs	\$2,689,000,000
Decommissioning @ 2.5% of Installation	\$67,200,000
Replacement Power for Lost MW During Construction @ \$70/MWhr	
1155 MWs x 24 Hrs/Day x 517 Days x 2-Units x 0.9 Capacity Factor	\$1,805,700,000
Annual Increase to Station Operation and Maintenance Costs	\$7,400,000. /Year
Annual Cost of Replacement Power for Lost MW due to Derated Capacity	
451,180 MWhrs/Yr [Ref. Table 3] @ \$70/MWhr = \$31,582,600 (2-Unit Total)	\$31,600,000. /Year

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Annual Increase to Station Operation and Maintenance Costs

Mechanical Draft Cooling Towers
Maintenance

Daily Maintenance (4Hr /Day)		1,460 Hr	120	175,200
Weekly Maintenance (8Hr /Wk)		416 Hr	120	49,920
Monthly Maintenance (2Hr /Mo. Per Cell)	80	24 Hr	120	230,400
Quarterly Maintenance (4Hr /Qtr. Per Cell)	80	16 Hr	120	153,600

Inspections

Semiannual Inspection (8Hr x 2 Insp /Yr Per Cell)	80	16 Hr	120	153,600
Annual Inspection (4Hr /Yr Per Cell)	80	4 Hr	120	38,400
Annual Transformer Inspection (16Hr /Yr.)		16 Hr	120	1,920
Quarterly Lighting Insp/Replacement (8Hr /Qtr.)		32 Hr	120	3,840

Corrective Maintenance

Average Annual Replacement Costs /Yr Per Cell		25,000 \$	80	2,000,000
---	--	-----------	----	-----------

Dechlorination System Chemicals

1 Yr	151,000	151,000
------	---------	---------

Increased Electrical Maintenance Due to Salt Drift

52 Wk	20,000	1,040,000
-------	--------	-----------

Facilities Maintenance for Protection Against
Accelerated Corrosion

1 Allow	1,500,000	1,500,000
---------	-----------	-----------

Cost of Travel Between Off-Site Facilities and DCPP

1 Allow	200,000	200,000
---------	---------	---------

Subtotal

5,697,880

Project Indirects (8% of Direct Cost)
(Capitalized A&G 2% + Material Burden 6%)

455,830

Contingency (20% of Direct and Indirect Costs)

1,230,742

Total: Annual Increase to Station Operation and Maintenance Costs

7,384,452

Say

7,400,000

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project : Enercon Cooling Tower Feasibility Study
DCPP Common Facilities
Cost Estimate

Capital Project Costs

1	Mechanical Draft Cooling Towers	\$242,100,000
2	Recirculating Water Pumps and Piping	\$178,800,000
3	Makeup Water Pumps and Piping	\$51,100,000
4	Condenser Replacement Bundles	\$83,800,000
5	Concrete Recirc Water Tunnel	\$72,000,000
6	Sitework	\$325,500,000
7	Electrical	\$100,900,000
8	Process Control and Instrumentation	\$23,700,000
9	Permit and Licensing Fees	\$55,500,000
10	Engineering	\$74,700,000
11	Construction Offices / Batch Plant / Temp Parking and Roadways	\$37,900,000
12	Project Management and Support Staff	\$93,800,000
13	Relocate Warehouse & Cold Machine Shop	\$10,300,000
14	Demo Displaced Structures	\$19,100,000
15	Construct Displaced Structures ON Site	\$105,100,000
16	Construct Displaced Structures OFF Site	\$40,400,000
17	Displaced Parking	\$93,300,000
18	Security Requirements	\$44,200,000
19	Pedestrian and Vehicle Bridges	\$5,600,000
20	Transportation - Permanent/Construction Personnel	\$189,000,000
21	Sewage Treatment Facility	\$12,000,000
22	Utility Relocations	\$36,200,000
23	SCW System	\$36,900,000
24	ASW & Blowdown Water Treatment	\$15,500,000
25	Blowdown, Mixing Station and Diffuser	\$39,600,000
26	Plant Shutdown and Start-Up	\$50,000,000
27	Site Infrastructure (Water/Storm/Power/Tel-Data/etc.)	\$38,000,000

Total: Direct Costs	\$2,075,000,000
----------------------------	------------------------

Project Indirects (8% of Direct Cost)	\$166,000,000
(Capitalized A&G 2% + Material Burden 6%)	

Contingency (20% of Direct and Indirect Costs)	\$448,200,000
--	---------------

Total: Capital Costs	\$2,689,200,000
-----------------------------	------------------------

Say	\$2,689,000,000
------------	------------------------

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project : Enercon Cooling Tower Feasibility Study DCCP Common Facilities Cost Estimate

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Mechanical Draft Cooling Towers

Excavation with Sitework

Concrete

Cooling Tower Basins	18,500	CY	3,000	55,500,000
Pump Pits	9,500	CY	3,000	28,500,000

Cooling Tower Erection

Cooling Tower Vendor (Marley)	2	Units	40,000,000	80,000,000
Erect Framing / Baffles per cell	80	Cell	80,000	6,400,000
Erect Mechanical per cell	80	Cell	150,000	12,000,000
Erect Electrical per cell	80	Cell	150,000	12,000,000
Rig, Erect and test Fans	80	Cell	400,000	32,000,000
Miscellaneous Platform, Ladders, Grating	80	Cell	25,000	2,000,000

Pump Pit

Trash Rack	6,500	SF	500	3,250,000
Miscellaneous Platform, Ladders, Grating	7,500	SF	225	1,687,500

Sales Tax and Freight on Equipment (7.25% Tax & 3.5% Allowance for Freight = 11%)	11%		80,000,000	8,800,000
--	-----	--	------------	-----------

Total: Mechanical Draft Cooling Towers				<u>242,137,500</u>
---	--	--	--	--------------------

			<u>Say</u>	<u>242,100,000</u>
--	--	--	-------------------	---------------------------

Excavation included with site-work.
 Backfill included with site-work.
 Based on 4 Cooling Towers at 40 ea. - 60' x 60' Cells.
 Trash Rack price based on 50% of current Intake Bar Rack project.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
-----------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Recirculating Water Pumps and Piping

Circ Water Pumps Vendor Quote	10	Ea	4,640,000	46,400,000
Circ Water Pumps Installation	10	Ea	7,733,333	77,333,333
Control Valves	1	Allow	5,000,000	5,000,000
Install New Mechanical in Pump Pits	2	Units	3,250,000	6,500,000
Install New Electrical in Pump Pits	2	Units	3,600,000	7,200,000
Install Pipe Supports in Pump Pits	2	Units	1,500,000	3,000,000
Install Paralined Pipe - 8'	1,440	LF	2,500	3,600,000
Install Paralined Pipe - 6'	800	LF	2,250	1,800,000
Install Paralined Pipe - 4'	480	LF	2,000	960,000
Purchase Paralined Pipe	2,720	LF	2,270	6,174,400
Pipe Supports for Large Bore Piping	300	Ea	10,000	3,000,000
Tie-In Paralined Pipe to Concrete Tunnel	4	Ea	500,000	2,000,000
Pipe Distribution to CT Cells	80	Cells	125,000	10,000,000
Process Controls	With Process Controls Section			
Excavation & Backfill	With Sitework Section			
Sales Tax and Freight on Equipment	11%		52,574,400.00	5,783,184
(7.25% Tax & 3.5% Allowance for Freight = 11%)				

Total: Recirculating Water Pumps and Piping

178,750,917

Say 178,800,000

Excavation included with site-work.
Backfill included with site-work.
Paralined Pipe price prorated from vendor quote.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Makeup Water Pumps and Piping

Make-Up Water Pumps Vendor Quote	6	Ea	640,000	3,840,000
Make-Up Water Pumps Installation	6	Ea	1,066,667	6,400,000
Control Valves	1	Allow	1,800,000	1,800,000
Excavate to Open Tunnel				
Saw Cut and Open Concrete Tunnels				
Demo Existing Circ Water Pumps	4	Ea	900,000	3,600,000
Demo Mechanical/Electrical	2	Units	2,500,000	5,000,000
Demo Slabs, Steel, Etc.	2	Units	2,000,000	4,000,000
Install New Slabs, Steel, Etc.	2	Units	2,500,000	5,000,000
Install New Mechanical/Electrical in Pump Pits	2	Units	4,000,000	8,000,000
Install Pipe Supports in Intake Tunnels	70	Ea	15,000	1,050,000
Install Paralined Pipe	670	LF	2,000	1,340,000
Purchase Paralined Pipe	670	LF	2,270	1,520,900
Tie-In Paralined Pipe to Concrete Tunnel	4	Ea	500,000	2,000,000
Process Controls	1	Allow	2,500,000	2,500,000
Backfill Excavations	40,000	CY	100	4,000,000
Civil Repairs/Modifications	1	Allow	500,000	500,000
Sales Tax and Freight on Equipment	11%		5,360,900.00	589,699

(7.25% Tax & 3.5% Allowance for Freight = 11%)

Total: Makeup Water Pumps and Piping

51,140,599

Say 51,100,000

Excavation included with site-work.

Backfill included with site-work.

Paralined Pipe price prorated from vendor quote.

Electrical price based on existing switchgear at intake with new circuitry to pumps.

Control price based on local instrumentation and control panel with basic signals to control room through existing conduit.

Demo includes requirements for SCW System.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Condenser Replacement

Building Mods for Delivery of Tube Bundles	1	Loc	1,500,000.00	1,500,000
Stage Tubes	2	Units	100,000.00	200,000
Set-Up Rigging and Open Boxes x 2	4	Boxes	150,000.00	600,000
Remove 720 Tubes x 2	4	Boxes	250,000.00	1,000,000
Clean Water Boxes x 2	4	Boxes	150,000.00	600,000
Water Box Modifications x 2	4	Boxes		w/ Vendor
Install Tube Bundles x 2	4	Boxes		w/ Vendor
Replace & Torque Water Box Covers x 2	4	Boxes		w/ Vendor
Water Box Insulation x 2	4	Boxes	500,000.00	2,000,000
Support Staff for Drain, Fill, QA, etc.	4	Boxes	500,000.00	2,000,000
Remove/Replace Eq./Mech./El..for Tube Installation	4	Boxes	1,500,000.00	6,000,000
Vendor Price	2	Units	31,500,000.00	63,000,000
Sales Tax and Freight on Equipment (7.25% Tax & 3.5% Allowance for Freight = 11%)	11%		63,000,000.00	6,930,000

Total: Condenser Replacement

83,830,000

Say

83,800,000

Based on Vendor Quote - Enercon Report Appendix A-1.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Concrete Recirc Water Tunnel

Circ Water Tunnel 10' x 10' Concrete

Excavation and Backfill				w/ Sitework
Metal Formwork	120,000	SF	100	12,000,000
Spiders for Interior	150	Ea	5,000	750,000
Exterior Formwork	60,000	SF	100	6,000,000
Tunnel Walls - Reinforced Concrete	12,000	CY	3,000	36,000,000

Flow Control

Turning Vanes	1	Allow	2,000,000	2,000,000
Gates/Weir/Baffles	4	Ea	2,000,000	8,000,000

Special Linings or Coatings	120,000	SF	60	7,200,000
-----------------------------	---------	----	----	-----------

Total: Concrete Recirc Water Tunnel				<u>71,950,000</u>
--	--	--	--	-------------------

<u>Say</u>	<u>72,000,000</u>
-------------------	--------------------------

Excavation included with Sitework.

Backfill included with Sitework.

Metal Formwork used for interior form. Minimum segments fabricated/purchased to be used as slip forms.

External Formwork includes preparation of trench walls to serve as exterior form as well as wood forms as required.

Quantity based on 4 Runs of +/- 750 LF Tunnel.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Sitework

Access Road

Relocate Access Road	3.0 Mi		1,250,000.00	3,750,000
Relocate ISFSI Roadway	5.0 Mi		1,250,000.00	6,250,000
Excavation for road relocation	350,000 CY			
Soil	175,000 CY		60.00	10,500,000
Rock	175,000 CY		150.00	26,250,000
Retaining Walls at road	1,500 CY		5,000.00	7,500,000
Drainage, rails, sign, etc	1 Allow		1,000,000.00	1,000,000

Main Site Excavation

Strip & remove asphalt	10 Acre		125,000.00	1,250,000
Main retaining walls	2,500 CY		5,000.00	12,500,000
Excavation	1,100,000			
Soil	770,000 CY		60.00	46,200,000
Rock	330,000 CY		150.00	49,500,000
Drainage	10 Acre		1,000,000.00	10,000,000
Roadway and walkway	1 Lot		3,000,000.00	3,000,000
Site Lighting	220 Loc		25,000.00	5,500,000
Landscaping	1 Lot		2,500,000.00	2,500,000
Retaining Walls	1,000 CY		5,000.00	5,000,000

Cooling Tower Basin

Excavation	65,000			
Soil		CY	60.00	0
Rock	65,000 CY		150.00	9,750,000
Backfill	1,320 CY		75.00	99,000

Cooling Tower Pump Pits

Excavation	46,000			
Soil		CY	60.00	0
Rock	46,000 CY		150.00	6,900,000
Backfill	22,500 CY		75.00	1,687,500

Electrical Equipment Rm

Excavation	300			
Soil		CY	60.00	0
Rock	300 CY		150.00	45,000
Backfill		CY	75.00	0

Retaining Wall

Excavation	7,000			
Soil		CY	60.00	0
Rock	7,000 CY		150.00	1,050,000

Appendix A-11 Project Cost Estimate

Backfill	5,000 CY	75.00	375,000
Concrete Tunnel (Pipe)			
Excavation	350,000		
Soil	CY	60.00	0
Rock	350,000 CY	150.00	52,500,000
Backfill	200,000 CY	75.00	15,000,000
Concrete Tunnel (Pipe) - Tie-In Locations			
Excavation	50,000		
Soil	CY	60.00	0
Rock / Concrete (10,000 Yd x 5 Locations)	50,000 CY	150.00	7,500,000
Sheet Piling	75,000 SF	100.00	7,500,000
Backfill	45,000 CY	75.00	3,375,000
Circ Water Pipe at Cooling Tower			
Excavation	10,500		
Soil	CY	60.00	0
Rock	10,500 CY	150.00	1,575,000
Backfill	4,250 CY	75.00	318,750
Miscellaneous Pipe			
Excavation	32,000		
Soil	CY	60.00	0
Rock	32,000 CY	150.00	4,800,000
Backfill	31,000 CY	75.00	2,325,000
Temporary Roadways	6 Mi	1,250,000.00	7,500,000
Repair Roadways on completion	10 Mi	1,250,000.00	12,500,000
			325,500,250
Total: Sitework			325,500,250
			<u>Say</u> <u>325,500,000</u>

This type of heavy traffic will require major repair to all access roads
Price only includes repairs to roadways inside the DCPD gate, public roads not included.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Electrical

Switch Yard - Complete Breaker-and-a-Half Bay				12,000,000
500 kV Metering System - Complete				500,000

Cathodic Protection: Intake, CT Area, Circ Water Tunnels Complete Major Impressed Current System	1	Allow	7,500,000	7,500,000
--	---	-------	-----------	-----------

Vendor Furnished Eq.:

High Voltage Transformers	4	Ea	2,000,000	8,000,000
Cooling Tower Transformers	6	Ea	420,000	2,520,000
Medium Voltage Transformers	2	Ea	420,000	840,000
500 kV Circuit Breakers	3	Ea	1,500,000	4,500,000
4160V/440V/500 kV Oil Filled Transformers for SCW Pumps	2	Ea	30,000	60,000
Electrical Equipment Houses for CTs (Incl Equip't)	2	Ea	3,366,150	6,732,300
Sales Tax and Freight on Equipment (7.25% Tax & 3.5% Allowance for Freight = 11%)	11%		22,652,300	2,491,753

Install Vendor Furnished Equipment				37,753,833
------------------------------------	--	--	--	------------

Ductbank - Switch Yard to Elect. Eq. Houses	5,000	LF	1,500	7,500,000
Electrical Manholes, Pull Boxes and Junction Boxes	1	Allow	3,000,000	3,000,000
Distribution Panels and Sub-Panels	1	Allow	2,000,000	2,000,000

Cable - Cooling Tower	185,000	LF	5.50	1,017,500
Cable - Switch Yard to El. Eq. House	100,000		25	2,500,000

Cable, Conduit, Cable Tray, Other	1	Allow	2,000,000	2,000,000
-----------------------------------	---	-------	-----------	-----------

Total: Electrical				<u>100,915,386</u>
--------------------------	--	--	--	--------------------

<u>Say</u>	<u>100,900,000</u>
-------------------	---------------------------

Ductbank Unit Price Includes; Excavation, Backfill, Concrete and Conduit.
Cooling Tower Cable Quantity based on Enercon Report Appendix A-9.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Process Control and Instrumentation

Vendor Furnished Eq.:

Operator Touch screens	2	Unit	40,000	80,000
Triconex Supplied Eq.	2	Unit	955,000	1,910,000
Bently Nevada Eq.	2	Unit	585,000	1,170,000
Other Eq.	2	Unit	560,000	1,120,000

Install Vendor Furnished Equipment	1	Lot		7,133,333
------------------------------------	---	-----	--	-----------

Control Points - Triconex	943	LF	2,500	2,357,500
Control Points - Bently Nevada	200	LF	2,500	500,000
Control Points - Other	150	LF	2,500	375,000

Control Cable - Cooling Tower	276,000	LF	5.50	1,518,000
-------------------------------	---------	----	------	-----------

Cable, Conduit, Cable Tray, Other	1	Allow	5,000,000	5,000,000
-----------------------------------	---	-------	-----------	-----------

Simulator Modifications / Training Program Mods.	1	Allow	2,500,000	2,500,000
--	---	-------	-----------	-----------

Total: Process Control and Instrumentation				<u>23,663,833</u>
		<u>Say</u>		<u>23,700,000</u>

Vendor Pricing Based on Enercon Report Appendix A-6.
 Vendor Prices Include Tax and Freight.
 Control Point Quantities from Enercon Report Documents SK-J-4 and SK-J-5.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
-----------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Permit and Licensing Fees

Environmental Services 6 Man Years	6	2,080 Hrs	150.00	1,872,000
LSA Environmental Services - EIR/Monitoring		7 Yrs	500,000.00	3,500,000
Legal Services 5 Man Years	5	2,080 Hrs	350.00	3,640,000
Regulatory Services 3 Man Years	3	2,080 Hrs	200.00	1,248,000
Prepare and Present Special Rate Case to CPUC		1 Allow	5,000,000.00	5,000,000
NRC License Amendment 15 Man Months - Preparation 6 Man Months - (1/2 FTE) Review Period	21	160 Hrs	200.00	672,000

Allowances for Permit Specific Administrative/Processing Costs and Initial Direct Fees:

California Coastal Commission - Coastal Development Permit (CDP)				1,500,000
SLO County Building Permits				500,000
Army Corps of Engineers - NWP Structural Discharge Permit				250,000
CA State Lands Commission - Lease for Wastewater Diffuser Area				75,000
SWRCB - Construction Storm Water Discharge Permit & SWPPP				75,000
RWQCB Region 3 - NPDES Wastewater Discharge Permit				500,000
SLO Air Pollution Control District - Batch Plant Operations/EIR				125,000
SLO Air Pollution Control District - Cooling Tower Emissions PTO				250,000

Allowance for Impacts Mitigation and/or Offsets Associated With Permit Approval Conditions 36,250,000

Anticipated Minimum Permit Specific Programs:

- Implement Coastal Development Permit Conditions (Various at Agency Discretion)
- PM₁₀ Emissions Offsets or Credits/Fees for Cooling Tower Operations
- Mitigation for Marine Rocky Benthic Habitat Disruption (Diffuser System Installation)
- Batch Plant Operations and Project Related Fossil Fuel Combustion Offsets

Total: Permit and Licensing Fees

55,457,000

Say

55,500,000

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Engineering

Preliminary Design Engineering

Mechanical	28,800 Hrs		150.00	4,320,000
Civil / Architectural	28,800 Hrs		150.00	4,320,000
Electrical	19,200 Hrs		150.00	2,880,000
I & C	5,760 Hrs		150.00	864,000
Piping	8,640 Hrs		150.00	1,296,000
Layout	11,520 Hrs		150.00	1,728,000
Engineering Planning & Scheduling	11,520 Hrs		150.00	1,728,000
Permitting/Environmental Support	19,200 Hrs		150.00	2,880,000
Licensing Support	19,200 Hrs		150.00	2,880,000
Management and Administration	19,200 Hrs		150.00	2,880,000
(41 Engineers x 2 Years) 171,840 Hrs.			

Procurement Support and Design Change Packages

Mechanical	65,880 Hrs		150.00	9,882,000
Piping	28,656 Hrs		150.00	4,298,400
Civil / Architectural	70,920 Hrs		150.00	10,638,000
I & C	28,560 Hrs		150.00	4,284,000
Electrical	77,220 Hrs		150.00	11,583,000
Seismic	8,280 Hrs		150.00	1,242,000
Environmental	5,280 Hrs		150.00	792,000
Procedures (Ops, Test, STP)	15,600 Hrs		150.00	2,340,000
PMT Procedure Preparation	15,840 Hrs		150.00	2,376,000
Other	9,600 Hrs		150.00	1,440,000
(52 Engineers x 3 Years) 325,836 Hrs			

Total: Engineering	497,676 Hrs			74,651,400
---------------------------	-------------	--	--	------------

Say 74,700,000

Technical Coordinator, ESC Designer and Drafter hours are included in engineering estimates.
Engineering Man-hours and billing rates provided by Enercon.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Construction Offices / Batch Plant / Temp Parking and Roadways

Install New / Temp Roadways	5 Mi		1,250,000	6,250,000
Clear Parking / Laydown and Trailer Areas	2 Acre		150,000	300,000
Crushed Stone	15,000 Ton		100	1,500,000
Road and Parking Maintenance	72 Mo		2,000	144,000
Construction Facilities	10,000 SF		250	2,500,000
Temp Sanitary	72 Mo		15,000	1,080,000
Temp Water	72 Mo		4,000	288,000
Office Equipment	1 Lot		1,000,000	1,000,000
Office Supplies	72 Mo		10,000	720,000
Office Maintenance	72 Mo		1,500	108,000
Temp Power	1 Lot		3,000,000	3,000,000
Area Lighting	25 Loc		25,000	625,000
Vehicles	25 Ea		25,000	625,000
Fuel Consumption	72 Mo		35,000	2,520,000
Tel/Data Service	1 Allow		1,000,000	1,000,000
Radio/Communications	1 Lot		500,000	500,000
Service Charges	72 Mo		10,000	720,000
Fencing	2,000 LF		25	50,000
Cleaning & Trash Service	72 Mo		24,000	1,728,000
Dust Control	36 Mo		75,000	2,700,000
Mob/De-mob Temp Facilities	1 Lot		500,000	500,000
Night Work Setup - Lighting, Generators and Fuel	1 Allow		5,000,000	5,000,000
Batch Plant	1 Allow		5,000,000	5,000,000

Total: Construction Offices / Batch Plant / Temp Parking and Roadways	37,858,000
--	-------------------

<u>Say</u>	<u>37,900,000</u>
-------------------	--------------------------

Set up and maintain a construction field office on site for a 6 year period.

Does not include Project Staff.

Batch Plant Price includes mob, de-mob, operation, maintenance, trucks and drivers.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
-----------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Project Management and Support Staff

Project Director	1	10 Yr	300,000.00	3,000,000
Sr. Project Managers	2	5 Yr	225,000.00	2,250,000
Project Managers	7	3 Yr	180,000.00	3,780,000
Work Planners	25	4 Yr	180,000.00	18,000,000
Field Engineers	25	4 Yr	200,000.00	20,000,000
Principal Engineer	4	6 Yr	200,000.00	4,800,000
Sr. Engineers	6	4 Yr	180,000.00	4,320,000
Project Engineers	15	3 Yr	150,000.00	6,750,000
Project Controls Manager	1	7 Yr	200,000.00	1,400,000
Cost Engineers	2	7 Yr	150,000.00	2,100,000
Schedulers	2	7 Yr	150,000.00	2,100,000
Field Office Manager	1	10 Yr	150,000.00	1,500,000
Project Clerks	5	7 Yr	100,000.00	3,500,000
Safety	5	3 Yr	200,000.00	3,000,000
Security	50	3 Yr	115,000.00	17,250,000

Total: Project Management and Support Staff

93,750,000

Say

93,800,000

Project Staff annual salaries based on PCC Cost amounts.

Size of security force based on SGRP experience (40 guards on 3 Shifts).

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
-----------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Relocate Warehouse & Cold Machine Shop

Crate Materials and Equipment Warehouse	25,000	Hrs	100.00	2,500,000
Crate Materials and Equipment Machine Shop	11,250	Hrs	100.00	1,125,000
Salvage - storage Bins, Shelves, Racks	7,500	Hrs	100.00	750,000
Load, Transport and Unload	3,200	Hrs	100.00	320,000
Set-Up New Warehouse	25,000	Hrs	100.00	2,500,000
Set-Up New Machine Shop	11,250	Hrs	100.00	1,125,000
Materials - Wood, Pallets, etc	1	Allow	200,000.00	200,000
Trucking	1	Allow	150,000.00	150,000
Allowance for Extra Handling	20%		8,320,000.00	1,664,000

Total: Relocate Warehouse & Cold Machine Shop

10,334,000

Say

10,300,000

Warehouse based on 500 Man-Weeks for Packing and Unpacking.
Cold Machine Shop based on 225 Man-Weeks for Packing and Unpacking.
Allowance for extra handling for interim storage.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Demo Displaced Structures

Bldg#				
116	Cold Machine Shop	15,000	SF	80.00 1,200,000
506	Radwaste Offices	1,000	SF	80.00 80,000
508	Other Shop	1,000	SF	80.00 80,000
127	Haz Mat Warehouse	4,000	SF	80.00 320,000
115	Main Warehouse	50,000	SF	80.00 4,000,000
201	Design Engineering Offices	12,000	SF	80.00 960,000
202	Design Engineering Offices	4,000	SF	80.00 320,000
220	Design Engineering Offices	1,000	SF	80.00 80,000
248	Outage Human Resources	1,000	SF	80.00 80,000
250	Project Offices	3,000	SF	80.00 240,000
252	Project Offices	3,000	SF	80.00 240,000
217	Restrooms	500	SF	80.00 40,000
253	Offices	500	SF	80.00 40,000
260	Security/Records Storage	2,000	SF	80.00 160,000
261	Records Storage/ Site Services Contractor Office	2,000	SF	80.00 160,000
262	Telecom/Project Office	2,000	SF	80.00 160,000
263	Site Services Contractor Training Facility	2,000	SF	80.00 160,000
264	Building Services	2,000	SF	80.00 160,000
251	Fire House	3,000	SF	80.00 240,000
254	Storage Facility	8,000	SF	80.00 640,000
255	Storage Facility	8,000	SF	80.00 640,000
114	Firing Range	3,000	SF	80.00 240,000
114A	Security Tower	500	SF	80.00 40,000
114B	Security Training Building	500	SF	80.00 40,000
113	Warehouse B	18,000	SF	80.00 1,440,000
120	Hazardous Waste	3,000	SF	80.00 240,000
125	Fire Water Tank and Pumphouse	1,000	SF	80.00 80,000
124	Sewage Treatment Plant	1,000	SF	80.00 80,000
165	Biology Offices / Career Center	2,000	SF	80.00 160,000
160	Biology Laboratory	4,000	SF	80.00 320,000
110	Blast and Paint Facility	3,000	SF	80.00 240,000
122	GC Fab Shop	8,000	SF	80.00 640,000
VIS	Vehicle Inspection Station	1,000	SF	80.00 80,000
	Hazardous Material Disposal Allowance	1	Allow	5,500,000 5,500,000

Total: Demo Displaced Structures

19,100,000

Say 19,100,000

Main Warehouse and Cold Machine Shop Relocation Priced Separately.
 Demo Price includes salvage of re-used equipment.
 Demo Price includes Hazardous Waste / Contaminated material Clean-Up.
 Hazardous Material Disposal Included (Lead, Asbestos, Ballasts).

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Construct Displaced Structures ON Site

116	Cold Machine Shop	15,000	SF	1,500.00	22,500,000
506	Radwaste Offices	1,000	SF	1,200.00	1,200,000
508	Other Shop	1,000	SF	1,200.00	1,200,000
127	Haz Mat Warehouse	4,000	SF	1,200.00	4,800,000
115	Main Warehouse	25,000	SF	1,500.00	37,500,000
201	Design Engineering Offices	6,000	SF	1,200.00	7,200,000
202	Design Engineering Offices	2,000	SF	1,200.00	2,400,000
220	Design Engineering Offices	500	SF	1,200.00	600,000
248	Outage Human Resources	500	SF	1,200.00	600,000
250	Project Offices	1,500	SF	1,200.00	1,800,000
252	Project Offices	1,500	SF	1,200.00	1,800,000
217	Restrooms	500	SF	1,200.00	600,000
253	Offices	250	SF	1,200.00	300,000
260	Security/Records Storage	1,000	SF	1,200.00	1,200,000
261	Records Storage/ Site Services Contractor Office	1,000	SF	1,200.00	1,200,000
262	Telecom/Project Office	1,000	SF	1,200.00	1,200,000
263	Site Services Contractor Training Facility	1,000	SF	1,200.00	1,200,000
264	Building Services	1,000	SF	1,200.00	1,200,000
251	Fire House	3,000	SF	1,200.00	3,600,000
114A	Security Tower	500	SF	1,200.00	600,000
114B	Security Training Building	1	Lot	1,500,000.00	1,500,000
120	Hazardous Waste	3,000	SF	1,200.00	3,600,000
125	Fire Water Tank and Pumphouse	1,000	SF	1,200.00	1,200,000
110	Blast and Paint Facility	3,000	SF	1,200.00	3,600,000
Special Equipment Allowance		1	Allow	2,500,000.00	2,500,000

Total: Construct Displaced Structures ON Site

105,100,000

Say

105,100,000

\$/SF based on historical cost data at DCPD.

Price Does Not include OFF Site Construction of Displaced Facilities.

Security Training Building Price based on recent experience.

Main Warehouse and Cold Machine Shop Relocation Priced Separately.

Vehicle Inspection Station Priced with Security.

Sewage Treatment Plant Priced Separately.

Special equipment allowance for Fire House, Shops and Hazardous Material Storage Building.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
-----------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Construct Displaced Structures OFF Site

115	Main Warehouse	25,000	SF	800.00	20,000,000
201	Design Engineering Offices	6,000	SF	1,000.00	6,000,000
202	Design Engineering Offices	2,000	SF	1,000.00	2,000,000
220	Design Engineering Offices	500	SF	1,000.00	500,000
248	Outage Human Resources	500	SF	1,000.00	500,000
250	Project Offices	1,500	SF	1,000.00	1,500,000
252	Project Offices	1,500	SF	1,000.00	1,500,000
260	Security/Records Storage	1,000	SF	1,000.00	1,000,000
261	Records Storage/ Site Services Contractor Office	1,000	SF	1,000.00	1,000,000
262	Telecom/Project Office	1,000	SF	1,000.00	1,000,000
263	Site Services Contractor Training Facility	1,000	SF	1,000.00	1,000,000
264	Building Services	1,000	SF	1,000.00	1,000,000
114	Firing Range	3,000	SF	800.00	2,400,000
Special Equipment Allowance		1	Allow	1,000,000.00	1,000,000

Total: Construct Displaced Structures OFF Site

40,400,000

Say

40,400,000

Price Includes procurement of 5+ Acres of commercial land in SLO County.
Main Warehouse Relocation Priced Separately.
Special Equipment Allowance for Firing Range and Main Warehouse.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
-----------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Displaced Parking

Displaced Parking

Lot #2 300 x 100	30,000	SF		
Lot #6 650 x 250	162,500	SF		
Lot #7 500 x 250	125,000	SF		
Lot #8 500 x 150	75,000	SF		
	<u>392,500</u>	SF		

Parking Garage

New 3 Story Parking Garage (200' x 300')	180,000	SF	400.00	72,000,000
--	---------	----	--------	------------

Parking Lot #2

Remote Paved Parking Areas	215,000	SF	40.00	8,600,000
----------------------------	---------	----	-------	-----------

Shuttle Service

Shuttle Bus Stops	10	Ea	25,000.00	250,000
Shuttle Busses	6	Ea	100,000.00	600,000
Shuttle Bus Drivers (6 Full Time Employees)	6	24 Yrs	80,000.00	11,520,000
Maintenance (6 Busses)	6	24 Yrs	2,500.00	360,000

Total: Displaced Parking

93,330,000

Say

93,300,000

Assumes Shuttle Service Day Shift Only.

Parking Garage location within walking distance to Plant.

24-Year Duration based on 4-Years left in current license + 1 full license period.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Security Requirements

New Vehicle Inspection Station				
Civil - Gates-Roadway-Structures	1	LS	5,000,000	5,000,000
Electrical - Power-Light-Tel/Data	1	LS	10,000,000	10,000,000
Mechanical - HVAC-Plumbing-Fire Protection	1	LS	2,000,000	2,000,000
New Guard Posts	3	Ea	2,500,000	7,500,000
New Perimeter Fence w/ Barb Wire	5,000	LF	250	1,250,000
Concrete Barrier	25,000	LF	125	3,125,000
CCTV	20	Ea	50,000	1,000,000
Other Security Devices	1	Allow	2,000,000	2,000,000
New PA Vehicle Barrier	2	Ea	3,500,000	7,000,000
Temporary PA Vehicle Barrier - During Construction	1	Sta.	1,724,625	1,724,625
Temp Security Personnel - During Construction (3 Yr)	10	Ea	300,000	3,000,000
Security System Outages				
Electrical - Re-Start and Test (8 Men x 30 Days)	2,880	MH	100.00	288,000
Security Comp Measures	30	Days	10,000.00	300,000

Total: Security Requirements

44,187,625

Say

44,200,000

Assuming all new construction will fall outside Protected Area.
All New Systems outside Protected Area will be Non Safety Related.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
-----------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Pedestrian and Vehicle Bridges

Pedestrian Access to Security Building				
12' Bridge with 30' Span	50	Ton	10,000	500,000
6' Crossover 30' Span 18' High	100	Ton	15,000	1,500,000
Vehicle Access To Protected Area				
25' Bridge with 30' Span	125	Ton	15,000	1,875,000
Miscellaneous Accessway	1	Allow	750,000	750,000
Miscellaneous Egress / Covered Walkway	1	Allow	1,000,000	1,000,000

Total: Pedestrian and Vehicle Bridges

5,625,000

Say

5,600,000

Access, Egress and Walkway allowances based on wood construction and basic lighting.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
-----------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Transportation - Permanent/Construction Personnel

Lease Land for Offsite Parking
 Prep Land for Parking
 Busses & Drivers
 Travel Pay / OT Expenses

Estimate Basis -

SGRP 2R14:

1,100 Craft for 3.5 Months Cost = \$15MM Total

1,100 Man x 3.5 Months = 3,850 Man Months

CCCT Project:

Up to 3,000 Craft + 1,000 Staff Require Transport During Project

Transport in Stages; Prior to Shutdown + Peak Period + Reduced Period

= (1,500 Man x 12 Months) + (3,000 x 18) + (1,000 x 9)

= 18,000 + 54,000 + 9,000

= 81,000 Man Months

CCCT Project Cost Estimate Factor Relative to 2R14:

81,000 / 3,850 =	21	15,000,000.00	315,000,000
------------------	----	---------------	-------------

Optimization - Non-Bargaining Unit Personnel vs. Bargaining Unit Travel Time
 Stronger Contract Negotiating Power for Long Term Leases/Contracts

-40% -126,000,000

Total: Transportation - Permanent/Construction Personnel

189,000,000

Say 189,000,000

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
-----------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Sewage Treatment Facility

Sitework and Concrete	1	Allow	1,500,000	1,500,000
Purchase all Equipment	1	Allow	500,000	500,000
Installation - Civil	1	Allow	1,000,000	1,000,000
Installation - Mechanical	1	Allow	4,000,000	4,000,000
Installation - Electrical	1	Allow	4,000,000	4,000,000
Installation - Process Controls	1	Allow	1,000,000	1,000,000

Total: Sewage Treatment Facility

12,000,000

Say 12,000,000

Allowance based on low volume treatment plant. Pricing would not cover storm water treatment.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
-----------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Utility Relocations

Trenching	10,000 LF			
Rock / Concrete (10,000 Yd x 5 Locations)	5,926 CY		125.00	740,741
Sheet Piling	5,000 SF		100.00	500,000
Backfill	5,500 CY		75.00	412,500
Electrical	1 Allow		10,000,000	10,000,000
Fiber Optic	1 Allow		5,000,000	5,000,000
Mechanical				
Fire Protection Loop	1 Allow		1,500,000	1,500,000
Mechanical Pressurized Systems	1 Allow		5,000,000	5,000,000
Mechanical Drainage Systems	1 Allow		3,000,000	3,000,000
Premium for Relocation of Class 1 Systems	1 Allow		10,000,000	10,000,000

Total: Utility Relocations

36,153,241

Say 36,200,000

Allowances based on remove and replace/relocate hundreds of systems in conflict with new Cooling Tower Footprint, Circulation and Makeup Water Systems Routing and Major Tie-Ins.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

SCW System

SCW Pumps - Vendor Quote	6	Ea	180,000	1,080,000
SCW Pumps - Installation	6	Ea	300,000	1,800,000
Control Valves	1	Allow	1,500,000	1,500,000
Install Pipe Supports in Intake Tunnels	400	Ea	15,000	6,000,000
Install Paralined Pipe	3,630	LF	2,000	7,260,000
Purchase Paralined Pipe	3,630	LF	2,270	8,240,100
Above Ground Pipe - Inside Turbine Building	1,500	LF	3,000	4,500,000
Electrical	1	Allow	3,000,000	3,000,000
Process Controls	1	Allow	2,500,000	2,500,000
Sales Tax and Freight on Equipment (7.25% Tax & 3.5% Allowance for Freight = 11%)	11%		9,320,100	1,025,211

Total: SCW System

36,905,311

Say

36,900,000

Excavation included with site-work.

Backfill included with site-work.

Condensate Cooler pricing based on reworking piping around existing Coolers.

Paralined Pipe price prorated from vendor quote.

Electrical price based on existing switchgear at intake with new circuitry to pumps.

Control price based on local instrumentation and control panel with basic signals to control room through existing conduit.

Demo at intake included with Makeup Water System.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

ASW & Blowdown Water Treatment

Chlorination System

Use Existing Chemical Injection Equipment for Chlorination as Required.

Miscellaneous Minor Modifications	1	Allow	1,000,000	1,000,000
-----------------------------------	---	-------	-----------	-----------

Dechlorination System

Dechlorination Skid w/ Tanks Pumps, etc.	1	Ea	5,000,000	5,000,000
--	---	----	-----------	-----------

Mechanical	1	Allow	3,500,000	3,500,000
------------	---	-------	-----------	-----------

Electrical	1	Allow	3,000,000	3,000,000
------------	---	-------	-----------	-----------

Instrumentation & Controls	1	Allow	2,000,000	2,000,000
----------------------------	---	-------	-----------	-----------

Tie-Ins	1	Allow	1,000,000	1,000,000
---------	---	-------	-----------	-----------

Total: ASW & Blowdown Water Treatment				<u>15,500,000</u>
--	--	--	--	-------------------

<u>Say</u>	<u>15,500,000</u>
-------------------	--------------------------

Pricing does not include special consideration for Chlorine Use or Storage.
Cost of Chemicals included in O&M Burden.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
-----------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Blowdown, Mixing Station and Diffuser

Blowdown Discharge Pipe 36" Paralined Steel - Vendor	1,600	LF	2,270	3,632,000
Blowdown Discharge Pipe 36" Paralined Steel - Install	1,600	LF	2,000	3,200,000

Mixing Station

Makeup Water 36" Paralined Steel - Vendor	1,500	LF	2,270	3,405,000
Makeup Water 36" Paralined Steel - Install	1,500	LF	2,000	3,000,000
SCW/CCW Paralined Steel - Vendor	1,500	LF	2,270	3,405,000
SCW/CCW Paralined Steel - Install	1,500	LF	2,000	3,000,000
Tie-Ins	1	Lot	1,000,000	1,000,000
Mixing Skid w/ Tanks Pumps, etc.	1	Ea	3,500,000	3,500,000
Temperature Control System	1	Ea	1,500,000	1,500,000
Power	1	Allow	1,800,000	1,800,000

Diffuser System

Flanged FRP Pipe on Land	1,000	LF	1,000	1,000,000
Flanged FRP Pipe in Water	1,400	LF	2,000	2,800,000
Floating Work Platforms	3	Mo	10,000	30,000
Anchors to Ocean Floor				
Divers 12 FTEs	36	Mo	110,000	3,960,000
5 CY Conc. Slurry every 50 LF	24	Ea	150,000	3,600,000

Sales Tax and Freight on Equipment (7.25% Tax & 3.5% Allowance for Freight = 11%)	11%		7,037,000	774,070
--	-----	--	-----------	---------

Total: Blowdown, Mixing Station and Diffuser

39,606,070

Say 39,600,000

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Plant Shutdown and Start-Up

Typical expense cost of a 1 unit shutdown = \$50MM	2 Units	25,000,000	50,000,000
--	---------	------------	------------

Plant Shutdown and Start-Up functions will be performed during Cooling Tower construction period. Work such as routine maintenance, preservation of safe conditions, and maintenance of mechanical equipment will be performed by existing staff, therefore there will be no savings in personnel during shutdown period.

Total: Plant Shutdown and Start-Up	<u>50,000,000</u>
Say	<u>50,000,000</u>

Based on 50% expense actuals from 2R14 refueling outage. Good representation of bare maintenance costs as the majority of plant recourses were dedicated to capital projects.

Appendix A-11 Project Cost Estimate

PG&E Diablo Canyon Power Plant

Project :	Enercon Cooling Tower Feasibility Study DCPP Common Facilities Cost Estimate
------------------	---

Description	Quantity	Unit	Unit Cost	Extension
-------------	----------	------	-----------	-----------

Site Infrastructure (Water/Storm/Power/Tel-Data/etc.)

Trenching and Backfill	1	Allow	5,000,000	5,000,000
Electrical	1	Allow	10,000,000	10,000,000
Fiber Optic	1	Allow	10,000,000	10,000,000
Mechanical				
Fire Protection Loop	1	Allow	5,000,000	5,000,000
Mechanical Pressurized Systems	1	Allow	3,000,000	3,000,000
Mechanical Drainage Systems	1	Allow	5,000,000	5,000,000


Total: Site Infrastructure (Water/Storm/Power/Tel-Data/etc.)	38,000,000
---	-------------------

Say 38,000,000

Based on upgrade of existing systems as well as new distribution based on the re-alignment of plant facilities and personnel.

Activity ID	Activity Description	Orig Dur	Early Start	Early Finish												
					2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021
Scheduled Refueling Outages																
1R20	1R20 - 29 Days	30	01MAY17*	30MAY17	30 1R20 - 29 Days 01MAY17* 30MAY17											
2R20	2R20 - 24 Days	25	05FEB18*	01MAR18	25 2R20 - 24 Days 05FEB18* 01MAR18											
1R21	1R21 - 24 Days (Estimated)	25	13OCT18	06NOV18	25 1R21 - 24 Days (Estimated) 13OCT18 06NOV18											
2R21	2R21 - 29 Days (Estimated)	30	23SEP19	22OCT19	30 2R21 - 29 Days (Estimated) 23SEP19 22OCT19											
1R22	1R22 - 24 Days (Estimated)	25	21MAR20	14APR20	25 1R22 - 24 Days (Estimated) 21MAR20 14APR20											
Significant Milestones																
U1@1155MW	U1 @ Full Power (1155 MWe)	501	06NOV18	20MAR20	501 U1 @ Full Power (1155 MWe) 06NOV18 20MAR20											
U2@1155MW	U2 @ Full Power (1155 MWe)	165	22OCT19	03APR20	165 U2 @ Full Power (1155 MWe) 22OCT19 03APR20											
CCSTSU1OFF	U1 OffLine	532*	21MAR20	03SEP21	532* U1 OffLine 21MAR20 03SEP21											
CCSTSU2OFF	U2 OffLine	574*	04APR20	29OCT21	574* U2 OffLine 04APR20 29OCT21											
CCSTS_999M	Deadline to comply with 316B Regs (1/1/2021)	0		01JAN21*	Deadline to comply with 316B Regs (1/1/2021) 01JAN21*											
CCSTS_991F	U1: Requirements of 316B met, Rdy for Startup	0		20AUG21	U1: Requirements of 316B met, Rdy for Startup 20AUG21											
U1@1065MW	U1 @ Full Power (1065 MWe)	161	03OCT21	12MAR22	161 U1 @ Full Power (1065 MWe) 03OCT21 12MAR22											
CCSTS_992F	U2: Requirements of 316B met, Rdy for Startup	0		15OCT21	U2: Requirements of 316B met, Rdy for Startup 15OCT21											
U2@1065MW	U2 @ Full Power (1065 MWe)	105	28NOV21	12MAR22	105 U2 @ Full Power (1065 MWe) 28NOV21 12MAR22											
CCSTS_999	All Work Completion Milestone	0	19FEB22		All Work Completion Milestone 19FEB22											
Engineering for Site Facilities																
CCSTS_000	Begin Milestone	0	04JAN10*		Begin Milestone 04JAN10*											
CCSTS_010A	Engineering: Preliminary Design for Permitting	250	04JAN10	10SEP10	Engineering: Preliminary Design for Permitting 04JAN10 10SEP10 Replace Facilities-Civil/Arch. Design Replace Facilities-Mech/Piping Replace Facilities-Electrical/Power											
CCSTS_010B	Engineering Design	729	12JUL11	09JUL13	Engineering Design 12JUL11 09JUL13 (41 Engineers x 2 years) Mechanical Civil/Architectural Electrical I&C Piping Layout Engineering Planning & Scheduling Permitting/Environmental Support Licensing Support Management & Administration											

Activity ID	Activity Description	Orig Dur	Early Start	Early Finish	Year															
					2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023		
CCSTS_067	U2-500kV SwYd (Using New 13.8Kv Xmfr)	105	10APR21	23JUL21											U2-500kV SwYd (Using New 13.8Kv Xmfr) 105 10APR21 23JUL21					
Startup Testing																				
CCSTS_069	U1-Testing, Fuel Reload, Startup	63	03JUL21	03SEP21											U1-Testing, Fuel Reload, Startup 63 03JUL21 03SEP21					
CCSTS_070	U2-Testing, Fuel Reload, Startup	56	04SEP21	29OCT21											U2-Testing, Fuel Reload, Startup 56 04SEP21 29OCT21					
Power Ascension																				
U1PARALLEL	U1 Parallel to Grid	0		03SEP21											U1 Parallel to Grid 0 03SEP21					
CCSTS_071	U1 Power Ascension (to 1065MW)	29	04SEP21	02OCT21											U1 Power Ascension (to 1065MW) 29 04SEP21 02OCT21					
U2PARALLEL	U2 Parallel to Grid	0		29OCT21											U2 Parallel to Grid 0 29OCT21					
CCSTS_072	U2 Power Ascension (to 1065MW)	29	30OCT21	27NOV21											U2 Power Ascension (to 1065MW) 29 30OCT21 27NOV21					
Misc Tie-ins																				
CCSTS_074	Compl. Security PA & Yard ties	126	17JUL21	19NOV21											Compl. Security PA & Yard ties 126 17JUL21 19NOV21					
CCSTS_075	Non-critical Utils tie-ins	140	24JUL21	10DEC21											Non-critical Utils tie-ins 140 24JUL21 10DEC21					
CCSTS_076	Complete backfill & util tie-ins	168	04SEP21	18FEB22											Complete backfill & util tie-ins 168 04SEP21 18FEB22					
CCSTS_078	Restoration of ISFSI Cask Loadings	42	27NOV21	07JAN22											Restoration of ISFSI Cask Loadings 42 27NOV21 07JAN22					



Note: Durations listed are 7days/week (not work days)

© Primavera Systems, Inc.

Appendix 13

Power Plant Systems Effluent Concerns

The following considers existing plant effluent management concerns that would occur due to the significant reduction in power plant once-through cooling system throughput. The issues require further assessment to determine potential impacts to the scope of a proposed retrofit, or the additional operation and management burdens that would be realized post retrofit.

1) Potential Residual Copper in Effluent Streams

With the proposed elimination of the large circulating water dilution flow, concerns would exist that effluent streams may contain levels exceeding 1 ppm of toxic copper ion. At DCPD, the Service Cooling Water heat exchangers, the Condensate Coolers and the Component Cooling Water (CCW) heat exchangers have 90-10 copper nickel tubing. Only one of each pair of these heat exchangers is normally in operation with the other on standby, filled with stagnant seawater. The concern is violating Cu discharge concentration limits when bringing the standby heat exchangers on-line with the proposed elimination of the large circulating water dilution flow. The residual copper concentration in these heat exchangers while operating (with saltwater flowing) would be extremely low, on the order of ppb levels. However, prediction of the Cu concentration level with stagnant saltwater is very difficult without detailed information and study. In the idle heat exchanger, the dissolved oxygen would be consumed. Then, in an anaerobic condition, certain bacteria could grow, and the Cu concentration would increase, being locally higher near where the bacteria colonies would thrive. Testing with tube samples and saline solutions would be necessary to predict copper concentration levels inside idle heat exchangers exposed to stagnant seawater. Depending on the results of these studies, corrective actions to prevent exceeding the Cu concentration limit in the effluent stream could be complex and expensive, exceptionally so for the nuclear safety related CCW System. Necessity for replacement of heat exchanger tube bundles with non copper containing alloy tubes for any of the systems would result in substantial additional project costs.

2) Liquid Radwaste Effluents Management

Processed water from Liquid Radwaste (LRW) is presently batch released at 60 gpm and is diluted by the large circulating water flow. Due to the concentration limits of tritium and other isotopes, retrofitting with cooling towers would result in most of DCPD's LRW streams being limited to a 10 gpm release rate limit. In order to empty tanks of 10,000 gallons, this would take 17 hours. For the 50,000 gallon capacity tanks that have pure water with some tritium, emptying the tanks would take up to four days. During outages, extra LRW water produced would present a management and scheduling challenge.

With a cooling tower retrofit, the reduced discharge rates to the ocean would significantly change the way LRW streams are managed and discharged. However with appropriate planning, effective implementation of reduced discharge rates during routine operations is potentially achievable. Availability of an additional wastewater holding tank onsite during outages might be required. Additional analysis is necessary to fully address retrofitting impacts to LRW management.

3) Seawater Reverse Osmosis System Effluents

The existing seawater reverse osmosis reject (2X normal seawater salinity at a maximum flow of 1000 gpm and an average flow of 240gpm) is directed to the suction forebay of the Unit 1 ASW screen wash pumps. In addition to high salinity, the effluent may contain residual water treatment chemicals and/or suspended solids from filter backwashing. Remaining seawater cooling flow projected for the ASW and SCW systems would be available to dilute the SWRO effluent. However, that flow would also be combined with several other existing plant waste streams prior to discharge to the ocean (Reference Other Plant System Effluents).

Adequate water quality at the point of outfall for the remaining once-through cooling system would need to be assured under all operating conditions. Therefore, the SWRO effluent would potentially need to be directed to the cooling tower blowdown diffuser array. Discharge via the ocean floor diffusion system would be the most prudent configuration to dispose of the relatively continuous and high concentration SWRO waste stream in the absence of main circulating water pump dilution flow. However this configuration, and potential effects on final discharge water quality, would require further evaluation.

4) Other Plant System Effluents

If the high saline wastewater from the facility's Seawater Reverse Osmosis Unit is directed to the cooling tower blowdown diffuser system, and facility sewage effluents treated to more conservative specifications, the proposed remaining plant once-through cooling flow of 43mgd (ASW and SCW systems) could be used to dilute most other remaining plant wastewater streams facilitating discharge to the Pacific Ocean.



Other major existing relatively continuous plant wastewater effluents include the Unit 1 and Unit 2 Steam Generator Blowdown (SGBD 160,000 gpd-average), the Turbine Building Sump System (TBS 44,000 gpd-average), Unit 1 and Unit 2 Condensate Regeneration System effluent (CDR 48,000 gpd-average), and the Makeup Water Treatment System effluent (MWTS 92,000 gpd-average). When mixed with estimated post retrofit once-through cooling system flow, collective potential contaminants in these waste streams (suspended solids, soluble salts and metals) may not result in challenges to State Ocean Plan requirements at plant outfall. Combined system effluents of 239 gpm (averaged) would represent only 1.3% of the total discharge flow. Actual individual system discharge rates can vary substantially however dependent on multiple operating factors. As these systems are in continuous use, routine discharge would be a necessity,

and the large volumes involved would preclude other options than discharge to receiving waters. In the event any system could not be discharged in the modified plant configuration, upgrades to directly treat the effluent from that system would likely be required, and increase associated project scope and costs. Additional evaluation is required to fully explore this issue.

SGBD effluents are also routinely elevated in temperature, initially ranging from 120 to 190 °F. The need to dilute this wastewater stream thermally would provide another reason to maintain the discharge of once-through cooling flow separate from the cooling tower blowdown. In a combined discharge, the heat content of relatively high volumes of SGBD could further challenge plant thermal compliance during periods when the Pacific Ocean receiving waters are very cold, and/or when ambient wet-bulb temperatures are high (and cooling tower blowdown would already be projected to exceed thermal discharge limits).

Additional lower volume, and intermittent, discharges also occur from the power plant, and are currently diluted by the existing once-through system. These include chemically treated freshwater coolants within the closed cooling systems (SCW & CCW), water storage tank drain downs, condensate hot well reject during startup, the Waste Holding and Treatment (WHAT) system effluents, and several additional minor discharges. These periodic streams could likewise be combined with remaining once-through cooling flow with precautions to insure constituent limitations were not exceeded at final outfall. If this was determined to be problematic however (most likely for freshwater coolants), system effluents would need to be alternatively managed. This could entail draining systems to transportable tankers, and removing the industrial wastewater from the site for treatment and disposal at an appropriate facility. The requirement to do this would result in additional ongoing operational and maintenance costs, and increase truck traffic and associated transportation fuel combustion.

DCPP COOLING TOWER FEASIBILITY STUDY CIRCULATING WATER SYSTEM FOR EACH UNIT FLOW DIAGRAM




SYMBOLS

-  Motor operated Butterfly Valve
-  Manually operated Butterfly Valve
-  Cooling Tower Fan
-  Flow Element

0					03/28/2008
REV	REASON FOR CHANGE	DRN	CHK	REV	APP DATE
 ENERCON SERVICES, INC. OAKLAND		CIRC WATER SYSTEM FLOW DIAGRAM			
CLIENT PG&E		DWG-SK SK-M-1		REV 0	

COOLING TOWER AUXILARY SYSTEMS FLOW DIAGRAM




Makeup water pumps 3x50%
22,500gpmx210'tdh

Service Cooling water sea water supply pumps 3x 50%
3150gpm x 86' tdh

Makeup water pumps 3x50%
22500gpmx210' tdh

Service Cooling water sea water supply pumps 3x 50%
3150gpm x 86' tdh

0					03/28/2008
REV	REASON FOR CHANGE	DRN	CHK	REV	APP
ENERCON SERVICES, INC. <small>OAKLAND</small>		AUX WATER SYSTEM FLOW DIAGRAM			
CLIENT		DWG-SK		REV	
PG&E		SK-M-2		0	




SERVICE COOLING WATER AND
SEA WATER PUMPS
3 x 50% CAPACITY


MAKE UP WATER PUMPS
3 x 50% CAPACITY

0	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE
						03/28/2008
 ENERCON SERVICES, INC. OAKLAND		AUX WATER SYSTEM				
CLIENT		DWG-SK				
PG&E		SK-M-3				
REV						0

SKETCH OF BLOWDOWN DIFFUSER LINES




DISTRIBUTION PIPE SKETCH
[SEC A-A]



NOT TO SCALE

0	REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE
							05/29/2008
		SKETCH OF BLOWDOWN DIFFUSER LINES					
CLIENT PG&E		DWG-SK		SK-M-4		REV 0	


DCPP COOLING TOWER FEASIBILITY STUDY
ELECTRICAL SINGLE LINE




NOTE: POWER SUPPLY FOR NEW PUMPS AT INTAKE STRUCTURE NOT SHOWN

0						05/22/2008
REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE
 ENERCON SERVICES, INC. OAKLAND		COOLING TOWER RETROFIT ELECTRICAL SINGLE LINE				
CLIENT		DWG-SK				REV
PG&E		SK-E-1				0

Intake Structure Electrical System One Line for Cooling Tower Auxiliaries



0						03/28/2008
REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE
 ENERCON SERVICES, INC. OAKLAND		ELECTRICAL SYSTEM ONELINE FOR C.T AUXILIAIRES				
CLIENT		DWG-SK			REV	
PG&E		SK-E-2			0	



ENERCON SERVICES, INC.
OAKLAND

TOPO LAYOUT OF COOLING TOWERS

CLIENT

DIABLO CANYON

DWG-SK


REV

DATE


SK-C-1

0

03/28/2008



NOTE : Unit in Feet




REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE
0						03/28/2008



ENERCON SERVICES, INC.
Oakland, CA, 94621

COOLING TOWER PROFILE
Existing Ground Elevation

CLIENT	DRAWING NO.	REV
DIABLO CANYON	SK-C-2	0



ATTORNEY - CLIENT PRIVILEGED




REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE
0						03/28/2008



ENERCON SERVICES, INC.
Oakland, CA, 94621

COOLING TOWER CROSS SECTION

CLIENT		DRAWING NO.		REV
DIABLO CANYON		SK-C-3		0



SECT A-A




REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE
0						04/29/2008



ENERCON SERVICES, INC.
Oakland, CA, 94621

COOLING TOWER BASIN LAYOUT -1

CLIENT	DRAWING NO.	REV
DIABLO CANYON	SK-C-4	0




REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE
0						03/28/2008




ENERCON SERVICES, INC.
Oakland, CA, 94621

COOLING TOWER BASIN LAYOUT -2


CLIENT		DRAWING NO.		REV
DIABLO CANYON		SK-C-5		0



SECTION C-C



Section D-D



0	REASON FOR CHANGE					03/28/2008
REV		DRN	CHK	REV	APP	DATE



ENERCON SERVICES, INC.
Oakland, CA, 94621

COOLING TOWER BASIN DETAILS

CLIENT


DIABLO CANYON

DRAWING NO.

SK-C-6

REV

0



0					03/28/2008	
REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE



ENERCON SERVICES, INC.
Oakland, CA, 94621

PUMP PIT PLAN

CLIENT


DIABLO CANYON

DRAWING NO.

SK-C-7

REV

0



SECTION A-A


0					03/28/2008	
REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE



ENERCON SERVICES, INC.
Oakland, CA, 94621


PUMP PIT SECTION

CLIENT		DRAWING NO.		REV
DIABLO CANYON		SK-C-8		0



SEC B-B

0						03/28/2008
REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE
 <p>ENERCON SERVICES, INC. Oakland, CA, 94621</p>		<p>PUMP PIT WALLS</p>				
CLIENT		DRAWING NO.				
DIABLO CANYON		SK-C-9				
						REV
						0




0					03/28/2008	
REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE



ENERCON SERVICES, INC.
Oakland, CA, 94621

COOLING TOWER SCHEMATIC LAYOUT

CLIENT		DRAWING NO.		REV
DIABLO CANYON		SK-C-10		0



ITEMS IN RED WILL REQUIRE RELOCATION

ITEMS IN BLUE ARE TO BE ADDED


REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE
0						05/30/2008



ENERCON SERVICES, INC.
Oakland, CA, 94621

COOLING TOWER LAYOUT & ACCESS
ROAD RELOCATION

CLIENT	DRAWING NO.	REV
DIABLO CANYON	SK-C-11	0



18




REASON FOR CHANGE					03/28/2008
0					
REV	DRN	CHK	REV	APP	DATE



ENERCON SERVICES, INC.
Oakland, CA, 94621


**COOLING TOWER
CIRCULATING WATER PIPING LAYOUT**

CLIENT					REV
DIABLO CANYON					0
DRAWING NO.					SK-C-12



PIPE CROSS SECTION

SINGLE CELL



PIPE CROSS SECTION

DOUBLE CELLS


0					03/28/2008
REV	REASON FOR CHANGE	DRN	CHK	REV	APP
					DATE



ENERCON SERVICES, INC.
Oakland, CA, 94621

COOLING TOWER
CONCRETE PIPE CROSS SECTION -1

CLIENT	DRAWING NO.	REV
DIABLO CANYON	SK-C-13	0



PIPING PLAN
Scale: 1" = 50'


0					03/28/2008	
REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE



ENERCON SERVICES, INC.
Oakland, CA, 94621

COOLING TOWER
CONCRETE TUNNEL LAYOUT

CLIENT	DRAWING NO.	REV
DIABLO CANYON	SK-C-15	0



SECTION A-A

0					03/28/2008	
REV	REASON FOR CHANGE	DRN	CHK	REV	APP	DATE


ENERCON SERVICES, INC.
Oakland, CA, 94621

**COOLING TOWER
CONCRETE PIPE LAYOUT SEC- A-A**

CLIENT		DRAWING NO.		REV
DIABLO CANYON		SK-C-16		0

VERTICAL BOARD NO. 4

VERTICAL BOARD NO. 4



14-C-9

0	03/28/2008
REV	DATE
REASON FOR CHANGE	DRN CHK REV APP
ENERCON SERVICES, INC.	DATE
CLIENT	BEFORE PROPOSED CONTROL BOARD CHANGES
DRAWING NO.	REV


DIABLO CANYON

SK-1-1

0

VERTICAL BOARD NO. 4

VERTICAL BOARD NO. 4



141-9*

0	REASON FOR CHANGE	03/28/2008			
REV	DRN	CHK	REV	APP	DATE

ENERCON SERVICES, INC.

CLIENT

DIABLO CANYON


DRAWING NO. SK-J-2

REV

0

AFTER PROPOSED CONTROL BOARD CHANGES

DCPP COOLING TOWER CONTROL SYSTEM CONCEPTUAL BLOCK DIAGRAM



0									03/28/2008
REV	REASON FOR CHANGE								DATE
	 ENERCON SERVICES, INC.	DCPP COOLING TOWER CONTROL SYSTEM CONCEPTUAL BLOCK DIAGRAM							
	CLIENT	DRAWING NO.						REV	
	DIABLO CANYON	SK-J-3						0	

DCPP COOLING TOWER FEASIBILITY STUDY
SK-J-4
Preliminary Triconex I/O Point Count

I/O Point Totals per Unit:

In cooling tower electrical room:

Total digital input points	359
Total relay output points	226
Total 0-5 VAC analog input points (signal converter required to convert to 4-20 mA or 0-5 VDC)	26
Total 0-5 VDC analog input points	1
Total 4-20 mA analog input points	84
Total pulse analog input points	4
Total thermocouple analog input points	53
Total RTD analog input points (4-20 mA transmitter required)	30
Total analog output points	0

Intake structure remote I/O:

Total digital input points	74
Total relay output points	27
Total 0-5 VAC analog input points (signal converter required to convert to 4-20 mA or 0-5 VDC)	2
Total 0-5 VDC analog input points	1
Total 4-20 mA analog input points	9
Total pulse analog input points	0
Total thermocouple analog input points	29
Total RTD analog input points (4-20 mA transmitter required)	18
Total analog output points	0

DCPP COOLING TOWER FEASIBILITY STUDY
SK-J-5
Preliminary Bently Nevada I/O Point Count

In cooling tower electrical room:

Total keyphasor inputs	5
Total proximitors inputs	50
Total accelerometers inputs	60
Total relay output points	10

In intake structure:

Total keyphasor inputs	3
Total proximitors inputs	30
Total accelerometers inputs	36
Total relay output points	6