

MANDALAY OTC DATA

October 1, 2017 - February 28, 2018

<u>Date</u>	<u>Value</u>	<u>Units</u>	<u>Date</u>	<u>Fish</u>	<u>Invertebrates (lbs)</u>	<u>Algae/Shells/Debris (lbs)</u>
01-Oct-17	1,301.3	MG				
Nov-18	1,042.0	MG	28-Nov-17	0.007	0.062	13.228
Dec-18	2,201.7	MG				
Jan-18	548.2	MG				
5-Feb-18	117.5	MG	7-Feb-18	0.000	0.095	0.220
TOTAL:	5,210.7	MG	TOTAL:	0.007	0.157	13.448

MG = Millions of Gallons

State Water Resources Control Board Note on Submitted Data:

The State Water Resources Control Board (State Water Board) agreed to include the final months of operation of the Once-Through Cooling (OTC) Units at Mandalay Generating Station from October 1, 2017, through February 5, 2018, in the 2016 to 2017 interim mitigation period Determination due to OTC Units retirement on February 5, 2018. The State Water Board requested the entrainment and impingement data from October 1, 2017 through February 5, 2018 in an email on April 19, 2018, and received the data provided in this table from NRG Energy in an email on April 27, 2018.