

WASTEWATER TREATMENT PLANT CLASSIFICATION TABLE

Class	Wastewater Treatment Process	<b>Design Flow</b> (in million gallons per day)
I	Primary . . . . . Conventional Treatment Pond . . . . .	1.0 or less All
II	Primary . . . . . Biofiltration . . . . . Modified Treatment Pond . . . . .	Greater than 1.0 through 5.0 1.0 or less All
III	Primary . . . . . Biofiltration . . . . . Activated Sludge . . . . . Sequencing Batch Reactor . . . . . Tertiary . . . . .	Greater than 5.0 through 20.0 Greater than 1.0 through 10.0 5.0 or less 1.0 or less 1.0 or less
IV	Primary . . . . . Biofiltration . . . . . Activated Sludge . . . . . Sequencing Batch Reactor . . . . . Tertiary . . . . .	Greater than 20.0 Greater than 10.0 through 30.0 Greater than 5.0 through 20.0 Greater than 1.0 through 10.0 Greater than 1.0 through 10.0
V	Biofiltration . . . . . Activated Sludge . . . . . Sequencing Batch Reactor . . . . . Tertiary . . . . .	Greater than 30.0 Greater than 20.0 Greater than 10.0 Greater than 10.0