



U.S. Environmental Protection Agency Information Collection Rule (ICR)

[Recent Additions](#) | [Contact Us](#) | [Print Version](#) | [EF Search:](#)



[EPA Home](#) > [Envirofacts](#) > [ICR](#) > [Disinfection Byproducts: A Reference Resource](#)

[Overview](#)

[Query](#)

[Model](#)

[Law](#)

[Limitations and
Cautions on Data Use](#)

[Why Collect
Contaminant
Information?](#)

[Current EPA Microbial
and Disinfection
Byproduct
Regulations](#)

[ICR Background](#)

[ICR Home Page](#)

[Data Source](#)

[Contact Us](#)

[EF Home](#)



ICR

Disinfection Byproducts: A Reference Resource

Disinfection byproducts are formed when disinfectants used in water treatment plants react with bromide and/or natural organic matter (i.e., decaying vegetation) present in the source water. Different disinfectants produce different types or amounts of disinfection byproducts. Disinfection byproducts for which regulations have been established have been identified in drinking water, including trihalomethanes, haloacetic acids, bromate, and chlorite.

Trihalomethanes (THM) are a group of four chemicals that are formed along with other disinfection byproducts when chlorine or other disinfectants used to control microbial contaminants in drinking water react with naturally occurring organic and inorganic matter in water. The trihalomethanes are chloroform, bromodichloromethane, dibromochloromethane, and bromoform. EPA has published the [Stage 1 Disinfectants/Disinfection Byproducts Rule](#) to regulate total trihalomethanes (TTHM) at a maximum allowable annual average level of 80 parts per billion. This standard will replace the current standard of a maximum allowable annual average level of 100 parts per billion in December 2001 for large surface water public water systems. The standard will become effective for the first time in December 2003 for small surface water and all ground water systems.

Haloacetic Acids (HAA5) are a group of chemicals that are formed along with other disinfection byproducts when chlorine or other disinfectants used to control microbial contaminants in drinking water react with naturally occurring organic and inorganic matter in water. The regulated haloacetic acids, known as HAA5, are: monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, monobromoacetic acid, and dibromoacetic acid. EPA has published the [Stage 1 Disinfectants/Disinfection Byproducts Rule](#) to regulate HAA5 at 60 parts per billion annual average. This standard will become effective for large surface water public water systems in December 2001 and for small surface water and all ground water public water systems in December 2003.

Bromate is a chemical that is formed when ozone used to disinfect drinking water reacts with naturally occurring bromide found in source water. EPA has established the [Stage 1 Disinfectants/Disinfection Byproducts Rule](#) to regulate bromate at annual average of 10 parts per billion in drinking water. This standard will become effective for large public water systems by December 2001 and for small surface water and all ground public water systems in December 2003.

Chlorite is a byproduct formed when chlorine dioxide is used to disinfect water. EPA has published the [Stage 1 Disinfectants/Disinfection Byproducts Rule](#) to regulate chlorite at a monthly average level of 1 part per million in drinking water. This standard will become effective for large surface water public water systems in December 2001 and for small surface water and all ground water public water systems in December 2003.

- ▶ [Disinfection Byproduct Information](#)
- ▶ [Disinfection Byproduct Health Effects](#)
 - ▶ [Drinking Water and Health](#)

[EPA Home](#) | [Privacy and Security Notice](#) | [Contact Us](#)

Last updated on Tuesday, November 27th, 2007

URL: <http://S%3A/WQS/303dlist/2008%2520List/Data%2520%2526%2520Fact%2520Sheets/Drinking%2520Source%2520Water%2520Reservoirs/EPA%2520-%2520Envirofacts%2520-%2520ICR%2520-%2520Disinfection%2520Byproducts%2520A%2520Reference%2520Resource.htm>