

TECHNICAL MEMORANDUM
Santa Rosa Subregional Long-Term Wastewater Project
Transport Pipeline Flowrate and Pumping Schedule
Present Worth Analysis
(TM-P-6)

TO: Ed Braunner (City of Santa Rosa)
Dan Carlson (City of Santa Rosa)
Marie Meredith (City of Santa Rosa)

FROM: Jessamy Zagel Trisler (Parsons ES)
Rich Maurer (Parsons ES)

DATE: 15 September 1995

GENERAL

The purpose of this memorandum is to:

- present the approach used to evaluate the relative economic benefit of alternative pumping rates and time of day pumping periods and the associated construction and present worth energy costs, and
- recommend the appropriate pumping rate and schedule to be used to obtain the least cost.

Transmission systems to two reservoir sites (Tolay A in South County and Carroll Road in West County) and to the Geysers steamfield recharge were evaluated. Note that this evaluation is to provide a *relative* cost comparison, therefore, evaluation of the three systems is proposed sufficient for this purpose. Flows used in this analysis are based on the flows presented in TM-PS-1 for the delivery system to the reservoirs.

PUMPING ECONOMIC ANALYSIS

The information used in the present worth analysis is shown in Table 1. Two reservoir transmission systems were evaluated for two pumping scenarios as indicated above (Tolay A in South County and Carroll Road in West County). These reservoir sites were selected as representative of the reservoir alignments in the southern and western sections of the county. The Geysers alignment was also evaluated for two pumping scenarios. The major components of each scenario are:

- pumping rate, which impacts the pipe size and pump horsepower requirements, and
- pumping schedule, which impacts the energy costs.

Each reservoir system was evaluated at:

1. Pumping rate of 26 mgd for a pumping schedule of 24 hours a day¹ over a period of five months, either December 1 through April 30 or January 1 through May 31, which represents the period during which reclaimed water will be stored for later use during the irrigation period, at an average energy rate of 0.05880 dollars per kilowatt-hour² (which includes peak demand period rates) (\$/kW-hr) and
2. Pumping rate of 35 mgd for 18 hours a day¹ over the same period at an average energy rate of 0.05668 \$/kW-hr² (which does not include peak demand period rates).

The Geysers system was evaluated at:

1. Pumping rate of 26 mgd for a pumping schedule of 24 hours a day³ over a period of a full year at an energy rate of 0.05837 dollars per kilowatt-hour⁴ (which includes peak rates) (\$/kW-hr) and
2. Pumping rate of 35 mgd for 18 hours a day¹ over the same period at an energy rate of 0.05545 \$/kW-hr² (which does not include peak rates).

Under each of these scenarios the pipeline and pump station costs and present worth energy costs were determined for a range of pipe diameters (24-inch, 30-inch, 36-inch, 42-inch, 48-inch, and 54-inch). With the change in pipe size the horsepower requirement changes. As the pipe size increases the cost of the pipe⁵ and installation⁶ increases, while the pump horsepower requirement and pumping energy cost decreases. At some point, the cost benefit incurred by using a larger pipe and smaller pump station is maximized and the total material cost begins to increase. When the cumulative material cost is plotted, the optimum pipe and pump station size is represented by the low point on the curve. As the pump horsepower requirement decreases, the energy cost to run the pumps decreases. When plotted, the energy cost is a continuous diminishing curve. Plotting the total present worth (material costs and present worth energy costs) yields a curve from

¹ Pump rate based on information in Parsons ES Draft Technical Memorandum PS-1 dated 8 May 1995.

² Energy rates based on information presented in Parsons ES memorandum dated 11 April 1995 and Schedule E-20 from PG&E dated 30 June 1993, attached.

³ Pump rate based on information in Draft Technical Memorandum PS-1 dated 8 May 1995.

⁴ Energy rates based on information presented in memorandum dated 11 April 1995 and Schedule E-20 from PG&E dated 30 June 1993, attached.

⁵ Pipe cost for pipe sizes 24-inch to 42-inch were provided by a local vendor. 48-inch and 54-inch pipe costs were extrapolated.

⁶ Installation costs include trenching (excavation, backfill, compaction and spoil removal) and bedding costs from Means 1994, corrected for San Francisco and January 1995 ENR.

which the optimum pipeline/pump station can be selected. The low point on this curve is the optimal selection based on cost.

CONCLUSIONS AND RECOMMENDATIONS

Pumping at 26 mgd for a 24 hour period requires a smaller diameter pipeline and smaller pump horsepower requirement than pumping at 35 mgd for 18 hours a day. Thus, the material cost is less for the first scenario. However, at the 24 hour a day pumping schedule the energy rate is higher due to the need for pumping during peak rate hours. This additional energy cost slightly diminishes the benefit of a lower capital cost.

Results of the present worth analysis are shown in Table 1. The present worth analysis is based on an interest rate of 8%, a 20 year period and a net energy rate based on an analysis of rate information provided by PG&E.

Graphical results are shown on Charts 1 through 6. The charts illustrate that material costs are the major factor in the total cost for larger pipelines. Pumping at a higher rate, 35 mgd, significantly increases the capital costs over pumping at a rate of 26 mgd. This higher capital cost is not significantly offset by the reduction in energy cost per hour incurred over the 18 hour pumping schedule. Pumping at 35 mgd for 18 hours a day, 5 months a year, for 20 years results in an energy savings of approximately \$170,000, much less than the additional costs incurred by the larger pumps and piping this pumping rate requires. Therefore, the 26 mgd, 24 hour a day pumping scenario will be used for design purposes.

Comparing Chart 1 and 2 for transmission to the Tolay A reservoir, it is seen that the lowest present worth occurs with a 48-inch pipeline and pumping at 26 mgd 24 hours a day (versus pumping at 35 mgd for 18 hours per day). The net savings is \$1,924,000.

Likewise, comparing Charts 3 and 4 for transmission to the Carroll Road reservoir, a 48-inch pipeline and pumping at 26 mgd 24 hours per day represents the lowest present worth cost. The net savings for this case is \$1,537,000.

Finally, comparing Charts 5 and 6 for transmission to the Geysers steamfield recharge, a 48-inch pipeline and pumping at 26 mgd 24 hours per day represents the lowest present worth cost. The net savings for this case is \$4,000,000.

TABLE 1
SELECT ROUTES FOR TRANSMISSION LINES (TL) TO STORAGE
EVALUATION OF PUMPING ALTERNATIVES

												Met'l & Installation Cost		PW Factor		8.82			
												Pipe Dia. (in)	Pipe Cost (\$/LF)	I (%)					
												24	67	n (years)					
												30	117	Pump. Period (yr)					
												36	121	Energy (\$/kW-hr)	0.0588	with Peak-5 Mo. Period			
												42	141	Energy (\$/kW-hr)	0.05688	without Peak-5 Mo. Period			
												48	146	Energy (\$/kW-hr)	0.05837	with Peak-Annual			
												54	181	Energy (\$/kW-hr)	0.05545	without Peak-Annual			
												C = 120							
Est. ¹																			
5					120														
Reservoir	Length	Flow	Flow	Flow	Pipe Dia.	Pipe ²	Unit Loss	Hf	Static Head	TDH	Total Pump	Pipe Cost	Pump Sta. ^{1,2}	Construction	Energy Use	Energy Cost	PW Energy	Total PW Cost	
	(Feet)	(MGD)	(GPM)	(CFS)	@ V = 5fps	Diameter	(ft/100ft)	(ft)	(ft)	(ft)	HP	(\$)	(\$)	(\$)	(kW-h/yr)	(\$/yr)	(\$)	(\$)	
Alternative 2A																			
Toley A	92,000	26	18,056	36.94	37	24	2.145	1974	195	2169	13,436	6,181,306	15,700,000	21,881,306	36,323,294	2,135,810	20,969,694	42,851,001	
(Alt. Align.)						30	0.724	666	195	861	5,337	10,740,224	8,200,000	18,940,224	14,428,164	848,376	8,329,481	27,269,706	
						36	0.298	274	195	469	2,908	11,134,580	5,800,000	16,934,580	7,863,112	462,351	4,539,430	21,474,010	
						42	0.141	130	195	325	2,011	12,950,454	4,600,000	17,550,454	5,437,412	319,720	3,139,056	20,689,510	
						48	0.074	68	195	263	1,627	13,410,454	4,025,000	17,435,454	4,399,860	258,712	2,540,070	19,975,524	
						54	0.041	38	195	233	1,444	16,666,688	3,800,000	20,466,688	3,905,204	229,626	2,254,502	22,721,190	
Alternative 2A																			
Toley A	92,000	35	24,306	49.72	43	24	3.718	3421	195	3616	30,154	6,181,306	25,000,000	31,181,306	61,140,182	3,465,426	34,024,059	65,205,365	
(Alt. Align.)						30	1.256	1155	195	1350	11,259	10,740,224	14,300,000	25,040,224	22,828,725	1,293,932	12,704,016	37,744,241	
						36	0.517	476	195	671	5,593	11,134,580	8,400,000	19,534,580	11,341,389	642,830	6,311,399	25,845,979	
						42	0.244	225	195	420	3,500	12,950,454	6,600,000	19,550,454	7,096,970	402,256	3,949,411	23,499,865	
						48	0.128	117	195	312	2,605	13,410,454	5,550,000	18,960,454	5,281,492	299,355	2,939,111	21,899,565	
						54	0.072	66	195	261	2,178	16,666,688	5,075,000	21,741,688	4,415,958	250,296	2,457,448	24,199,136	
Alternative 4C																			
Carroll Road	64,500	26	18,056	36.94	37	24	2.145	1384	260	1644	10,183	4,333,633	13,900,000	18,233,633	27,530,625	1,618,801	15,893,624	34,127,258	
(Alt. Align.)						30	0.724	467	260	727	4,505	7,529,831	7,200,000	14,729,831	12,180,235	716,198	7,031,736	21,761,567	
						36	0.298	192	260	452	2,803	7,806,309	5,800,000	13,606,309	7,577,562	445,561	4,374,580	17,980,889	
						42	0.141	91	260	351	2,174	9,079,394	5,075,000	14,154,394	5,876,936	345,564	3,382,797	17,547,191	
						48	0.074	47	260	307	1,905	9,401,894	4,510,000	13,911,894	5,149,522	302,782	2,972,855	16,884,749	
						54	0.041	27	260	287	1,776	11,684,798	4,250,000	15,934,798	4,802,725	282,400	2,772,647	18,707,445	
Alternative 4C																			
Carroll Road	64,500	35	24,306	49.72	43	24	3.718	2398	260	2658	22,168	4,333,633	21,250,000	25,583,633	44,849,276	2,547,725	25,013,939	50,597,572	
(Alt. Align.)						30	1.256	810	260	1070	8,922	7,529,831	13,200,000	20,729,831	18,089,613	1,025,319	10,066,735	30,796,567	
						36	0.517	334	260	594	4,950	7,806,309	7,700,000	15,506,309	10,035,991	568,840	5,584,955	21,091,263	
						42	0.244	158	260	418	3,482	9,079,394	6,525,000	15,604,394	7,080,284	400,177	3,928,996	19,533,390	
						48	0.128	82	260	342	2,854	9,401,894	5,800,000	15,201,894	5,787,476	328,034	3,220,688	18,422,582	
						54	0.072	46	260	306	2,555	11,684,798	5,500,000	17,184,798	5,180,662	293,640	2,883,000	20,067,798	

TABLE 1
SELECT ROUTES FOR TRANSMISSION LINES (TL) TO STORAGE
EVALUATION OF PUMPING ALTERNATIVES

													<u>Mat'l & Installation Cost</u>		<u>PW Factor</u>		9.82	
													Pipe Dia. (in)	ipe Cost (\$/LF)	I (%)	8		
													24	67	n (years)	20		
													30	117	Pump. Period (yr)	1		
													36	121	Energy (\$/kW-hr)	0.0688 with Peak-5 Mo. Period		
													42	141	Energy (\$/kW-hr)	0.0668 without Peak-5 Mo. Period		
													48	146	Energy (\$/kW-hr)	0.0637 with Peak-Annual		
													54	181	Energy (\$/kW-hr)	0.0646 without Peak-Annual		

Chart 1
Material vs Energy Costs - Tolay 26 mgd




Chart 2
Material vs Energy Costs - Tolay 35 mgd




Chart 3
Material vs Energy Costs - Carroll Road 26 mgd




Chart 4
Material vs Energy Costs - Carroll Road 35 mgd




Chart 5
Material vs Energy Costs - The Geysers 26 mgd




Chart 6
Material vs Energy Costs - The Geysers 35 mgd

