

Issue Date: April 15, 2022

Franklin Fueling Systems

**Franklin Fueling Systems EVO200, EVO400, EVO600, EVO6000 with
FMP-HIS-U Hydrostatic Interstitial Float Sensor, and FMP-HIS-XL-U Hydrostatic Interstitial
Float Sensor**

INTERSTITIAL DETECTOR (LIQUID-PHASE)

Detector:

Output type: qualitative
Sampling frequency: continuous
Operating principle: float switch

Test Results:

FMP-HIS-U	<u>brine</u>
Detection time (min)	<1
Fall time (min)	<1
Threshold Level	
Low level (in)	1.0167
High level (in)	7.3218
FMP-HIS-XL-U	<u>brine</u>
Detection time (min)	<1
Fall time (min)	<1
Threshold Level	1.0678
Low level (in)	0.9895
High level (in)	10.8398

Applicability:

California Code of Regulations require a written statement of compatibility for systems containing products other than those used in this evaluation.

Comments:

Sensors can be removed, cleaned and reinstalled if an alarm is triggered or if the sensor is periodically tested.

3760 Marsh Road

Tel: (816) 443-2494

Madison, WI 53718

Date of Evaluation: 05/02/2017, 11/08/2018

Tel: (800) 225-9787

email: info@franklinfueling.com

URL: www.franklinfueling.com

| [Home](#) | [Vendors: A - F](#) | [Vendors: G - M](#) | [Vendors: N - S](#) | [Vendors: T - Z](#) | [Method Index](#) |

Appearance on this list is not to be construed as an endorsement by any regulatory agency nor is it any guarantee of the performance of the method or equipment. Equipment should be installed and operated in accordance with all applicable laws and regulations. For full details, please refer to our expanded "[Disclaimer](#)" page.