

Franklin Fueling Systems

**Incon TS-1001/2001, TS-5, TS-550, TS-5000, TS-550evo, TS-5000evo, EVO 400, EVO 200,
and S940 Alarm Consoles with FMP-ULS Universal Liquid
Sensor, FMP-UHS Universal Hydrostatic Sensor, FMP-ULS-C Universal Liquid Sensor
Chemical, FMP-ULS-PS Universal Liquid Sensor Position Sensitive sensors**

INTERSTITIAL DETECTOR (LIQUID-PHASE)

Detector:

Output Type: qualitative

Sampling Frequency: continuous

Operating principle: float/reed switch

Test Results:

	<u>unleaded gasoline</u>	<u>diesel</u>	<u>biodiesel</u>	<u>water</u>	<u>E85</u>	<u>brine</u>
FMP-ULS						
Detection time (min)	<1	<1	<1	<1	<1	
Fall time (min)	<1	<1	<1	<1	<1	
Threshold Level (in)	1.0155	0.9944	0.9925	0.8775	1.0198	
FMP-UHS						
Detection time (min)	<1	<1	<1	<1	<1	<1
Fall time (min)	<1	<1	<1	<1	<1	<1
Threshold Level (in)	0.9602	0.9144	0.9218	0.9397	0.9397	0.7561
FMP-ULS-PS						
Detection time (min)	<1	<1	<1	<1	<1	
Fall time (min)	<1	<1	<1	<1	<1	
Threshold Level (in)	1.4915	1.4882	1.4758	1.3770	1.4962	
	<u>Lubrizol</u>	<u>Afton</u>				

FMP-ULS-C

Detection time (min)	<1	<1
Fall time (min)	<1	<1
Threshold Level (in)	1.1707	1.1281

FMP-ULS-PS

Detection time (min)	<1	<1
Fall time (min)	<1	<1
Threshold Level (in)	1.4959	1.4290

Applicability:

California Code of Regulations require a written statement of compatibility for systems containing products other than those used in this evaluation.

Comments:

Ken Wilcox Associates (KWA) has previously evaluated these sensors on one or more Franklin Fueling Systems ATG consoles. Results from the alarm functionality testing with the EVO600 and EVO6000 consoles have been combined with previously evaluated sensor threshold data performed by KWA.

The FMP-ULS-PS is a position sensitive float switch that issues an alarm if not installed properly at the bottom of the intestinal or sump. Sensors are reusable.

Franklin Fueling Systems
 3760 Marsh Road
 Madison, WI 53718
 Tel: (800) 225-9787
 E-mail: info@franklinfueling.com
 URL: www.franklinfueling.com

Evaluator: Ken Wilcox Associates
 Tel: (816) 443-2494
 Dates of Evaluations: 05/02/2017, 11/08/18