

STATE OF CALIFORNIA  
STATE WATER RESOURCES CONTROL BOARD  
**ORDER WQ 2020-0027-UST**

---

---

**In the Matter of Underground Storage Tank (UST) Case Closure  
Pursuant to Health and Safety Code Section 25296.10 and the  
Low-Threat Underground Storage Tank Case Closure Policy**

---

---

**BY THE CHIEF DEPUTY DIRECTOR:<sup>1</sup>**

By this order, the Chief Deputy Director directs closure of the UST case at the site listed below, pursuant to section 25296.10 of the Health and Safety Code.<sup>2</sup> The name of the responsible party, the site name, the site address, the Underground Storage Tank Cleanup Fund (Fund) claim number if applicable, current and former lead agencies, and case numbers are as follows:

**United States Department of the Navy (Responsible Party)**

**NAF El Centro Tank 386**

**Area 7 (East of 2nd St, North of Building 386), El Centro, Imperial County**

**Colorado River Regional Water Quality Control Board, Case No. 7DODT22430043**

**I. STATUTORY AND PROCEDURAL BACKGROUND**

Upon review of a UST case, the State Water Resources Control Board (State Water Board) is authorized to close or require closure of a UST case where an unauthorized release has occurred, if the State Water Board determines that corrective

---

<sup>1</sup> State Water Board Resolution No. 2012-0061 delegates to the Executive Director the authority to close or require the closure of any UST case if the case meets the criteria found in the State Water Board's Low-Threat Underground Storage Tank Case Closure Policy adopted by State Water Board Resolution No. 2012-0016. Pursuant to Resolution No. 2012-0061, the Executive Director has delegated this authority to the Chief Deputy Director.

<sup>2</sup> Unless otherwise noted, all references are to the California Health and Safety Code.

action at the site is in compliance with all the requirements of subdivisions (a) and (b) of section 25296.10. The State Water Board, or in certain cases the State Water Board Executive Director or Chief Deputy Director, may close a case or require the closure of a UST case. Closure of a UST case is appropriate where the corrective action ensures the protection of human health, safety, and the environment and where the corrective action is consistent with: 1) chapter 6.7 of division 20 of the Health and Safety Code and implementing regulations; 2) any applicable waste discharge requirements or other orders issued pursuant to division 7 of the Water Code; 3) all applicable state policies for water quality control; and 4) all applicable water quality control plans.

State Water Board staff has completed a review of the UST case identified above, and recommends that this case be closed. The recommendation is based upon the facts and circumstances of this particular UST case. The UST case record that is the basis for determining compliance with the Water Quality Control Policy for Low-Threat Underground Storage Tank Case Closures (Low-Threat Closure Policy or Policy) is available on the State Water Board's GeoTracker database.

**[GeoTracker Case Record:](https://geotracker.waterboards.ca.gov/profile_report.asp?global_id=T060259550)**

[https://geotracker.waterboards.ca.gov/profile\\_report.asp?global\\_id=T060259550](https://geotracker.waterboards.ca.gov/profile_report.asp?global_id=T060259550)

**Low-Threat Closure Policy**

The Policy became effective on August 17, 2012. The Policy establishes consistent statewide case closure criteria for certain low threat petroleum UST sites. In the absence of unique attributes or site-specific conditions that demonstrably increase the risk associated with residual petroleum constituents, cases that meet the general and media-specific criteria in the Low-Threat Closure Policy pose a low threat to human health, safety, the environment, and are appropriate for closure under Health and Safety Code section 25296.10. The Policy provides that if a regulatory agency determines that a case meets the general and media-specific criteria of the Policy, then the regulatory agency shall notify responsible parties and other specified interested persons that the

case is eligible for case closure. Unless the regulatory agency revises its determination based on comments received on the proposed case closure, the Policy provides that the agency shall issue a uniform closure letter as specified in Health and Safety Code section 25296.10. The uniform closure letter may only be issued after the expiration of the 60-day comment period, proper destruction or maintenance of monitoring wells or borings, and removal of waste associated with investigation and remediation of the site.

Health and Safety Code section 25299.57, subdivision (I)(1) provides that claims for reimbursement of corrective action costs that are received by the Fund more than 365 days after the date of a uniform closure letter or a letter of commitment, whichever occurs later, shall not be reimbursed unless specified conditions are satisfied.

## **II. FINDINGS**

Based upon the facts in the UST record and the hydrogeologic conditions at the site, as summarized in the attached UST Case Closure Summary, the State Water Board finds that corrective action taken to address the unauthorized release of petroleum at the UST release site identified as:

**United States Department of the Navy (Responsible Party)**

**NAF EI Centro Tank 386**

**Area 7 (East of 2nd St, North of Building 386), EI Centro, Imperial County**

**Colorado River Regional Water Quality Control Board, Case No. 7DODT22430043**

ensures protection of human health, safety, and the environment and is consistent with chapter 6.7 of division 20 of the Health and Safety Code and implementing regulations, the Low-Threat Closure Policy and with other applicable water quality control policies and plans.

The unauthorized release from the UST consisted only of petroleum. This order directs closure for the petroleum UST case at the site. This order does not address non-petroleum contamination at the site, if non-petroleum contamination is present.

Pursuant to the Low-Threat Closure Policy, notification has been provided to all entities that are required to receive notice of the proposed case closure, a 60-day comment period has been provided to notified parties, and any comments received have been considered by the State Water Board in determining that the case should be closed.

Pursuant to section 21080.5 of the Public Resources Code, environmental impacts associated with the adoption of this order were analyzed in the substitute environmental document (SED) the State Water Board approved on May 1, 2012. The SED concludes that all environmental effects of adopting and implementing the Low-Threat Closure Policy are less than significant, and environmental impacts as a result of adopting this order in compliance with the Policy are no different from the impacts that are reasonably foreseen as a result of the Policy itself. A Notice of Decision was filed August 17, 2012. No new environmental impacts or any additional reasonably foreseeable impacts beyond those that were addressed in the SED will result from adopting this order.

The UST case identified above may be the subject of orders issued by the Regional Water Quality Control Board (Regional Water Board) pursuant to division 7 of the Water Code. Any orders that have been issued by the Regional Water Board pursuant to division 7 of the Water Code, or directives issued by a Local Oversight Program (LOP) agency for this case should be rescinded to the extent they are inconsistent with this order.

### **III. ORDER**

**IT IS THEREFORE ORDERED** that:

- A. The UST case identified in Section II of this order, meeting the general and media-specific criteria established in the Low-Threat Closure Policy, be closed in accordance with the following conditions and after the following actions are complete. Prior to the issuance of a uniform closure letter, the responsible party

is ordered to:

1. Properly destroy monitoring wells and borings unless the owner of real property on which the well or boring is located certifies that the wells or borings will be maintained in accordance with local or state requirements;


2. Properly remove from the site and manage all waste piles, drums, debris, and other investigation and remediation derived materials in accordance with local or state requirements; and

3. Within six months of the date of this order, submit documentation to the regulatory agency overseeing the UST case identified in Section II of this order that the tasks in subparagraphs (1) and (2) have been completed.

- B. The tasks in subparagraphs (1) and (2) of Paragraph (A) are ordered pursuant to Health and Safety Code section 25296.10, and failure to comply with these requirements may result in the imposition of civil penalties pursuant to Health and Safety Code section 25299, subdivision (d)(1). Penalties may be imposed administratively by the State Water Board or Regional Water Board.
- C. Within 30 days of receipt of proper documentation from the responsible party that requirements in subparagraphs (1) and (2) of Paragraph (A) are complete, the regulatory agency that is responsible for oversight of the UST case identified in Section II of this order shall notify the State Water Board that the tasks have been satisfactorily completed.
- D. Within 30 days of notification from the regulatory agency that the tasks are complete pursuant to Paragraph (C), the Deputy Director of the Division of Water Quality shall issue a uniform closure letter consistent with Health and Safety Code section 25296.10, subdivision (g) and upload the uniform closure letter to GeoTracker.

E. Pursuant to section 25299.57, subdivision (l)(1), and except in specified circumstances, all claims for reimbursement of corrective action costs must be received by the Fund within 365 days of issuance of the uniform closure letter in order for the costs to be considered.

F. Any Regional Water Board or LOP agency directive or order that directs corrective action or other action inconsistent with case closure for the UST case identified in Section II is rescinded, but only to the extent the Regional Water Board order or LOP agency directive is inconsistent with this order.

  
\_\_\_\_\_  
Chief Deputy Director

September 9, 2020  
\_\_\_\_\_  
Date

## State Water Resources Control Board

### UNDERGROUND STORAGE TANK (UST) CASE CLOSURE SUMMARY

#### Agency Information

Agency Name: Colorado River Basin Regional Water Quality Control Board	Address: 73-720 Fred Waring Dr. Ste 100 Palm Desert, CA 92260
Agency Caseworker: Jessica Bagby	Case No.: 7DODT22430043

#### Case Information

UST Cleanup Fund (Fund) Claim No.: N/A	Global ID: T060259550
Site Name: Naval Air Facility (NAF) El Centro Tank 386	Site Address: Area 7 (East of 2nd St, North of Building 386) El Centro, CA 92243
Responsible Party: United States Department of the Navy Attn: Mr. Robert Fischer	Address: 1605 Third Street NAF El Centro, CA 92243
Fund Expenditures to Date: N/A	Number of Years Case Open: 23

#### GeoTracker Case Record:

[https://geotracker.waterboards.ca.gov/profile\\_report.asp?global\\_id=T060259550](https://geotracker.waterboards.ca.gov/profile_report.asp?global_id=T060259550)

#### Summary

**This case has been proposed for closure by the State Water Resources Control Board at the request of the Colorado River Basin Regional Water Quality Control Board, which concurs with closure.**

The Low-Threat Underground Storage Tank Case Closure Policy (Policy) contains general and media-specific criteria, and cases that meet those criteria are appropriate for closure pursuant to the Policy. This case meets all of the required criteria of the Policy.

The site operates as an active Naval Base in Imperial County. The petroleum release was discovered when elevated petroleum constituents were identified during the removal of a 2,400-gallon diesel tank in 1996. An unreported volume of impacted soil

was over-excavated to thirteen feet below ground surface (bgs) and disposed off-site at that time. Elevated petroleum hydrocarbons were detected in soil samples from the bottom of the excavation. Additional soil and groundwater sampling in 2000 indicated water quality objectives are met and remaining soil impact is limited.

Residual petroleum constituents in soil is limited in areal extent. Remaining petroleum constituents are limited, stable, and decreasing. Additional assessment would be unnecessary and will not likely change the conceptual model. Any remaining petroleum constituents do not pose significant risk to human health, safety, or the environment under current conditions.

### **Rationale for Closure Under the Policy**

- General Criteria – Site **MEETS ALL EIGHT GENERAL CRITERIA** under the Policy
- Groundwater Media-Specific Criteria – Site **meets the criteria in Class 1**. The contaminant plume that exceeds water quality objectives is less than 100 feet in length. There is no free product. The nearest existing water supply well or surface water body is greater than 250 feet from the defined plume boundary.
- Petroleum Vapor Intrusion to Indoor Air – Site **meets Criteria 2 (a), Scenario 2**. There is a bioattenuation zone that provides a separation of at least 30 feet both laterally and vertically between the Light Non-Aqueous Phase Liquid in soil and the foundation of existing or potential buildings. Concentrations of total petroleum hydrocarbons as gasoline and diesel combined in soil are less than 100 milligrams per kilogram throughout the entire depth of the bioattenuation zone.
- Direct Contact and Outdoor Air Exposure – Site **meets Criteria 3 (a)**. Maximum concentrations of petroleum constituents in soil from confirmation soil samples are less than or equal to those listed in Table 1 of the Policy.


There are no soil sample results in the case record for naphthalene. However, the relative concentration of naphthalene in soil can be conservatively estimated using the published relative concentrations of naphthalene and benzene in gasoline. Taken from Potter and Simmons (1998), gasoline mixtures contain approximately 2% benzene and 0.25% naphthalene. Therefore, benzene concentrations can be used as a surrogate for naphthalene concentrations with a safety factor of eight. Benzene concentrations from the Site are below the naphthalene thresholds in Table 1 of the Policy. Therefore, estimated naphthalene concentrations meet the thresholds in Table 1 and the Policy criteria for direct contact with a safety factor of eight. It is highly unlikely that naphthalene concentrations in the soil, if any, exceed the threshold.



NAF El Centro Tank 386 (T060259550)  
Area 7 (East of 2nd St, North of Building 386), El Centro, Imperial County

### Recommendation for Closure

The corrective action performed at this Site ensures the protection of human health, safety, and the environment. The corrective action performed at this Site is consistent with chapter 6.7 of division 20 of the Health and Safety Code, implementing regulations, applicable state policies for water quality control and applicable water quality control plans. Case closure is recommended.

Reviewed By:   
Matthew Cohen, P.G. No. 9077  
Senior Engineering Geologist  
State Water Resources Control Board



12/16/19  
Date